

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : BESSEMER PLYWOOD CORP	SRN : N1393
Location : 1000 YALE AVE	District : Marquette
	County : GOGEBIC
City : BESSEMER State: MI Zip Code : 49911	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Joe Scanlan
FCE Begin Date : 3/2/2022	FCE Completion Date : 6/13/2023
Comments : FCE complete. No current compliance issues with facility.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
03/02/2023	On-site Inspection	Compliance	Unannounced inspection to determine compliance with PTI 35-20B
11/02/2022	Stack Test	Compliance	Stack test for NOx, CO, and PM on Dryer 4. 3 exhaust stacks were tested on the emission unit, SVHEAT1, SVCOOL1, and SVCOOL2. Average results from 3 test runs were below permitted limits. This satisfies SC V.1 of PTI 35-20B.
10/13/2022	Complaint Investigation	Compliance	Odor complaint investigation and survey
08/16/2022	Visible Emissions Evaluation	Compliance	VE observation for excessive opacity from wood boiler

Name:



Date:

06/13/2023

Supervisor:

