

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
ACTIVITY REPORT: Self Initiated Inspection

N139536694

FACILITY: Cadillac Renewable Energy Facility		SRN / ID: N1395
LOCATION: 1525 Miltner St., CADILLAC		DISTRICT: Gaylord
CITY: CADILLAC		COUNTY: WEXFORD
CONTACT: Scott Clark , Maintenance Manager		ACTIVITY DATE: 09/07/2016
STAFF: Gloria Torello	COMPLIANCE STATUS: Compliance	SOURCE CLASS: MAJOR
SUBJECT: Site visit for Gloria Torello to be introduced to permittee staff.		
RESOLVED COMPLAINTS:		

From AQD: Gloria Torello and Rob Dickman.
From CRE: Scott Clark

Torello is now assigned to this facility. The purpose of the site visit was to introduce Gloria Torello to permittee staff.

Mr. Clark showed AQD staff around the facility. This maximum 40 MW facility was operating at 34 MW during the site visit. No visible emissions were noted. No fugitive dust was noted. Trucks unloaded wood chips.

During the site visit, EUBLR, the generator monitor included these readings:

Pollutant	Permit Limit	Monitor
NOx	78.5pph	73.95 pph
NOx	0.15 #/MMBtu	0.1494 #/MMBtu
CO	209.2 pph	62.43 pph
CO	0.40 #/MMBtu	0.10 #/MMBtu
Opacity	20%	1.32 %

NAME Gloria Torello

DATE 9-21-16

SUPERVISOR [Signature]