

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

<b>Facility :</b> Upper Peninsula Power Company - Gladstone	<b>SRN :</b> N1430
<b>Location :</b> East Delta Avenue	<b>District :</b> Upper Peninsula
	<b>County :</b> DELTA
<b>City :</b> GLADSTONE <b>State:</b> MI <b>Zip Code :</b> 49837	<b>Compliance Status :</b> Compliance
<b>Source Class :</b> SM OPT OUT	<b>Staff :</b> Ed Lancaster
<b>FCE Begin Date :</b> 10/1/2015	<b>FCE Completion Date :</b> 11/4/2015
<b>Comments :</b> Facility has not reported to MAERS in several years as it was considered a minor source. However, their PTI limits their SO2 emissions to 31.12 tons per year, making them a synthetic minor source and they have been flagged for MAERS beginning 1/16.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
11/02/2015	Scheduled Inspection	Compliance	Conducted scheduled compliance inspection.

Name: Ed Lancaster    Date: 11/4/15    Supervisor: \_\_\_\_\_