

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : Holland BPW, 48th Street Peaking Station	SRN : N2586
Location : 491 E 48th St	District : Kalamazoo
	County : ALLEGAN
City : HOLLAND State: MI Zip Code : 49423	Compliance Status :
Source Class : MAJOR	Staff : Dale Turton
FCE Begin Date : 10/1/2014	FCE Completion Date : 8/19/2015
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
08/19/2015	Scheduled Inspection	Compliance	
08/17/2015	Excess Emissions (CEM)	Compliance	There were no NOx excess emissions during the period. The NOx monitor downtime was 9.83% on unit #7 & 6.95 on unit #9. This is a high number but it is acceptable due to a very low run time, resulting in a small denominator. The down time was mostly related to calibrations. There were no equipment malfunctions.
08/13/2015	ROP Semi 1 Cert	Compliance	
03/20/2015	MAERS	Compliance	
03/03/2015	ROP SEMI 2 CERT	Compliance	
03/03/2015	ROP Annual Cert	Compliance	
02/10/2015	Excess Emissions (CEM)	Compliance	There were no NOx excess emissions during the period. The NOx monitor downtime was 2.8 to 5.8, but was mostly during linearity checks. Also, runtime is low, thus having a small denominator.

Name: Dale Turton Date: 8/24/15 Supervisor: MD 8/24/2015