



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
BAY CITY DISTRICT OFFICE



LIESL EICHLER CLARK
DIRECTOR

March 23, 2021

Ms. Charlene Hudson - Superintendent
Sebewaing Light and Water
110 West Main Street
P.O. Box 645
Sebewaing, Michigan 48759

SRN: N2726, Huron County

Dear Ms. Hudson:

VIOLATION NOTICE

On July 23, 2020, stack emissions testing was conducted on Engines 7 & 8 located at 350 Pine Street, Sebewaing, Michigan. The purpose of the testing was to determine Sebewaing Light and Water's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; and the conditions of Permit to Install (PTI) number 146-17A.

The results of testing were provided in a report submitted to the Department of Environment Great Lakes and Energy (EGLE), Air Quality Division (AQD) on September 2, 2020. The AQD Technical Programs Unit (TPU) staff reviewed the report and provided correspondence on December 14, 2020 and January 5, 2021. A revised report was submitted January 15, 2021. TPU reviewed the revised report and provided the results to the district office. Additional review and discussion results in the following:

Process Description	Rule/Permit Condition Violated	Comments
Engine 8	FG Gen 7 & 8 SC I (1)	NOx limit of 0.5 g/HP-hr exceeded for Engine 8 (0.6 g/HP-hr)

The failure to demonstrate compliance with an emissions limit necessitates additional testing. Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by April 13, 2021 (which coincides with 21 calendar days from the date of this letter). The written response should include the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.


Ms. Charlene Hudson
Sebewaing Light and Water
Page 2
March 23, 2021

Please submit the written response to EGLE, AQD, Bay City District, at 401 Ketchum Street, Suite B, Bay City, Michigan 48708 and submit a copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

If Sebewaing Light and Water believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Ben Witkopp
Environmental Engineer
Air Quality Division
989-894-6219

cc: Ms. Mary Ann Dolehanty, EGLE
Dr. Eduardo Olaguer, EGLE
Ms. Jenine Camilleri, EGLE
Mr. Christopher Ethridge, EGLE
Mr. Chris Hare, EGLE
Ms. Karen Kajiya-Mills, EGLE
Mr. Matt Karl, EGLE