

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : Consumers Energy - Muskegon River Compressor Stat	SRN : N2901
Location : 8613 Pine Rd. Marion, MI	District : Saginaw Bay
	County : CLARE
City : CHURCH BRIDGE State: MI Zip Code : 49665	Compliance Status : Compliance
Source Class : MAJOR	Staff : Benjamin Witkopp
FCE Begin Date : 8/1/2017	FCE Completion Date : 8/1/2018
Comments : Facility operations and records in order. Facility Manager is on top of things.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
08/01/2018	Scheduled Inspection	Compliance	Facility Inspection
05/29/2018	MACT (Part 63)	Compliance	Semiannual Periodic Report - Subpart HHH - NESHAP for Natural Gas Transmission and Storage Facilities
05/10/2018	MAERS	Compliance	Submitted on time
04/03/2018	ROP Annual Cert	Compliance	Deviation previously presented in second semi-annual certification.
04/03/2018	ROP SEMI 2 CERT	Compliance	Co had flame failure on thermal oxidizer for dehy unit after hours on 11-17-17. Alarm not sent off site. Personnel re-lit flame upon arrival in the morning. Communications card replaced so alarms are properly sent out. Benzene and BTEX emissions not exceeded based on GRI-GLYcalc.

Name: B. Witkopp Date: 9-13-18 Supervisor: C. Hove