

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : Consumers Energy - Muskegon River Compressor Stat	SRN : N2901
Location : 8613 Pine Rd. Marion, MI	District : Bay City
	County : CLARE
City : CHURCH BRIDGE	State: MI Zip Code : 49665 Compliance Status : Compliance
Source Class : MAJOR	Staff : Nathanael Gentle
FCE Begin Date : 1/13/2021	FCE Completion Date : 1/13/2022
Comments : FCE for FY2022 Inspection	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
01/13/2022	On-site Inspection	Compliance	Scheduled Onsite Inspection FY2022
12/06/2021	ROP R215 Notification	Compliance	Six engines have been retired and disconnected. These engines were a part of FGCOMPRESSORS and include: EUENGINE306, EUENGINE316, EUENGINE319, EUENGINE320, EUENGINE3-1 and EUENGINE3-2. Included in the notice were completed C-001: Certification and M-001: Rule 215 Change Notification forms.
10/11/2021	ROP Semi 1 Cert	Compliance	No deviations reported.
10/11/2021	MACT (Part 63)	Compliance	Semiannual Report Subpart HHH Semiannual periodic report received for EUGLYCDEHY, a TEG thermal oxidizer subject to 40 CFR Part 63, Subpart HHH. The report states no malfunctions or excursions occurred during the reporting period.
08/31/2021	Release Reports	Compliance	Email notification provided that the facility will be venting approximately 1.958 MMCF of natural gas on 09/08/2021. Personnel stated the venting is required for the facilities Firegate Valve Project GC-00639 and Jet Installation Project GC-00597.
03/18/2021	ROP SEMI 2 CERT	Compliance	No deviations reported.
03/18/2021	ROP Annual Cert	Compliance	No deviations reported.

Activity Date	Activity Type	Compliance Status	Comments
03/18/2021	MACT (Part 63)	Compliance	Subpart HHH Semiannual Report. NESHAP for Natural Gas Transmission and Storage Facilities Semiannual Periodic Report. Report includes EUGLYCDEHY. The unit uses glycol type TEG and has a thermal oxidizer control device. No malfunctions, no excursions, no leaks, or defects detected and no periodic performance tests. CPMS was always operative during reporting period report incorporates.
03/18/2021	MACT (Part 63)	Compliance	Subpart DDDDD 5-year Compliance Plan. EUFUELHTR last tune-up on 1/19/2021. EUFUELHTR1 last tune-up on 1/19/2021. EUBLR9 last tune-up on 12/19/2020. EUREBOILER last tune-up on 3/1/2021.

Nathanael Dentel

Name: _____

Date: 2/1/2022

Supervisor: *Chris Hare*