

RECEIVED

AUG 01 2022

AIR QUALITY DIVISION

**AIR EMISSION TEST REPORT
FOR THE
VERIFICATION OF AIR POLLUTANT EMISSIONS
FROM A
LANDFILL GAS FUELED FLARE**

**Prepared for:
Ottawa County Farms Landfill
SRN N3294**

Test Date: June 16, 2022

**ICT Project No.: 2200137
July 18, 2022**



Report Certification


AIR EMISSION TEST REPORT FOR THE VERIFICATION OF AIR POLLUTANT EMISSIONS FROM A LANDFILL GAS FUELED FLARE

**Ottawa County Farms Landfill
Coopersville, MI**

Report Certification

The material and data in this document were prepared under the supervision and direction of the undersigned.

Impact Compliance & Testing, Inc.



Andrew Eisenberg
Environmental Consultant

Table of Contents

1.0 INTRODUCTION.....	2
2.0 SUMMARY OF TEST RESULTS AND OPERATING CONDITIONS	3
2.1 Purpose and Objective of the Tests.....	3
2.2 Operating Conditions During the Compliance Tests	3
2.3 Summary of Air Pollutant Sampling Results	3
3.0 SOURCE AND SAMPLING LOCATION DESCRIPTION.....	5
3.1 General Process Description	5
3.2 Rated Capacities and Air Emission Controls	5
3.3 Sampling Locations	5
4.0 SAMPLING AND ANALYTICAL PROCEDURES.....	6
4.1 Summary of Sampling Methods.....	6
4.2 Exhaust Gas Velocity Determination (USEPA Method 2)	6
4.3 Exhaust Gas Molecular Weight Determination (USEPA Method 3A).....	6
4.4 Exhaust Gas Moisture Content (USEPA Method 4).....	7
4.5 CO Concentration Measurements (USEPA Method 10)	7
5.0 QA/QC ACTIVITIES.....	8
5.1 Flow Measurement Equipment.....	8
5.2 Gas Divider Certification (USEPA Method 205).....	8
5.3 Instrumental Analyzer Interference Check.....	8
5.4 Instrument Calibration and System Bias Checks	8
5.5 Determination of Exhaust Gas Stratification	8
5.6 System Response Time	9
5.7 Meter Box Calibrations	9
6.0 RESULTS	10
6.1 Test Results and Allowable Limits	10
6.2 Variations from Normal Sampling Procedures or Operating Conditions	10

List of Tables

2.1	Average operating conditions during the enclosed flare test periods	4
2.2	Average measured air pollutant data for the enclosed flare (three-test average)	4
6.1	Measured exhaust gas conditions and air pollutant emission rates for the enclosed flare (EUENCLOSEDFLARE).....	11

List of Appendices

APPENDIX 1	SAMPLE PORT DIAGRAM
APPENDIX 2	OPERATING RECORDS
APPENDIX 3	FLOWRATE CALCULATIONS AND DATA SHEETS
APPENDIX 4	AIR POLLUTANT CALCULATIONS
APPENDIX 5	INSTRUMENTAL ANALYZER RAW DATA
APPENDIX 6	QA/QC RECORDS

RECEIVED

AUG 01 2022

AIR QUALITY DIVISION

Last Updated: July 18, 2022

1.0 Introduction

Ottawa County Farms Landfill (OCFL) operates a landfill gas (LFG) fueled enclosed flare (enclosed flare) at its facility in Coopersville, Ottawa County, Michigan.

The State of Michigan Department of Environment, Great Lakes, and Energy – Air Quality Division (EGLE-AQD) has issued to OCFL Renewable Operating Permit (ROP) No. MI-ROP-N3294-2019 and Permit to Install (PTI) No. 116-20, which consists of:

- One (1) enclosed flare identified as emission unit EUENCLOSEDFLARE.

Air emission compliance testing was performed pursuant to conditions of MI-ROP-N3294-2019, PTI No. 116-20, the federal Standards of Performance for Municipal Solid Waste Landfills (40 CFR 60, Subpart XXX, and 40 CFR 63, Subpart AAAA). While PTI No. 116-20 references 40 CFR 63, Subpart WWW, it is no longer applicable in Michigan as it has been superseded by 40 CFR 63, Subpart AAAA.

The compliance testing presented in this report was performed by Impact Compliance & Testing, Inc. (ICT), a Michigan-based environmental consulting and testing company. ICT representatives Blake Beddow and Andrew Eisenberg performed the field sampling and measurements June 16, 2022.

The enclosed flare performance tests consisted of triplicate, one-hour sampling periods for carbon monoxide (CO). Exhaust gas velocity, moisture, oxygen (O₂) content, and carbon dioxide (CO₂) content were determined for each test period to calculate pollutant mass emission rates.

The exhaust gas sampling and analysis was performed using procedures specified in the Stack Test Protocol submitted May 9, 2022, that was reviewed and approved by EGLE-AQD. Mr. Trevor Drost of EGLE-AQD observed portions of the compliance testing.

Questions regarding this air emission test report should be directed to:

Tyler J. Wilson
Senior Project Manager
Impact Compliance & Testing, Inc.
37660 Hills Tech Drive
Farmington Hills, MI 48331
(734) 357-8046
Tyler.Wilson@impactCandT.com

Mr. Tyler Smith
Environmental Scientist
Environmental Information Logistics, LLC
130 E. Main Street
Caledonia, MI 49316
tsmith@eilllc.com
(616) 558-3978

2.0 Summary of Test Results and Operating Conditions

2.1 Purpose and Objective of the Tests

Conditions of MI-ROP-N3294-2019, PTI No. 116-20, the federal Standards of Performance for Municipal Solid Waste Landfills (40 CFR 60, Subpart XXX, and 40 CFR 63, Subpart AAAA) require OCFL to test an enclosed flare (EUENCLOSEDFLARE) for air pollutant emissions. EUENCLOSEDFLARE was tested during this compliance test event.

2.2 Operating Conditions During the Compliance Tests

The flare testing was performed while the enclosed flare was operated at normal routine operating conditions. For the enclosed flare, OCFL representatives monitored and recorded the combustion zone temperature (°F), fuel use (scfm), and fuel methane content (%) at 15-minute intervals for each test period.

Appendix 2 provides operating records provided by OCFL representatives for the test periods.

Average process operating data for the emission unit is presented in Tables 2.1 and 6.1.

2.3 Summary of Air Pollutant Sampling Results

The gases exhausted from the sampled LFG fueled enclosed fare were each sampled for three (3) one-hour test periods during the compliance testing performed June 16, 2022.

Table 2.2 presents the average measured required air pollutant data for the enclosed flare (average of the three test periods).

Test results for each one-hour sampling period and comparison to the permitted emission rates are presented in Section 6.0 of this report.

RECEIVED

AUG 01 2022

Table 2.1 Average enclosed flare operating conditions during the test periods

Emission Unit	Combustion Temperature (°F)	LFG Fuel Use (scfm)	LFG CH ₄ Content (%)
EUENCLOSEDFLARE	1,546	2,199	51.0

Table 2.2 Average measured air pollutant data for the enclosed flare (three-test average)

Emission Unit	CO (lb/MMBtu)
EUENCLOSEDFLARE	0.004
<i>Permit Limit</i>	0.20

3.0 Source and Sampling Location Description

3.1 General Process Description

OCFL is permitted to operate one (1) enclosed flare at its facility. The unit is fired exclusively with LFG that is recovered from the OCFL facility and treated prior to use.

3.2 Rated Capacities and Air Emission Controls

The enclosed flare has a rated LFG use rate of 3,700 scfm.

The enclosed flare serves as the control device for LFG generated at the OCFL. The enclosed flare is not equipped with add-on emission control equipment.

3.3 Sampling Locations

The EUENCLOSEDFLARE exhaust gas is released to the atmosphere through a dedicated vertical exhaust stack. The vertical exhaust stack has an inner diameter of 132 inches. The vertical exhaust stack is equipped with four (4) sample ports, each opposed by 90°, that provide a sampling location 96.0 inches (0.73 duct diameters) upstream and 444 inches (3.4 duct diameters) downstream from any flow disturbance and satisfies the USEPA Method 1 criteria for a representative sample location.

All sample port locations satisfy the USEPA Method 1 criteria for a representative sample location. Individual traverse points were determined in accordance with USEPA Method 1.

Appendix 1 provides a diagram of the emission test sampling locations with actual stack dimension measurements.

4.0 Sampling and Analytical Procedures

A Stack Test Protocol for the air emission testing was reviewed and approved by EGLE-AQD. This section provides a summary of the sampling and analytical procedures that were used during the testing periods.

4.1 Summary of Sampling Methods

- | | |
|-----------------|--|
| USEPA Method 1 | Exhaust gas velocity measurement locations were determined based on the physical stack arrangement and requirements in USEPA Method 1. |
| USEPA Method 2 | Exhaust gas velocity pressure was determined using a Type-S Pitot tube connected to a red oil incline manometer; temperature was measured using a K-type thermocouple connected to the Pitot tube. |
| USEPA Method 3A | Exhaust gas O ₂ and CO ₂ content was determined using paramagnetic and infrared instrumental analyzers, respectively. |
| USEPA Method 4 | Exhaust gas moisture was determined based on the water weight gain in chilled impingers. |
| USEPA Method 10 | Exhaust gas CO concentration was measured using an infrared instrumental analyzer. |

4.2 Exhaust Gas Velocity Determination (USEPA Method 2)

Exhaust stack gas velocities and volumetric flow rates were determined using USEPA Method 2 once during each test period. An S-type Pitot tube connected to a red-oil manometer was used to determine velocity pressure at each traverse point across the stack cross section. Gas temperature was measured using a K-type thermocouple mounted to the Pitot tube. The Pitot tube and connective tubing were leak-checked periodically throughout the test periods to verify the integrity of the measurement system.

The absence of significant cyclonic flow at each sampling location was verified using an S-type Pitot tube and oil manometer. The Pitot tube was positioned at each velocity traverse point with the planes of the face openings of the Pitot tube perpendicular to the stack cross-sectional plane. The Pitot tube was then rotated to determine the null angle (rotational angle as measured from the perpendicular, or reference, position at which the differential pressure is equal to zero).

Appendix 3 provides exhaust gas flowrate calculations and field data sheets.

4.3 Exhaust Gas Molecular Weight Determination (USEPA Method 3A)

CO₂ and O₂ content in the enclosed flare exhaust gas stream were measured continuously throughout each test period in accordance with USEPA Method 3A. The CO₂ content of the exhaust was monitored using a Servomex 1440D infrared gas analyzer. The O₂ content of the exhaust was monitored using a Servomex 1440D gas analyzer that uses a paramagnetic sensor.

During each sampling period, a continuous sample of the exhaust gas stream was extracted from the stack using an Inconel probe connected to a Teflon® heated sample line. The sampled gas was conditioned by removing moisture prior to being introduced to the analyzers; therefore, measurement of O₂ and CO₂ concentrations correspond to standard dry gas conditions. Instrument response data were recorded using an ESC Model 8816 data acquisition system that monitored the analog output of the instrumental analyzers continuously and logged data as one-minute averages.

Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias (described in Section 5.0 of this document). Sampling times were recorded on field data sheets.

Appendix 4 provides O₂ and CO₂ calculation sheets. Raw instrument response data are provided in Appendix 5.

4.4 Exhaust Gas Moisture Content (USEPA Method 4)

Moisture content of the enclosed flare exhaust gas stream was determined in accordance with USEPA Method 4 using a chilled impinger sampling train. Exhaust gas moisture content measurements were performed concurrently with the instrumental analyzer sampling periods. At the conclusion of each sampling period the moisture gain in the impingers was determined gravimetrically by weighing each impinger to determine net weight gain.

4.5 CO Concentration Measurements (USEPA Method 10)

CO pollutant concentration in the enclosed flare exhaust gas stream was determined using a Thermo Environmental Instruments, Inc. (TEI) Model 48i infrared CO analyzer.

Throughout each test period, a continuous sample of the engine exhaust gas was extracted from the stack using the Teflon® heated sample line and gas conditioning system and delivered to the instrumental analyzers. Instrument response for each analyzer was recorded on an ESC Model 8816 data acquisition system that logged data as one-minute averages. Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias.

Appendix 4 provides CO calculation sheets. Raw instrument response data are provided in Appendix 5.

5.0 QA/QC Activities

5.1 Flow Measurement Equipment

Prior to arriving onsite, the instruments used during the source test to measure exhaust gas properties and velocity (pyrometer, Pitot tube, and scale) were calibrated to specifications in the sampling methods.

5.2 Gas Divider Certification (USEPA Method 205)

A STEC Model SGD-710C 10-step gas divider was used to obtain appropriate calibration span gases. The ten-step STEC gas divider was NIST certified (within the last 12 months) with a primary flow standard in accordance with Method 205. When cut with an appropriate zero gas, the ten-step STEC gas divider delivered calibration gas values ranging from 0% to 100% (in 10% step increments) of the USEPA Protocol 1 calibration gas that was introduced into the system. The field evaluation procedures presented in Section 3.2 of Method 205 were followed prior to use of gas divider. The field evaluation yielded no errors greater than 2% of the triplicate measured average and no errors greater than 2% from the expected values.

5.3 Instrumental Analyzer Interference Check

The instrumental analyzers used to measure CO, O₂, and CO₂ have had an interference response test preformed prior to their use in the field, pursuant to the interference response test procedures specified in USEPA Method 7E. The appropriate interference test gases (i.e., gases that would be encountered in the exhaust gas stream) were introduced into each analyzer, separately and as a mixture with the analyte that each analyzer is designed to measure. All of analyzers exhibited a composite deviation of less than 2.5% of the span for all measured interferent gases. No major analytical components of the analyzers have been replaced since performing the original interference tests.

5.4 Instrument Calibration and System Bias Checks

At the beginning of each day of the testing program, initial three-point instrument calibrations were performed for the CO, CO₂, and O₂ analyzers by injecting calibration gas directly into the inlet sample port for each instrument. System bias checks were performed prior to and at the conclusion of each sampling period by introducing the upscale calibration gas and zero gas into the sampling system (at the base of the Inconel sampling probe prior to the particulate filter and Teflon® heated sample line) and determining the instrument response against the initial instrument calibration readings.

The instruments were calibrated with USEPA Protocol 1 certified concentrations of CO₂, O₂, and CO in nitrogen and zeroed using hydrocarbon free nitrogen. A STEC Model SGD-710C ten-step gas divider was used to obtain intermediate calibration gas concentrations as needed.

5.5 Determination of Exhaust Gas Stratification

A stratification test was performed for each port on the exhaust stack. The stainless-steel sample probe was positioned at multiple sample points across each plane of the stack diameter. Pollutant concentration data were recorded at each sample point for a minimum of twice the maximum system response time.

The recorded concentration data for the exhaust stack indicated that the measured CO concentrations did vary by more than 10% of the mean across the stack diameter. Therefore, the exhaust stack was considered to be stratified and the compliance test sampling was performed at twelve (12) sampling locations within the exhaust stack.

5.6 System Response Time

The response time of the sampling system was determined prior to the compliance test program by introducing upscale gas and zero gas, in series, into the sampling system using a tee connection at the base of the sample probe. The elapsed time for the analyzer to display a reading of 95% of the expected concentration was determined using a stopwatch.

Sampling periods did not commence until the sampling probe had been in place for at least twice the greatest system response time.

5.7 Meter Box Calibrations

The dry gas meter sampling console used for moisture testing was calibrated prior to and after the testing program. This calibration uses the critical orifice calibration technique presented in USEPA Method 5. The metering console calibration exhibited no data outside the acceptable ranges presented in USEPA Method 5.

The digital pyrometer in the metering console was calibrated using a NIST traceable Omega® Model CL 23A temperature calibrator.

6.0 Results

6.1 Test Results and Allowable Limits

Enclosed flare operating data and air pollutant concentration and emission measurement results for each one-hour test period are presented in Table 6.1.

The measured CO air pollutant emission rates for the enclosed flare are less than the allowable limit specified in MI-ROP-N3294-2019, PTI No. 116-20, the federal Standards of Performance for Municipal Solid Waste Landfills (40 CFR 60, Subpart XXX, and 40 CFR 63, Subpart AAAA). The allowable limit for CO emissions is listed in the following table.

CO	
EUENCLOSEDFLARE	(lb/MMBtu)
<i>Permit Limit</i>	0.02

6.2 Variations from Normal Sampling Procedures or Operating Conditions

The testing for all pollutants was performed in accordance with USEPA methods and the approved Stack Test Protocol. The enclosed flare was operated at normal routine operating conditions. No variations from normal operating conditions occurred during the test periods.

The exhaust gas velocity measurement for the fourth (4th) port during the third (3rd) test run was deemed inaccurate so the manometer was re-zeroed and leak checked and another exhaust gas velocity measurement was taken.


Table 6.1 Measured exhaust gas conditions and air pollutant emission rates for EUENCLOSEDFLARE

Test No.	1 6/16/2022 0835-1012	2 6/16/2022 1045-1215	3 6/16/2022 1335-1509	Three Test Average
Test date	6/16/2022	6/16/2022	6/16/2022	
Test period (24-hr clock)	0835-1012	1045-1215	1335-1509	
Combustion temperature (°F)	1,568	1,569	1,500	1,546
Fuel flowrate (scfm)	2,248	2,217	2,132	2,199
LFG methane content (%)	51.8	51.3	49.7	51.0
<u>Exhaust Gas Composition</u>				
CO ₂ content (% vol)	6.04	6.26	5.84	6.05
O ₂ content (% vol)	14.4	14.0	14.6	14.4
Moisture (% vol)	10.4	9.2	8.6	9.4
Exhaust gas temperature (°F)	1,575	1,463	1,595	1,544
Exhaust gas flowrate (dscfm)	30,853	26,646	27,881	28,460
Exhaust gas flowrate (scfm)	34,439	29,353	30,516	31,436
<u>Carbon Monoxide</u>				
CO conc. (ppmv)	2.10	0.21	3.93	2.08
CO emissions (lb/hr)	0.28	0.02	0.48	0.26
CO emissions (lb/MMBtu)	0.0045	0.0004	0.0083	0.0044
CO permit limit (lb/MMBtu)	-	-	-	0.20

APPENDIX 1

- Sample Port Diagram

EUENCLOSEDFLARE



Enclosed Flare Sampling and Measurement Locations

5/5/2022	Ottawa County Farms Landfill EUENCLOSEDFLARE Exhaust Sample Location		
	Scale None	Sheet 1 of 1	

Appendix 2

- Facility Operating Records

Landfill Gas Fueled Enclosed Flare Process Operating Data

Facility: OCFL
 Location: Coopersville, MI
 Date: 6/16/2022
 Unit ID: EUENCLOSEDFLARE

Date	EUENCLOSEDFLARE	Test #	Combustion Temp. (°F)	Fuel Flow (scfm)	Fuel CH ₄ (%)
6/16/2022	8:35	1	1,575	2,250	51.7
	8:59	1	1,570	2,249	51.9
	9:20	1	1,560	2,255	51.7
	9:56	1	1,560	2,250	51.8
	10:12	1	1,575	2,235	51.8

Date	EUENCLOSEDFLARE	Test #	Combustion Temp. (°F)	Fuel Flow (scfm)	Fuel CH ₄ (%)
6/16/2022	10:45	2	1,565	2,235	51.9
	11:04	2	1,568	2,222	51.7
	11:25	2	1,568	2,215	51.3
	12:00	2	1,571	2,210	51.0
	12:15	2	1,574	2,204	50.8

Date	EUENCLOSEDFLARE	Test #	Combustion Temp. (°F)	Fuel Flow (scfm)	Fuel CH ₄ (%)
6/16/2022	13:35	3	1,535	2,135	50.1
	14:00	3	1,533	2,132	49.9
	14:20	3	1,475	2,138	49.6
	14:54	3	1,470	2,129	49.6
	15:09	3	1,488	2,128	49.5

PROCESS OPERATING DATA

Facility Name:

Republic - OCFL

Location:

Coopersville, MI

Test Date:

6/16/2022

Source ID:

EVE Enclosed Flame

Engine No.:

Serial No.:

Engine Hours:

TEST NO. 1

Start Time:

8:35

Combustion Temp.
(°F)

Fuel Use
(scfm)

CH4 Content
(%)

0 min	<u>1575</u>	<u>2250</u>	<u>51.7</u>	
15 min	<u>1570</u>	<u>2249</u>	<u>51.9</u>	
30 min	<u>1560</u>	<u>2255</u>	<u>51.7</u>	
45 min	<u>1560</u>	<u>2250</u>	<u>51.8</u>	
60 min	<u>1575</u>	<u>2235</u>	<u>51.8</u>	

Stop Time:

10:12

TEST NO. 2

Start Time:

10:44

Combustion temp.
Generator Output

Engine Fuel Use
scfm or lb/hr

CH4 Content
(%)

0 min	<u>1565</u>	<u>2235</u>	<u>51.9</u>	
15 min	<u>1568</u>	<u>2222</u>	<u>51.7</u>	
30 min	<u>1568</u>	<u>2215</u>	<u>51.3</u>	
45 min	<u>1571</u>	<u>2210</u>	<u>51.0</u>	
60 min	<u>1574</u>	<u>2201</u>	<u>50.6</u>	

Stop Time:

12:15

TEST NO. 3

Start Time:

13:35

Combustion temp.
Generator Output

Engine Fuel Use
scfm or lb/hr

CH4 Content
(%)

0 min	<u>1580</u>	<u>2180</u>	<u>50.1</u>	
15 min	<u>1533</u>	<u>2132</u>	<u>49.9</u>	
30 min	<u>1475</u>	<u>2138</u>	<u>49.6</u>	
45 min	<u>1470</u>	<u>2129</u>	<u>49.6</u>	
60 min	<u>1488</u>	<u>2128</u>	<u>49.5</u>	

Stop Time:

15:09

Operator Initials:

B.M.

RECEIVED

AUG 01 2022

APPENDIX 3

- Flowrate Field Data Sheets
- Flowrate Calculation Sheets

EXHAUST GAS VELOCITY, MOISTURE, AND FLOWRATE CALCULATION SHEET

Company	OCFL	Pitot Tube Number	8F-I
Source Designation	EUENCLOSEDFLARE	Pitot Tube Corr. Factor	0.84
Test Date	6/16/2022	% CO ₂	6.04
Test Number	1	% O ₂	14.45
Time	8:40	% CO	0.000
Barometric Pressure	29.21	% N ₂	79.51
Stack Static Pressure	-0.13	Md	29.54
Stack Diameter (in.)	132.00	Ms	28.34
Traverse points	16	Moisture Content (%)	10.4
Operator	AE/BB		

Traverse			Traverse		
Point	Stack Temp.	Velocity Pres.	Point	Stack Temp.	Velocity Pres.
Number	(°F)	("H ₂ O)	Number	(°F)	("H ₂ O)
Side A					
1	1,496	0.04	1	1,681	0.05
2	1,498	0.05	2	1,648	0.05
3	1,500	0.05	3	1,678	0.05
4	1,500	0.04	4	1,710	0.04
5	1,527	0.04	5	1,561	0.05
6	1,536	0.05	6	1,570	0.04
7	1,551	0.04	7	1,598	0.04
8	1,542	0.04	8	1,598	0.04
Average	1,519	0.04		1,631	0.05

Average Velocity Pressure ("H ₂ O)	0.044
Average Velocity Pressure Sqrt ("H ₂ O)	0.212
Stack Pressure ("Hg)	29.20
Stack Gas Specific Gravity (Gs)	0.98
Average Stack Temperature (°F)	1574.6
Average Stack Velocity (fps)	23.85
Average Stack Velocity (fpm)	1430.9
Area of Stack (ft ²)	95.033
Flowrate (Actual-CFM)	135,987
Flowrate (Standard Wet-SCFM)	34,439
Flowrate (Standard Dry-DSCFM)	30,853

Moisture Calculation		
Bws=	0.104	
Cond. Vol.=	3.09	
Samp. Vol. std=	26.57	
Vwc=	55.8	
Wsg=	9.8	
Vmf=	871.266	
Vmi=	843.839	
Ym=	1.0216	
Delta H=	1.898	
Tm=	83	

EXHAUST GAS VELOCITY, MOISTURE, AND FLOWRATE CALCULATION SHEET

Company	OCFL	Pitot Tube Number	8F-I
Source Designation	EUENCLOSEDFLARE	Pitot Tube Corr. Factor	0.84
Test Date	6/16/2022	% CO ₂	6.26
Test Number	2	% O ₂	14.02
Time	10:46	% CO	0.000
Barometric Pressure	29.24	% N ₂	79.72
Stack Static Pressure	-0.13	Md	29.56
Stack Diameter (in.)	132.00	Ms	28.50
Traverse points	16	Moisture Content (%)	9.2
Operator	AE/BB		

Traverse			Traverse		
Point	Stack Temp.	Velocity Pres.	Point	Stack Temp.	Velocity Pres.
Number	(°F)	("H ₂ O)	Number	(°F)	("H ₂ O)
Side A			Side B		
1	1,450	0.03	1	1,320	0.02
2	1,450	0.02	2	1,360	0.02
3	1,520	0.02	3	1,400	0.02
4	1,680	0.01	4	1,498	0.01
5	1,359	0.04	5	1,390	0.08
6	1,354	0.04	6	1,400	0.07
7	1,472	0.04	7	1,590	0.06
8	1,570	0.02	8	1,590	0.04
Average	1,482	0.03		1,444	0.04

Average Velocity Pressure ("H ₂ O)	0.034
Average Velocity Pressure Sqrt ("H ₂ O)	0.176
Stack Pressure ("Hg)	29.23
Stack Gas Specific Gravity (Gs)	0.98
Average Stack Temperature (°F)	1462.7
Average Stack Velocity (fps)	19.19
Average Stack Velocity (fpm)	1151.4
Area of Stack (ft ²)	95.033
Flowrate (Actual-CFM)	109,424
Flowrate (Standard Wet-SCFM)	29,353
Flowrate (Standard Dry-DSCFM)	26,646

Moisture Calculation		
Bws=	0.092	
Cond. Vol.=	2.66	
Samp. Vol. std=	26.14	
Vwc=	51.2	
Wsg=	5.2	
Vmf=	898.563	
Vmi=	871.456	
Ym=	1.0216	
Delta H=	1.898	
Tm=	86	

EXHAUST GAS VELOCITY, MOISTURE, AND FLOWRATE CALCULATION SHEET

Company	OCFL		
Source Designation	EUENCLOSEDFLARE	Pitot Tube Number	8F-I
Test Date	6/16/2022	Pitot Tube Corr. Factor	0.84
Test Number	3	% CO₂	5.84
Time	13:30	% O₂	14.59
Barometric Pressure	29.21	% CO	0.000
Stack Static Pressure	-0.13	% N₂	79.57
Stack Diameter (in.)	132.00	Md	29.52
Traverse points	16	Ms	28.52
Operator	AE/BB	Moisture Content (%)	8.6

Traverse Point			Traverse Point		
Number	Stack Temp. (°F)	Velocity Pres. ("H ₂ O)	Number	Stack Temp. (°F)	Velocity Pres. ("H ₂ O)
Side A					
1	1,625	0.03	1	1,590	0.04
2	1,625	0.04	2	1,590	0.04
3	1,622	0.02	3	1,566	0.04
4	1,622	0.04	4	1,564	0.05
5	1,550	0.05	5	1,590	0.04
6	1,560	0.04	6	1,590	0.05
7	1,649	0.02	7	1,560	0.04
8	1,649	0.01	8	1,560	0.04
Average	1,613	0.03		1,576	0.04

Average Velocity Pressure ("H ₂ O)	0.037
Average Velocity Pressure Sqrt ("H ₂ O)	0.189
Stack Pressure ("Hg)	29.20
Stack Gas Specific Gravity (Gs)	0.98
Average Stack Temperature (°F)	1594.5
Average Stack Velocity (fps)	21.34
Average Stack Velocity (fpm)	1280.2
Area of Stack (ft ²)	95.033
Flowrate (Actual-CFM)	121,657
Flowrate (Standard Wet-SCFM)	30,516
Flowrate (Standard Dry-DSCFM)	27,881

Moisture Calculation		
Bws=	0.086	
Cond. Vol.=	2.60	
Samp. Vol. std=	27.55	
Vwc=	46.1	
Wsg=	9.2	
Vmf=	927.740	
Vmi=	898.891	
Ym=	1.0216	
Delta H=	1.898	
Tm=	91	

USEPA Method 2
Gas Velocity Measurement Data Sheet

Company: Republic - CCFL

Source ID: Enclosed Flare

No. Points: 16
Operator: BR/AE

Pitot Type:
Pitot ID:

Type S or Standard
SF-I

Date: <u>6/16/2022</u>	Date: <u>6/16/2022</u>	Date: <u>6/16/2022</u>	Date: <u>6/16/2022</u>
Test No.: <u>1</u>	Test No.: <u>2</u>	Test No.: <u>3</u>	Test No.: <u></u>
Time: <u>8:40</u> (24-hr)	Time: <u>10:46</u> (24-hr)	Time: <u>13:30</u> (24-hr)	Time: <u></u> (24-hr)
Bar. Press.: <u>29.208</u> in. Hg	Bar. Press.: <u>29.236</u> in. Hg	Bar. Press.: <u>29.212</u> in. Hg	Bar. Press.: <u></u> in. Hg
Static Press.: <u>-0.13</u> in. H ₂ O	Static Press.: <u>-0.13</u> in. H ₂ O	Static Press.: <u>-0.13</u> in. H ₂ O	Static Press.: <u></u> in. H ₂ O
O ₂ Content: <u>14.4</u> %	O ₂ Content: <u>14.6</u> %	O ₂ Content: <u>14.7</u> %	O ₂ Content: <u></u> %
CO ₂ Content: <u>5.46</u> %	CO ₂ Content: <u>5.55</u> %	CO ₂ Content: <u>5.40</u> %	CO ₂ Content: <u></u> %
Wet Bulb Temp.: <u>—</u> °F	Wet Bulb Temp.: <u>—</u> °F	Wet Bulb Temp.: <u>—</u> °F	Wet Bulb Temp.: <u>—</u> °F

Point No.	Stack Temp. (°F)	Velocity Head (in. H ₂ O)	Stack Temp. (°F)	Velocity Head (in. H ₂ O)	Stack Temp. (°F)	Velocity Head (in. H ₂ O)	Stack Temp. (°F)	Velocity Head (in. H ₂ O)
1	1496	0.04	1450	0.03	1625	0.03		
2	1498	0.05	1450	0.02	1625	0.04		
3	1500	0.05	1500	0.02	1622	0.02		
4	1500	0.04	1640	0.01	1622	0.04		
1	1521	0.04	1359	0.04	1560	0.05		
2	1536	0.05	1359	0.04	1560	0.04		
3	1551	0.04	1472	0.04	1649	0.02		
4	1592	0.04	1570	0.02	1649	0.01		
1	1651	0.05	1320	0.02	1590	0.09		
2	1648	0.05	1360	0.02	1590	0.04		
3	1678	0.05	1460	0.02	1566	0.04		
4	1710	0.04	1498	0.01	1564	0.05		
1	1561	0.05	1390	0.08	1560	0.08		
2	1570	0.09	1400	0.07	1570	0.08		
3	1598	0.09	1510	0.06	1570	0.09		
4	1698	0.09	1510	0.04	1575	0.08		
					1590	0.04		
					1590	0.05		
					1560	0.04		
					1560	0.04		

APPENDIX 4

- Air Pollutant Calculation Sheets

EPA Method 10 CO Calculation Summary

Company: OCFL
Location: Coopersville, MI
Source: EUENCLOSEDFLARE
Date: 6/16/2022

	=	Test 1	Test 2	Test 3	
Average CO concentration	=	2.59	0.68	4.46	ppmvd
Average pre-test and post-test instrument zero	=	0.44	0.47	0.44	ppmvd
Average pre-test and post-test instrument calibration	=	151	152	151	ppmvd
Midrange calibration gas concentration	=	147	147	147	ppmvd
Volumetric flow rate	=	30,853	26,646	27,881	dscfm

CO CONCENTRATION CORRECTED FOR CALIBRATION AND ZERO DRIFT

$$C_d = (\text{CO conc.-Avg. zero}) \times (\text{Cal. gas conc.}) / (\text{Avg. cal.-Avg. zero}) = \quad 2.10 \quad 0.21 \quad 3.93 \quad \text{ppmvd}$$

CO EMISSION RATE

$$E_{CO} = (C_d) (Q_d \text{std}) (60 \text{ min/hr}) (MW_{CO}) / (V_M) = \quad 0.28 \quad 0.02 \quad 0.48 \quad \text{lb/hr}$$

where:

C_d = observed CO concentration, dry basis ($\text{ft}^3 \text{ CO} / 10^6 \text{ ft}^3$ stack gas)

$Q_d \text{std}$ = stack gas flowrate (dscfm)

MW_{CO} = molecular weight CO (28.0 lb/lb-mol)

V_M = molar volume of ideal gas at std conditions ($385 \text{ ft}^3/\text{lb-mol}$)

$$HE = (CH_4) (909 \text{ Btu/scf}) (GF) / (1,000,000 \text{ Btu}) (60 \text{ min/hr}) = \quad 63.5 \quad 62.1 \quad 57.8 \quad \text{MMBtu}$$

where:

CH_4 = Methane content of gas to flare (%)

GF = Gas flow to flare (scfm)

$$(ECO) / HE = \quad 0.0045 \quad 0.0004 \quad 0.0083 \quad \text{lb/MMBtu}$$

where:

ECO = CO emission rate (lb/hr)

HE = Heat energy of gas to flare

EPA Method 3A O₂ Calculation Summary

Company: OCFL
Location: Coopersville, MI
Source: EUENCLOSEDFLARE
Date: 6/16/2022

	=	Test 1	Test 2	Test 3	
Average O ₂ concentration	=	14.5	14.1	14.5	%
Average pre-test and post-test instrument zero	=	0.34	0.22	0.21	%
Average pre-test and post-test instrument calibration	=	10.6	10.6	10.5	%
Midrange calibration gas concentration	=	10.5	10.5	10.5	%
Volumetric flow rate	=	30,853	26,646	27,881	dscfm

O₂ CONCENTRATION CORRECTED FOR CALIBRATION AND ZERO DRIFT

$$(O_2 \text{ conc.} - \text{Avg. zero}) \times (\text{Cal. gas conc.}) / (\text{Avg. cal.} - \text{Avg. zero}) = 14.4 \quad 14.0 \quad 14.6 \quad \%$$

EPA Method 3A CO₂ Calculation Summary

Company: OCFL
Location: Coopersville, MI
Source: EUENCLOSEDFLARE
Date: 6/16/2022

	=	Test 1	Test 2	Test 3	%
Average CO ₂ concentration	=	5.81	5.97	5.56	%
Average pre-test and post-test instrument zero	=	0.03	0.03	0.02	%
Average pre-test and post-test instrument calibration	=	11.3	11.2	11.2	%
Midrange calibration gas concentration	=	11.8	11.8	11.8	%
Volumetric flow rate	=	30,853	26,646	27,881	dscfm

CO₂ CONCENTRATION CORRECTED FOR CALIBRATION AND ZERO DRIFT

$$(\text{CO}_2 \text{ conc.} - \text{Avg. zero}) \times (\text{Cal. gas conc.}) / (\text{Avg. cal.} - \text{Avg. zero}) = 6.04 \quad 6.26 \quad 5.84 \quad \%$$

APPENDIX 5

- Instrumental Analyzer Raw Data

OCFL 6-15-2022

Date	Hour	CO	CO2	O2
06/15/22	12:50	715.7	4.97	5.13
06/15/22	12:51	41.38	0	0.09
06/15/22	12:52	633.72	17.76	15.29
06/15/22	12:53	1712.85	23.55	21.22
06/15/22	12:54	1737.76	23.57	21.23
06/15/22	12:55	1741.27	23.65	21.31

M205 Divider Certification - Oxygen

06/15/22	12:56	1733.84	24.01	21.33
06/15/22	12:57	1522.69	16.56	15.14
06/15/22	12:58	1105.94	14.16	12.61
06/15/22	12:59	1092.47	13.2	11.91
06/15/22	13:00	845.57	9.51	8.32
06/15/22	13:01	941.97	17.47	14.94
06/15/22	13:02	1668.85	23.99	21.31
06/15/22	13:03	1720.14	24.01	21.31
06/15/22	13:04	1701.92	21.26	19.28
06/15/22	13:05	1202.79	14.18	12.6
06/15/22	13:06	1085.79	14.16	12.59
06/15/22	13:07	907.45	9.62	8.6
06/15/22	13:08	770.48	9.51	8.31
06/15/22	13:09	768.14	9.5	8.3
06/15/22	13:10	767.23	9.5	8.3
06/15/22	13:11	767.75	9.49	8.3
06/15/22	13:12	1008.84	18.94	16.23
06/15/22	13:13	1668.4	24	21.31
06/15/22	13:14	1614.85	19.1	17.37
06/15/22	13:15	1121.33	14.16	12.6
06/15/22	13:16	1019.58	11.51	10.35
06/15/22	13:17	772.47	9.51	8.31
06/15/22	13:18	762.73	9.5	8.3
06/15/22	13:19	762.81	9.5	8.3
06/15/22	13:20	592.16	4.42	14.79
06/15/22	13:21	70.01	0.12	15.94
06/15/22	13:22	13.75	0.08	12.73
06/15/22	13:23	1.36	0.05	12.63
06/15/22	13:24	1.43	0.05	9.59
06/15/22	13:25	1.54	0.05	4.98
06/15/22	13:26	1.19	0.03	12.61
06/15/22	13:27	0.84	0.03	12.61
06/15/22	13:28	0.84	0.03	12.61
06/15/22	13:29	0.91	0.03	7.5
06/15/22	13:30	0.47	0.02	0.01
06/15/22	13:31	0.31	0.02	0.01
06/15/22	13:32	0.32	0.02	0.01
06/15/22	13:33	1.69	0.03	11.63
06/15/22	13:34	0.82	0.02	12.59

OCFL 6-15-2022

06/15/22	13:35	0.81	0.02	12.58
06/15/22	13:36	50.94	2.15	8.58
06/15/22	13:37	378.76	4.71	4.07
06/15/22	13:38	398.57	4.73	4.07
06/15/22	13:39	309.48	4.73	4.07
06/15/22	13:40	291.52	4.74	4.07

OCFL 6-16-2022

Test ID	Time	CO	CO2	O2
EF T1	0835-1012	2.59	5.81	14.47
EF T2	1045-1215	0.68	5.97	14.09
EF T3	1335-1509	4.46	5.56	14.51

Date	Hour	CO	CO2	O2
06/16/22	06:55	11.59	0.1	0
06/16/22	06:56	-0.02	0.07	0.01
06/16/22	06:57	181.46	12.62	10.66
06/16/22	06:58	892.44	23.74	21.27
06/16/22	06:59	940.64	23.95	21.33
06/16/22	07:00	942.25	22.7	20.57
06/16/22	07:01	646.9	11.72	10.47
06/16/22	07:02	500.61	10.19	9.28
06/16/22	07:03	281.16	4.76	4.14
06/16/22	07:04	261.52	4.74	4.13
06/16/22	07:05	294.41	4.74	4.12
06/16/22	07:06	295.13	4.74	4.12
06/16/22	07:07	292.86	4.47	3.94
06/16/22	07:08	187.35	2.49	2.05
06/16/22	07:09	150.68	2.48	2.04
06/16/22	07:10	150.51	2.48	2.04
06/16/22	07:11	109.81	0.81	0.77
06/16/22	07:12	1.44	0.02	0
06/16/22	07:13	0.51	0.02	0
06/16/22	07:14	1.1	0.07	15.8
06/16/22	07:15	2	0.08	21.2
06/16/22	07:16	2.26	0.08	21.2
06/16/22	07:17	2.01	0.08	21.2
06/16/22	07:18	2.75	0.07	21.21
06/16/22	07:19	3.04	0.07	21.21
06/16/22	07:20	3.05	0.07	21.22
06/16/22	07:21	2.62	0.08	21.22
06/16/22	07:22	2.7	0.08	21.22
06/16/22	07:23	2.5	0.08	21.22
06/16/22	07:24	3.37	0.07	21.22
06/16/22	07:25	3.48	0.07	21.23
06/16/22	07:26	44.37	2.21	18.98
06/16/22	07:27	492.56	11.23	10.64
06/16/22	07:28	646.83	11.38	10.53
06/16/22	07:29	622.51	8.48	7.88
06/16/22	07:30	215.02	2.5	2.4
06/16/22	07:31	148.26	2.45	2.37
06/16/22	07:32	137.03	1.6	1.68
06/16/22	07:33	13.73	0.07	0.39
06/16/22	07:34	0.97	0.05	0.39

OCFL 6-16-2022

06/16/22	07:35	0.73	0.04	0.39
06/16/22	07:36	0.44	0.03	0.39
06/16/22	07:37	0.45	0.04	5.55
06/16/22	07:38	1.01	0.08	20.04
06/16/22	07:39	1.15	0.08	20.13
06/16/22	07:40	0.96	0.08	20.16
06/16/22	07:41	0.95	0.08	20.2
06/16/22	07:42	0.96	0.08	20.66
06/16/22	07:43	1.27	0.08	21.19
06/16/22	07:44	1.92	0.08	21.21
06/16/22	07:45	0.97	0.08	21.22
06/16/22	07:46	1.21	0.08	21.23
06/16/22	07:47	0.97	0.08	21.23
06/16/22	07:48	0.97	0.08	21.24
06/16/22	07:49	0.98	0.08	21.24
06/16/22	07:50	0.98	0.08	21.24
06/16/22	07:51	0.96	0.08	21.25
06/16/22	07:52	0.98	0.08	21.25
06/16/22	07:53	1.46	0.08	21.25
06/16/22	07:54	1.16	0.08	21.25
06/16/22	07:55	0.97	0.08	21.25
06/16/22	07:56	0.96	0.07	21.25
06/16/22	07:57	1.05	0.08	21.25
06/16/22	07:58	0.97	0.07	21.25
06/16/22	07:59	1.3	0.08	21.25
06/16/22	08:00	1.29	0.08	21.25
06/16/22	08:01	1.65	0.08	21.25
06/16/22	08:02	5.89	0.09	21.24
06/16/22	08:03	4.35	0.08	21.25
06/16/22	08:04	2.22	0.08	21.25
06/16/22	08:05	3.9	0.08	21.25
06/16/22	08:06	3.49	0.08	21.25
06/16/22	08:07	4.57	0.08	21.25
06/16/22	08:08	4.33	0.08	21.25
06/16/22	08:09	3.08	0.07	21.25
06/16/22	08:10	2.03	0.07	21.25
06/16/22	08:11	0.97	0.07	21.25
06/16/22	08:12	0.96	0.07	21.25
06/16/22	08:13	0.95	0.07	21.25
06/16/22	08:14	1.34	2.78	18.07
06/16/22	08:15	1.87	5.91	14.28
06/16/22	08:16	1.61	5.69	14.57
06/16/22	08:17	2.3	5.53	14.77
06/16/22	08:18	5.53	5.33	15.03
06/16/22	08:19	3.93	5.57	14.73
06/16/22	08:20	1.46	5.53	14.78
06/16/22	08:21	1.99	1.89	19.11
06/16/22	08:22	1.23	0.12	21.21

OCFL 6-16-2022

06/16/22	08:23	0.96	0.1	21.23
06/16/22	08:24	0.96	0.09	21.23
06/16/22	08:25	0.97	0.08	21.23
06/16/22	08:26	0.97	0.08	21.23
06/16/22	08:27	0.96	3.38	17.34
06/16/22	08:28	2.31	5.72	14.5
06/16/22	08:29	3.64	5.58	14.7
06/16/22	08:30	2.54	5.53	14.78
06/16/22	08:31	1.4	5.59	14.7
06/16/22	08:32	0.95	5.57	14.72
06/16/22	08:33	1.03	5.5	14.82
06/16/22	08:34	1.38	5.49	14.82

EUECLOSEDFLARE, Test No. 1

06/16/22	08:35	2.55	5.47	14.85
06/16/22	08:36	1.29	5.47	14.86
06/16/22	08:37	1.14	5.5	14.82
06/16/22	08:38	2.71	5.43	14.91
06/16/22	08:39	2.26	5.48	14.85
06/16/22	08:40	0.97	5.46	14.85
06/16/22	08:41	0.98	5.54	14.77
06/16/22	08:42	1.44	5.47	14.85
06/16/22	08:43	2.09	5.53	14.78
06/16/22	08:44	2.02	5.6	14.69
06/16/22	08:45	1.78	5.6	14.69
06/16/22	08:46	2.12	5.63	14.65
06/16/22	08:47	2.55	5.75	14.5
06/16/22	08:48	3.01	5.68	14.59
06/16/22	08:49	1.28	5.55	14.75
06/16/22	08:50	0.96	4.55	16.01

Paused for Port Change

06/16/22	08:51	0.97	4.34	16.19
06/16/22	08:52	0.97	0.16	21.16
06/16/22	08:53	0.98	0.11	21.21
06/16/22	08:54	0.97	0.09	21.22
06/16/22	08:55	0.96	0.08	21.23
06/16/22	08:56	1.47	0.08	21.23
06/16/22	08:57	1.24	0.08	21.23
06/16/22	08:58	1.14	1.71	19.34

Resumed

06/16/22	08:59	1.46	6.05	14.11
06/16/22	09:00	2.01	5.81	14.4
06/16/22	09:01	2.49	5.76	14.48
06/16/22	09:02	2.53	5.7	14.56
06/16/22	09:03	2.68	5.66	14.61
06/16/22	09:04	3.04	5.7	14.57
06/16/22	09:05	3.05	5.72	14.54
06/16/22	09:06	3.04	5.75	14.51

OCFL 6-16-2022

06/16/22	09:07	2.96	5.85	14.38
06/16/22	09:08	3.02	5.95	14.27
06/16/22	09:09	2.56	6.33	13.86
06/16/22	09:10	2.01	6.43	13.76
06/16/22	09:11	2.02	6.78	13.38
06/16/22	09:12	1.75	6.97	13.18
06/16/22	09:13	1.46	6.93	13.21
06/16/22	09:14	1.46	7.03	13.12

Paused for Port Change

06/16/22	09:15	1.46	7.14	12.97
06/16/22	09:16	1.47	1.24	19.9
06/16/22	09:17	1.45	0.13	21.2
06/16/22	09:18	1.46	0.58	20.72
06/16/22	09:19	1.47	6.48	13.68

Resumed

06/16/22	09:20	1.97	6.3	13.88
06/16/22	09:21	2.01	6.15	14.05
06/16/22	09:22	2.02	6.09	14.12
06/16/22	09:23	2.01	6	14.21
06/16/22	09:24	2	6	14.21
06/16/22	09:25	2.01	6.04	14.17
06/16/22	09:26	2.42	6.01	14.19
06/16/22	09:27	2.23	6.13	14.07
06/16/22	09:28	2.33	6.07	14.13
06/16/22	09:29	2.49	6.38	13.81
06/16/22	09:30	2.4	6.37	13.82
06/16/22	09:31	2.43	6.27	13.93
06/16/22	09:32	2	6.28	13.92
06/16/22	09:33	2	6.72	13.46
06/16/22	09:34	2.01	6.97	13.18
06/16/22	09:35	2	7.03	13.11

Paused for Port Change

06/16/22	09:36	1.84	6.82	13.35
06/16/22	09:37	1.47	1.47	19.63
06/16/22	09:38	1.46	0.14	21.19
06/16/22	09:39	1.46	0.11	21.21
06/16/22	09:40	1.07	0.1	21.22
06/16/22	09:41	0.96	0.1	21.22
06/16/22	09:42	0.96	0.09	21.23
06/16/22	09:43	0.97	0.09	21.23
06/16/22	09:44	1.37	0.09	21.23
06/16/22	09:45	1.05	0.09	21.23
06/16/22	09:46	1.86	0.09	21.24
06/16/22	09:47	1.71	0.09	21.23
06/16/22	09:48	6.41	0.08	21.24
06/16/22	09:49	2.05	0.08	21.24
06/16/22	09:50	0.96	0.08	21.24

OCFL 6-16-2022

06/16/22	09:51	0.95	0.08	21.24
06/16/22	09:52	1.1	0.08	21.24
06/16/22	09:53	1.46	0.08	21.24
06/16/22	09:54	1.22	0.08	21.24
06/16/22	09:55	0.95	3.39	17.36

Resumed

06/16/22	09:56	3.14	5.6	14.7
06/16/22	09:57	1.64	5.36	15.01
06/16/22	09:58	8.47	5.26	15.15
06/16/22	09:59	6.73	5.25	15.15
06/16/22	10:00	5.71	5.29	15.1
06/16/22	10:01	4.54	5.22	15.19
06/16/22	10:02	3.55	5.32	15.07
06/16/22	10:03	5.58	5.28	15.12
06/16/22	10:04	3.55	5.22	15.19
06/16/22	10:05	4.67	5.23	15.17
06/16/22	10:06	5.57	5.22	15.19
06/16/22	10:07	4.43	5.36	15.01
06/16/22	10:08	2.06	5.35	15.04
06/16/22	10:09	3.41	5.3	15.09
06/16/22	10:10	1.79	5.34	15.05
06/16/22	10:11	1.52	5.37	15.01
06/16/22	10:12	1.21	5.43	14.94
06/16/22	10:13	31.67	6.84	13.93
06/16/22	10:14	588.88	11.25	10.67
06/16/22	10:15	669.23	11.29	10.65
06/16/22	10:16	567.55	6.95	6.68
06/16/22	10:17	233.1	2.76	2.84
06/16/22	10:18	153.52	2.44	2.53
06/16/22	10:19	152.96	2.42	2.49
06/16/22	10:20	143.87	1.62	1.82
06/16/22	10:21	14.91	0.07	0.5
06/16/22	10:22	0.95	0.05	0.37
06/16/22	10:23	0.94	0.04	0.32
06/16/22	10:24	0.72	0.03	0.28
06/16/22	10:25	0.43	0.03	0.27
06/16/22	10:26	0.43	0.03	0.25
06/16/22	10:27	0.43	0.03	0.51
06/16/22	10:28	0.75	0.07	17.69
06/16/22	10:29	0.95	0.07	19.98
06/16/22	10:30	2.51	0.07	20.03
06/16/22	10:31	3.5	0.07	20.05
06/16/22	10:32	0.95	0.07	20.07
06/16/22	10:33	0.65	0.07	20.89
06/16/22	10:34	0.94	0.07	21
06/16/22	10:35	0.95	0.07	21.01
06/16/22	10:36	0.96	0.07	21.02

OCFL 6-16-2022

06/16/22	10:37	0.54	0.07	21.02
06/16/22	10:38	0.7	0.07	21.03
06/16/22	10:39	0.87	0.07	21.03
06/16/22	10:40	0.96	0.07	21.03
06/16/22	10:41	0.96	0.07	21.03
06/16/22	10:42	0.88	0.07	21.03
06/16/22	10:43	0.52	0.07	21.03
06/16/22	10:44	0.63	4.21	16.16

EUENCLOSEDFLARE, Test No. 2

06/16/22	10:45	2.35	5.72	14.32
06/16/22	10:46	3.29	5.59	14.51
06/16/22	10:47	1.43	5.56	14.55
06/16/22	10:48	1.74	5.55	14.56
06/16/22	10:49	0.73	5.5	14.63
06/16/22	10:50	0.79	5.51	14.61
06/16/22	10:51	2.8	5.54	14.59
06/16/22	10:52	0.72	5.64	14.45
06/16/22	10:53	1.12	5.7	14.37
06/16/22	10:54	1.47	5.67	14.41
06/16/22	10:55	1.04	5.71	14.37
06/16/22	10:56	0.44	5.73	14.34
06/16/22	10:57	0.45	5.79	14.26
06/16/22	10:58	0.77	5.83	14.21
06/16/22	10:59	0.46	5.46	14.69
06/16/22	11:00	0.45	5.56	14.56

Paused for Port Change

06/16/22	11:01	0.45	4.53	15.77
06/16/22	11:02	0.46	1.32	19.65
06/16/22	11:03	0.39	6.46	13.51

Resumed

06/16/22	11:04	0.45	6.29	13.71
06/16/22	11:05	0.45	6.28	13.72
06/16/22	11:06	0.44	6.25	13.76
06/16/22	11:07	0.44	6.29	13.71
06/16/22	11:08	0.44	6.31	13.7
06/16/22	11:09	0.44	6.49	13.51
06/16/22	11:10	0.45	6.68	13.3
06/16/22	11:11	0.44	6.68	13.31
06/16/22	11:12	0.45	6.61	13.38
06/16/22	11:13	0.42	6.93	13.03
06/16/22	11:14	0.28	7.09	12.85
06/16/22	11:15	0.32	7.1	12.85
06/16/22	11:16	0.43	6.9	13.07
06/16/22	11:17	0.43	7.28	12.64
06/16/22	11:18	0.43	7.01	12.94
06/16/22	11:19	0.43	7.12	12.83

Paused for Port Change

RECEIVED

AUG 01 2022

AIR QUALITY DIVISION

OCFL 6-16-2022

06/16/22	11:20	0.42	5.27	14.97
06/16/22	11:21	0.51	0.18	20.95
06/16/22	11:22	0.75	0.12	20.99
06/16/22	11:23	0.53	0.11	21.01
06/16/22	11:24	0.43	2.89	17.75

Resumed

06/16/22	11:25	0.44	6.16	13.81
06/16/22	11:26	0.43	5.92	14.09
06/16/22	11:27	0.45	5.9	14.12
06/16/22	11:28	0.44	5.92	14.1
06/16/22	11:29	0.45	5.97	14.05
06/16/22	11:30	0.44	5.87	14.16
06/16/22	11:31	0.44	5.87	14.16
06/16/22	11:32	0.45	5.83	14.21
06/16/22	11:33	0.45	6.02	13.99
06/16/22	11:34	0.5	6.05	13.96
06/16/22	11:35	0.96	6.25	13.75
06/16/22	11:36	0.45	6.31	13.69
06/16/22	11:37	0.84	6.32	13.68
06/16/22	11:38	0.46	6.66	13.31
06/16/22	11:39	0.5	6.65	13.33
06/16/22	11:40	0.93	6.84	13.12

Paused for Port Change

06/16/22	11:41	0.62	6.79	13.19
06/16/22	11:42	0.8	0.37	20.72
06/16/22	11:43	1.05	0.13	20.97
06/16/22	11:44	1.03	0.11	20.99
06/16/22	11:45	1.02	0.1	21
06/16/22	11:46	0.7	0.09	21
06/16/22	11:47	0.81	0.09	21.01
06/16/22	11:48	1.02	0.09	21.01
06/16/22	11:49	1.47	0.08	21.01
06/16/22	11:50	1.09	0.08	21.01
06/16/22	11:51	5.6	0.08	21.01
06/16/22	11:52	2.89	0.08	21.02
06/16/22	11:53	1.19	0.08	21.02
06/16/22	11:54	1.02	0.08	21.02
06/16/22	11:55	1	0.08	21.02
06/16/22	11:56	1.02	0.08	21.02
06/16/22	11:57	1.01	0.08	21.02
06/16/22	11:58	0.96	5.27	14.89
06/16/22	11:59	0.48	5.59	14.49

Resumed

06/16/22	12:00	0.5	5.43	14.7
06/16/22	12:01	0.49	5.45	14.67
06/16/22	12:02	0.5	5.37	14.79
06/16/22	12:03	0.44	5.38	14.78

OCFL 6-16-2022

06/16/22	12:04	0.5	5.42	14.72
06/16/22	12:05	0.49	5.33	14.83
06/16/22	12:06	0.5	5.31	14.85
06/16/22	12:07	0.53	5.35	14.81
06/16/22	12:08	0.51	5.35	14.81
06/16/22	12:09	0.51	5.34	14.82
06/16/22	12:10	0.51	5.34	14.82
06/16/22	12:11	0.51	5.43	14.7
06/16/22	12:12	0.52	5.29	14.89
06/16/22	12:13	0.53	5.37	14.79
06/16/22	12:14	0.52	5.44	14.69
06/16/22	12:15	0.44	5.53	14.58
06/16/22	12:16	0.44	4.33	16
06/16/22	12:17	8.77	2.15	18.84
06/16/22	12:18	512.12	11.11	10.56
06/16/22	12:19	655.38	11.21	10.52
06/16/22	12:20	627.44	8.22	7.73
06/16/22	12:21	218.47	2.47	2.45
06/16/22	12:22	150.2	2.42	2.38
06/16/22	12:23	149.88	2.4	2.35
06/16/22	12:24	143.14	1.69	1.74
06/16/22	12:25	19.4	0.06	0.38
06/16/22	12:26	1.02	0.04	0.37
06/16/22	12:27	0.53	0.03	0.29
06/16/22	12:28	0.51	0.02	0.27
06/16/22	12:29	0.5	0.02	0.21
06/16/22	12:30	0.51	0.02	0.15
06/16/22	12:31	0.5	0.02	0.14
06/16/22	12:32	0.49	0.02	0.13
06/16/22	12:33	0.41	0.04	7.88
06/16/22	12:34	0.47	0.07	19.89
06/16/22	12:35	0.83	0.07	19.97
06/16/22	12:36	1.23	0.07	19.99
06/16/22	12:37	0.95	0.07	20.01
06/16/22	12:38	0.75	0.07	20.5
06/16/22	12:39	1.11	0.07	20.95
06/16/22	12:40	0.4	0.07	20.97
06/16/22	12:41	0.39	0.07	20.98
06/16/22	12:42	0.39	0.07	20.99
06/16/22	12:43	0.4	0.07	20.99
06/16/22	12:44	0.4	0.07	21
06/16/22	12:45	0.41	0.07	21
06/16/22	12:46	0.41	0.07	21
06/16/22	12:47	0.4	0.07	21
06/16/22	12:48	0.4	4.23	16.13
06/16/22	12:49	0.41	6.03	13.94
06/16/22	12:50	0.26	5.88	14.13

OCFL 6-16-2022

06/16/22	12:51	-0.11	5.76	14.28
06/16/22	12:52	-0.11	5.67	14.39
06/16/22	12:53	-0.09	5.64	14.43
06/16/22	12:54	-0.08	5.63	14.45
06/16/22	12:55	-0.1	5.67	14.39
06/16/22	12:56	-0.01	5.69	14.37
06/16/22	12:57	0.11	5.53	14.58
06/16/22	12:58	0.28	5.72	14.33
06/16/22	12:59	0.38	5.67	14.4
06/16/22	13:00	0.15	5.72	14.33
06/16/22	13:01	0.41	5.7	14.36
06/16/22	13:02	-0.05	5.69	14.37
06/16/22	13:03	-0.08	5.66	14.41
06/16/22	13:04	-0.1	5.73	14.31
06/16/22	13:05	130.68	4.63	-3.55
06/16/22	13:06	-23.07	2.49	3.38
06/16/22	13:07	0.76	5.7	14.35
06/16/22	13:08	-0.08	5.61	14.47
06/16/22	13:09	0.06	5.55	14.55
06/16/22	13:10	1.13	2.26	1.68
06/16/22	13:11	-35.75	-0.24	2.12
06/16/22	13:12	38.38	-0.56	-1.01
06/16/22	13:13	-11.06	-3.44	-0.34
06/16/22	13:14	50.82	3.52	-1.68
06/16/22	13:15	-114.14	5.36	7.67
06/16/22	13:16	-33.37	3.58	12.95
06/16/22	13:17	46.76	5.73	14.32
06/16/22	13:18	0.31	5.78	14.25
06/16/22	13:19	0.39	5.7	14.35
06/16/22	13:20	0.39	5.8	14.23
06/16/22	13:21	0.4	5.78	14.26
06/16/22	13:22	0.4	5.59	14.5
06/16/22	13:23	0.42	5.38	14.76
06/16/22	13:24	0.4	5.46	14.65
06/16/22	13:25	0.35	5.62	14.46
06/16/22	13:26	0.14	5.61	14.47
06/16/22	13:27	-0.11	5.65	14.42
06/16/22	13:28	-0.1	5.61	14.47
06/16/22	13:29	-0.08	5.48	14.63
06/16/22	13:30	-0.09	5.51	14.59
06/16/22	13:31	0.37	5.53	14.57
06/16/22	13:32	0.4	5.77	14.26
06/16/22	13:33	0.14	5.74	14.3
06/16/22	13:34	1.79	5.52	14.58

EUENCLOSED FLARE, Test No. 3

06/16/22	13:35	2.57	5.57	14.51
06/16/22	13:36	1.04	5.62	14.44

OCFL 6-16-2022

06/16/22	13:37	0.46	5.62	14.44
06/16/22	13:38	0.98	5.55	14.53
06/16/22	13:39	6.05	5.4	14.73
06/16/22	13:40	1.2	5.3	14.84
06/16/22	13:41	0.94	5.35	14.78
06/16/22	13:42	1.66	5.41	14.7
06/16/22	13:43	0.79	5.53	14.55
06/16/22	13:44	0.41	5.59	14.47
06/16/22	13:45	-0.12	5.65	14.39
06/16/22	13:46	0.28	5.58	14.49
06/16/22	13:47	0.42	5.55	14.53
06/16/22	13:48	0.48	5.58	14.48
06/16/22	13:49	0.48	5.7	14.34
06/16/22	13:50	0.38	5.76	14.26

Paused for Port Change

06/16/22	13:51	0.48	5.4	14.68
06/16/22	13:52	0.46	0.23	20.83
06/16/22	13:53	0.47	0.11	20.94
06/16/22	13:54	0.49	0.09	20.96
06/16/22	13:55	0.47	0.08	20.96
06/16/22	13:56	0.47	0.07	20.97
06/16/22	13:57	0.47	0.07	20.97
06/16/22	13:58	0.48	0.07	20.97
06/16/22	13:59	0.24	5.2	14.94

Resumed

06/16/22	14:00	0.47	5.82	14.15
06/16/22	14:01	0.49	5.68	14.34
06/16/22	14:02	0.35	5.69	14.33
06/16/22	14:03	0.39	5.67	14.35
06/16/22	14:04	0.35	5.74	14.26
06/16/22	14:05	0.14	5.64	14.4
06/16/22	14:06	0.06	5.71	14.3
06/16/22	14:07	1.66	5.56	14.5
06/16/22	14:08	0.94	5.49	14.58
06/16/22	14:09	1.06	5.47	14.61
06/16/22	14:10	0.86	5.67	14.36
06/16/22	14:11	0.73	5.76	14.24
06/16/22	14:12	0.72	5.9	14.09
06/16/22	14:13	0.83	6.12	13.85
06/16/22	14:14	0.67	6.14	13.82
06/16/22	14:15	0.63	6.04	13.93

Paused for Port Change

06/16/22	14:16	0.52	3.99	16.36
06/16/22	14:17	0.49	0.15	20.9
06/16/22	14:18	2.63	2.93	17.64
06/16/22	14:19	13.81	5.8	14.18

Resumed

OCFL 6-16-2022

06/16/22	14:20	10.05	5.71	14.3
06/16/22	14:21	6.76	5.6	14.44
06/16/22	14:22	19.95	5.68	14.35
06/16/22	14:23	8.24	5.76	14.23
06/16/22	14:24	4.25	5.79	14.2
06/16/22	14:25	5.67	5.7	14.31
06/16/22	14:26	6.48	5.7	14.32
06/16/22	14:27	5.54	5.86	14.12
06/16/22	14:28	3.2	5.9	14.06
06/16/22	14:29	3.22	5.8	14.18
06/16/22	14:30	2.15	5.83	14.15
06/16/22	14:31	3.25	6.01	13.97
06/16/22	14:32	4.57	5.82	14.18
06/16/22	14:33	1.25	6.11	13.85
06/16/22	14:34	0.97	6.43	13.51
06/16/22	14:35	0.27	6.41	13.52

Paused for Port Change

06/16/22	14:36	2.86	6.2	13.75
06/16/22	14:37	1.69	4.06	16.28
06/16/22	14:38	0.51	0.15	20.9
06/16/22	14:39	0.49	0.1	20.94
06/16/22	14:40	0.43	0.09	20.95
06/16/22	14:41	0.47	0.08	20.95
06/16/22	14:42	0.47	0.08	20.95
06/16/22	14:43	0.49	0.08	20.96
06/16/22	14:44	0.48	0.07	20.96
06/16/22	14:45	0.49	0.07	20.96
06/16/22	14:46	0.48	0.07	20.96
06/16/22	14:47	0.64	0.07	20.96
06/16/22	14:48	1.68	0.07	20.96
06/16/22	14:49	0.64	0.07	20.96
06/16/22	14:50	0.5	0.07	20.96
06/16/22	14:51	0.45	0.07	20.96
06/16/22	14:52	0.41	0.09	20.93
06/16/22	14:53	26.61	5.07	15.1

Resumed

06/16/22	14:54	26.24	5.09	15.06
06/16/22	14:55	14.85	5.05	15.12
06/16/22	14:56	7.22	4.97	15.21
06/16/22	14:57	21.22	4.95	15.24
06/16/22	14:58	11.49	4.94	15.24
06/16/22	14:59	29.14	4.85	15.36
06/16/22	15:00	19.74	4.94	15.26
06/16/22	15:01	13.75	5.05	15.13
06/16/22	15:02	1.63	5.05	15.13
06/16/22	15:03	1.15	5.15	15
06/16/22	15:04	2.13	5.05	15.13

OCFL 6-16-2022

06/16/22	15:05	3.93	5.06	15.11
06/16/22	15:06	6.62	5.1	15.06
06/16/22	15:07	4.67	5.08	15.09
06/16/22	15:08	3.79	5.08	15.08
06/16/22	15:09	3.81	5.14	15.01
06/16/22	15:10	3.44	5.01	15.16
06/16/22	15:11	2.12	5.12	15.04
06/16/22	15:12	14.3	3.41	17.05
06/16/22	15:13	77.04	4.59	16
06/16/22	15:14	598.43	11.11	10.52
06/16/22	15:15	657	11.21	10.46
06/16/22	15:16	648.67	9.11	8.49
06/16/22	15:17	256.41	2.49	2.41
06/16/22	15:18	151.05	2.42	2.34
06/16/22	15:19	151.08	2.4	2.32
06/16/22	15:20	154.86	2.39	2.3
06/16/22	15:21	154.3	2.38	2.28
06/16/22	15:22	121.23	1.05	1.14
06/16/22	15:23	4.13	0.04	0.29
06/16/22	15:24	0.39	0.02	0.27
06/16/22	15:25	0.38	0.02	0.26
06/16/22	15:26	0.38	0.01	0.24
06/16/22	15:27	0.38	0.01	1.37
06/16/22	15:28	0.05	0.05	20.63
06/16/22	15:29	-0.12	0.05	20.93
06/16/22	15:30	-0.13	0.05	20.94

APPENDIX 6

- Test Equipment QA/QC Records

CALIBRATION SUMMARY

Page 1 of ____

Company: Republic - OCFL

Location: Coopersville, MI

Source Designation: Enclosed Flame

Date: 6/13/22

Operator(s): BB

Pre 1: Run High, Mid, Low, Zero, for CH₄, NMOC, THCRun High, Mid, Low (Zero) Instrument Cal, and Mid, Zero Dynamic Cal
for NOX, O₂, CO, CO₂, SO₂

Cylinder ID	Analyte	Concentration	Unit
	CO/CO ₂ /O ₂	148.7 / 23.61 / 20.98	
	O ₂	12.49	

	Time	Procedure	Response (ppm)	Exp. Value (ppm)	Notes
Test 1	1256	O ₂ Inst	21.33	20.98	
	1258		12.61	12.59	
	1300		8.32	8.39	
	1303		21.31	20.98	
	1305		12.60	12.59	
	1310		8.30	8.39	
	1313		21.31	20.98	
	1315		12.60	12.59	
	1318		8.30	8.39	
	1323	O ₂ Inst	12.63	12.49	Direct Inject
Test 2	1328		12.61	12.49	
	1334		12.59	12.49	
	659	O ₂ Inst	21.33	20.98	
	701		10.47	10.48	
	712		0.00	0	
	759	CO ₂ Inst	23.95	23.61	
	761		11.72	11.81	
	762		0.02	0	
	766	CO ₂ Inst	295.13	293.4	
	769		150.68	146.7	
Test 3	773		0.51	0	
	778	O ₂ Sys	10.53	10.47	Response Time (RT): 37s
	736		0.39	0	
	728	CO ₂ Sys	11.33	11.72	RT: 39s
	736		0.03	0	
	731	CO Sys	148.26	150.68	RT: 55s
	736		0.44	0	
	1014	O ₂ Sys	10.67	10.47	
	1024		0.28	0	
	1014	CO ₂ Sys	11.25	11.72	
Test 4	1024		0.03	0	
	1018	CO Sys	153.52	150.68	
	1028		0.43	0	
	1219	O ₂ Sys	10.52	10.47	
	1238		0.18	0	
	1219	CO ₂ Sys	11.21	11.72	
	1231		0.02	0	
	1222	CO Sys	150.20	150.68	
	1231		0.50	0	
	1518	O ₂ Sys	10.46	10.47	
Calibration	1524		0.27	0	
	1518	CO ₂ Sys	11.21	11.72	
	1524		0.02	0	
	1524	CO Sys	150.68		

Calibration Error = $(C_{dir} - C_v)/CS \times 100$ (must be $\leq 2\%$)Bias (SB) = $(C_s - C_{dir})/CS \times 100$ (must be $\leq 5\%$)Calibration Drift = $(S_{Bf} - S_{Bi})$ (must be $\leq 3\%$)


GO Sys	1518	181.05	150.68
	1525	0.38	0

USEPA Method 2
Gas Velocity Measurement Data Sheet

Company	<u>Republic - OCFL</u>	No. of Points	<u>16</u>
Source Designation	<u>Carpenter, mi Enclosed Flue</u>	Operator(s)	<u>BB/AE</u>
Test Date	<u>6/16/72</u>	Pitot Type	<u>Type S or Standard</u>
Test Number	<u>Prelim</u>	Pitot Identification	<u>8F-I</u>
Time (24-hr clock)	<u>1500 - 1535</u>	O ₂ Content (%)	<u>15%</u>
Barometric Press. (in. Hg)	<u>29.194</u>	CO ₂ Content (%)	<u>5%</u>
Static Pressure (in. H ₂ O)	<u>-0.13</u>	Wet Bulb Temp.	<u>N/A</u>

Inches from Stack Wall	Traverse Point Number	Stack Temperature (°F)	Velocity Head (in. H ₂ O)	Null Angle (zero angle)
4.22	1	1360	0.05	0
13.86	2	1462	0.05	0
25.61	3	1460	0.05	0
42.50	4	1465	0.05	0
89.36	1	1492	0.06	0
	2		0.06	0
	3		0.05	0
	4		0.05	0
	1	1526	0.08	0
	2	1525	0.07	0
	3	1525	0.07	0
	4	1525	0.07	0
	1	1525	0.07	0
	2	1525	0.05	0
	3	1525	0.05	0
	4	1525	0.05	0

Stack / Duct Measurements



Round Duct Dia. (D) 132"


Square Duct (LxW) — x —

Square Duct Dia. (De): —

$$De = 2LW / (L+W)$$

Straight Length: A/D 96/6.73

B/D 444/3.36



a- Higher No. for rectangular stacks
b- For stacks between 12 and 24 in.

Traverse Point	No. of Traverse Points Per Dia.			
	6	8	10	12
1	4.4	3.2	2.6	2.1
2	14.6	10.5	8.2	6.7
3	29.6	19.4	14.6	11.8
4	70.4	32.2	22.6	17.7
5	85.4	67.7	34.2	25.0
6	95.6	80.6	65.8	35.6
7	89.5	77.4	64.4	
8	96.8	85.4	75.0	
9		91.8	82.3	
10		97.4	88.2	
11			93.3	
12			97.9	

Impact Compliance & Testing, Inc.

1575°F

1830 scfm

520°C/H

Method 7E Stratification Testing Field Data Sheet

Facility: Republic - OCFL

Date: _____

Source: _____

Operator: _____


	Point No. 1	Point No. 2	Point No. 3	Point 4 Average	Average
Time	835-837	838-840	841-843	844-846	
Pollutant					
CO	1.66	1.98	1.50	1.97	1.78
CO ₂	5.48	5.46	5.51	5.61	
O ₂	14.8	14.9	14.8	14.7	

PITOT TUBE INSPECTION CRITERIA
CHECKLIST

Tube #: 8F-I

Date: 6/15/2022

$3/16'' \leq D_t \leq 3/8''$



$P_A = P_B$

$1.05D_t \leq P_{A,B} \leq 1.5D_t$

Yes

No

Yes


No

Yes

No

α_1 and $\alpha_2 < 10^\circ$

Transversal
Tube Axis




Yes

No

β_1 and $\beta_2 < 5^\circ$


Longitudinal
Tube Axis



Yes

No


$z < 0.32$ cm



Yes

No

$w < 0.08$ cm



Yes

No

Pitot Tube Correction Factor: 0.84

Impact Compliance & Testing**Scale Calibration Sheet**Facility: OCAFScale ID: T-2Source: FlareOperator: A E

Expected (grams)	Date: <u>6/16/2022</u>		Date:	
	Actual (g)	% Difference	Actual (g)	% Difference
2.0				
5.0	<u>5.0</u>			
10.0	<u>9.9</u>			
20.0	<u>19.7</u>			
50.0	<u>49.7</u>			
100.0	<u>100.0</u>			
200.0	<u>199.7</u>			
500.0	<u>499.8</u>			
1000.0	<u>999.2</u>			

RECEIVED

AUG 01 2022

Page of

AIR QUALITY DIVISION

METHOD 205 - DILUTION MODULE VERIFICATION

Date: 6/15/2022
Client: OCFL

Evaluate dilution module at two (2) dilutions within the range of the module. Repeat twice (total of 3 trials). Calculate average instrument response for each triplicate injection.

Gas used: 20.98 %, oxygen calibration gas

Divider Setting	Expected Concentration	Injection			Average	%Error
		No. 1	No. 2	No. 3		
100%	20.98	21.33	21.31	21.31	21.32	1.60%
60%	12.59	12.61	12.60	12.60	12.60	0.12%
40%	8.39	8.32	8.30	8.30	8.31	-1.02%

Individual Response Errors as Compared to Average		
0.1%	0.0%	0.0%
0.1%	0.0%	0.0%
0.2%	-0.1%	-0.1%

Introduce mid-level protocol gas (instrument). Repeat twice (total of 3 injections).

Mid-Range Gas	Expected Concentration	Injection			Average	%Error
		No. 1	No. 2	No. 3		
O ₂	12.49	12.63	12.61	12.59	12.61	0.96%

Individual Response Errors as Compared to Average		
0.2%	0.0%	-0.2%

Criteria:

1. Each injection shall differ no more than 2% from the triplicate average.
2. No average shall be greater than 2% of the predicted value.

METHOD 7E - STACK STRATIFICATION DETERMINATION

Date: 6/16/2022
Client: OCFL

Measure three points located at 16.7%, 50.0% and 83.3% of stack diameter for twice the system response time. Determine the percent difference of the response at each point compared the the three point average.

EUENCLOSEDFLARE Point	Recorded Time	Concentration		
		CO ₂ (%)	O ₂ (%)	CO (ppm)
1	8:37	5.48	14.8	1.66
2	8:40	5.46	14.9	1.98
3	8:43	5.51	14.8	1.50
4	8:46	5.61	14.7	1.97
Average	-	5.52	14.8	1.78

Response as Compared to Average		
CO ₂	O ₂	CO
-0.6%	0.0%	-6.6%
-1.0%	0.7%	11.4%
-0.1%	0.0%	-15.6%
1.7%	-0.7%	10.8%
-	-	-

Criteria:

1. If the response differs no more than 5% from the three point average, measure at one point.
2. If the response differs more than 5% but no more than 10% from the three point average, measure at three points.
3. If the response differs more than 10% from the three point average, measure at twelve points.

Summary of Calibration Data

Client: OCFL
Source: EUENCLOSEDFLARE
Date: 6/16/2022
CO 1,467 ppm
O₂ 20.98 %
CO₂ 23.61 %

Instrument: Servomex Model 1400D - O₂

Span: 20.98 %

ACE Expected Values (ppm)	20.98	10.49	0	Analyzer Calibration Error (%)		
Test ID	Hi	Mid	Low	Hi	Mid	Low
Initial Calibration Response	21.33	10.47	0.00	1.67	-0.10	0.00
System Bias (ppm)						
Test ID	Upscale	Bias (%)	Drift (%)	Zero	Bias (%)	Drift (%)
EF, Pre Test 1	10.53	0.29	-	0.39	1.86	-
EF, Post Test 1/Pre Test 2	10.67	0.95	0.67	0.28	1.33	0.52
EF, Post Test 2/Pre Test 3	10.52	0.24	0.71	0.15	0.71	0.62
EF, Post Test 3	10.46	-0.05	0.29	0.27	1.29	0.57

Instrument: Servomex Model 1400D - CO₂

Span: 23.61 %

ACE Expected Values (ppm)	23.61	11.81	0	Analyzer Calibration Error (%)		
Test ID	Hi	Mid	Low	Hi	Mid	Low
Initial Calibration Response	23.95	11.72	0.02	1.44	-0.36	0.08
System Bias (ppm)						
Test ID	Upscale	Bias (%)	Drift (%)	Zero	Bias (%)	Drift (%)
EF, Pre Test 1	11.38	-1.44	-	0.03	0.04	-
EF, Post Test 1/Pre Test 2	11.25	-1.99	0.55	0.03	0.04	0.00
EF, Post Test 2/Pre Test 3	11.21	-2.16	0.17	0.02	0.00	0.04
EF, Post Test 3	11.21	-2.16	0.00	0.02	0.00	0.00

Instrument: Thermo Environmental Instruments, Inc., Model 48i - CO

Span: 293.4 ppm

ACE Expected Values (ppm)	293.4	146.7	0	Analyzer Calibration Error (%)		
Test ID	Hi	Mid	Low	Hi	Mid	Low
Initial Calibration Response	295.1	150.7	0.51	0.59	1.36	0.17
System Bias (ppm)						
Test ID	Upscale	Bias (%)	Drift (%)	Zero	Bias (%)	Drift (%)
EF, Pre Test 1	148.3	-0.82	-	0.44	-0.02	-
EF, Post Test 1/Pre Test 2	153.5	0.97	1.79	0.43	-0.03	0.00
EF, Post Test 2/Pre Test 3	150.2	-0.16	1.13	0.50	0.00	0.02
EF, Post Test 3	151.1	0.13	0.29	0.38	-0.04	0.04

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

IMPACT COMPLIANCE & TESTING, INC.

- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at maximum attainable vacuum (open coarse valve, close fine valve), for period of 5 minutes minimum for large orifice up to 10 minutes for smallest orifice.
- 4) Record readings in outlined boxes below, other columns are automatically calculated.

DATE: 6/08/2022		METER SERIAL #: N1		CRITICAL ORIFICE SET SERIAL #: 1316		BAROMETRIC PRESSURE (in Hg): 29.08		INITIAL	FINAL	AVG (P _{bar})	IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED						
ORIFICE #	RUN #	K' FACTOR	TESTED VACUUM (in Hg)	DGM READINGS (FT ³)			TEMPERATURES °F				ELAPSED TIME (MIN) θ	DGM ΔH (in H ₂ O)	(1) V _m (STD)	(2) V _{cr} (STD)	(3) Y	VARIATION (%)	
				INITIAL	FINAL	NET (V _m)	AMBIENT	DGM INLET INITIAL FINAL	DGM OUTLET INITIAL FINAL	DGM AVG							
#29	1	0.7968	18.00	782.518	787.53	5.012	73	74	76	71	71	73.0	5.00	3.60	4.8704	5.0197	1.0307
	2	0.7968	18.00	787.53	792.54	5.010	73	76	78	71	72	74.3	5.00	3.60	4.8571	5.0197	1.0335
	3	0.7968	18.00	792.54	797.568	5.028	73	78	79	72	73	75.5	5.00	3.60	4.8631	5.0197	1.0322
#24	1	0.6534	19.75	797.568	806.00	8.432	73	79	80	73	74	76.5	10.00	2.40	8.1158	8.2326	1.0144
	2	0.6534	19.75	806.00	814.43	8.430	73	80	81	74	75	77.5	10.00	2.40	8.0988	8.2326	1.0165
	3	0.6534	19.75	814.43	822.894	8.464	74	81	82	75	76	78.5	10.00	2.40	8.1163	8.2249	1.0134
#20	1	0.5333	21.00	822.894	829.80	6.906	74	82	82	76	77	79.3	10.00	1.50	6.5982	6.7131	1.0174
	2	0.5333	21.00	829.80	836.69	6.890	75	82	82	77	77	79.5	10.00	1.50	6.5798	6.7068	1.0193
	3	0.5333	21.00	836.69	843.597	6.907	75	82	82	77	78	79.8	10.00	1.50	6.5930	6.7068	1.0173
AVG = 1.0321 1.03																	
AVG = 1.0148 -0.67																	
AVG = 1.0148 -0.67																	
AVG = 1.0180 -0.36																	

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

$$(1) \quad V_m (\text{std}) = K_1 V_m \frac{P_{\text{bar}} + [\Delta H / 13.6]}{T_m} = \text{Net volume of gas sample passed through DGM, corrected to standard conditions}$$

$K_1 = 17.64 \text{ "R/in. Hg (English), } 0.3858 \text{ "K/mm Hg (Metric)}$

$T_m = \text{Absolute DGM avg. temperature ("R - English, "K - Metric)}$

$$(2) \quad V_{cr} (\text{std}) = K' \sqrt{\frac{P_{\text{bar}} \theta}{T_{\text{amb}}}} = \text{Volume of gas sample passed through the critical orifice, corrected to standard conditions}$$

$T_{\text{amb}} = \text{Absolute ambient temperature ("R - English, "K - Metric)}$

$K' = \text{Average K' factor from Critical Orifice Calibration}$

$$(3) \quad Y = \frac{V_{cr} (\text{std})}{V_m (\text{std})} = \text{DGM calibration factor}$$

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 1.0216

Y-5% = 0.971 1.073 = Y+5%
6/08/2022 Delta H@ 1.898
Kiso 1749.954

PYROMETER CALIBRATION

Meter	32	100	252	500	1000	1500
Omega	32	100	250	500	1000	1500
% Difference	0.0	0.0	0.8	0.0	0.0	0.0

METHOD 5 DRY GAS METER CALIBRATION USING CRITICAL ORIFICES

IMPACT COMPLIANCE & TESTING, INC.

- 1) Select three critical orifices to calibrate the dry gas meter which bracket the expected operating range.
- 2) Record barometric pressure before and after calibration procedure.
- 3) Run at maximum attainable vacuum (open coarse valve, close fine valve), for period of 5 minutes minimum for large orifice up to 10 minutes for smallest orifice.
- 4) Record readings in outlined boxes below, other columns are automatically calculated.

DATE:		7/08/2022	METER SERIAL #:		N1	CRITICAL ORIFICE SET SERIAL #:		1316	BAROMETRIC PRESSURE (in Hg):		29.21	FINAL	29.21	AVG (P _{bar})	29.207	IF Y VARIATION EXCEEDS 2.00%, ORIFICE SHOULD BE RECALIBRATED			
ORIFICE #	RUN #	K' FACTOR (AVG)	TESTED VACUUM (in Hg)	DGM READINGS (FT ³)			TEMPERATURES °F				ELAPSED TIME (MIN) θ	DGM ΔH (in H ₂ O)	(1) V _m (STD)	(2) V _{cr} (STD)	(3) Y	VARIATION (%)			
				INITIAL	FINAL	NET (V _m)	AMBIENT	DGM INLET INITIAL	DGM INLET FINAL	DGM OUTLET INITIAL	DGM OUTLET FINAL	DGM AVG							
#29	1	0.7968	18.00	982.444	987.50	5.056	80	83	84	82	82	82.8	5.00	3.60	4.8457	5.0088	1.0337		
	2	0.7968	18.00	987.50	992.56	5.060	80	84	85	82	82	83.3	5.00	3.60	4.8451	5.0088	1.0338		
	3	0.7968	18.00	992.56	997.615	5.055	80	85	86	82	82	83.8	5.00	3.60	4.8359	5.0088	1.0358	Avg = 1.0344 1.25	
#24	1	0.6534	19.75	997.615	1006.18	8.565	81	86	88	82	83	84.8	10.00	2.40	8.1542	8.2071	1.0065		
	2	0.6534	19.75	1006.18	1014.75	8.570	81	88	90	83	84	86.3	10.00	2.40	8.1365	8.2071	1.0087		
	3	0.6534	19.75	1014.75	1023.300	8.550	81	90	91	84	85	87.5	10.00	2.40	8.0990	8.2071	1.0134	Avg = 1.0095 -1.19	
#20	1	0.5333	21.00	1023.300	1030.23	6.930	82	91	91	85	86	88.3	10.00	1.50	6.5407	6.6924	1.0232		
	2	0.5333	21.00	1030.23	1037.18	6.950	82	91	91	86	86	88.5	10.00	1.50	6.5566	6.6924	1.0207		
	3	0.5333	21.00	1037.18	1044.142	6.962	82	91	91	86	87	88.8	10.00	1.50	6.5649	6.6924	1.0194	Avg = 1.0211 -0.05	

USING THE CRITICAL ORIFICES AS CALIBRATION STANDARDS:

The following equations are used to calculate the standard volumes of air passed through the DGM, V_m (std), and the critical orifice, V_{cr} (std), and the DGM calibration factor, Y. These equations are automatically calculated in the spreadsheet above.

$$(1) \quad V_m (\text{std}) = K_1 V_m \frac{P_{\text{bar}} + (\Delta H / 13.6)}{T_m} = \text{Net volume of gas sample passed through DGM, corrected to standard conditions}$$

$K_1 = 17.64 \text{ "R/in. Hg (English), } 0.3858 \text{ "K/mm Hg (Metric)}$

$T_m = \text{Absolute DGM avg. temperature ("R - English, "K - Metric)}$

$$(2) \quad V_{cr} (\text{std}) = K' \sqrt{\frac{P_{\text{bar}} \theta}{T_{\text{amb}}}} = \text{Volume of gas sample passed through the critical orifice, corrected to standard conditions}$$

$T_{\text{amb}} = \text{Absolute ambient temperature ("R - English, "K - Metric)}$

$K' = \text{Average K' factor from Critical Orifice Calibration}$

$$(3) \quad Y = \frac{V_{cr} (\text{std})}{V_m (\text{std})} = \text{DGM calibration factor}$$

AVERAGE DRY GAS METER CALIBRATION FACTOR, Y = 1.0217

Y-5% = 0.971

1.073 = Y+5%

7/08/2022

Delta H@

Kiso

1.885

1775.037

PYROMETER CALIBRATION

Meter	32	100	252	500	1000	1500
Omega	32	100	250	500	1000	1500
% Difference	0.0	0.0	0.8	0.0	0.0	0.0

Method 7E Interference Response Verification

Date: 7/26/2006
Analyzer: Thermo Model 42c

Tested Calibration Span: 44.0 ppm

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response¹</i>	<i>Deviation from Expected Response (ppm)</i>
CO ₂ /NO _x	1.72% / 26.4	26.20	0.20
CO ₂	4.29%	-0.10	0.10
O ₂ /NO _x	8.36% / 26.4	26.27	0.13
O ₂	20.9%	0.00	0.00
CO/NO _x	23.88 / 26.4	26.40	0.00
CO	59.70	-0.11	0.11
CH ₄ /NO _x	33.6 / 26.4	26.10	0.30
CH ₄	84.0	-0.11	0.11
SO ₂ /NO _x	8.16 / 26.4	26.20	0.20
SO ₂	20.4	-0.10	0.10
C ₃ H ₈ /NO _x	33.32 / 26.4	26.34	0.06
C ₃ H ₈	83.3	-0.11	0.11
<hr/>			Total Deviation (ppm)²
<hr/>			1.05
<hr/>			% of Calibration Span³
<hr/>			2.38

1 - Measured concentrations were corrected for system bias.

2 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

3 - Total Interference must be less than 2.50% of the calibration span.


Calibrator: Andy Rusnak

7/26/2006

Date

Method 7E Interference Response Verification

Date: 1/27/2021
Analyzer: Thermo Model 42i

Tested Calibration Span: 100.7 ppm

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response</i>	<i>Deviation from Expected Response (ppm)</i>
CO ₂ /NO _x	18.51% / 100.68	100.73	0.05
CO ₂	23.14%	0.08	0.08
O ₂ /NO _x	16.81% / 100.68	100.73	0.05
O ₂	21.01%	0.08	0.08
CO/NO _x	1188 / 100.68	100.73	0.05
CO	1485	0.08	0.08
Acetaldehyde/NO _x	168.6 / 100.68	100.86	0.18
Acetaldehyde	210.7	0.17	0.17
SO ₂ /NO _x	165.0 / 100.68	100.86	0.18
SO ₂	206.3	0.17	0.17
C ₃ H ₈ /NO _x	67.4 / 100.68	100.71	0.03
C ₃ H ₈	84.25	0.17	0.17
			Total Deviation (ppm)¹ 0.77
			% of Calibration Span² 0.76

1 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

2 - Total Interference must be less than 2.50% of the calibration span.


Calibrator: Andy Rusnak

1/27/2021

Date

Method 7E Interference Response Verification

Date: 6/21/2011
Analyzer: Thermo Model 48c

Tested Calibration Span: 100.0 ppm

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response¹</i>	<i>Deviation from Expected Response (ppm)</i>
CO ₂ /CO	5.40% / 60.0	60.1	0.07
CO ₂	13.50%	0.00	0.00
O ₂ /CO	5.02% / 60.0	60.2	0.15
O ₂	12.55%	0.00	0.00
NO _x /CO	39.7 / 60.0	59.9	0.09
NO _x	99.3	0.01	0.01
CH ₄ /CO	35.2 / 60.0	60.6	0.64
CH ₄	88.1	-0.05	0.05
SO ₂ /CO	12.2 / 60.0	60.17	0.17
SO ₂	30.4	-0.04	0.04
C ₃ H ₈ /CO	40.8 / 60.0	60.90	0.90
C ₃ H ₈	102	0.41	0.41
<hr/>			Total Deviation (ppm)²
<hr/>			% of Calibration Span³
<hr/>			2.02
<hr/>			2.02

1 - Measured concentrations were corrected for system bias.

2 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

3 - Total Interference must be less than 2.50% of the calibration span.



6/21/2011

Calibrator: Andy Rusnak

Date

Method 7E Interference Response Verification

Date: 4/19/2016
Analyzer: Thermo Model 48i

Tested Calibration Span: 1484.0 ppm

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response</i>	<i>Deviation from Expected Response (ppm)</i>
CO ₂ /CO	11.22% / 742.0	746.3	4.31
CO ₂	22.44%	-0.50	0.50
O ₂ /CO	10.45% / 742.0	736.6	5.37
O ₂	21.11%	0.10	0.10
NO/CO	148.8 / 742.0	741.9	0.10
NO	119.0	0.09	0.09
NO ₂ /CO	25.1 / 742.0	741.4	0.61
NO ₂	50.24	0.07	0.07
C ₃ H ₈ /CO	42.9 / 742.0	736.63	5.37
C ₃ H ₈	85.8	1.08	1.08
<hr/>			Total Deviation (ppm)¹
<hr/>			15.76
<hr/>			% of Calibration Span²
<hr/>			1.06

1 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

2 - Total Interference must be less than 2.50% of the calibration span.


Calibrator: Andy Rusnak

4/21/2016
Date

Method 7E Interference Response Verification

Date: 7/26/2006
Analyzer: Fuji ZRF CO Cell

Tested Calibration Span: 298.8 ppm

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response</i> ¹	<i>Deviation from Expected Response (ppm)</i>
CO ₂ /CO	1.72% / 179.3	179.1	0.20
CO ₂	1.72%	0.06	0.06
O ₂ /CO	8.36% / 179.3	180.6	1.37
O ₂	20.9%	-0.09	0.09
NO _x /CO	26.4 / 179.3	179.3	0.02
NO _x	44.0	-0.10	0.10
CH ₄ /CO	33.6 / 179.3	180.6	1.28
CH ₄	84.0	-0.01	0.01
SO ₂ /CO	8.16 / 179.3	179.08	0.20
SO ₂	20.4	1.29	1.29
C ₃ H ₈ /CO	33.32 / 179.3	179.42	0.14
C ₃ H ₈	83.3	0.02	0.02
<hr/>			Total Deviation (ppm)²
<hr/>			4.38
<hr/>			% of Calibration Span³
<hr/>			1.46

1 - Measured concentrations were corrected for system bias.

2 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

3 - Total Interference must be less than 2.50% of the calibration span.


Calibrator: Andy Rusnak

7/26/2006

Date

Method 7E Interference Response Verification

Date: 7/26/2006
Analyzer: Fuji ZRF CO₂ Cell

Tested Calibration Span: 4.29 %

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response¹</i>	<i>Deviation from Expected Response (ppm)</i>
NO _x /CO ₂	26.4 / 1.72%	1.72	0.01
NO _x	44.0	0.00	0.00
O ₂ /CO ₂	8.36% / 1.72%	1.73	0.02
O ₂	20.9%	0.00	0.00
CO/CO ₂	23.88 / 2.57%	2.57	0.00
CO	59.70	0.00	0.00
CH ₄ /CO ₂	33.6 / 2.57%	2.57	0.00
CH ₄	84.0	0.00	0.00
C ₃ H ₈ /CO ₂	33.32 / 2.57	2.57	0.00
C ₃ H ₈	83.3	0.00	0.00
<hr/>			Total Deviation (ppm)²
<hr/>			% of Calibration Span³
<hr/>			0.03
<hr/>			0.59

1 - Measured concentrations were corrected for system bias.

2 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

3 - Total Interference must be less than 2.50% of the calibration span.



7/26/2006

Calibrator: Andy Rusnak

Date

Method 7E Interference Response Verification

Date: 7/26/2006
Analyzer: Fuji ZFK3 O₂ Cell

Tested Calibration Span: 20.9 %

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response¹</i>	<i>Deviation from Expected Response (ppm)</i>
CO ₂ /O ₂	1.72% / 12.54%	12.62	0.08
CO ₂	4.29%	0.00	0.00
NO _x /O ₂	26.4 / 8.36%	8.41	0.05
NO _x	44.0	0.00	0.00
CO/O ₂	23.88 / 12.54	12.56	0.02
CO	59.70	0.00	0.00
SO ₂ /O ₂	8.16 / 12.54	12.62	0.08
SO ₂	20.4	0.29	0.29
C ₃ H ₈ /O ₂	33.32 / 12.54	12.58	0.04
C ₃ H ₈	83.3	0.00	0.00
<hr/>			Total Deviation (ppm)²
<hr/>			% of Calibration Span³
<hr/>			0.48
<hr/>			2.30

1 - Measured concentrations were corrected for system bias.

2 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

3 - Total Interference must be less than 2.50% of the calibration span.



7/26/2006

Calibrator: Andy Rusnak

Date

Method 7E Interference Response Verification

Date: 7/3/2007
Analyzer: API Model 100 AH


Tested Calibration Span: 20.9 ppmv

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response</i> ¹	<i>Deviation from Expected Response (ppm)</i>
SO ₂ /CO ₂	20.9 / 4.33%	20.85	0.05
CO ₂	4.29%	-0.12	0.12
SO ₂ /NO _x	16.72 / 5.04	16.71	0.01
NO _x	5.04	-0.10	0.10
SO ₂ /CO	16.72 / 11.94	16.80	0.08
CO	59.70	-0.06	0.06
SO ₂ /O ₂	16.72 / 1.75%	16.78	0.06
O ₂	8.75%	0.07	0.07
SO ₂ /C ₃ H ₈	16.72 / 34.84	16.75	0.03
C ₃ H ₈	174.2	0.03	0.03
Total Deviation (ppm)²			0.40
% of Calibration Span³			1.91

1 - Measured concentrations were corrected for system bias.

2 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

3 - Total Interference must be less than 2.50% of the calibration span.



7/3/2007

Calibrator: Andy Rusnak

Date

RECEIVED

AUG 01 2022

AIR QUALITY DIVISION

Method 7E Interference Response Verification

Date: 4/3/2012
Analyzer: Servomex CO₂ Cell


Tested Calibration Span: 13.32 %

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response¹</i>	<i>Deviation from Expected Response (ppm)</i>
NO _x /CO ₂	109 / 5.33%	5.29	0.03
NO _x	109.0	0.00	0.00
O ₂ /CO ₂	12.5% / 5.33%	5.33	0.01
O ₂	12.5%	0.00	0.00
CO/CO ₂	60.0 / 5.33%	5.31	0.01
CO	60.0	0.00	0.00
CH ₄ /CO ₂	61.2 / 5.33%	5.28	0.04
CH ₄	61.2	0.00	0.00
SO ₂ /CO ₂	30.4 / 5.33%	5.34	0.02
SO ₂	30.4	0.00	0.00
C ₃ H ₈ /CO ₂	50.9 / 5.33%	5.26	0.06
C ₃ H ₈	50.9	0.00	0.00
Total Deviation (ppm)²			0.16
% of Calibration Span³			1.20

1 - Measured concentrations were corrected for system bias.

2 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

3 - Total Interference must be less than 2.50% of the calibration span.



Calibrator: Andy Rusnak

4/3/2012

Date

Method 7E Interference Response Verification

Date: 4/3/2012
Analyzer: Servomex O₂ Cell

Tested Calibration Span: 20.8 %

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response¹</i>	<i>Deviation from Expected Response (ppm)</i>
CO ₂ /O ₂	5.33% / 12.5%	12.55	0.05
CO ₂	7.99%	0.04	0.04
NO _x /O ₂	109 / 8.33%	8.33	0.01
NO _x	109	0.00	0.00
CO/O ₂	60.0 / 8.33%	8.28	0.06
CO	60.0	0.00	0.00
SO ₂ /O ₂	30.4 / 8.33%	8.30	0.04
SO ₂	30.4	0.03	0.03
CH ₄ /O ₂	61.2 / 12.5%	12.44	0.06
C ₃ H ₈ /O ₂	50.9 / 12.5%	12.50	0.00
<hr/>			Total Deviation (ppm)²
<hr/>			% of Calibration Span³
<hr/>			0.14
<hr/>			0.68

1 - Measured concentrations were corrected for system bias.

2 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

3 - Total Interference must be less than 2.50% of the calibration span.



4/3/2012

Calibrator: Andy Rusnak

Date

Method 7E Interference Response Verification

Date: 6/12/2014
Analyzer: Servomex 1440D CO₂ Cell

Tested Calibration Span: 22.63 %

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response</i>	<i>Deviation from Expected Response (ppm)</i>
CO ₂ /O ₂	11.32 / 10.47%	11.35	0.03
O ₂	13.58%	0.03	0.03
NOx/CO ₂	248 / 11.32%	11.35	0.03
NOx	497	0.05	0.05
CO/CO ₂	746 / 11.32%	11.49	0.17
CO	1491	0.03	0.03
SO ₂ /CO ₂	100.7 / 11.32%	11.37	0.05
SO ₂	201.3	0.07	0.07
CH ₄ /CO ₂	867 / 11.32%	11.39	0.07
CH ₄	867	0.04	0.04
C ₃ H ₈ /CO ₂	42.23 / 11.32%	11.38	0.06
C ₃ H ₈	42.23	0.03	0.03
<hr/>			Total Deviation (ppm)¹
<hr/>			0.45
<hr/>			% of Calibration Span²
<hr/>			1.99

1 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

2 - Total Interference must be less than 2.50% of the calibration span.


Calibrator: Andy Rusnak

6/12/2014
Date

Method 7E Interference Response Verification

Date: 6/12/2014
Analyzer: Servomex 1440D O₂ Cell

Tested Calibration Span: 20.9 %

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response</i>	<i>Deviation from Expected Response (ppm)</i>
CO ₂ /O ₂	11.32 / 10.47	10.52	0.05
CO ₂	13.58%	0.06	0.06
NOx/O ₂	248 / 10.47%	10.35	0.12
NOx	497	0.00	0.00
CO/O ₂	746 / 10.47%	10.50	0.03
CO	1491	-0.01	0.01
SO ₂ /O ₂	100.7 / 10.47%	10.47	0.00
SO ₂	201.3	-0.15	0.15
CH ₄ /O ₂	867 / 10.47%	10.40	0.07
C ₃ H ₈ /O ₂	42.23 / 10.47%	10.40	0.07
			Total Deviation (%)² <u>0.50</u>
			% of Calibration Span³ <u>2.39</u>

1 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

2 - Total Interference must be less than 2.50% of the calibration span.


Calibrator: Andy Rusnak

6/12/2014

Date

Method 7E Interference Response Verification

Date: 11/12/2015
Analyzer: TEI 43i HL SO2 Analyzer

Tested Calibration Span: 80.52 ppm

<i>Test Gas Type</i>	<i>Concentration (ppm)</i>	<i>Analyzer Response</i>	<i>Deviation from Expected Response (ppm)</i>
CO ₂ /SO ₂	13.58% / 80.52	80.76	0.24
CO ₂	22.63%	0.44	0.23
NOx	50.5	0.65	0.44
CO/SO ₂	892 / 80.52	80.41	0.11
CO	1487.0	0.35	0.14
O ₂ /SO ₂	12.76% / 80.52	80.31	0.21
O ₂	21.27%	0.17	0.04
C ₃ H ₈ /SO ₂	50.6 / 80.52	80.93	0.41
C ₃ H ₈	84.41	0.21	0.00
Total Deviation (ppm)²			1.43
% of Calibration Span³			1.78

1 - In summing the total deviation use the larger of the absolute values obtained for the interferent tested with and without the pollutant present.

2 - Total Interference must be less than 2.50% of the calibration span.



11/12/2015

Calibrator: Andy Rusnak

Date



Airflow Sciences Corporation

Probe Calibration for Method 2

Data Collection and Analysis

Date: 8/19/2021

Temperature ($^{\circ}$ F): 79.8

Pressure ("Hg): 29.37

Personnel: mcn

Probe: 8F-IN-A

Wind Tunnel Target DP [I.W.C]	Wind Tunnel Actual DP [I.W.C]	S-Probe DP [I.W.C.]	C_p	$C_p(\text{avg})$	$C_p - C_p(\text{avg})$	σ_{max}	
0.81	0.81	1.17	0.823	0.823	0.000	0.001	Pass
0.81	0.81	1.17	0.824		0.001		
0.81	0.81	1.17	0.822		-0.001		
1.81	1.82	2.64	0.821	0.821	0.000	0.000	Pass
1.81	1.82	2.64	0.821		0.000		
1.81	1.82	2.64	0.821		0.000		



Airflow Sciences Corporation

Probe Calibration for Method 2

Wind Tunnel Facility: Airflow Sciences Corporation
 Wind Tunnel Location: Livonia, MI
 Probe Type: S-Type Pitot
 Probe ID: 8F-JN-A
 Probe Calibration Date: 08/19/21
 Test Point Location: center
 Ambient Temperature (°F): 79.8
 Barometric Pressure ("Hg): 29.37

Repetition	Nominal Low Velocity Setting (ft/s)	Calibration Pitot		Tested Probe		Calculated C _p
		D _P _{std} ("H ₂ O)	Temperature (°F)	D _P ("H ₂ O)	Yaw Angle (°)	
1	60	0.81	79.8	1.17	0	0.82
2	60	0.81	79.8	1.17	0	0.82
3	60	0.81	79.8	1.17	0	0.82
Average (C _{p(avg-low)})						0.82

Repetition	Nominal High Velocity Setting (ft/s)	Calibration Pitot		Tested Probe		Calculated C _p
		D _P _{std} ("H ₂ O)	Temperature (°F)	D _P ("H ₂ O)	Yaw Angle (deg)	
1	90	1.82	79.8	2.64	0	0.82
2	90	1.82	79.8	2.64	0	0.82
3	90	1.82	79.8	2.64	0	0.82
Average (C _{p(avg-high)})						0.82

$$\% \text{ Difference} = \frac{C_{p(\text{avg-low})} - C_{p(\text{avg-high})}}{C_{p(\text{avg-low})}} \times 100\% = 0.26\% \quad \text{Pass}$$

Note: (1) The percent difference between the low and high velocity setting C_p values shall be within +/- 3 %.
 (2) If calibrating a 3-D probe for this method, the pitch angle setting must be 0°.

C_p = 0.822



HORIBA Instruments Incorporated
5900 Hines Drive
Ann Arbor, MI 48108

Certificate of Calibration

Certificate Number: K4CG7DTB-102721

The calibration was performed using reference standards which have traceability to the International System of Units (SI) through the United States National Institute of Standards and Technology (NIST). This calibration is accredited under the laboratory's ISO/IEC 17025 accreditation issued by the ANSI-ASQ National Accreditation Board. Refer to certificate and scope of accreditation ACT-1312. The calibration was performed using the procedure number stated below.

Customer: Impact Compliance & Testing
Customer Address: 4180 Keller Road, Suite B
Holt, MI 48842

Manufacturer: STEC
Description: Gas Divider
Condition Received: Passed
Cal Procedure: WI-QM-B-010

Date Calibrated: 10/27/21
Calibration Gas: Zero N₂

Part Number: SGD-710C
HGS Number: K4CG7DTB
Condition Returned: Passed
Uncertainty: +/- 0.048 L/min
Recommended
Re-calibration Due: 10/27/22
Lot Number: 32-402237693-1

Standards Traceability

Mfr./Model Number	Serial #	Test Number	Cal. Date	Due Date
Fluke / 3E4-VCR-V-Q	1016+	PHC4504.0005	06/21/21	06/21/22
Fluke / 3E4-VCR-V-Q	1015+	PHC4504.0005	06/21/21	06/21/22
Fluke / Molbox 1+	448+	PHC4504.0006	06/21/21	06/21/22

Calibrated by: Kerry L. Tif Date: 10/27/21
Approved by: Frank J. Burns Date: 10/27/21

This certificate may not be reproduced, except in full, without the written approval of HORIBA. The calibrated system is operating within the specification. The recommended calibration cycle implies system usage in normal, non-extreme, environmental conditions.

The uncertainty is calculated at a 95% confidence interval with a coverage factor of k=2. Pass/Fail determination is based on the simple acceptance rule. The unit is considered passing if calibration data is within the specification limits.

This certificate is issued under the authority of: HORIBA Instruments Incorporated, 2890 John R Road, Troy, MI 48083.

GDC-03, SGD-A10, SGD-710 GAS DIVIDERS VERIFICATION CHECK SHEET

As Found Data

CUSTOMER: Impact Compliance DATE: 10/27/21

MODEL: SGD-710C

HGS NUMBER: K4CG7DTB

CUT PT.	COMP A MIXTURE GAS	COMP B DILUTANT GAS	TOTAL FLOW POINT	MIXTURE FLOW %	%POINT ERROR >2.0%	STATUS
0	0.0000	3.9742	3.9742	0.000	0.000	Pass
10	0.3994	3.5986	3.9980	9.990	0.100	Pass
20	0.8017	3.2182	4.0199	19.943	0.284	Pass
30	1.2018	2.8360	4.0378	29.764	0.794	Pass
40	1.6101	2.4353	4.0454	39.801	0.501	Pass
50	2.0141	2.0392	4.0533	49.690	0.623	Pass
60	2.4329	1.6232	4.0561	59.981	0.031	Pass
70	2.8345	1.2262	4.0607	69.803	0.282	Pass
80	3.2467	0.8202	4.0669	79.832	0.210	Pass
90	3.6674	0.4089	4.0763	89.969	0.035	Pass
100	4.0705	0.0000	4.0705	100.000	0.000	Pass

STD. DEV. 0.0321 LPM

MIXTURE GAS INLET PRESSURE TO DIVIDER: 21.0 PSIG
(At 100% CUTPOINT)DILUTION GAS INLET PRESSURE TO DIVIDER: 17.0 PSIG
(AT 0.0% CUTPOINT)

OUTLET FLOW FROM GAS DIVIDER: 4.00 LPM

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Customer:	DERENZO & ASSOCIATES	
Part Number:	E03NI56E15A0002	Reference Number: 32-401412499-1
Cylinder Number:	SG9152485BAL	Cylinder Volume: 162.0 CF
Laboratory:	112 - Troy-32 (SAP) - MI	Cylinder Pressure: 2015 PSIG
PGVP Number:	B62019	Valve Outlet: 590
Gas Code:	CO2,O2,BALN	Certification Date: Feb 05, 2019

Expiration Date: Feb 05, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	21.00 %	21.41 %	G1	+/- 0.5% NIST Traceable	02/05/2019
CARBON DIOXIDE	22.50 %	22.26 %	G1	+/- 0.6% NIST Traceable	02/05/2019
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	10010924	K021247	20.89 % OXYGEN/NITROGEN	+/-0.5%	Jun 27, 2022
NTRM	12661526	CC354795	19.87 % CARBON DIOXIDE/NITROGEN	+/-0.6%	Jan 11, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
CO2 SIEMENS ULTRAMAT 6 E/N 173	Nondispersive Infrared (NDIR)	Jan 29, 2019
O2 FS, SIEMENS OXYMAT 6 E/N 182	Paramagnetic	Jan 08, 2019

Triad Data Available Upon Request



Approved for Release

RECEIVED
AUG 01 2022
AIR QUALITY DIVISION

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Customer: IMPACT COMPLIANCE
& TESTING

Part Number: E04NI56E15A0001 Reference Number: 32-402117338-1
Cylinder Number: ALM-047867 Cylinder Volume: 162.0 CF
Laboratory: 112 - Troy-32 (SAP) - MI Cylinder Pressure: 2015 PSIG
PGVP Number: B62021 Valve Outlet: 590
Gas Code: CO,CO2,O2,BALN Certification Date: Jun 07, 2021

Expiration Date: Jun 07, 2029

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	1500 PPM	1467 PPM	G1	+/- 0.5% NIST Traceable	06/03/2021
OXYGEN	21.00 %	20.98 %	G1	+/- 0.5% NIST Traceable	06/03/2021
CARBON DIOXIDE	22.50 %	23.61 %	G2	+/- 0.8% NIST Traceable	06/07/2021
NITROGEN	Balance				

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	080122	KAL004663	2466 PPM CARBON MONOXIDE/NITROGEN	+/-0.5%	May 09, 2024
NTRM	100109	K-022371	20.89 % OXYGEN/NITROGEN	+/-0.5%	Jun 27, 2022
NTRM	12061511	CC354702	19.87 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 11, 2024

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
E/N 54 NICOLET IS50 CO2 13/20%	FTIR	May 25, 2021
CO SIEMENS ULTRAMAT 6 E/N 173	Nondispersive Infrared (NDIR)	May 06, 2021
O2 FS, SIEMENS OXYMAT 6 E/N 182	Paramagnetic	May 12, 2021

Triad Data Available Upon Request



Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Customer: DERENZO AND ASSOCIATES
 Part Number: E02NI87E15A0480
 Cylinder Number: CC15940
 Laboratory: 112 - Troy-32 (SAP) - MI
 PGVP Number: B62019
 Gas Code: O2,BALN

Reference Number: 32-401414049-1
 Cylinder Volume: 145.5 CF
 Cylinder Pressure: 2015 PSIG
 Valve Outlet: 590
 Certification Date: Feb 05, 2019

Expiration Date: Feb 05, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
OXYGEN	12.50 %	12.49 %	G1	+/- 0.4% NIST Traceable	02/05/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	100106	K015462	9.967 % OXYGEN/NITROGEN	+/-0.3%	Apr 19, 2022

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
O2 FS, SIEMENS OXYMAT 6 E/N 182	Paramagnetic	Jan 08, 2019

Triad Data Available Upon Request



Approved for Release

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Customer: IMPACT COMPLIANCE
& TESTING

Part Number: E02NI99E15A0077 Reference Number: 32-401572021-1
Cylinder Number: XC004936B Cylinder Volume: 144.3 CF
Laboratory: 112 - Troy-32 (SAP) - MI Cylinder Pressure: 2015 PSIG
PGVP Number: B62019 Valve Outlet: 350
Gas Code: CO,BALN Certification Date: Aug 19, 2019

Expiration Date: Aug 19, 2027

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON MONOXIDE	100.0 PPM	100.2 PPM	G1	+/- 0.6% NIST Traceable	08/19/2019
NITROGEN	Balance				

CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	09010249	KAL004915	98.48 PPM CARBON MONOXIDE/NITROGEN	+/- 0.5%	Oct 16, 2024

ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
E/N 54 Nicolet 6700 CO	FTIR	Jul 23, 2019

Triad Data Available Upon Request



Approved for Release