

DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION

**FCE Summary Report**

Facility : THUMB ELECTRIC COOPERATIVE	SRN : N3517
Location : 4151 UBLY RD	District : Saginaw Bay
	County : HURON
City : UBLY      State: MI   Zip Code : 48475	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Matthew Karl
FCE Begin Date : 8/26/2013	FCE Completion Date : 9/28/2018
Comments : Source appears to be in compliance with Opt-Out PTI No. 90-12 and the RICE MACT, 40 CFR Part 63, Subpart ZZZZ.	

**List of Partial Compliance Evaluations :**

Activity Date	Activity Type	Compliance Status	Comments
07/30/2018	MACT (Part 63)	Compliance	RICE NESHAP ZZZZ - Semiannual Compliance Report- Did not operate over the reporting period- MK
01/25/2018	MACT (Part 63)	Compliance	Semiannual Compliance Report - RICE NESHAP ZZZZ There were no deviations from any emission or operating limitations during the reporting period; there was no time that the CPMS was out of control during the reporting period (1/1/17-12/31/17) MK
01/16/2018	Self Initiated Inspection	Compliance	Self-initiated inspection to determine compliance with PTI 90-12 and the air regulations.
04/19/2017	MACT (Part 63)	Compliance	Notification of Intent to test May 3, 2017 for 40 CFR Part 63 Subpart ZZZZ

Name: Matthew R. Karl      Date: 10-2-2018      Supervisor: C. Hase