

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : ANR Pipeline Company - Bridgman Compressor Station	SRN : N5575
Location : 3372 Browntown Rd	District : Kalamazoo
	County : BERRIEN
City : BRIDGMAN State: MI Zip Code : 49106	Compliance Status : Compliance
Source Class : MAJOR	Staff : Matthew Deskins
FCE Begin Date : 2/21/2017	FCE Completion Date : 2/21/2018
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
02/21/2018	Scheduled Inspection	Compliance	Unannounced Scheduled Inspection
02/01/2018	MACT (Part 63)	Unknown	Semi-Annual Compliance Report and Notification of Compliance Status for 40 CFR Part 63 Subpart DDDDD (NESHAP for Industrial, Commercial, and Institutional Boilers and Process Heaters). The AQD is not delegated to enforce this regulation so the report wasn't reviewed for compliance.
09/29/2017	ROP Semi 1 Cert	Compliance	The facility certified that no deviations occurred during the reporting period.
08/11/2017	Stack Test	Compliance	The facility tested their 12,000 hp engine that is subject to the NOx emission reduction rule (R 336.1818) for the ozone control period of May 1 through September 30 of each calendar year. The report indicates they met the NOx limits that they established in their approved NOx Reduction Compliance Plan.
05/16/2017	Stack Test Observation	Compliance	Stack test observation for NOx emissions limits that are required for the ozone season of May 1st through September 30th of each calendar year.
04/03/2017	MAERS	Compliance	

Activity Date	Activity Type	Compliance Status	Comments
03/24/2017	ROP SEMI 2 CERT	Compliance	The facility certified that no deviations occurred during the reporting period.
03/24/2017	ROP Annual Cert	Compliance	The facility certified that no deviations occurred during the reporting period.

Name: Matt Dak

Date: 2-22-18

Supervisor: MA 2/22/2018