

DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION

**FCE Summary Report**

<b>Facility :</b> ANR Pipeline Company - Bridgman Compressor Station	<b>SRN :</b> N5575
<b>Location :</b> 3372 Browntown Rd	<b>District :</b> Kalamazoo
	<b>County :</b> BERRIEN
<b>City :</b> BRIDGMAN <b>State:</b> MI <b>Zip Code :</b> 49106	<b>Compliance Status :</b> Compliance
<b>Source Class :</b> MAJOR	<b>Staff :</b> Matthew Deskins
<b>FCE Begin Date :</b> 10/6/2020	<b>FCE Completion Date :</b> 10/6/2021
<b>Comments :</b>	

**List of Partial Compliance Evaluations :**

Activity Date	Activity Type	Compliance Status	Comments
10/06/2021	On-site Inspection	Compliance	Unannounced Scheduled Inspection
09/27/2021	Stack Test	Compliance	The facility tested their 12,000 hp engine on July 7, 2021 that is subject to the NOx emission reduction rule (R 336.1818) for the ozone control period of May 1 through September 30 of each calendar year. The report indicates they met the NOx limits that they established in their approved NOx Reduction Compliance Plan. Their permitted limit during the ozone season is 6.6 g/bhp-hr and their results averaged 5.9064.
09/16/2021	ROP Semi 1 Cert	Compliance	The facility certified that no deviations occurred within the reporting period.
06/02/2021	ROP Other	Compliance	Initial Notification of Start of Construction of (2) Solar Turbines and One Emergency Generator that will be replacing all existing equipment.
04/07/2021	ROP Annual Cert	Compliance	The facility certified that no deviations occurred during the reporting period.
04/07/2021	ROP SEMI 2 CERT	Compliance	The facility certified that no deviations occurred during the reporting period.

Activity Date	Activity Type	Compliance Status	Comments
11/18/2020	Stack Test	Compliance	The facility tested their 12,000 hp engine on September 3, 2020 that is subject to the NOx emission reduction rule (R 336.1818) for the ozone control period of May 1 through September 30 of each calendar year. The report indicates they met the NOx limits that they established in their approved NOx Reduction Compliance Plan. Their permitted limit during the ozone season is 6.6 g/bhp-hr and their results averaged 4.228.

Name: Matt Dark Date: 10-13-21 Supervisor: RIL 10/22/21  
Page 2 of 2