

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : Consumers Energy - Overisel Compressor Station		SRN : N5792
Location : 4131 138th Ave. Route 1		District : Kalamazoo
		County : ALLEGAN
City : HAMILTON	State: MI	Zip Code : 49419
Compliance Status :		Compliance
Source Class : MAJOR	Staff : Cody Yazzie	
FCE Begin Date : 05/26/2016	FCE Completion Date :	7/10/2018
Comments :		

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
06/19/2018	Scheduled Inspection	Compliance	Scheduled Inspection
05/25/2018	MACT (Part 63)	Compliance	Semiannual report for the 40 CFR Part 63 subpart HHH for EUGLYCDEHY. There were no malfunctions, excursions, or deviations for the CPMS.
05/24/2018	Telephone Notes	Compliance	Natural Gas Release
05/15/2018	Telephone Notes	Compliance	Emergency Natural Gas Release on Pipeline
03/26/2018	ROP SEMI 2 CERT	Compliance	No Deviations were reported
03/26/2018	ROP Annual Cert	Compliance	No deviations were reported
03/26/2018	MACT (Part 63)	Compliance	Biennial Compliance Report for the Major Source Industrial Boiler MACT (40 CFR Part 63, Subpart DDDDD). No deviations were reported.
03/26/2018	MACT (Part 63)	Compliance	Biennial compliance report for the MACT (40 CFR Subpart DDDDD) Major Sources Industrial, Commercial, and Institutional Boilers and Process Heaters. No deviations were reported.
09/29/2017	ROP Semi 1 Cert	Compliance	The facility certified that no deviations occurred during the reporting period.
04/27/2017	Stack Test	Compliance	Performance test of EUEMERGENGINEGEN for NOx, CO, and VOC emissions as required by 40 CFR Part 60 Subpart JJJJ (NSPS for Stationary Spark Ignition ICEs. The results reported indicated compliance

Activity Date	Activity Type	Compliance Status	Comments
03/15/2017	MAERS	Compliance	
03/13/2017	ROP SEMI 2 CERT	Compliance	
03/13/2017	ROP Annual Cert	Compliance	
03/07/2017	Stack Test Observation	Compliance	
12/08/2016	MACT (Part 63)	Compliance	Semi-annual report for the Natural Gas Transmission and Storage MACT.
09/30/2016	ROP Semi 1 Cert	Compliance	
05/26/2016	Scheduled Inspection	Compliance	

Name: Cody Yagji Date: 7/10/18 Supervisor: M/D 7/10/2018