

RECEIVED

MAR 18 2013

AIR QUALITY DIV.

AIR EMISSION TEST REPORT

Title AIR EMISSION TEST REPORT FOR THE LANDFILL
 GAS FUELED INTERNAL COMBUSTION ENGINES
 OPERATED AT THE GRANGER BRENT RUN FACILITY

Report Date March 11, 2013

Test Dates January 22-23, 2013 and February 5, 2013

Facility Information	
Name	Granger Electric Company
Street Address	8247 Vienna Rd.
City, County	Montrose, Genesee

Facility Permit Information	
Permit No.: 105-12	Facility SRN : N5987

Testing Contractor	
Company	Derenzo and Associates, Inc.
Mailing Address	39395 Schoolcraft Road Livonia, MI 48150
Phone	(734) 464-3880
Project No.	1211006

AIR EMISSION TEST REPORT
FOR THE
LANDFILL GAS FUELED
INTERNAL COMBUSTION ENGINES
OPERATED AT THE
GRANGER BRENT RUN FACILITY

1.0 INTRODUCTION

Granger Electric Company (Granger) (Facility SRN: N5987) owns and operates two (2) Caterpillar (CAT®) Model No. G3516 landfill gas (LFG) fueled reciprocating internal combustion engines (RICE), one (1) CAT® Model No. G3512 LFG fueled RICE and two (2) CAT® Model No. G3520C LFG fueled RICE at the Granger Brent Run facility in Montrose, Genesee County, Michigan. The facility has been issued Permit to Install No. 105-12. The facility has also been issued Renewable Operating Permit (ROP) No. MI-ROP-N5987-2010.

The CAT® Model No. G3516 engines are identified in the permit as Emission Unit ID: EUICEENGINE4 and 5 (FGICEENGINES2), however, the facility refers to these engines as Engine Nos. 1 and 2. The CAT® Model No. G3512 engine is identified in the permit as Emission Unit ID: EUICEENGINE3 (FGICEENGINES), however, the facility refers to this engine as Engine No. 5. The CAT® Model No. G3520C engines are identified in the permit as Emission Unit ID: EUICEENGINE1 and 2 (FGICEENGINES), however, the facility refers to these engines as Engine Nos. 3 and 4. Granger plans to submit permit application documents to correct the naming issues, therefore, for the purposes of this report the engines will be referred to by the names the facility uses.

Air emission compliance testing was performed to satisfy the following requirements contained in PTI No. 105-12:

- Test air pollutant emissions for Engine Nos. 3 and 4 (EUICEENGINE1 and 2) in accordance with 40 CFR Part 60 Subpart JJJJ;
- Test Engine No. 3 or 4 (EUICEENGINE1 or 2) for formaldehyde in accordance with Special Condition V.2. of FGICENGINES;
- Test Engine No. 1 or 2 (EUICEENGINE4 or 5) for formaldehyde in accordance with Special Condition V.1. of FGICENGINES2; and
- Test Engine No. 5 (EUICEENGINE3) for formaldehyde in accordance with Special Condition V.2. of FGICENGINES.

The compliance testing was performed by Derenzo and Associates, Inc. (Derenzo and Associates), a Michigan-based environmental consulting and testing company and Prism Analytical Technologies, Inc. (PATI). Derenzo and Associates representatives Tyler Wilson, Jason Logan and Andrew Rusnak and PATI representative Ms. Lindsey Wells performed the field sampling and measurements January 22 – 23 and February 5, 2013.

The exhaust gas sampling and analysis was performed using procedures specified in the Test Plan that was reviewed and approved by the Michigan Department of Environmental Quality

Derenzo and Associates, Inc.

Granger Electric Company
Air Emission Test Report

March 11, 2013
Page 2

(MDEQ) in the January 9, 2013 test plan approval letter. MDEQ representatives Mr. Tom Gasloli observed portions of the testing project.

Questions regarding this emission test report should be directed to:

Andy Rusnak, QSTI
Environmental Engineer
Derenzo and Associates, Inc.
4970 Northwind Dr. Ste. 120
East Lansing, MI 48823
Ph: (517) 324-1880

Mr. Dan Zimmerman
Compliance Manger
Granger Electric Company
16980 Wood Road
Lansing, MI 48906
Ph: (517) 371-9711

Report Certification

I certify under penalty of law that I believe the information provided in this document is true, accurate, and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for knowingly submitting false, inaccurate, or incomplete information.

Report Prepared By:



Andrew Rusnak, QSTI
Environmental Engineer
Derenzo and Associates, Inc.

Responsible Official Certification:



Marc Pauley
Operations Manager
Granger Electric Company

2.0 SOURCE AND SAMPLING LOCATION DESCRIPTION

2.1 General Process Description

Landfill gas (LFG) containing methane is generated in the Brent Run Landfill from the anaerobic decomposition of disposed waste materials. The LFG is collected from both active and capped landfill cells using a system of wells (gas collection system). The collected LFG is transferred to the Granger LFG power station facility where it is treated and used as fuel for the five (5) RICE. Each RICE is connected to an electricity generator that produces electricity that is transferred to the local utility.

2.2 Rated Capacities and Air Emission Controls

The CAT® Model No. G3516 RICE has a rated output of 1,148 brake-horsepower (bhp) and the connected generator has a rated electricity output of 800 kilowatts (kW). The engine is designed to fire low-pressure, lean fuel mixtures (e.g., LFG).

The CAT® Model No. G3512 RICE has a rated output of 861 brake-horsepower (bhp) and the connected generator has a rated electricity output of 600 kilowatts (kW). The engine is designed to fire low-pressure, lean fuel mixtures (e.g., LFG).

The CAT® Model No. G3520C RICE has a rated output of 2,233 brake-horsepower (bhp) and the connected generator has a rated electricity output of 1,600 kilowatts (kW). The engine is designed to fire low-pressure, lean fuel mixtures (e.g., LFG) and is equipped with an air-to-fuel ratio controller that monitors engine performance parameters and automatically adjusts the air-to-fuel ratio and ignition timing to maintain efficient fuel combustion.

The engine/generator sets are not equipped with add-on emission control devices. Air pollutant emissions are minimized through the proper operation of the gas treatment system and efficient fuel combustion in the engines.

The fuel consumption rate is regulated automatically to maintain the heat input rate required to support engine operations and is dependent on the fuel heat value (methane content) of the treated LFG.

2.3 Sampling Locations

The RICE exhaust gas is directed through mufflers and is released to the atmosphere through dedicated vertical exhaust stacks with horizontal release points. The two (2) CAT® Model G3516 RICE exhaust stacks are identical and the two (2) CAT® Model G3520C RICE exhaust stacks are identical.

The exhaust stack sampling ports for the CAT® Model G3516 Engine No. 1 (EUICEENGINE4) is located in the individual exhaust stack with an inner diameter of 12.25 inches. The stack is

equipped with two (2) sample ports, opposed 90°, that provide a sampling location 180.0 inches (14.7 duct diameters) upstream and 114.0 inches (9.31 duct diameters) downstream from any flow disturbance and satisfies the USEPA Method 1 criteria for a representative sample location.

The exhaust stack sampling ports for the CAT® Model G3512 Engine No. 5 (EUICEENGINE3) is located in the individual exhaust stack with an inner diameter of 12.5 inches. The stack is equipped with two (2) sample ports, opposed 90°, that provide a sampling location 42.5 inches (3.40 duct diameters) upstream and 113.0 inches (9.04 duct diameters) downstream from any flow disturbance and satisfies the USEPA Method 1 criteria for a representative sample location.

The exhaust stack sampling ports for the CAT® Model G3520C Engine Nos. 3 and 4 (EUICEENGINE1 and 2) are located in individual exhaust stacks with an inner diameter of 13.5 inches. Each stack is equipped with two (2) sample ports, opposed 90°, that provide a sampling location 300.0 inches (22.2 duct diameters) upstream and 114.0 inches (8.44 duct diameters) downstream from any flow disturbance and satisfies the USEPA Method 1 criteria for a representative sample location.

Individual traverse points were determined in accordance with USEPA Method 1.

Appendix A provides diagrams of the emission test sampling locations.

3.0 SUMMARY OF TEST RESULTS AND OPERATING CONDITIONS

3.1 Purpose and Objective of the Tests

The conditions of Permit to Install No. 105-12 and 40 CFR Part 60 Subpart JJJJ require Granger to test Engine Nos. 3 and 4 (EUICEENGINE1 and 2) for carbon monoxide (CO), nitrogen oxides (NO_x) and volatile organic compounds (VOCs) every 8,760 hours of operation. The permit also specifies that one of Engine Nos. 3 and 4 (EUICEENGINE1 and 2), one of Engine Nos. 1 and 2 (EUICEENGINE4 and 5) and Engine No. 5 (EUICEENGINE3) be tested for formaldehyde. Therefore, Engine Nos. 3 and 4 (EUICEENGINE1 and 2) were sampled for CO, NO_x and VOC emissions and exhaust gas oxygen (O₂) and carbon dioxide (CO₂) content and Engine Nos. 1, 4 and 5 (EUICEENGINE2, 3 and 4) were sampled for formaldehyde to satisfy the testing requirements.

3.2 Operating Conditions During the Compliance Tests

The testing was performed while the Granger engine/generator sets were operated at maximum operating conditions (800 kW / 600 kW / 1,600 kW electricity output +/- 10%). Granger representatives provided the kW output in 15-minute increments for each test period. The Engine No. 1 (EUICEENGINE4) generator kW output ranged between 807 and 834 kW for each test period. The Engine Nos. 3 and 4 (EUICEENGINE1 and 2) generator kW output ranged between 1,575 and 1,645 kW for each test period. The Engine No. 5 (EUICEENGINE3) generator kW output ranged between 593 and 605 kW for each test period.

AIR QUALITY DIV.

Fuel flowrate (cubic feet per minute), fuel methane content (%) and fuel inlet pressure (psi) were also recorded by Granger representatives in 15-minute increments for each test period. The Engine No. 1 (EUICEENGINE4) fuel consumption rate was approximately 318 scfm, fuel methane content ranged between 48.3 and 49.1% and fuel inlet pressure was 7.0 psi for each test period. The Engine Nos. 3 and 4 (EUICEENGINE1 and 2) fuel consumption rate ranged between 552 and 574 scfm, fuel methane content ranged between 45.6 and 47.5% and fuel inlet pressure was 18.0 psi for each test period. The Engine No. 5 (EUICEENGINE3) fuel consumption rate ranged between 212.1 and 218.6 scfm, fuel methane content ranged between 48.7 and 49.8% and fuel inlet pressure was 7.0 psi for each test period.

Appendix B provides operating records provided by Granger representatives for the test periods.

Engine output (bhp) cannot be measured directly and was calculated based on the recorded electricity output, the calculated CAT® Model G3520C generator efficiency (96.0%), and the unit conversion factor for kW to horsepower (0.7457 kW/hp).

$$\text{Engine output (bhp)} = \text{Electricity output (kW)} / (0.960) / (0.7457 \text{ kW/hp})$$

A lower heating value of 910 Btu/scf was used to calculate the LFG heating value.

Table 3.1 presents a summary of the average engine operating conditions during the test periods.

3.3 Summary of Air Pollutant Sampling Results

The gases exhausted from the sampled LFG fueled RICE were each sampled for three (3) one-hour test periods during the compliance testing performed January 22 through January 23, 2013 and February 5, 2013.

Table 3.2 presents the average measured CO, NO_x, VOC and formaldehyde emission rates for the engines (average of the three test periods for each engine).

Test results for each one hour sampling period and comparison to the permitted emission rates is presented in Section 6.0 of this report.

4.0 SAMPLING AND ANALYTICAL PROCEDURES

Test protocols for the air emission testing were reviewed and approved by the MDEQ. This section provides a summary of the sampling and analytical procedures that were used during the Granger testing periods.

4.1 Summary of Sampling Methods

USEPA Method 2	Exhaust gas velocity pressure was determined using a Type-S Pitot tube connected to a red oil incline manometer; temperature was measured using a K-type thermocouple connected to the Pitot tube.
USEPA Method 3A	Exhaust gas O ₂ and CO ₂ content was determined using zirconia ion/paramagnetic and infrared instrumental analyzers, respectively.
USEPA Method 4	Exhaust gas moisture was determined based on the water weight gain in chilled impingers.
USEPA Method 7E	Exhaust gas NO _x concentration was determined using chemiluminescence instrumental analyzers.
USEPA Method 10	Exhaust gas CO concentration was measured using NDIR instrumental analyzers.
USEPA Method ALT-096	Exhaust gas VOC (as NMHC) concentration was determined using flame ionization analyzers equipped with GC columns.
USEPA Method 320	Measurement of vapor phase organic and inorganic emissions by extractive Fourier transform infrared (FTIR) spectroscopy.

4.2 Exhaust Gas Velocity Determination (USEPA Method 2)

The RICE exhaust stack gas velocities and volumetric flow rates were determined using USEPA Method 2 prior to and after each test. An S-type Pitot tube connected to a red-oil manometer was used to determine velocity pressure at each traverse point across the stack cross section. Gas temperature was measured using a K-type thermocouple mounted to the Pitot tube. The Pitot tube and connective tubing were leak-checked to verify the integrity of the measurement system.

The absence of significant cyclonic flow for the exhaust configuration was verified using an S-type Pitot tube and oil manometer. The Pitot tube was positioned at each velocity traverse point with the planes of the face openings of the Pitot tube perpendicular to the stack cross-sectional plane. The Pitot tube was then rotated to determine the null angle (rotational angle as measured from the perpendicular, or reference, position at which the differential pressure is equal to zero).

Appendix C provides exhaust gas flowrate calculations and field data sheets.

4.3 Exhaust Gas Molecular Weight Determination (USEPA Method 3A)

CO₂ and O₂ content in the RICE exhaust gas streams were measured continuously throughout each test period in accordance with USEPA Method 3A. The CO₂ content of the exhaust was monitored using a Servomex 4100 single beam single wavelength (SBSW) infrared gas analyzer. The O₂ content of the exhaust was monitored using a Servomex 4100 gas analyzer that uses a paramagnetic sensor.

During each sampling period, a continuous sample of the IC engine exhaust gas stream was extracted from the stack using a stainless steel probe connected to a Teflon® heated sample line. The sampled gas was conditioned by removing moisture prior to being introduced to the analyzers; therefore, measurement of O₂ and CO₂ concentrations correspond to standard dry gas conditions. Instrument response data were recorded using an ESC Model 8816 data acquisition system that monitored the analog output of the instrumental analyzers continuously and logged data as one-minute averages.

Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias (described in Section 5.0 of this document). Sampling times were recorded on field data sheets.

Appendix D provides O₂ and CO₂ calculation sheets. Raw instrument response data are provided in Appendix E.

4.4 Exhaust Gas Moisture Content (USEPA Method 4)

Moisture content of the RICE exhaust gas was determined in accordance with USEPA Method 4 using a chilled impinger sampling train. The moisture sampling was performed concurrently with the instrumental analyzer sampling. During each sampling period a gas sample was

extracted at a constant rate from the source where moisture was removed from the sampled gas stream using impingers that were submersed in an ice bath. At the conclusion of each sampling period, the moisture gain in the impingers was determined gravimetrically by weighing each impinger to determine net weight gain.

4.5 NO_x and CO Concentration Measurements (USEPA Methods 7E and 10)

NO_x and CO pollutant concentrations in the RICE exhaust gas streams were determined using a Thermo Environmental Instruments, Inc. (TEI) Model 42c High Level chemiluminescence NO_x analyzer and a TEI Model 48c infrared CO analyzer.

Throughout each test period, a continuous sample of the engine exhaust gas was extracted from the stack using the Teflon® heated sample line and gas conditioning system and delivered to the instrumental analyzers. Instrument response for each analyzer was recorded on an ESC Model 8816 data acquisition system that logged data as one-minute averages. Prior to, and at the conclusion of each test, the instruments were calibrated using upscale calibration and zero gas to determine analyzer calibration error and system bias.

Appendix D provides CO and NO_x calculation sheets. Raw instrument response data are provided in Appendix E.

4.6 Measurement of Volatile Organic Compounds (USEPA Method ALT-096)

VOC emission rate was determined by measuring the nonmethane hydrocarbon (NMHC) concentration in the exhaust gas for each RICE. NMHC pollutant concentration was determined using TEI Model 55i Methane / Nonmethane hydrocarbon analyzer.

Throughout each one-hour test period, a continuous sample of the IC engine exhaust gas was extracted from the stack using the Teflon® heated sample line described in Section 4.3 of this document, and delivered to the instrumental analyzer. The sampled gas was not conditioned prior to being introduced to the analyzer; therefore, the measurement of NMHC concentration corresponds to standard wet gas conditions. Instrument NMHC (VOC) response for the analyzer was recorded on an ESC Model 8816 data logging system that monitored the analog output of the instrumental analyzers continuously and logged data as one-minute averages. Prior to, and at the conclusion of each test, the instrument was calibrated using mid-range calibration and zero gas to determine analyzer calibration error and system bias (described in Section 5.0 of this document).

Appendix D provides VOC calculation sheets. Raw instrument response data for the NMHC analyzer is provided in Appendix E.

4.7 Measurement of Formaldehyde (USEPA Method 320)

PATI was contracted to measure the formaldehyde concentration in the Engine Nos. 1, 4 and 5 (EUIECEENGINE2, 3 and 4) exhaust gas stream. Formaldehyde concentrations in the RICE exhaust gas streams were determined using a MKS Multigas 2030 FTIR spectrometer.

Throughout each one-hour test period, a continuous sample of the IC engine exhaust gas was extracted from the stack using a Teflon® heated sample line and delivered to the instrumental analyzer. The sampled gas was not conditioned prior to being introduced to the analyzer; therefore, the measurement of formaldehyde concentration corresponds to standard wet gas conditions. Instrument formaldehyde response for the analyzer was recorded continuously and logged data as one-minute averages.

Appendix F provides the PATI laboratory report which presents the formaldehyde results, QA/QC activities and raw instrument response data.

5.0 QA/QC ACTIVITIES

5.1 NO_x Converter Efficiency Test

The NO₂ – NO conversion efficiency of the Model 42c analyzer was verified prior to the testing program. A USEPA Protocol 1 certified concentration of NO₂ was injected directly into the analyzer, following the initial three-point calibration, to verify the analyzer's conversion efficiency. The analyzer's NO₂ – NO converter uses a catalyst at high temperatures to convert the NO₂ to NO for measurement. The conversion efficiency of the analyzer is deemed acceptable if the measured NO₂ concentration is within 90% of the expected value.

The NO₂ – NO conversion efficiency test satisfied the USEPA Method 7E criteria (measured NO₂ concentration was 2.76% of the expected value, i.e., within 10% of the expected value as required by Method 7E).

5.2 Sampling System Response Time Determination

The response time of the sampling system was determined prior to the compliance test program by introducing upscale gas and zero gas, in series, into the sampling system using a tee connection at the base of the sample probe. The elapsed time for the analyzer to display a reading of 95% of the expected concentration was determined using a stopwatch.

The TEI Model 48c analyzer exhibited the longest system response time at 86 seconds. Results of the response time determinations were recorded on field data sheets. For each test period, test data were collected once the sample probe was in position for at least twice the maximum system response time.

5.3 Gas Divider Certification (USEPA Method 205)

A STEC Model SGD-710C 10-step gas divider was used to obtain appropriate calibration span gases. The ten-step STEC gas divider was NIST certified (on January 11, 2013) with a primary flow standard in accordance with Method 205. When cut with an appropriate zero gas, the ten-step STEC gas divider delivered calibration gas values ranging from 0% to 100% (in 10% step increments) of the USEPA Protocol 1 calibration gas that was introduced into the system. The field evaluation procedures presented in Section 3.2 of Method 205 were followed prior to use of gas divider. The field evaluation yielded no errors greater than 2% of the triplicate measured average and no errors greater than 2% from the expected values.

5.4 Instrumental Analyzer Interference Check

The instrumental analyzers used to measure NO_x, CO, O₂ and CO₂ have had an interference response test performed prior to their use in the field (July 26, 2006, June 21, 2011 and April 3, 2012), pursuant to the interference response test procedures specified in USEPA Method 7E. The appropriate interference test gases (i.e., gases that would be encountered in the exhaust gas stream) were introduced into each analyzer, separately and as a mixture with the analyte that each analyzer is designed to measure. All of analyzers exhibited a composite deviation of less than 3.0% of the span for all measured interferent gases. No major analytical components of the analyzers have been replaced since performing the original interference tests.

5.5 Instrument Calibration and System Bias Checks

At the beginning of each day of the testing program, initial three-point instrument calibrations were performed for the NO_x, CO, CO₂ and O₂ analyzers by injecting calibration gas directly into the inlet sample port for each instrument. System bias checks were performed prior to and at the conclusion of each sampling period by introducing the upscale calibration gas and zero gas into the sampling system (at the base of the stainless steel sampling probe prior to the particulate filter and Teflon® heated sample line) and determining the instrument response against the initial instrument calibration readings.

At the beginning of each test day, appropriate high-range, mid-range, and low-range span gases followed by a zero gas were introduced to the NMHC analyzer, in series at a tee connection, which is installed between the sample probe and the particulate filter, through a poppet check valve. After each one hour test period, mid-range and zero gases were re-introduced in series at the tee connection in the sampling system to check against the method's performance specifications for calibration drift and zero drift error.

The instruments were calibrated with USEPA Protocol 1 certified concentrations of CO₂, O₂, NO_x, and CO in nitrogen and zeroed using hydrocarbon free nitrogen. The NMHC (VOC) instrument was calibrated with USEPA Protocol 1 certified concentrations of propane in air and zeroed using hydrocarbon-free air. A STEC Model SGD-710C ten-step gas divider was used to obtain intermediate calibration gas concentrations as needed.

5.6 Meter Box Calibrations

The Nutech Model 2010 sampling console, which was used for exhaust gas moisture content sampling, was calibrated prior to and after the testing program. This calibration uses the critical orifice calibration technique presented in USEPA Method 5. The metering console calibration exhibited no data outside the acceptable ranges presented in USEPA Method 5.

The digital pyrometer in the Nutech metering consoles were calibrated using a NIST traceable Omega[®] Model CL 23A temperature calibrator.

Appendix G presents test equipment quality assurance data (NO₂ – NO conversion efficiency test data, instrument calibration and system bias check records, calibration gas and gas divider certifications, interference test results, meter box calibration records, cyclonic flow determinations sheets, Pitot tube and probe assembly calibration records).

6.0 RESULTS

6.1 Test Results and Allowable Emission Limits

Engine operating data and air pollutant emission measurement results for each one hour test period are presented in Tables 6.1 through 6.4.

The measured formaldehyde concentration and emission rate for Engine Nos. 1 and 5 (EUICEENGINE3 and 4) is less than the allowable limits (0.75 lb formaldehyde per hour for each engine) specified in Permit to Install No. 105-12.

The measured air pollutant concentrations and emission rates for Engine Nos. 3 and 4 (EUICEENGINE1 and 2) are less than the allowable limits specified in Permit to Install No. 105-12 for EUICEENGINE1 and 2:

- 4.94 lb/hr and 1.0 g/bhp-hr for NO_x;
- 16.3 lb/hr and 3.3 g/bhp-hr for CO;
- 1.0 g/bhp-hr for VOC; and
- 2.10 lb/hr for formaldehyde.

6.2 Variations from Normal Sampling Procedures or Operating Conditions

The testing for all pollutants was performed in accordance with the approved test protocols. The engine-generator sets were operated within 10% of maximum output (800 kW, 600 kW or 1,600 kW generator output) and no variations from the normal operating conditions of the RICE occurred during the engine test periods.

Derenzo and Associates, Inc.

Granger Electric Company
Air Emission Test Report

March 11, 2013
Page 14

During the third test run performed on Engine No. 1 (EUICEENGINE4) the CO₂ and O₂ sample acquisition was placed on hold twice due to issues with the sample probe and filter freezing. After the issue had been resolved the test was restarted.

The testing for Engine No. 5 (EUICEENGINE3) was postponed 13 days from the original scheduled test date due to electrical issues with engine. After the issue was corrected the engine was tested on February 5, 2013.

Table 6.1 Measured exhaust gas conditions and formaldehyde air pollutant emission rates
Granger Brent Run Facility Engine No. 1 (EUICEENGINE4)

Test No.	1	2	3	Three Test
Test date	1/23/13	1/23/13	1/23/13	Average
Test period (24-hr clock)	930 - 1030	1055 - 1155	1212-1342	
Fuel flowrate (scfm)	318	318	318	318
Generator output (kW)	820	812	823	818
Engine output (bhp)	1,177	1,165	1,181	1,174
LFG methane content (%)	48.3	48.6	48.9	48.6
LFG heat content (Btu/scf)	440	442	445	442
Fuel inlet pressure (psi)	7.0	7.0	7.0	7.0
Air to fuel ratio	-	-	-	N/A
<u>Exhaust Gas Composition</u>				
CO ₂ content (% vol)	15.2	15.2	15.1	15.2
O ₂ content (% vol)	4.50	4.60	4.40	4.50
Moisture (% vol)	13.6	12.9	13.1	13.2
Exhaust gas temperature (°F)	706	715	722	714
Exhaust gas flowrate (scfm)	2,165	2,151	2,147	2,154
<u>Formaldehyde</u>				
HCOH conc. (ppmv)	57.6	57.2	56.3	57.0
HCOH emissions (lb/hr)	0.58	0.58	0.57	0.58
Permitted emissions (lb/hr)	-	-	-	0.75

Table 6.2 Measured exhaust gas conditions and NO_x, CO and VOC air pollutant emission rates
Granger Brent Run Facility Engine No. 3 (EUICEENGINE1)

Test No.	1	2	3	Three Test
Test date	1/22/13	1/22/13	1/22/13	Average
Test period (24-hr clock)	1415 - 1515	1547 - 1647	1713 - 1813	
Fuel flowrate (scfm)	558	560	558	559
Generator output (kW)	1,627	1,625	1,620	1,624
Engine output (bhp)	2,273	2,270	2,262	2,268
LFG methane content (%)	47.3	47.5	47.3	47.4
LFG heat content (Btu/scf)	430	432	431	431
Fuel inlet pressure (psi)	18.0	18.0	18.0	18.0
Air to fuel ratio	7.66	7.74	7.72	7.71
<u>Exhaust Gas Composition</u>				
CO ₂ content (% vol)	12.0	12.0	11.9	12.0
O ₂ content (% vol)	8.32	8.32	8.31	8.32
Moisture (% vol)	10.9	11.1	11.1	11.0
Exhaust gas temperature (°F)	826	825	842	834
Exhaust gas flowrate (dscfm)	4,351	4,371	4,337	4,353
Exhaust gas flowrate (scfm)	4,884	4,917	4,878	4,893
<u>Nitrogen Oxides</u>				
NO _x conc. (ppmvd)	107	106	104	106
NO _x emissions (g/bhp*hr)	0.67	0.66	0.65	0.66
Permitted emissions (g/bhp*hr)	-	-	-	1.0
NO _x emissions (lb/hr)	3.34	3.31	3.25	3.30
Permitted emissions (lb/hr)	-	-	-	4.94
<u>Carbon Monoxide</u>				
CO conc. (ppmvd)	771	771	770	770
CO emissions (g/bhp*hr)	2.92	2.94	2.92	2.93
Permitted emissions (g/bhp*hr)	-	-	-	3.3
CO emissions (lb/hr)	14.6	14.7	14.6	14.6
Permitted emissions (lb/hr)	-	-	-	16.3
<u>Volatile Organic Compounds</u>				
VOC conc. (ppmv)	18.1	18.1	17.9	18.1
VOC emissions (g/bhp*hr)	0.12	0.12	0.12	0.12
Permitted emissions (g/bhp*hr)	-	-	-	1.0

Table 6.3 Measured exhaust gas conditions and NO_x, CO, VOC and formaldehyde air pollutant emission rates Granger Brent Run Facility Engine No. 4 (EUICEENGINE2)

Test No.	1	2	3	
Test date	1/22/13	1/22/13	1/22/13	Three Test
Test period (24-hr clock)	853 - 953	1033 - 1133	1213 - 1313	Average
Fuel flowrate (scfm)	569	567	556	564
Generator output (kW)	1,612	1,609	1,618	1,613
Engine output (bhp)	2,252	2,247	2,261	2,253
LFG methane content (%)	45.6	45.6	46.7	46.0
LFG heat content (Btu/scf)	415	415	425	418
Fuel inlet pressure (psi)	18.0	18.0	18.0	18.0
Air to fuel ratio	7.44	7.40	7.50	7.45
<u>Exhaust Gas Composition</u>				
CO ₂ content (% vol)	11.9	11.9	12.0	11.9
O ₂ content (% vol)	7.85	8.04	7.98	7.95
Moisture (% vol)	11.6	11.4	11.6	11.5
Exhaust gas temperature (°F)	830	841	834	832
Exhaust gas flowrate (dscfm)	4,243	4,318	4,271	4,277
Exhaust gas flowrate (scfm)	4,794	4,880	4,832	4,836

Table 6.3 Continued

Test No.	1	2	3	Three Test
Test date	1/22/13	1/22/13	1/22/13	Average
Test period (24-hr clock)	853 - 953	1033 - 1133	1213 - 1313	
<u>Formaldehyde</u>				
HCOH conc. (ppmv)	76.6	77.2	77.1	77.0
HCOH emissions (lb/hr)	1.72	1.76	1.74	1.74
Permitted emissions (lb/hr)	-	-	-	2.10
<u>Nitrogen Oxides</u>				
NO _x conc. (ppmvd)	84.0	85.0	86.0	85.0
NO _x emissions (g/bhp*hr)	0.51	0.53	0.53	0.52
Permitted emissions (g/bhp*hr)	-	-	-	1.0
NO _x emissions (lb/hr)	2.56	2.63	2.63	2.61
Permitted emissions (lb/hr)	-	-	-	4.94
<u>Carbon Monoxide</u>				
CO conc. (ppmvd)	787	650	656	698
CO emissions (g/bhp*hr)	2.94	2.47	2.45	2.62
Permitted emissions (g/bhp*hr)	-	-	-	3.3
CO emissions (lb/hr)	14.6	12.3	12.2	13.0
Permitted emissions (lb/hr)	-	-	-	16.3
<u>Volatile Organic Compounds</u>				
VOC conc. (ppmv)	16.1	16.8	17.1	16.7
VOC emissions (g/bhp*hr)	0.11	0.11	0.11	0.11
Permitted emissions (g/bhp*hr)	-	-	-	1.0

Derenzo and Associates, Inc.

Granger Electric Company
Air Emission Test Report

March 11, 2013

Page 19

RECEIVED

MAR 18 2013

AIR QUALITY DIV.

Table 6.4 Measured exhaust gas conditions and formaldehyde air pollutant emission rates
Granger Brent Run Facility Engine No. 5 (EUI3ENGINE3)

Test No.	1	2	3	Three Test Average
Test date	2/5/13	2/5/13	2/5/13	
Test period (24-hr clock)	816 - 916	933 - 1033	1051 - 1151	
Fuel flowrate (scfm)	218	217	214	216
Generator output (kW)	602	602	600	601
Engine output (bhp)	863	864	861	863
LFG methane content (%)	48.7	49.4	49.8	49.3
LFG heat content (Btu/scf)	443	450	453	449
Fuel inlet pressure (psi)	7.0	7.0	7.0	7.0
Air to fuel ratio	-	-	-	N/A
<u>Exhaust Gas Composition</u>				
CO ₂ content (% vol)	14.0	14.2	14.6	14.3
O ₂ content (% vol)	5.77	5.53	5.19	5.50
Moisture (% vol)	13.3	13.4	13.6	13.4
Exhaust gas temperature (°F)	773	772	760	767
Exhaust gas flowrate (scfm)	1,793	1,772	1,719	1,761
<u>Formaldehyde</u>				
HCOH conc. (ppmv)	43.5	41.2	38.6	41.1
HCOH emissions (lb/hr)	0.37	0.34	0.31	0.34
Permitted emissions (lb/hr)	-	-	-	0.75