

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : FEDERAL MOGUL POWERTRAIN INC	SRN : N6266
Location : 560 AVIS DR	District : Jackson
	County : WASHTENAW
City : ANN ARBOR State: MI Zip Code : 48108	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Zachary Durham
FCE Begin Date : 9/1/2014	FCE Completion Date : 12/8/2015
Comments : FCE of PCE's for Federal Mogul, a synthetic minor source, holding PTI 220-03.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
12/08/2015	Other	Compliance	Review of 2014 MAERS report previously reviewed by Glen Erickson on 5/29/15. Shows substantial compliance.
12/03/2015	Telephone Notes	Compliance	Confirmation that the 50 kW emergency diesel generator is still on site and being maintained in accordance with 40 CFR 63 Subpart ZZZZ. It was noted that they have not needed to run it in an emergency situation recently, but rather only for testing and maintenance purposes.
08/06/2015	Scheduled Inspection	Compliance	Scheduled, unannounced facility inspection.
05/29/2015	Other	Compliance	Audit of MAERS emission data for reporting year 2014 completed.

Name: Zach Durham Date: 12/8/15 Supervisor: 