

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : DEPOR INDUSTRIES	SRN : N7599
Location : 1902 NORTHWOOD	District : Southeast Michigan
	County : OAKLAND
City : TROY State: MI Zip Code : 48084	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Joyce Zhu
FCE Begin Date : 3/1/2013	FCE Completion Date : 3/7/2014
Comments :	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
02/25/2014	Scheduled Inspection	Compliance	annual inspection
05/15/2013	Stack Test	Compliance	Emission Test Report. The report shows that the average destruction efficiency for the RTO was at 99.6% by weight; & the capture efficiency was at 88.1% by weight. The resulted the VOC reduction efficiency was at 87.7%. The recorded RTO temperature during the test period had a range from 1454 F to 1499 F.

Name: _____

Joyce Zhu

Date: _____

3/7/14

Supervisor: _____

CJE