

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : VECTOR PIPELINE L.P., Athens Compressor Station		SRN : N8151
Location : 4981 2 Mile Rd		District : Kalamazoo
		County : CALHOUN
City : ATHENS	State: MI	Zip Code : 49011
Compliance Status :		Compliance
Source Class : MAJOR	Staff : Rex Lane	
FCE Begin Date : 8/20/2014	FCE Completion Date :	9/8/2015
Comments : FCE		

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
08/20/2015	Self Initiated Inspection	Compliance	Self Initiated Inspection
05/06/2015	Telephone Notes		Conference Call - ROP Renewal Application Questions
03/17/2015	ROP SEMI 2 CERT	Compliance	Review of 2nd Semi-annual certification report: 7/1/14 - 12/31/14 Report contains an original dated signature by a qualified responsible official. Report certifies that the facility was in compliance with all ROP terms and conditions during the reporting period.
03/17/2015	ROP Annual Cert	Compliance	Review of 2014 ROP annual report: Report contains an original dated signature by a qualified responsible official. Report certifies that the facility was in compliance with all ROP terms and conditions during the reporting period.

Activity Date	Activity Type	Compliance Status	Comments
03/17/2015	MAERS	Compliance	<p>MAERS report was received electronically on 3/12/15.</p> <p>Reported NOX emissions for EUTURBINE1 were within 205 lbs. of staff calculated value based on the March 2014 NOX emission test. No changes made to report after reviewing AQD only fields. - RIL</p>
09/10/2014	ROP Semi 1 Cert	Compliance	<p>Review of ROP Semi-annual Certification Report: 1/1/14 - 6/30/14</p> <p>Report contains an original dated signature by a qualified responsible official. Report certifies that the facility was in compliance with all ROP terms and conditions during the reporting period.</p>

Name: _____

RIL

Date: _____

9/8/15

Supervisor: _____

MA 9/8/2015