



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DETROIT DISTRICT OFFICE

EGLE
DANIEL EICHINGER
ACTING DIRECTOR

January 11, 2023

Marion Krchmar, Plant Manager
EES Coke Battery LLC
P.O. Box 18309, Zug Island
River Rouge, MI 48218

SRN: P0408, Wayne County

Dear Marion Krchmar:

VIOLATION NOTICE

On December 22, 2022, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), completed review of the Pushing Emissions Control System (PECS) baghouse stack test particulate matter results received on November 9, 2022, for EES Coke Battery, LLC, located at 1400 Zug Island Road, River Rouge, Michigan. The test was performed September 20 through September 23, 2022. The purpose of this review was to determine EES Coke Battery's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; the conditions of Permit to Install (PTI) No. 51-08C; and the conditions of Renewable Operating Permit (ROP) No. 199600132d, Section 7.

Based on the review of the report, the following violation was noted:

Process Description	Rule/Permit Condition Violated	Comments
No. 5 Coke Battery (EUCCOKE-BATTERY)	PTI 51-08C, EUCCOKE-BATTERY, Table I, Emission Limits, Condition 13	Facility exceeded the emission limit of 0.69 lb/hr for particulate matter 10 microns or less (PM10) from the PECS baghouse stack. The stack test result was 0.82 lb/hr of PM10 based on a three-run average.

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by February 1, 2023 (which coincides with 21 calendar days from the date of this letter). The written response should include, at a minimum, the dates the violation occurred, an explanation of the causes and duration of the violation, whether the violation is ongoing, a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place, and what steps are being taken to prevent a recurrence.


Marion Krchmar
Page 2
January 11, 2023

Please submit the written response to the EGLE, AQD, Detroit District, at 3058 West Grand Boulevard, Suite 2-300, Detroit, Michigan 48202 and submit a copy to Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

If EES Coke believes the above observations or statements are inaccurate or do not constitute a violation of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Katherine Koster
Environmental Engineer Specialist
Air Quality Division
(313) 418-0715

cc: Brenna Harden, DTE
Annette Switzer, EGLE
Christopher Ethridge, EGLE
Brad Myott, EGLE
Jenine Camilleri, EGLE
Dr. April Wendling, EGLE
Regina Angellotti, EGLE
Jeff Korniski, EGLE