



RICK SNYDER  
GOVERNOR

STATE OF MICHIGAN  
DEPARTMENT OF ENVIRONMENTAL QUALITY  
KALAMAZOO DISTRICT OFFICE



DAN WYANT  
DIRECTOR

April 3, 2015

Mr. Christopher Gill  
Mastronardi Produce  
270 North Filmore Road  
Coldwater, Michigan 49036

SRN: P0517, Branch County

Dear Mr. Gill:

**VIOLATION NOTICE**

The Department of Environmental Quality (DEQ), Air Quality Division, has become aware that Mastronardi Produce (Facility), located at 270 North Filmore Road, Coldwater, Michigan, has installed equipment and failed to submit proper notification. Specifically, the Facility is in violation of the requirements of the federal Clean Air Act as follows:

Process Description	Rule/Permit Condition Violated	Comments
Three hot water boilers	40 CFR 60, Subpart A and Dc	Failure to notify of installation.

Hot Water Boilers

The three hot water boilers installed in December of 2014 are subject to the federal Standards of Performance for New Sources for Small Industrial-Commercial-Institutional Steam Generating Units. These standards are found in Title 40 of the Code of Federal Regulations (CFR), Part 60, Subpart A and Dc.

Both §60.7 & §60.48c require that the owner or operator of each affected facility shall submit notification of the date of construction, actual startup, and size of the unit.

A Permit to Install was not needed. Rule 282(b)(i) exempts sweet natural gas burning equipment with a rated heat input capacity of not more than 50,000,000 Btu per hour. These units are rated at about 37,000,000 Btu per hour.

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by May 8, 2015. The written response should include: the proper notification forms(s).

If the Facility believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Mr. Christopher Gill

Page 2

April 3, 2015

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this Facility into compliance, please contact me at the telephone number listed below.

Sincerely,



Dale Turton  
Senior Environmental Engineer  
Air Quality Division  
269-567-3554

DT:CF

cc: Ms. Lynn Fiedler, DEQ  
Ms. Teresa Seidel, DEQ  
Mr. Thomas Hess, DEQ  
Ms. Mary Douglas, DEQ