

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : Avancez Highland Park	SRN : P1217
Location : 1430 E 10 Mile Road	District : Warren
	County : OAKLAND
City : HAZEL PARK State: MI Zip Code : 48030	Compliance Status : Non Compliance
Source Class : SM OPT OUT	Staff : Shamim Ahammod
FCE Begin Date : 2/16/2022	FCE Completion Date : 2/16/2023
Comments : FCE	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
02/16/2023	Other Non ROP	Non Compliance	Notification they have installed a new Generator per the terms of PTI 67-21. The emergency engine (EUENGINE1) was installed on June 29, 2021, and started operation on October 18, 2021. The AQD district supervisor received the notification on February 16, 2023.
02/16/2023	Other Non ROP	Non Compliance	Notification for Certified engine per the terms of PTI 67-21. • The emergency engine (EUENGINE1) was installed on June 29, 2021, and started operation on October 18, 2021. AQD district office received the notification that EUENGINE1 will be operated as a certified emergency generator via email on February 16, 2023.
02/16/2023	On-site Inspection	Non Compliance	Conducted a scheduled inspection of Avancez Highland Park (SRN: P1217) to determine the company's compliance with the requirements of the Air Pollution Control Rules; and the conditions of the Permit to Install (PTI) No. 67-21.

Name: Shamim Ahammod **Date:** 4/17/2024

Supervisor: 