



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
DETROIT



KEITH CREAGH
DIRECTOR

February 12, 2016

Mr. Matt Soave
P.O. Box 863
Fowlerville, MI 48836

Mr. Pat Shields, LLC
4632 N. Latson Road
Howell, MI 48855

SRN: U471600371, Livingston County

Dear Mr. Soave and Mr. Shields:

VIOLATION NOTICE

On January 15, 2016, the Department of Environmental Quality (DEQ), Air Quality Division, conducted an inspection of a demolished facility located at 306 East Grand River Ave, Fowlerville, MI. The purpose of this inspection was to determine this sites compliance with the requirements of Title 40 of the Code of Federal Regulations, Part 61, Subpart M (National Emission Standard for Asbestos), and Rule 942 of Part 55, Air Pollution Control of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended.

According to our investigation, Mr. Matt Soave owns the facility and Mr. Pat Shields performed the demolition activities at the facility. The National Emission Standard for Asbestos holds both the owner and operator equally liable for violations.

During the inspection, staff observed the following:

| Process Description | Section Violated | Comments |
|--------------------------------|------------------|--|
| Demolished commercial facility | §61.145(a) | Failure to thoroughly inspect |
| | §61.145(b)(1) | Failure to provide 10 working day notification |
| | §61.145(c)(1) | Failure to remove RACM |

Please initiate actions necessary to correct the cited violations and submit a written response to this Violation Notice by March 4, 2016 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violations and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Mr. Matt Soave
Mr. Pat Shields
Page 2
February 12, 2016

If Mr. Soave and Mr. Shields believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited above and for the cooperation that was extended to me during my inspection of 306 E. Grand River. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

A handwritten signature in black ink, appearing to read "Joe G. Goeddeke", written in a cursive style.

Joseph G. Goeddeke
Environmental Quality Analyst
Air Quality Division
517-331-7906

cc: Ms. Lynn Fiedler, DEQ
Ms. Teresa Seidel, DEQ
Ms. Heidi Hollenbach, DEQ
Mr. Thomas Hess, DEQ
Ms. Karen Kajiya-Mills, DEQ
Ms. Wilhemina McLemore, DEQ