

SUPPLEMENT TO PERMIT NO. 458-97

Detroit Edison
Detroit, Michigan

February 9, 1998

GENERAL CONDITIONS

1. Rule 201(1) - The process or process equipment covered by this permit shall not be reconstructed, relocated, altered, or modified, unless a Permit to Install authorizing such action is issued by the Department, except to the extent such action is exempt from the Permit to Install requirements by any applicable rule.
2. Rule 201(4) - If the installation, reconstruction, relocation, or alteration of the equipment for which this permit has been approved has not commenced within 18 months, or has been interrupted for 18 months, this permit shall become void unless otherwise authorized by the Department. Furthermore, the person to whom this permit was issued, or the designated authorized agent, shall notify the Department via the Supervisor, Permit Section, Air Quality Division, Michigan Department of Environmental Quality, P.O. Box 30260, Lansing, Michigan 48909, if it is decided not to pursue the installation, reconstruction, relocation, or alteration of the equipment allowed by this Permit to Install.
3. Rule 201(6)(a) - If this Permit to Install is issued for a process or process equipment located at a stationary source which is subject to a Renewable Operating Permit pursuant to Rule 210, trial operation is allowed if the equipment performs in accordance with the terms and conditions of this Permit to Install and until the appropriate terms and conditions of this Permit to Install have been incorporated into the Renewable Operating Permit as a modification pursuant to Rule 216 or upon renewal pursuant to Rule 217. Upon incorporation of the appropriate terms and conditions into the Renewable Operating Permit, this Permit to Install shall become void.
4. Rules 201(7)(a) or 216(1)(a)(v)(A) - Except as provided in General Condition No. 3, operation of the process or process equipment is allowed if, not more than 30 days after completion of the installation, construction, reconstruction, relocation, alteration, or modification authorized by this Permit to Install, the person to whom this Permit to Install was issued, or the authorized agent pursuant to Rule 204, notifies the District Supervisor, Air Quality Division, in writing, of the completion of the activity. Completion of the installation, construction, reconstruction, relocation, alteration, or modification is considered to occur not later than commencement of trial operation of the process or process equipment.
5. Rule 201(7)(b) - Except as provided in General Condition No. 3, not more than 18 months after completion of the installation, construction, reconstruction, relocation, alteration, or modification authorized by this Permit to Install, the person to whom this permit was issued, or the authorized agent pursuant to Rule 204, shall notify the District Supervisor, Air Quality Division, in writing, of the status of compliance of the process or process equipment with the terms and conditions of the Permit to Install. The notification shall include all of the following:
 - A. The results of all testing, monitoring, and recordkeeping performed to determine the actual emissions from the process or process equipment and to demonstrate compliance with the terms and conditions of the Permit to Install.
 - B. A schedule of compliance for the process or process equipment as described in Rule 119(a).

- C. A statement, signed by the person owning or operating the process or process equipment, that, based on information and belief formed after reasonable inquiry, the statements and information in the notification are true, accurate, and complete.
6. Rule 201(8) and Section 5510 of Act 451, P.A. 1994 - The Department may, after notice and opportunity for a hearing, revoke this Permit to Install if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of this permit or is violating the Departments' rules or the Clean Air Act.
 7. Rule 219 - A new owner or operator of the process or process equipment covered by this Permit to Install shall immediately make a written request to the Department for a change of ownership or operational control. The request shall include all of the information required in Rule 219(1)(a), (b) and (c). If the request for a change in ownership or operational control is approved, the terms and conditions of this Permit to Install shall apply to the person or legal entity which hereafter owns or operates the process or process equipment for which this Permit to Install is issued. The written request shall be sent to the Supervisor, Permit Section, Air Quality Division, Michigan Department of Environmental Quality, P.O. Box 30260, Lansing, Michigan 48909.
 8. Rule 901 - Operation of this equipment shall not result in the emission of an air contaminant which causes injurious effects to human health or safety, animal life, plant life of significant economic value, or property, or which causes unreasonable interference with the comfortable enjoyment of life and property.
 9. Rule 912 - The owner or operator of a source, process, or process equipment shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant in excess of standards for more than one hour, or of any air contaminant in excess of standards for more than two hours, as required in this rule, to the District Supervisor, Air Quality Division. The notice shall be provided not later than two business days after start-up, shutdown, or discovery of the abnormal condition or malfunction. Written reports, if required, must be filed with the District Supervisor within 10 days, with the information required in this rule.
 10. Approval of this permit does not exempt the person to whom this permit was issued from complying with any future regulations which may be promulgated under Part 55 of Act 451, P.A. 1994.
 11. Approval of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.
 12. Operation of this equipment may be subject to other requirements of Part 55 of Act 451, P.A. 1994, and the rules promulgated thereunder.

SPECIAL CONDITIONS

13. The total combined nitrogen oxides (NO_x) emission rate from the four boilers shall not exceed 55.9 tons/year based on a 12-month rolling time period as determined at the end of each calendar month.
14. The NO_x emission from the 2 boilers associated with the West Stack when firing natural gas shall not exceed 0.13 lbs. per million BTUs heat input, nor 6.38 lbs./hour.
15. The NO_x emission from the 2 boilers associated with the East Stack when firing natural gas shall not exceed 0.13 lbs. per million BTUs heat input, nor 6.38 lbs./hour.
16. Rule 331-The particulate emission from the 2 boilers associated with the West Stack shall not exceed 0.02 pounds per 1000 lbs. of exhaust gases, calculated on a dry gas basis, nor 0.7 lbs./hour.
17. Rule 331-The particulate emission from the 2 boilers associated with the East Stack shall not exceed 0.02 pounds per 1000 lbs. of exhaust gases, calculated on a dry gas basis, nor 0.7 lbs./hour.
18. Visible emissions from the four boilers shall not exceed 10% opacity based on a 6 minute average.
19. Applicant shall only fire the four boilers with natural gas.
20. Rules 1001, 1003 and 1004-Verification of NO_x and particulate emission rates from the four boilers, by testing, at owner's expense, in accordance with Department requirements, may be required. The testing shall be conducted within 60 days following the receipt of the written notification of the requirement. Verification of emission rates includes the submittal of a complete report of the test results. If testing is required, a complete test plan must be submitted to the Air Quality Division. The final plan must be approved by the Division prior to testing and a complete report of test results must be submitted to the Division within 60 days following the last date of testing.
21. The exhaust gases from the four boilers shall be discharged unobstructed vertically upwards to the ambient air from 2 individual stacks with a maximum diameter of 40 inches at an exit point not less than 80 feet above ground level.
22. Written notification of the actual date of initial startup of the four boilers is required to comply with the Federal Standards of Performance for New Stationary Sources, as specified in 40 CFR, Part 60, Subpart A and Dc. This notification shall be submitted to the Air Quality Division within 15 days after the startup date and may be submitted in conjunction with notification requirements per General Condition No. 4 of this permit.
23. For purposes of this permit to install, all requirements for notifications or submittal of records to or approvals by the District Supervisor, Air Quality Division, should be submitted to the Director of Compliance and Enforcement, Air Quality Management Division, Wayne County Department of Environment, unless you are otherwise notified in writing by the Air Quality Division. At no time shall notifications or submittals to or approvals by both agencies be required pursuant to this permit.