

**MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION**

October 17, 2012

PERMIT TO INSTALL
139-12

ISSUED TO
Bank of America National Association

LOCATED AT
2600 West Big Beaver Road
Troy, Michigan

IN THE COUNTY OF
Oakland

STATE REGISTRATION NUMBER
P0376

The Air Quality Division has approved this Permit to Install, pursuant to the delegation of authority from the Michigan Department of Environmental Quality. This permit is hereby issued in accordance with and subject to Section 5505(1) of Article II, Chapter I, Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended. Pursuant to Air Pollution Control Rule 336.1201(1), this permit constitutes the permittee's authority to install the identified emission unit(s) in accordance with all administrative rules of the Department and the attached conditions. Operation of the emission unit(s) identified in this Permit to Install is allowed pursuant to Rule 336.1201(6).

DATE OF RECEIPT OF ALL INFORMATION REQUIRED BY RULE 203:

August 24, 2012

DATE PERMIT TO INSTALL APPROVED:

October 17, 2012

SIGNATURE:

DATE PERMIT VOIDED:

SIGNATURE:

DATE PERMIT REVOKED:

SIGNATURE:

PERMIT TO INSTALL

Table of Contents

Section	Page
Alphabetical Listing of Common Abbreviations / Acronyms	2
General Conditions	3
Special Conditions	5
Emission Unit Summary Table.....	5
Flexible Group Summary Table	5
Special Conditions for FG-GENERATORS.....	6

Common Abbreviations / Acronyms

Common Acronyms		Pollutant/Measurement Abbreviations	
AQD	Air Quality Division	Btu	British thermal unit
BACT	Best Available Control Technology	°C	Degrees Celsius
CAA	Clean Air Act	CO	Carbon monoxide
CEM	Continuous Emission Monitoring	dscf	Dry standard cubic foot
CFR	Code of Federal Regulations	dscm	Dry standard cubic meter
COM	Continuous Opacity Monitoring	°F	Degrees Fahrenheit
EPA	Environmental Protection Agency	gr	Grains
EU	Emission Unit	Hg	Mercury
FG	Flexible Group	hr	Hour
GACS	Gallon of Applied Coating Solids	H ₂ S	Hydrogen sulfide
GC	General Condition	hp	Horsepower
HAP	Hazardous Air Pollutant	lb	Pound
HVLP	High Volume Low Pressure *	m	Meter
ID	Identification	mg	Milligram
LAER	Lowest Achievable Emission Rate	mm	Millimeter
MACT	Maximum Achievable Control Technology	MM	Million
MAERS	Michigan Air Emissions Reporting System	MW	Megawatts
MAP	Malfunction Abatement Plan	ng	Nanogram
MDEQ	Michigan Department of Environmental Quality (Department)	NO _x	Oxides of nitrogen
MSDS	Material Safety Data Sheet	PM	Particulate matter
NESHAP	National Emission Standard for Hazardous Air Pollutants	PM10	PM less than or equal to 10 microns aerodynamic diameter
NSPS	New Source Performance Standards	PM2.5	PM less than or equal to 2.5 microns aerodynamic diameter
NSR	New Source Review	pph	Pound per hour
PS	Performance Specification	ppm	Parts per million
PSD	Prevention of Significant Deterioration	ppmv	Parts per million by volume
PTE	Permanent Total Enclosure	ppmw	Parts per million by weight
PTI	Permit to Install	psia	Pounds per square inch, absolute
RACT	Reasonably Available Control Technology	psig	Pounds per square inch, gauge
ROP	Renewable Operating Permit	scf	Standard cubic feet
SC	Special Condition	sec	Seconds
SCR	Selective Catalytic Reduction	SO ₂	Sulfur dioxide
SRN	State Registration Number	THC	Total hydrocarbons
TAC	Toxic Air Contaminant	tpy	Tons per year
TEQ	Toxicity Equivalence Quotient	µg	Microgram
VE	Visible Emissions	VOC	Volatile organic compounds
		yr	Year

* For High Volume Low Pressure (HVLP) applicators, the pressure measured at the HVLP gun air cap shall not exceed ten (10) pounds per square inch gauge (psig).

GENERAL CONDITIONS

1. The process or process equipment covered by this permit shall not be reconstructed, relocated, or modified, unless a Permit to Install authorizing such action is issued by the Department, except to the extent such action is exempt from the Permit to Install requirements by any applicable rule. **(R 336.1201(1))**
2. If the installation, construction, reconstruction, relocation, or modification of the equipment for which this permit has been approved has not commenced within 18 months, or has been interrupted for 18 months, this permit shall become void unless otherwise authorized by the Department. Furthermore, the permittee or the designated authorized agent shall notify the Department via the Supervisor, Permit Section, Air Quality Division, Michigan Department of Environmental Quality, P.O. Box 30260, Lansing, Michigan 48909-7760, if it is decided not to pursue the installation, construction, reconstruction, relocation, or modification of the equipment allowed by this Permit to Install. **(R 336.1201(4))**
3. If this Permit to Install is issued for a process or process equipment located at a stationary source that is not subject to the Renewable Operating Permit program requirements pursuant to R 336.1210, operation of the process or process equipment is allowed by this permit if the equipment performs in accordance with the terms and conditions of this Permit to Install. **(R 336.1201(6)(b))**
4. The Department may, after notice and opportunity for a hearing, revoke this Permit to Install if evidence indicates the process or process equipment is not performing in accordance with the terms and conditions of this permit or is violating the Department's rules or the Clean Air Act. **(R 336.1201(8), Section 5510 of Act 451, PA 1994)**
5. The terms and conditions of this Permit to Install shall apply to any person or legal entity that now or hereafter owns or operates the process or process equipment at the location authorized by this Permit to Install. If the new owner or operator submits a written request to the Department pursuant to R 336.1219 and the Department approves the request, this permit will be amended to reflect the change of ownership or operational control. The request must include all of the information required by subrules (1)(a), (b), and (c) of R 336.1219 and shall be sent to the District Supervisor, Air Quality Division, Michigan Department of Environmental Quality. **(R 336.1219)**
6. Operation of this equipment shall not result in the emission of an air contaminant which causes injurious effects to human health or safety, animal life, plant life of significant economic value, or property, or which causes unreasonable interference with the comfortable enjoyment of life and property. **(R 336.1901)**
7. The permittee shall provide notice of an abnormal condition, start-up, shutdown, or malfunction that results in emissions of a hazardous or toxic air pollutant which continue for more than one hour in excess of any applicable standard or limitation, or emissions of any air contaminant continuing for more than two hours in excess of an applicable standard or limitation, as required in Rule 912, to the Department. The notice shall be provided not later than two business days after start-up, shutdown, or discovery of the abnormal condition or malfunction. Written reports, if required, must be filed with the Department within 10 days after the start-up or shutdown occurred, within 10 days after the abnormal conditions or malfunction has been corrected, or within 30 days of discovery of the abnormal condition or malfunction, whichever is first. The written reports shall include all of the information required in Rule 912(5). **(R 336.1912)**
8. Approval of this permit does not exempt the permittee from complying with any future applicable requirements which may be promulgated under Part 55 of 1994 PA 451, as amended or the Federal Clean Air Act.
9. Approval of this permit does not obviate the necessity of obtaining such permits or approvals from other units of government as required by law.
10. Operation of this equipment may be subject to other requirements of Part 55 of 1994 PA 451, as amended and the rules promulgated thereunder.

11. Except as provided in subrules (2) and (3) or unless the special conditions of the Permit to Install include an alternate opacity limit established pursuant to subrule (4) of R 336.1301, the permittee shall not cause or permit to be discharged into the outer air from a process or process equipment a visible emission of density greater than the most stringent of the following. The grading of visible emissions shall be determined in accordance with R 336.1303. **(R 336.1301)**
 - a) A six-minute average of 20 percent opacity, except for one six-minute average per hour of not more than 27 percent opacity.
 - b) A visible emission limit specified by an applicable federal new source performance standard.
 - c) A visible emission limit specified as a condition of this Permit to Install.
12. Collected air contaminants shall be removed as necessary to maintain the equipment at the required operating efficiency. The collection and disposal of air contaminants shall be performed in a manner so as to minimize the introduction of contaminants to the outer air. Transport of collected air contaminants in Priority I and II areas requires the use of material handling methods specified in R 336.1370(2). **(R 336.1370)**
13. The Department may require the permittee to conduct acceptable performance tests, at the permittee's expense, in accordance with R 336.2001 and R 336.2003, under any of the conditions listed in R 336.2001. **(R 336.2001)**

SPECIAL CONDITIONS

EMISSION UNIT SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Emission Unit ID	Emission Unit Description (Process Equipment & Control Devices)	Installation Date / Modification Date	Flexible Group ID
EUML_Gen#1	A 1,750 kilowatts (kW) diesel-fueled emergency engine manufactured before 2006. Located at 2600 West Big Beaver Road, Troy, Michigan.	1989	FG-GENERATORS
EUML_Gen#2	A 1,750 kilowatts (kW) diesel-fueled emergency engine manufactured before 2006. Located at 2600 West Big Beaver Road, Troy, Michigan.	1989	FG-GENERATORS
EUML_Gen#3	A 1,750 kilowatts (kW) diesel-fueled emergency engine manufactured before 2006. Located at 2600 West Big Beaver Road, Troy, Michigan.	2005	FG-GENERATORS
Changes to the equipment described in this table are subject to the requirements of R 336.1201, except as allowed by R 336.1278 to R 336.1290.			

FLEXIBLE GROUP SUMMARY TABLE

The descriptions provided below are for informational purposes and do not constitute enforceable conditions.

Flexible Group ID	Flexible Group Description	Associated Emission Unit IDs
FG-GENERATORS	Three (3) 1,750 kilowatts (kW) diesel-fueled emergency engines. Engines will be used for back up to maintain operation of office building and banking operations during power outages.	EUML_Gen#1, EUML_Gen#2, EUML_Gen#3

The following conditions apply to: FG-GENERATORS

DESCRIPTION: Three (3) 1,750 kilowatts (kW) diesel-fueled emergency engines. Engines will be used for back up to maintain operation of office building and banking operations during power outages.

POLLUTION CONTROL EQUIPMENT: NA

I. EMISSION LIMITS

Pollutant	Limit	Time Period / Operating Scenario	Equipment	Testing / Monitoring Method	Underlying Applicable Requirements
1. NO _x	18.2 g/kW-hr	Test Protocol*	Each engine in FG-GENERATORS	SC V.1 SC VI.2	R 336.1205(1)(a)
2. CO	3.65 g/kW-hr	Test Protocol*	Each engine in FG-GENERATORS	SC V.1 SC VI.2	R 336.1205(1)(a)

*Test Protocol shall determine averaging time.

II. MATERIAL LIMITS

1. The permittee shall burn only diesel fuel, in each engine in FG-GENERATORS with the maximum sulfur content of 15 ppm (0.0015 percent) by weight. **(R 336.1205(1)(a), R 336.1402(1))**

III. PROCESS/OPERATIONAL RESTRICTIONS

1. The permittee shall not operate each engine in FG-GENERATORS for more than 500 hours per year on a 12-month rolling time period basis as determined at the end of each calendar month. The 500 hours includes the 100 hours for the purpose of necessary maintenance checks and readiness testing as described in SC III.2. **((R 336.1205(1)(a) & (3), R 336.1225, R 336.1702(a), R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))**
2. The permittee may operate each engine in FG-GENERATORS for no more than 100 hours per 12-month rolling time period as determined at the end of each calendar month for the purpose of necessary maintenance checks and readiness testing, provided that the tests are recommended by Federal, State, or local government, the manufacturer, the vendor, or the insurance company associated with the engine. Permittee may petition the Department for approval of additional hours to be used for maintenance checks and readiness testing. A petition is not required if the owner or operator maintains records indicating that Federal, State, or local standards require maintenance and testing of emergency internal combustion engines beyond 100 hours per year. Each engine in FG-GENERATORS may operate up to 50 hours per year in non-emergency situations, but those 50 hours are counted towards the 100 hours per year provided for maintenance and testing. The 50 hours per year for non-emergency situations cannot be used for peak shaving or to generate income for a facility to supply non-emergency power as part of a financial arrangement with another entity. **((R 336.1205(1)(a) & (3), R 336.1225, R 336.1702(a), R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))**
3. The permittee shall install, maintain, and operate each engine in FG-GENERATORS according to the manufacturer written instructions, or procedures developed by the owner/operator and approved by the engine manufacturer, over the entire life of the engine. **(R 336.1205(1)(a) & (3), R 336.1225, R 336.1911, R 336.2803, R 336.2804, 40 CFR 52.21(c) & (d))**

IV. DESIGN/EQUIPMENT PARAMETERS

1. The permittee shall equip and maintain each each engine in FG-GENERATORS with non-resettable hours meters to track the operating hours. **(R 336.1205(1)(a) & (3))**
2. The nameplate capacity of each engine in FG-GENERATORS shall not exceed 2000 kW, as certified by the equipment manufacturer. **(R 336.1205(1)(a) & (3))**

V. TESTING/SAMPLING

Records shall be maintained on file for a period of five years. **(R 336.1201(3))**

1. Upon request from the district supervisor, the permittee shall verify NO_x and CO emission rates from each engine in FG-GENERATORS, by testing at owner's expense, in accordance with Department requirements or by providing documentation as required in SC VI.2. No less than 60 days prior to testing, the permittee must submit a complete stack-testing plan to the AQD. The AQD must approve the final plan prior to testing. Verification of emission rates includes the submittal of a complete report of the test results to the AQD within 60 days following the last date of the test. **(R 336.2001, R 336.2003, R 336.2004)**

VI. MONITORING/RECORDKEEPING

Records shall be maintained on file for a period of five years. **(R 336.1201(3))**

1. The permittee shall complete all required calculations in a format acceptable to the AQD District Supervisor by the 30th day of the calendar month, for the previous calendar month, unless otherwise specified in any monitoring/recordkeeping special condition. **(R 336.1205(1)(a) & (3), R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d))**
2. The permittee shall keep records of performance test results indicating that each engine in FG-GENERATORS meets the applicable emission limitations contained SC I.1-2. The permittee shall keep all records on file and make them available to the Department upon request. **(R 336.1205(1)(a) & (3))**
3. The permittee shall monitor and record the hours of operation of each engine in FG-GENERATORS, on a monthly and 12- month rolling time period basis, in a manner that is acceptable to the District Supervisor, Air Quality Division. **(R 336.1205(1)(a) & (3))**
4. The permittee shall keep, in a satisfactory manner, fuel supplier certification records or fuel sample test data, for each delivery of diesel fuel oil used in each engine in FG-GENERATORS, demonstrating that the fuel sulfur content meets the requirement of SC II.1. The certification or test data shall include the name of the oil supplier or laboratory, and the sulfur content of the fuel oil. **(R 336.1205(1)(a) & (3), R 336.1402)**

VII. REPORTING

NA

VIII. STACK/VENT RESTRICTIONS

The exhaust gases from the stacks listed in the table below shall be discharged unobstructed to the ambient air:

Stack & Vent ID	Maximum Exhaust Diameter (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
1. SVML_Gen#1	16	13	R 336.1225, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)

Stack & Vent ID	Maximum Exhaust Diameter (inches)	Minimum Height Above Ground (feet)	Underlying Applicable Requirements
2. SVML_Gen#2	16	13	R 336.1225, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)
3. SVML_Gen#3	16	13	R 336.1225, R 336.2803, R 336.2804, 40 CFR 52.21 (c) & (d)

IX. OTHER REQUIREMENTS

1. The permittee shall comply with the provisions of the National Emission Standards for Hazardous Air Pollutants, as specified in 40 CFR, Part 63, Subpart A and Subpart ZZZZ, as they apply to FG-GENERATORS, by the initial compliance date upon startup of each engine. **(40 CFR Part 63 Subparts A and ZZZZ, 40 CFR 63.6595)**

Footnotes:

¹This condition is state only enforceable and was established pursuant to Rule 201(1)(b).