



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
DETROIT DISTRICT OFFICE



LIESL EICHLER CLARK
DIRECTOR

October 17, 2019

Ms. Deborah Manzano, Plant Manager
Ford Motor Company Dearborn Truck Plant
3001 Miller Road
P.O. Box 1659
Dearborn, MI 48121

SRN: A8648, Wayne County

Dear Ms. Manzano:

VIOLATION NOTICE

On October 14, 2019, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), received an email notice regarding the Ford Dearborn Assembly Plant located at 3001 Miller Road, Dearborn, Michigan. The purpose of this email was to inform the Department of Environment, Great Lakes and Energy, Air Quality Division of an abatement device malfunction as required under the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; the conditions of Renewable Operating Permit (ROP) number MI-ROP-A8648-2015a; and Consent Order AQD number 19-2017.

During the review of the email, staff have observed the following:

Process Description	Rule/Permit Condition Violated	Comments
FG-CONTROLS	Rules 336.1702(a), R336.1910, 40 CFR 64.6(c)(1)(i)(ii)(iii)/special conditions IV.1 & VI.2.	Did not maintain the desorption gas inlet temperature for the carbon concentrator.
FG-CONTROLS	Rule 336.1912, Consent Order 19-2017 paragraph 9d, the Operations and Maintenance Plan (OMP) and the Malfunction Abatement Plan (MAP).	Failure to provide notice of an abnormal condition or malfunction continuing for more than 2 hours within the proper timeframe.

Please initiate actions necessary to correct the cited Violation and submit a written response to this Violation Notice by November 7, 2019 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

Ms. Deborah Manzano, Plant Manager
Ford Motor Company Dearborn Truck Plant
Page 2
October 17, 2019

Please submit the written response to EGLE, AQD, Detroit District, at 3058 West Grand Boulevard, Detroit, Michigan 48202-6058 and submit a copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

If Ford Motor Company believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me by sending an email and a phone discussion with John Grace on October 14, 2019. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Robert Byrnes
Senior Environmental Engineer
Air Quality Division
517-275-0439

cc: Ms. Mary Ann Dolehanty, EGLE
Dr. Eduardo Olaguer, EGLE
Ms. Jenine Camilleri, EGLE
Mr. Christopher Ethridge, EGLE
Ms. Wilhemina McLemore, EGLE
Mr. Jeff Korniski, EGLE