

## 1.0 INTRODUCTION

### 1.1 Identification, location and dates of tests

Erthwrks, Inc. was contracted to conduct the emissions performance test the NHT Charge Heater in operation at the Marathon Detroit Refinery, located in Detroit, Michigan. The performance test was conducted on April 21, 2021.

### 1.2 Purpose of Testing

This test program was conducted to determine the nitric oxide (NO<sub>x</sub>) emissions emitted from the NHT Charge Heater. All testing and audit procedures were conducted in accordance with the requirements set forth in the USEPA Title 40, Code of Federal Regulations (CFR), Part 60, Appendix B which defines the testing procedures.

### 1.3 Description of Source

The NHT Charge Heater (EU16-NHTCHARHTR-S1) preheats the feed to the Naphtha Hydrotreater. The unit is fired by refinery fuel gas. Emissions are vented to the atmosphere via the NHT Charge Heater Stack where testing was performed.

### 1.4 Contact Information

#### **Marathon Petroleum Company LP**

Aamani Kura  
Environmental Professional  
Michigan Refining Division  
O: (313)551-7963 | C: (734)899-7343  
AaKura@marathonpetroleum.com

#### **Erthwrks, Inc.**

John Wood  
Senior Partner  
P.O. Box 150549  
Austin, TX 78715  
512-585-1685 office  
888-573-9994 fax  
jwood@erthwrks.com

## 2.0 SUMMARY OF RESULTS

**Table 2.1: NHT Charge Heater Emissions Results**

Pollutant Measured	Mass Emission Rate	Applicable Limit	Pass/Fail
NO <sub>x</sub>	0.157 lb/MMBtu	0.20 lb/MMBtu	Pass

## 3.0 SOURCE DESCRIPTION

### 3.1 Description of the process

The Naphtha Hydrotreater unit uses hydrogen to remove sulfur and nitrogen from straight-run and coker naphthas. This process, known as hydrotreating, uses a catalyst to promote the desulfurization reaction. The desulfurized or sweet naphtha is blended into gasoline or used for platformer feed. The NHT unit consists of process vessels (including exchangers, reactors, receivers, separators, and a stripper column), heaters, tanks, containers, pumps, piping, drains, and various components (pump seals, process valves, pressure relief valves, flanges, connectors, etc.).

The NHT Charge Heater preheats the feed to the reactor. The unit is fired by refinery fuel gas. Emissions are vented to the atmosphere via the NHT Charge Heater Stack.

### 3.2 Applicable permit and source designation

The Marathon Detroit Refinery operates the NHT Charge Heater under the Permit No. MI-ROP-A9831-2012c. The NHT Charge Heater is also identified as EU16- NHTCHARHTR-S1. The Marathon Detroit Refinery is required to conduct an annual compliance test to demonstrate that NO<sub>x</sub> emissions remain below the applicable limit.

### 3.3 Type and quantity of materials processed during tests

During the emission testing on April 21, 2021 at the Marathon Detroit Refinery, the NHT Charge Heater was tested at the highest achievable rate. The actual load conditions during the testing were documented by facility personnel and are summarized in Appendix A. Raw data records are provided in Appendix F.

## 4.0 SAMPLING AND ANALYTICAL PROCEDURES

### 4.1 Description of sampling and field procedures

Erthwrks completed this compliance test utilizing all applicable test methods specified in the USEPA Title 40 CFR Part 60, Appendix A. EPA Method 3A was used to determine the O<sub>2</sub> concentration and EPA Method 7E was used to determine the NO<sub>x</sub> concentration.

All gaseous sampling was done utilizing three appropriate traverse points. The three traverse points were selected to ensure acquisition of a representative sample over the stack cross section.

### 4.2 Quality Assurance Procedures

As required by EPA Methods 3A and 10, Erthwrks followed all quality assurance and quality control procedures as defined in US EPA 40 CFR 60 Appendix A, Method 7E for the determination of the concentrations of CO and O<sub>2</sub>.

The Calibration Error (CE) Test was conducted as specified in EPA Method 7E §8.2.3. In accordance with this requirement, a three-point analyzer calibration error test was conducted prior to sampling. The CE test was conducted by introducing the low, mid, and high-level calibration gasses (as defined in EPA Method 7E §3.3.1-3) sequentially and the response was recorded. The results of the CE test are acceptable if the calculated calibration error is within  $\pm 2.0\%$  of calibration span (or  $\leq 0.5$  ppmv).

The NO<sub>2</sub>-NO Conversion Efficiency Test was conducted prior to each field test in accordance with EPA Method 7E §8.2.4.1. This was conducted by introducing the converter efficiency gas (~50 ppm NO<sub>2</sub>) directly to the NO<sub>x</sub> analyzer and recording the NO value. The NO<sub>2</sub>-NO Conversion Efficiency test was within acceptable limits.

A Stratification Test was conducted at the beginning of the test as described in EPA Method 7E §8.1.2. Three points at 16.7%, 50%, and 83.3% of the stack diameter was used as the traverse line. The highest emitted pollutant was measured at each point for a period of at least twice the sample system response time. The concentration at each point was compared to the average concentration. The exhaust gas stream was considered unstratified because the variance at each point was  $< 5.0\%$  from the average, and the sample was taken the centroid of the stack.

The Initial System Bias and System Calibration Error Check was conducted in accordance with EPA Method 7E §8.2.5. The upscale calibration gas was introduced at the probe upstream of all sample system components and the response was recorded. The procedure was repeated with the low-level gas and the response was recorded. The sample system response time was also recorded. This specification is acceptable if the calculated values of the system calibration error check are within  $\pm 5.0\%$  of the calibration span value (or  $\leq 0.5$  ppmv).

After each compliance test run, the sample system bias check was conducted to validate the run data. The low-level and upscale drift was calculated using Equation 7E-4. The run data was deemed valid if the calculated drift is within  $\pm 3.0\%$  of the calibration span value (or  $\leq 0.5$  ppmv).

Each test run, the effluent gas concentration was calculated as specified in EPA Method 7E §12.6. The arithmetic average of all valid concentration values was adjusted for bias using Equation 7E-5B.

EPA Method 19 was used for the calculation of the mass emission rates. In accordance with this method, the volumes of combustion components per unit of heat content ( $F_d$ ) was calculated using the comprehensive fuel analysis (Eq. 19-13). Utilizing this “F-Factor”, the emission rates were calculated using Equation 19-1. The fuel analysis worksheets are found in Appendix C and the example calculations are found in Appendix E.

#### 4.3 Discussion of sampling procedure or operational variances

Erthwrks, Inc. conducted the emission testing with no sampling or procedural variances. The NHT Charge Heater tested, operated with no operational variances.

RECEIVED

JUN 17 2021

AIR QUALITY DIVISION

8681.1.B1 Marathon Detroit NHT Stripper (Reboiler) Test Report April 2021

Version 1 (5/18/21)

**Attachment A**  
**Detailed Results of Emission Test**

## Erthwrks Summary of Results

**Date:** 4/21/2021  
**Client:** Marathon  
**Facility:** Detroit  
**Unit ID:** NHT Charge Heater  
**Erthwrks Tech:** JW, JT, JM

Run Information			
Run Number	Run 1	Run 2	Run 3
Date	4/21/2021	4/21/2021	4/21/2021
Run Start Time	12:56	14:06	15:13
Run End Time	13:56	15:06	16:13
Operating Conditions			
NHT Charge Rate (Reactor) BPD	34009.0	33992.2	33996.4
NHT Charge Heater Duty	58.6	58.2	58.2
Fuel Gas MSCFD	1401.0	1400.3	1393.5
Unit Fuel Flow Data			
Fuel F Factor (F <sub>d</sub> ) (scf/MMBtu)	8586.3	8586.3	8586.3
Emission Concentrations			
NOx (ppmv)	105.90	106.18	106.26
O <sub>2</sub> (%)	6.35	6.38	6.45
Emission Concentrations O2 Corrected		Corrected To: 0 %O2	
NOx (ppmv @ %O <sub>2</sub> )	152.13	152.84	153.64
Emission Rates (lb/scf)			
NOx (lb/scf)	1.26E-05	1.27E-05	1.27E-05
Emission Rates (lb/MMBtu)			
NOx (lb/MMBtu)	0.1560	0.1567	0.1575

**Average**  
**152.9 ppmv**

**Average**  
**0.1567 lb/MMBtu**

**Attachment B**  
**Quality Control Documentation**

## Erthwrks Method 1 Traverse Point Location Worksheet

**Client:** Marathon  
**Project #:** 8681.1.B1  
**Facility:** Detroit  
**Unit ID:** NHT Charge Heater  
**Technician:** JW, JT, JM

**Stack ID Measurements**


Stack ID + Port (inches): 63.5  
 Port Extension (inches): 8.5  
 Stack Diameter (inches): 55

**Port Location Measurements**

Distance Upstream (A) (inches): 150  
 Distance Downstream (B) (inches): 125  
 Stack Diameters Upstream (A): 2.7  
 Stack Diameters Downstream (B): 2.3


Total Traverse Points to be used: 3  
 Traverse Points per Diameter: 3

*Traverse Point Table and Stack Side View*



**Stack Cross Section View**

Traverse Point Locations <sup>(1)(2)</sup>	
Point 1:	9.19"
Point 2:	27.50"
Point 3:	45.82"



<sup>(1)</sup>For stack diameter >4.0" and <2.4 meters, stratification is measured at 16.7%, 50.0%, and 83.3% of stack diameter (M7E, §8.1.2).

<sup>(2)</sup>For stack diameter >2.4 meters, stratification is measured at 0.4, 1.2, and 2.0 meters from stack wall (M7E, §8.1.2).