




Marathon Petroleum Company
1300 South Fort Street
Detroit, MI 48217



RECEIVED

DEC 13 2013

AIR QUALITY DIV.

REPORT ON COMPLIANCE TESTING


Performed for:
**MARATHON PETROLEUM COMPANY
DETROIT REFINERY**

**CCR INTERHEATER STACK (SV14-H4A)
CCR HEATER STACK (SV14-H6)**

Client Reference No: CN00081321
CleanAir Project No: 12317
Revision 0: September 10, 2013

To the best of our knowledge, the data presented in this report are accurate, complete, error free, legible and representative of the actual emissions during the test program. Clean Air Engineering operates in conformance with the requirements of ASTM D7036-04 Standard Practice for Competence of Air Emission Testing Bodies.

Submitted by,


Andy Obuchowski
Project Manager
abuchowski@cleanair.com
(800) 627-0033 ext. 4537

Reviewed by,


Scott Brown
Senior Project Manager
sbrown@cleanair.com
(800) 627-0033 ext. 4544

REVISION HISTORY

REPORT ON COMPLIANCE TESTING

DRAFT REPORT REVISION HISTORY

Revision:	Date	Pages	Comments
D0a	08/22/13	All	Draft version of original document.

FINAL REPORT REVISION HISTORY

Revision:	Date	Pages	Comments
0	09/10/13	All	Final version of original document.

CONTENTS

iii

1	PROJECT OVERVIEW	1-1
	INTRODUCTION.....	1-1
	Key Project Participants.....	1-1
	Test Program Parameters	1-1
	TEST PROGRAM SYNOPSIS	1-2
	Test Schedule	1-2
	Table 1-1: Schedule of Activities	1-2
	Results Summary.....	1-3
	Table 1-2: Summary of RATA Results.....	1-3
	Table 1-3: Summary of Emission Compliance Test Results.....	1-3
	Discussion of Test Program.....	1-4
2	RESULTS.....	2-1
	Table 2-1: CCR Interheater Stack – O ₂ Relative Accuracy (USEPA M-3A / PS3).....	2-1
	Table 2-2: CCR Interheater Stack – NO _x Relative Accuracy (USEPA M-7E / PS2).....	2-2
	Table 2-3: CCR Interheater Stack – NO _x Emissions (USEPA M-7E).....	2-3
	Table 2-4: CCR Heater Stack – O ₂ Relative Accuracy (USEPA M-3A / PS3).....	2-5
	Table 2-5: CCR Heater Stack – NO _x Relative Accuracy (USEPA M-7E / PS2).....	2-6
	Table 2-6: CCR Heater Stack – NO _x Emissions (USEPA M-7E).....	2-7
3	DESCRIPTION OF INSTALLATION	3-1
	PROCESS DESCRIPTION	3-1
	DESCRIPTION OF SAMPLING LOCATIONS	3-1
	Table 3-1: Sampling Points.....	3-1
	Figure 3-1: CCR Interheater Sampling Points - RATA.....	3-2
	Figure 3-2: CCR Heater Sampling Points – RATA	3-3
4	METHODOLOGY.....	4-1
	Table 4-1: Summary of Sampling Procedures.....	4-1
5	APPENDIX	5-1
	TEST METHOD SPECIFICATIONS	A
	SAMPLE CALCULATIONS	B
	PARAMETERS.....	C
	QA/QC DATA	D
	REFERENCE METHOD CEMS DATA.....	E
	FACILITY CEMS AND OPERATING DATA.....	F
	FUEL ANALYSIS.....	G

PROJECT OVERVIEW

1-1

INTRODUCTION

Marathon Petroleum Company (MPC) contracted Clean Air Engineering (CleanAir) to perform a relative accuracy test audit (RATA) on a continuous emissions monitoring system (CEMs) installed at the Detroit Refinery and to demonstrate compliance with permit limits.

All testing was conducted in accordance with the regulations set-forth by the United States Environmental Protection Agency (USEPA) and the Michigan Department of Environmental Quality (DEQ). The permit limits are referenced in Michigan Department of Environmental Quality, Air Quality Division Permit to Install No. 63-08C, issued January 11, 2012.

Key Project Participants

Individuals responsible for coordinating and conducting the test program were:

Tabetha Daum – MPC
Joe Reidy – MPC
Thomas Gasloli – DEQ
Ken Sullivan – CleanAir

Test Program Parameters

The testing was performed at the CCR Interheater Stack (Emission Unit ID No. EG14-CCRPLINTHTR; Stack ID No. SV14-H4A) on August 6, 2013, and at the CCR Heater Stack (Emission Unit ID No. EG14-CCRPLCHARHTR; Stack ID No. SV14-H6) on August 7, 2013.

Identical testing was performed at each location and included the following emissions measurements:

- nitrogen oxides (NO_x)
- oxygen (O₂)

RECEIVED
DEC 13 2013
AIR QUALITY DIV.

PROJECT OVERVIEW**TEST PROGRAM SYNOPSIS****Test Schedule**

The on-site schedule followed during the test program is outlined in Table 1-1.

**Table 1-1:
Schedule of Activities**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	CCR Interheater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/06/13	11:33	11:54
2	CCR Interheater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/06/13	12:11	12:32
3	CCR Interheater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/06/13	12:45	13:06
4	CCR Interheater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/06/13	13:17	13:38
5	CCR Interheater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/06/13	13:51	14:12
6	CCR Interheater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/06/13	14:25	14:46
7	CCR Interheater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/06/13	14:57	15:18
8	CCR Interheater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/06/13	15:30	15:51
9	CCR Interheater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/06/13	16:00	16:21
10	CCR Interheater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/06/13	16:34	16:55
1	CCR Heater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/07/13	09:12	09:33
2	CCR Heater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/07/13	09:47	10:08
3	CCR Heater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/07/13	10:20	10:41
4	CCR Heater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/07/13	10:55	11:16
5	CCR Heater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/07/13	11:31	11:52
6	CCR Heater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/07/13	12:02	12:23
7	CCR Heater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/07/13	12:34	12:55
8	CCR Heater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/07/13	13:03	13:24
9	CCR Heater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/07/13	13:33	13:54
10	CCR Heater Stack	USEPA Method 3A/7E	O ₂ /CO ₂ /NO _x	08/07/13	14:03	14:24

081513 131411

PROJECT OVERVIEW

1-3

Results Summary

Table 1-2 and Table 1-3 summarize the results of the test program. A more detailed presentation of the test conditions and results of analysis are shown on pages 2-1 through 2-8.

**Table 1-2:
Summary of RATA Results**

<u>Source</u> Constituent (Units)	Reference Method (USEPA)	Applicable Specification	Relative Accuracy (%)	Units	Specification Limit ¹
<u>CCR Interheater Stack</u>					
O ₂ (% dv)	M-3A	PS3	0.15	% dv	±1.0% dv
NO _x (ppmdv)	M-7E	PS2	3.3	% of RM	20% of RM
<u>CCR Heater Stack</u>					
O ₂ (% dv)	M-3A	PS3	0.06	% dv	±1.0% dv
NO _x (ppmdv)	M-7E	PS2	3.5	% of RM	20% of RM

¹ Specification limits obtained from 40 CFR 60, Appendix B, Performance Specifications.

082113 092306

**Table 1-3:
Summary of Emission Compliance Test Results**

<u>Source</u> Constituent (Units)	Sampling Method	Average Emission	Permit Limit ¹
<u>CCR Interheater Stack</u>			
NO _x (lb/MMBtu)	USEPA M-7E	0.02	0.05
<u>CCR Heater Stack</u>			
NO _x (lb/MMBtu)	USEPA M-7E	0.02	0.05

¹ Permit limits obtained from MDEQ Permit To Install No. 63-08C.

082113 092306

PROJECT OVERVIEW

1-4

Discussion of Test Program***O₂ and NO_x Emissions / RATA Testing - USEPA Methods 3A and 7E;
Performance Specifications 2, 3***

Minute-average data points for O₂, CO₂ and NO_x, (dry basis) were collected over a period of 21 minutes for each RATA Reference Method (RM) run. The average result for each RM run was calculated and compared to the average result from the facility CEMs over an identical time interval in order to calculate relative accuracy (RA).

- For O₂, RA is expressed as the average absolute difference between the RM and facility CEMs runs. The final results at both locations were below the limit of $\pm 1.0\%$ dv set by PS3.
- For NO_x, RA is expressed as the percent difference between RM and facility CEMs runs. The final results at both locations were below the limit of 20% of the RM set by PS2.
- CO₂ data was collected only as supplemental information.

NO_x results from the RATA were converted from units of dry volume-based concentration (ppmdv) to mass-based emission rate units (lb/MMBtu) to demonstrate compliance with permit limits. The final results were expressed as the average of all ten (10) RATA runs. For each unit, the final results were below the permit limits.

All reference method raw data in Appendix C, D and E prior to and including Run 1 on August 6, 2013, coordinate with Central Time. Reference method raw data subsequent to Run 1 on August 6, 2013, as well as all other run times included in this report, coordinate with Eastern Time.

Calculation of Final Results

Emission results in units of dry volume-based concentration (lb/dscf, ppmdv) were converted to units of pounds per million Btu (lb/MMBtu) by calculating an oxygen-based fuel factor (F_d) for refinery gas per USEPA Method 19 specifications. The heat content and F_d factor were calculated from percent volume composition analytical data provided by MPC and tabulated heating values for the measured constituent.

End of Section 1 – Project Overview

RESULTS

**Table 2-1:
CCR Interheater Stack – O₂ Relative Accuracy (USEPA M-3A / PS3)**

Run No.	Start Time	Date (2013)	RM Data (%dv)	CEMS Data (%dv)	Difference (%dv)
1	10:33	Aug 6	4.50	4.72	-0.22
2	12:11	Aug 6	4.46	4.66	-0.20
3	12:45	Aug 6	4.40	4.60	-0.19
4	13:17	Aug 6	4.44	4.64	-0.20
5	13:51	Aug 6	4.41	4.58	-0.16
6	14:25	Aug 6	4.37	4.48	-0.11
7	14:57	Aug 6	4.29	4.45	-0.16
8	15:30	Aug 6	4.27	4.48	-0.21
9 *	16:00	Aug 6	4.32	4.58	-0.25
10	16:34	Aug 6	4.32	4.53	-0.21
Average			4.38	4.57	-0.15


Relative Accuracy Test Audit Results
Avg. Abs. Diff. (%dv) 0.15 1.0

RM = Reference Method (CleanAir Data)

082113 092306

CEMS = Continuous Emissions Monitoring System (Marathon Petroleum Company Data)

RATA calculations are based on 9 of 10 runs. * indicates the excluded run.



RECEIVED
DEC 13 2013
AIR QUALITY DIV.

RESULTS

**Table 2-2:
CCR Interheater Stack – NO_x Relative Accuracy (USEPA M-7E / PS2)**

Run No.	Start Time	Date (2013)	RM Data (ppmdv)	CEMS Data (ppmdv)	Difference (ppmdv)	Difference Percent
1 *	10:33	Aug 6	20.35	19.63	0.72	3.5%
2	12:11	Aug 6	19.84	19.29	0.55	2.8%
3	12:45	Aug 6	19.98	19.41	0.56	2.8%
4	13:17	Aug 6	19.68	19.24	0.45	2.3%
5	13:51	Aug 6	19.57	19.01	0.56	2.9%
6	14:25	Aug 6	19.25	18.63	0.62	3.2%
7	14:57	Aug 6	19.27	18.67	0.60	3.1%
8	15:30	Aug 6	19.38	18.87	0.51	2.6%
9	16:00	Aug 6	19.83	19.11	0.72	3.6%
10	16:34	Aug 6	19.69	19.12	0.57	2.9%
Average			19.61	19.04	0.47	2.9%

Relative Accuracy Test Audit Results


Standard Deviation of Differences	0.240	
Confidence Coefficient (CC)	0.185	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	3.3%	Limit 20.0%

RM = Reference Method (CleanAir Data)

082113 092306

CEMS = Continuous Emissions Monitoring System (Marathon Petroleum Company Data)

RATA calculations are based on 9 of 10 runs. * indicates the excluded run.



RESULTS**Table 2-3:
CCR Interheater Stack – NO_x Emissions (USEPA M-7E)**

Run No.		1	2	3	4	5	6
Date (2013)		Aug 6	Aug 6	Aug 6	Aug 6	Aug 6	Aug 6
Start Time (approx.)		11:33	12:11	12:45	13:17	13:51	14:25
Stop Time (approx.)		11:54	12:32	13:06	13:38	14:12	14:46
Process Conditions							
P ₁	Fuel gas flow rate (Mscf/day)	2,013	2,020	2,007	2,012	2,038	2,086
P ₂	Feed to charge heater (BPD)	19,000	18,999	19,002	18,992	19,003	18,993
F _d	Oxygen-based F-factor (dscf/MMBtu)	8,335	8,335	8,335	8,335	8,335	8,335
H _i	Actual heat input (MMBtu/hr)	95.5	95.8	95.2	95.4	96.6	98.9
Gas Conditions							
O ₂	Oxygen (dry volume %)	4.5	4.5	4.4	4.4	4.4	4.4
Nitrogen Oxides Results							
C _{sd}	Concentration (ppmdv)	20.4	19.8	20.0	19.7	19.6	19.3
C _{sd}	Concentration (lb/dscf)	2.43E-06	2.37E-06	2.39E-06	2.35E-06	2.34E-06	2.30E-06
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	0.0258	0.0251	0.0252	0.0249	0.0247	0.0242

RESULTS**Table 2-3 (Continued):
CCR Interheater Stack – NO_x Emissions (USEPA M-7E)**

Run No.		7	8	9	10	Average
Date (2013)		Aug 6	Aug 6	Aug 6	Aug 6	
Start Time (approx.)		14:57	15:30	16:00	16:34	
Stop Time (approx.)		15:18	15:51	16:21	16:55	
Process Conditions						
P ₁	Fuel gas flow rate (Mscf/day)	2,095	2,067	2,018	2,010	2,037
P ₂	Feed to charge heater (BPD)	19,001	19,003	19,002	19,004	19,000
F _d	Oxygen-based F-factor (dscf/MMBtu)	8,335	8,335	8,335	8,335	8,335
H _i	Actual heat input (MMBtu/hr)	99.4	98.0	95.7	95.3	96.6
Gas Conditions						
O ₂	Oxygen (dry volume %)	4.3	4.3	4.3	4.3	4.4
Nitrogen Oxides Results						
C _{sd}	Concentration (ppm _v)	19.3	19.4	19.8	19.7	19.7
C _{sd}	Concentration (lb/dscf)	2.30E-06	2.31E-06	2.37E-06	2.35E-06	2.35E-06
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	0.0241	0.0242	0.0249	0.0247	0.0248

Average includes 10 runs.

080410 154528

RESULTS

Table 2-4:
CCR Heater Stack – O₂ Relative Accuracy (USEPA M-3A / PS3)

Run No.	Start Time	Date (2013)	RM Data (%dv)	CEMS Data (%dv)	Difference (%dv)
1	09:12	Aug 7	4.38	4.41	-0.03
2 *	09:47	Aug 7	4.31	4.40	-0.09
3	10:20	Aug 7	4.45	4.52	-0.07
4	10:55	Aug 7	4.42	4.49	-0.07
5	11:31	Aug 7	4.44	4.51	-0.07
6	12:02	Aug 7	4.61	4.68	-0.07
7	12:34	Aug 7	4.40	4.47	-0.07
8	13:03	Aug 7	4.31	4.37	-0.06
9	13:33	Aug 7	4.29	4.34	-0.05
10	14:03	Aug 7	4.28	4.35	-0.07
Average			4.40	4.46	-0.06


Relative Accuracy Test Audit Results
Avg. Abs. Diff. (%dv) 0.06 1.0

RM = Reference Method (CleanAir Data)

081513 153619

CEMS = Continuous Emissions Monitoring System (Marathon Petroleum Company Data)

RATA calculations are based on 9 of 10 runs. * indicates the excluded run.



RESULTS

**Table 2-5:
CCR Heater Stack – NO_x Relative Accuracy (USEPA M-7E / PS2)**

Run No.	Start Time	Date (2013)	RM Data (ppmdv)	CEMS Data (ppmdv)	Difference (ppmdv)	Difference Percent
1	09:12	Aug 7	18.76	18.15	0.61	3.2%
2	09:47	Aug 7	18.59	18.27	0.33	1.8%
3	10:20	Aug 7	18.69	18.64	0.06	0.3%
4	10:55	Aug 7	19.05	18.83	0.21	1.1%
5	11:31	Aug 7	18.71	18.53	0.18	0.9%
6	12:02	Aug 7	18.79	18.04	0.75	4.0%
7	12:34	Aug 7	18.87	18.28	0.59	3.2%
8 *	13:03	Aug 7	18.71	17.79	0.92	4.9%
9	13:33	Aug 7	18.77	18.52	0.25	1.3%
10	14:03	Aug 7	18.96	18.07	0.89	4.7%
Average			18.80	18.37	0.43	2.3%

Relative Accuracy Test Audit Results


Standard Deviation of Differences	0.288	
Confidence Coefficient (CC)	0.221	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	3.5%	Limit 20.0%

RM = Reference Method (CleanAir Data)

082113 092306

CEMS = Continuous Emissions Monitoring System (Marathon Petroleum Company Data)

RATA calculations are based on 9 of 10 runs. * indicates the excluded run.



RECEIVED
DEC 13 2013
AIR QUALITY DIV.

RESULTS

2-7

**Table 2-6:
CCR Heater Stack – NO_x Emissions (USEPA M-7E)**

Run No.		1	2	3	4	5	6
Date (2013)		Aug 7	Aug 7	Aug 7	Aug 7	Aug 7	Aug 7
Start Time (approx.)		09:12	09:47	10:20	10:55	11:31	12:02
Stop Time (approx.)		09:33	10:08	10:41	11:16	11:52	12:23
Process Conditions							
P ₁	Fuel gas flow rate (Mscf/day)	2,462	2,458	2,432	2,412	2,421	2,411
P ₂	Feed to charge heater (BPD)	18,995	19,008	18,994	18,993	19,009	18,999
F _d	Oxygen-based F-factor (dscf/MMBtu)	8,328	8,328	8,328	8,328	8,328	8,328
H _i	Actual heat input (MMBtu/hr)	115.	115.	114.	113.	114.	113.
Gas Conditions							
O ₂	Oxygen (dry volume %)	4.4	4.3	4.5	4.4	4.4	4.6
Nitrogen Oxides Results							
C _{sd}	Concentration (ppmdv)	18.8	18.6	18.7	19.0	18.7	18.8
C _{sd}	Concentration (lb/dscf)	2.24E-06	2.22E-06	2.23E-06	2.27E-06	2.23E-06	2.24E-06
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	0.0236	0.0233	0.0236	0.0240	0.0236	0.0240

RESULTS**Table 2-6 (Continued):
CCR Heater Stack – NO_x Emissions (USEPA M-7E)**

Run No.		7	8	9	10	Average
Date (2013)		Aug 7	Aug 7	Aug 7	Aug 7	
Start Time (approx.)		12:34	13:03	13:33	14:03	
Stop Time (approx.)		12:55	13:24	13:54	14:24	
Process Conditions						
P ₁	Fuel gas flow rate (Mscf/day)	2,383	2,391	2,348	2,323	2,404
P ₂	Feed to charge heater (BPD)	19,000	19,004	19,000	19,003	19,000
F _d	Oxygen-based F-factor (dscf/MMBtu)	8,328	8,328	8,328	8,328	8,328
H _i	Actual heat input (MMBtu/hr)	112.	112.	110.	109.	113.
Gas Conditions						
O ₂	Oxygen (dry volume %)	4.4	4.3	4.3	4.3	4.4
Nitrogen Oxides Results						
C _{sd}	Concentration (ppm _{dv})	18.9	18.7	18.8	19.0	18.8
C _{sd}	Concentration (lb/dscf)	2.25E-06	2.23E-06	2.24E-06	2.26E-06	2.24E-06
E _{Fd}	Emission Rate - F _d -based (lb/MMBtu)	0.0238	0.0234	0.0235	0.0237	0.0237

Average includes 10 runs.

080410 154528

End of Section 2 – Results

DESCRIPTION OF INSTALLATION

3-1

PROCESS DESCRIPTION

MPC's facility in Detroit, Michigan, produces refined petroleum products from crude oil. As part of the Detroit Heavy Oil Upgrade Project (DHOUP), new equipment is being installed to process heavy crude oil from Canada. As a condition of proceeding with the DHOUP, MPC must demonstrate that select process units are in compliance with permitted emission limits.

The Continuous Catalytic Regeneration Platformer Unit (EG14-CCRPLATFORMER) is a catalytic reformer that rearranges the structure of low octane naphtha feed into higher-octane reformates. Hydrogen is produced as a product of the reaction and is used in other refinery processes.

The CCR Heater (EG14-CCRPLCHARHTR) preheats the feed to the reactor. The unit is fired by refinery fuel gas. Emissions are vented to the atmosphere via the CCR Heater Stack (SV14-H6).

The CCR Interheater (EG14-CCRPLINTHTR) heats the intermediate reformate reactants prior to their re-entry into the multi-staged reactor system. The unit is fired by refinery fuel gas. Emissions are vented to the atmosphere via the CCR Interheater Stack (SV14-H4A).

The testing reported in this document was performed at the CCR Interheater Stack and CCR Heater Stack.

DESCRIPTION OF SAMPLING LOCATIONS

Sampling point locations were determined according to USEPA Performance Specification 2.

Table 3-1 outlines the sampling point configurations. The figures shown on pages 3-2 and 3-3 illustrate the sampling points and orientation of sampling ports.


**Table 3-1:
Sampling Points**

Source Constituent	Method (USEPA)	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
CCR Interheater Stack O ₂ / NO _x	M-3A+PS3 / 7E+PS2	1-10	1	3	7	21	3-1
CCR Heater Stack O ₂ / NO _x	M-3A+PS3 / 7E+PS2	1-10	1	3	7	21	3-2

RECEIVED
DEC 13 2013
AIR QUALITY DIV.

DESCRIPTION OF INSTALLATION

3-2




<u>Sampling Point</u>	<u>Port to Point Distance (in.)</u>
1	55.0
2	33.0
3	11.0

Duct diameters upstream from flow disturbance (A): 13.1 Limit: 0.5
 Duct diameters downstream from flow disturbance (B): 3.6 Limit: 2.0

Figure 3-1: CCR Interheater Sampling Points - RATA

DESCRIPTION OF INSTALLATION

3-3



<u>Sampling Point</u>	<u>Port to Point Distance (in.)</u>
1	75.0
2	45.0
3	15.0

Duct diameters upstream from flow disturbance (A):	>0.9	Limit: 0.5
Duct diameters downstream from flow disturbance (B):	3.6	Limit: 2.0

Figure 3-2: CCR Heater Sampling Points – RATA

End of Section 3 – Description of Installation

METHODOLOGY

4-1

Clean Air Engineering followed procedures as detailed in USEPA Methods 3A, 7E, 19 and Performance Specifications 2 and 3. The following table summarizes the methods and their respective sources.

**Table 4-1:
Summary of Sampling Procedures**

Title 40 CFR Part 60 Appendix A

Method 3A	"Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)"
Method 7E	"Determination of Nitrogen Oxides Emissions from Stationary Sources (Instrumental Analyzer Procedure)"
Method 19	"Determination of Sulfur Dioxide Removal Efficiency and Particulate Matter, Sulfur Dioxide, and Nitrogen Oxide Emission Rates"

Title 40 CFR Part 60 Appendix B (Performance Specifications (PS))

PS2	"Specifications and Test Procedures for SO ₂ and NO _x Continuous Emission Monitoring Systems in Stationary Sources"
PS3	"Specifications and Test Procedures for O ₂ and CO ₂ Continuous Emission Monitoring Systems in Stationary Sources"

These methods appear in detail in Title 40 of the Code of Federal Regulations (CFR) and are located on the internet at <http://ecfr.gpoaccess.gov>.

Diagrams of the sampling apparatus and major specifications of the sampling, recovery and analytical procedures are summarized for each method in Appendix A.

CleanAir followed specific quality assurance and quality control (QA/QC) procedures as outlined in the individual methods and as prescribed in CleanAir's internal Quality Manual. Results of all QA/QC activities performed by CleanAir are summarized in Appendix D.

RECEIVED
DEC 13 2013
AIR QUALITY DIV.

METHODOLOGY

4-2

O₂, CO₂ and NO_x Emissions / RATA Testing - USEPA Methods 3A and 7E; Performance Specifications 2 and 3

Reference method O₂ and CO₂ emissions were determined using a paramagnetic/NDIR CEMs analyzer per EPA Method 3A and Performance Specification 3. Reference method NO_x emissions were determined using a chemiluminescent CEMs analyzer per EPA Method 7E and Performance Specification 2.

The sampling system consisted of a heated probe, heated filter, and heated sample line. Flue gas was extracted at a constant rate at the points specified by Performance Specification 2 and delivered at 250°F to a gas conditioner which removed moisture. The flue gas was then delivered via a flow panel to an analyzer bank. Each analyzer measured concentration on a dry basis (units of %dv or ppmdv).

Calibration error checks were performed by introducing zero nitrogen (N₂), high-range and mid-range calibration gases to the inlet of each analyzer during calibration error checks. Bias checks were performed before and after each sampling run by introducing calibration gas to the inlet of the sampling system's heated filter. Per M-3A and 7E, the average results for each run were drift-corrected. Documentation of interference checks and NO₂ converter efficiency checks are included in Appendix D.

End of Section 4 – Methodology