



Marathon Petroleum Company LP  
1001 Oakwood  
Detroit, MI 48217

**RECEIVED**

OCT 31 2016

**AIR QUALITY DIV.**

---

**REPORT ON COMPLIANCE TESTING**

Performed for:  
**MARATHON PETROLEUM COMPANY LP  
DETROIT REFINERY**

**FCCU REGENERATOR STACK (SVFCCU)**


Client Reference No: 4100665755  
CleanAir Project No: 12993-2  
Revision 0: October 27, 2016


---

To the best of our knowledge, the data presented in this report are accurate, complete, error free, legible and representative of the actual emissions during the test program. Clean Air Engineering operates in conformance with the requirements of ASTM D7036-04 Standard Practice for Competence of Air Emission Testing Bodies.

Submitted by,

Reviewed by,

  
Andy Obuchowski  
Midwest Engineering Group Leader  
aobuchowski@cleanair.com  
(800) 627-0033 ext. 4537

  
Scott Brown  
Quality Director  
sbrown@cleanair.com  
(800) 627-0033 ext. 4544



## PROJECT OVERVIEW

1-1

### INTRODUCTION

Marathon Petroleum Company LP (MPC) contracted Clean Air Engineering (CleanAir) to perform emission measurements at the Detroit Refinery for compliance purposes.

All testing was conducted in accordance with the regulations set-forth by the United States Environmental Protection Agency (USEPA) and the Michigan Department of Environmental Quality (DEQ). The permit limits are referenced in Michigan Department of Environmental Quality, Air Quality Division Permit to Install No. 63-08E, issued June 10, 2016.

### Key Project Participants

Individuals responsible for coordinating and conducting the test program were:

Crystal Davis – MPC  
Joe Reidy – MPC  
Thomas Gasloli – Michigan DEQ  
Ken Sullivan – CleanAir

### Test Program Parameters

The testing was performed at the FCCU Regenerator Stack (Emission Unit ID No. EU11-FCCU-S1; Stack ID No. SVFCCU) on August 30 - September 1, 2016, and included the following emissions measurements:

- particulate matter (PM), assumed equivalent to non-sulfate filterable particulate matter (NSFPM)
- total particulate matter less than or equal to 10 microns ( $\mu\text{m}$ ) in diameter (Total  $\text{PM}_{10}$ ), assumed equivalent to the sum of the following constituents:
  - non-sulfate filterable particulate matter (NSFPM)
  - condensable particulate matter (CPM)
- ammonia ( $\text{NH}_3$ )
- flue gas composition (e.g.,  $\text{O}_2$ ,  $\text{CO}_2$ ,  $\text{H}_2\text{O}$ )
- flue gas flow rate
- flue gas velocity decay (wall effects)

**RECEIVED**  
OCT 31 2016  
AIR QUALITY DIV.

**PROJECT OVERVIEW**

1-2

**TEST PROGRAM SYNOPSIS****Test Schedule**

The on-site schedule followed during the test program is outlined in Table 1-1.

**Table 1-1:  
Schedule of Activities**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	FCCU Regenerator Stack	USEPA CTM-027	NH <sub>3</sub>	08/30/16	10:45	11:57
2	FCCU Regenerator Stack	USEPA CTM-027	NH <sub>3</sub>	08/30/16	13:56	15:06
1	FCCU Regenerator Stack	USEPA Method 5F/202	NSFPM/CPM	08/30/16	10:45	11:57
2	FCCU Regenerator Stack	USEPA Method 5F/202	NSFPM/CPM	08/30/16	13:56	15:06
3	FCCU Regenerator Stack	USEPA Method 5F/202	NSFPM/CPM	08/31/16	08:35	09:48
4	FCCU Regenerator Stack	USEPA Method 5F/202	NSFPM/CPM	08/31/16	10:43	11:50
5	FCCU Regenerator Stack	USEPA Method 5F/202	NSFPM/CPM	08/31/16	15:26	16:33
6	FCCU Regenerator Stack	USEPA Method 5F/202	NSFPM/CPM	08/31/16	17:38	18:45
7	FCCU Regenerator Stack	USEPA Method 5F/202	NSFPM/CPM	08/31/16	19:23	00:00
8	FCCU Regenerator Stack	USEPA Method 5F/202	NSFPM/CPM	09/01/16	11:42	12:51
1	FCCU Regenerator Stack	USEPA Method 2H	Wall Effects	08/30/16	08:10	08:38
1	FCCU Regenerator Stack	USEPA Method 2F	3-D Velocity & Flow Rate	08/30/16	08:47	09:11
2	FCCU Regenerator Stack	USEPA Method 2F	3-D Velocity & Flow Rate	08/30/16	12:48	13:15
3	FCCU Regenerator Stack	USEPA Method 2F	3-D Velocity & Flow Rate	08/30/16	15:44	16:09
4	FCCU Regenerator Stack	USEPA Method 2F	3-D Velocity & Flow Rate	08/31/16	08:34	09:27
5	FCCU Regenerator Stack	USEPA Method 2F	3-D Velocity & Flow Rate	08/31/16	10:42	11:28
6	FCCU Regenerator Stack	USEPA Method 2F	3-D Velocity & Flow Rate	08/31/16	15:25	16:14
7	FCCU Regenerator Stack	USEPA Method 2F	3-D Velocity & Flow Rate	08/31/16	17:39	18:21
8	FCCU Regenerator Stack	USEPA Method 2F	3-D Velocity & Flow Rate	08/31/16	19:22	20:06
9	FCCU Regenerator Stack	USEPA Method 2F	3-D Velocity & Flow Rate	09/01/16	11:42	12:28

09 05 144047

**PROJECT OVERVIEW****Results Summary**

Tables 1-2 through 1-4 and Figures 1-1 through 1-3 summarize the results of the test program. A more detailed presentation of the test conditions and results of analysis are shown on pages 2-1 through 2-4.

**Table 1-2:  
Summary of NSFPM, CPM and Total PM<sub>10</sub> Results (USEPA 5F/202) Runs 1-4**

FCCU Regenerator Stack		NSFPM Rate (lb/Mlb coke)	CPM Rate (lb/Mlb coke)	Total PM <sub>10</sub> Rate (lb/Mlb coke)	
Test Dates: 8/30/16 & 8/31/16					
Coke Burn Rate (lb/hr)	24,469	Run 1	0.8	0.3	1.1
FCC Rate (bpd)	41,005	Run 2	0.8	0.3	1.1
Aqueous NH <sub>3</sub> Injection (lb/hr)	27.6	Run 3	0.8	0.3	1.1
ESP Operation	Both/LPR	Run 4	0.9	0.4	1.2
		Average	0.8	0.3	1.1
		Limit	0.8		1.1

Note: Average includes 4 runs for all parameters.

10/27/2016 12:26

**Table 1-3:  
Summary of NSFPM, CPM and Total PM<sub>10</sub> Results (USEPA 5F/202) Runs 5-8**

FCCU Regenerator Stack		NSFPM Rate (lb/Mlb coke)	CPM Rate (lb/Mlb coke)	Total PM <sub>10</sub> Rate (lb/Mlb coke)	
Test Dates: 8/31/16 & 9/1/16					
Coke Burn Rate (lb/hr)	23,536	Run 5	0.8	0.5	1.3
FCC Rate (bpd)	40,998	Run 6	0.7	0.3	1.0
Aqueous NH <sub>3</sub> Injection (lb/hr)	29.3	Run 7	0.8		
ESP Operation	Both/LPR	Run 8	0.8	0.3	1.1
		Average	0.8	0.4	1.1
		Limit	0.8		1.1

Note: Average includes 4 Runs for NSFPM, and 3 Runs for CPM & Total PM<sub>10</sub>.

9/16/2016 14:47

**Table 1-4:  
Summary of NH<sub>3</sub> Results (USEPA CTM-027) Run 1-2**

FCCU Regenerator Stack		NH <sub>3</sub> Conc. (ppmdv)	NH <sub>3</sub> Slip (lb/hr)	NH <sub>3</sub> Slip (lb/Mlb coke)	
Test Dates: 8/30/16					
Coke Burn Rate (lb/hr)	24,469	Run 1	7.9	1.6	0.064
FCC Rate (bpd)	41,005	Run 2	7.6	1.5	0.061
Aqueous NH <sub>3</sub> Injection (lb/hr)	27.6				
ESP Operation	Both/LPR	Average	7.8	1.5	0.063

Note: Average includes 2 runs for all parameters.

10/27/2016 12:26

**PROJECT OVERVIEW**




Figure 1-1: NSFPM, CPM and Total PM<sub>10</sub> Results Runs 1-4





Figure 1-2: NSFPM, CPM and Total PM<sub>10</sub> Results Runs 5-8

**PROJECT OVERVIEW**

1-5

Figure 1-3: CPM and NH<sub>3</sub> Results**Discussion of Test Program****Flow Rate Measurements**

A wall-effects adjustment factor (WAF) was determined per Method 2H prior to the start of the first test run.

3-D flow traverses per Method 2F were performed before and after each Method 5F/202 test run for Runs 1 and 2 based on port availability. 3-D flow traverses per Method 2F were performed during each Method 5F/202 test run for Runs 3-8 based on port availability.

**NSFPM and CPM Testing - USEPA Method 5F/202**

For this test program, PM emission rate is assumed equivalent to NSFPM emission rate and PM<sub>10</sub> emission rate is assumed equivalent to the sum of NSFPM and CPM emission rates (units of lb/hr, Ton/yr, or lb/Mlb coke for all constituents). For emissions inventory purposes, MPC applies a correction factor to NSFPM to eliminate particles with a diameter less than 10 microns. Application of that correction factor is not included in this test report.

**PROJECT OVERVIEW**

1-6

Based on the preliminary results of the first three Method 5F/202 test runs MPC requested a fourth run to be performed. Four (4) 60- minute test runs were performed with the unit operating at “condition 1” on August 30-31, 2016.

MPC requested an additional set of Method 5F/202 testing with the unit operating at “condition 2”. Runs 5 through 7 were completed on August 31, 2016. Following Run 7 the condenser and first impinger were cracked during the recovery process. The Method 5F portion of Run 7 remained intact, however the 202 portion was considered invalid. The Method 202 portion of the sample train was recovered to the extent possible, however a post test purge could not be performed. The Method 202 samples for Run 7 were not analyzed. A fourth test run (Run 8) was performed on September 1, 2016, at “condition 2”. Four (4) 60- minute test runs were performed with the unit operating at “condition 2” on August 31 - September 1, 2016.

Upon reporting it was noticed that the measured total liquid volume collected during Run 3 was significantly higher than the other test runs and the expected amount. CleanAir believes that there was an error in measuring and recording this liquid volume following the test run. The moisture utilized during the following test run (Run 4) was utilized for Run 3 result calculations.

The analytical procedures in EPA Method 202 include an ammonium titration of the inorganic sample fractions with pH less than 7.0 to neutralize acids with hygroscopic properties such as H<sub>2</sub>SO<sub>4</sub> that may be present in the sample. This step speeds up the sample desiccation process and allows the samples to come to a constant weight prior to weighing. The weight of ammonium added to the sample as a result of the titration is subtracted from the analytical result.

The laboratory performing the gravimetric analysis (Clean Air Analytical Services) has determined that only samples with an initial pH less than 4.5 require a significant amount of ammonium neutralization, resulting in a correction in excess of 0.5 mg. Based on this observation, the laboratory has altered their procedures. Only samples with a pH lower than 4.5 are titrated.

All of the inorganic sample fractions analyzed from Runs 1 through 8 had a pH less than 4.5 and were titrated. The field train reagent blanks had a pH above 4.5 and were not titrated. The sample fractions were observed to come to a constant weight without having to titrate the sample.



## PROJECT OVERVIEW

1-7

### *NH<sub>3</sub> Testing – USEPA CTM-027 - Stack*

Two (2) 60-minute CTM-027 test runs were performed on August 30, 2016. Each test run was performed concurrently with Method 5F/202 testing.

### *Calculation of Final Results*

Sample flow rates as determined by EPA Method 2 without the WEF corrections factor were used to calculate isokinetic sampling conditions.

Mass-based emission rates in units of pounds per hour (lb/hr) for Method 5F/202 and CTM-027 were calculated using the applicable average (pre-run and post run) or concurrent flow rate determined by Method 2F combined with the respective WEF correction factor.

Emission rates in units of tons per year (Ton/yr) were calculated using an assumed capacity factor of 8,760 operating hours per year. Emission rates in units of pounds per 1,000 pounds of coke burn (lb/Mlb coke) were calculated using coke burn rate data provided by MPC.

Ammonia (NH<sub>3</sub>) injection rates shown in Tables 2-1 through 2-4 are the aqueous ammonia, (11FC2032), times 0.2.

---

*End of Section 1 – Project Overview*

**RESULTS****Table 2-1:  
NSFPM, CPM and Total PM<sub>10</sub> (USEPA 5F/202) – Runs 1-4**

Run No.		1	2	3	4	Average
Date (2016)		Aug 30	Aug 30	Aug 31	Aug 31	
Start Time (approx.)		10:45	13:56	08:35	10:43	
Stop Time (approx.)		11:57	15:06	09:48	11:50	
<b>Process Conditions</b>						
R <sub>P</sub>	Production rate (lb coke/hr)	24,514	24,371	24,498	24,493	24,469
P <sub>1</sub>	FCC charge rate (bpd)	41,007	41,008	41,004	40,999	41,005
P <sub>2</sub>	NH <sub>3</sub> Injection (lb/hr)	5.47	5.47	5.53	5.58	5.51
P <sub>3</sub>	ESP Operation	Both/LPR	Both/LPR	Both/LPR	Both/LPR	
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>						
O <sub>2</sub>	Oxygen (dry volume %)	1.5	0.9	1.4	1.3	1.3
CO <sub>2</sub>	Carbon dioxide (dry volume %)	15.9	16.6	16.7	16.8	16.5
T <sub>s</sub>	Sample temperature (°F)	533	534	532	530	532
B <sub>w</sub>	Actual water vapor in gas (% by volume) <sup>1</sup>	9.4	10.4	11.7	11.7	10.8
<b>Gas Flow Rate<sup>2</sup></b>						
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	155,000	156,000	151,000	154,000	154,000
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	82,500	82,700	80,800	84,800	82,700
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	74,800	74,100	71,300	74,800	73,800
<b>Sampling Data</b>						
V <sub>mstd</sub>	Volume metered, standard (dscf)	38.20	38.36	38.37	38.79	38.43
%I	Isokinetic sampling (%) <sup>3</sup>	96.4	99.1	100.9	100.6	99.2
<b>Laboratory Data</b>						
m <sub>n</sub>	Total NSFPM (g)	0.07624	0.07634	0.08319	0.08357	
m <sub>CPM</sub>	Total CPM (g)	0.02680	0.02777	0.02600	0.03410	
m <sub>part</sub>	Total particulate (expressed as PM-10) (g)	0.10304	0.10412	0.10919	0.11767	
DLC	Detection level classification	ADL	ADL	ADL	ADL	
<b>NSFPM Results</b>						
C <sub>sd</sub>	Particulate Concentration (lb/dscf)	4.4E-06	4.4E-06	4.8E-06	4.8E-06	4.6E-06
E <sub>lb/hr</sub>	Particulate Rate (lb/hr)	20	20	20	21	20
E <sub>T/yr</sub>	Particulate Rate (Ton/yr)	86	85	90	93	89
E <sub>Rp</sub>	Particulate Rate - Production-based (lb/Mlb coke)	0.8	0.8	0.8	0.9	0.8
<b>CPM Results</b>						
C <sub>sd</sub>	Particulate Concentration (lb/dscf)	1.5E-06	1.6E-06	1.5E-06	1.9E-06	1.6E-06
E <sub>lb/hr</sub>	Particulate Rate (lb/hr)	6.9	7.1	6.4	8.7	7.3
E <sub>T/yr</sub>	Particulate Rate (Ton/yr)	30	31	28	38	32
E <sub>Rp</sub>	Particulate Rate - Production-based (lb/Mlb coke)	0.3	0.3	0.3	0.4	0.3
<b>Total Particulate (as PM10) Results</b>						
C <sub>sd</sub>	Particulate Concentration (lb/dscf)	5.9E-06	6.0E-06	6.3E-06	6.7E-06	6.2E-06
E <sub>lb/hr</sub>	Particulate Rate (lb/hr)	27	27	27	30	28
E <sub>T/yr</sub>	Particulate Rate (Ton/yr)	117	117	118	132	121
E <sub>Rp</sub>	Particulate Rate - Production-based (lb/Mlb coke)	1.1	1.1	1.1	1.2	1.1

Average includes 4 runs.

Detection level classifications are defined as follows:

102716 122836

ADL = Above Detection Level - all fractions are above detection limit

<sup>1</sup> The moisture results from Run 4 were utilized for Run 3.<sup>2</sup> Gas flow rates obtained from bracketing or concurrent Method 2F test runs combined with the WAF determined by Method 2H.<sup>3</sup> Sample flow rates as determined by EPA Method 2 were used to calculate isokinetic sampling conditions.

**RESULTS****Table 2-2:  
NSFPM, CPM and Total PM<sub>10</sub> (USEPA 5F/202) – Runs 5-8**

Run No.		5	6	7*	8	Average
Date (2016)		Aug 31	Aug 31	Aug 31	Sep 1	
Start Time (approx.)		15:26	17:38	19:23	11:42	
Stop Time (approx.)		16:33	18:45	20:29	12:51	
<b>Process Conditions</b>						
R <sub>p</sub>	Production rate (lb coke/hr)	23,512	23,492	23,435	23,605	23,536
P <sub>1</sub>	FCC charge rate (bpd)	40,997	41,010	41,005	40,986	40,998
P <sub>2</sub>	NH <sub>3</sub> Injection (lb/hr)	5.97	6.03	5.94	5.59	5.86
P <sub>3</sub>	ESP Operation	Both/LPR	Both/LPR	Both/LPR	Both/LPR	
Cap	Capacity factor (hours/year)	8,760	8,760	8,760	8,760	8,760
<b>Gas Conditions</b>						
O <sub>2</sub>	Oxygen (dry volume %)	1.9	1.7	2.1	2.0	1.9
CO <sub>2</sub>	Carbon dioxide (dry volume %)	16.1	16.5	16.1	16.2	16.3
T <sub>s</sub>	Sample temperature (°F)	526	526	525	525	525
B <sub>w</sub>	Actual water vapor in gas (% by volume)	11.1	11.0	11.1	10.1	10.7
<b>Gas Flow Rate<sup>1</sup></b>						
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	148,000	151,000	144,000	146,000	148,000
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	83,900	82,500	85,600	83,500	83,300
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	74,600	73,500	76,100	75,100	74,400
<b>Sampling Data</b>						
V <sub>mstd</sub>	Volume metered, standard (dscf)	37.73	37.46	38.28	38.75	37.98
%I	Isokinetic sampling (%) <sup>2</sup>	100.5	100.8	101.2	101.1	100.8
<b>Laboratory Data</b>						
m <sub>n</sub>	Total NSFPM (g)	0.06947	0.06450	0.06850	0.07270	
m <sub>CPM</sub>	Total CPM (g)	0.04804	0.02671		0.02922	
m <sub>Part</sub>	Total particulate (expressed as PM-10) (g)	0.11751	0.09122		0.10191	
DLC	Detection level classification	ADL	ADL	ADL	ADL	
<b>NSFPM Results</b>						
C <sub>sd</sub>	Particulate Concentration (lb/dscf)	4.1E-06	3.8E-06	3.9E-06	4.1E-06	4.0E-06
E <sub>lb/hr</sub>	Particulate Rate (lb/hr)	18	17	18	19	18
E <sub>T/yr</sub>	Particulate Rate (Ton/yr)	80	73	79	82	78
E <sub>Rp</sub>	Particulate Rate - Production-based (lb/Mlb coke)	0.8	0.7	0.8	0.8	0.8
<b>CPM Results</b>						
C <sub>sd</sub>	Particulate Concentration (lb/dscf)	2.8E-06	1.6E-06		1.7E-06	2.0E-06
E <sub>lb/hr</sub>	Particulate Rate (lb/hr)	13	6.9		7.5	9.0
E <sub>T/yr</sub>	Particulate Rate (Ton/yr)	55	30		33	39
E <sub>Rp</sub>	Particulate Rate - Production-based (lb/Mlb coke)	0.5	0.3		0.3	0.4
<b>Total Particulate (as PM10) Results</b>						
C <sub>sd</sub>	Particulate Concentration (lb/dscf)	6.9E-06	5.4E-06		5.8E-06	6.0E-06
E <sub>lb/hr</sub>	Particulate Rate (lb/hr)	31	24		26	27
E <sub>T/yr</sub>	Particulate Rate (Ton/yr)	135	104		114	118
E <sub>Rp</sub>	Particulate Rate - Production-based (lb/Mlb coke)	1.3	1.0		1.1	1.1

Average includes 3 runs. \* indicates that the run is not included in the average.

Detection level classifications are defined as follows:

102716 122828

ADL = Above Detection Level - all fractions are above detection limit

<sup>1</sup> Gas flow rates obtained from concurrent Method 2F test runs combined with the WAF determined by Method 2H.<sup>2</sup> Sample flow rates as determined by EPA Method 2 were used to calculate isokinetic sampling conditions.

**RESULTS**

2-3

**Table 2-3:  
Uncertainty Analysis – NSFPM, CPM and Total PM<sub>10</sub> – Runs 1-4**

Method	NSFPM Results (lb/Mlb coke)		CPM Results (lb/Mlb coke)		Total PM (as PM <sub>10</sub> ) Results (lb/Mlb coke)	
	Run No.	5F	Run No.	202	Run No.	5F/202
	1	0.805	1	0.283	1	1.088
	2	0.800	2	0.291	2	1.091
	3	0.835	3	0.261	3	1.097
	4	0.871	4	0.355	4	1.226
<b>SD</b>		0.0324		0.0404		0.0669
<b>AVG</b>		<b>0.828</b>		<b>0.298</b>		<b>1.126</b>
<b>RSD</b>		3.9%		13.6%		5.9%
<b>N</b>		4		4		4
<b>SE</b>		0.0162		0.0202		0.0335
<b>RSE</b>		2.0%		6.8%		3.0%
<b>P</b>		95.0%		95.0%		95.0%
<b>TINV</b>		3.18		3.18		3.18
<b>CI +</b>		0.879		0.362		1.232
<b>AVG</b>		<b>0.828</b>		<b>0.298</b>		<b>1.126</b>
<b>CI -</b>		0.776		0.233		1.019
<b>TB +</b>		0.995		0.506		1.47

AVG (average) is the mean value of the runs; N is the number of individual runs.

SD (standard deviation) and RSD (relative standard deviation) are measures of the variability of individual runs.

SE (standard error) and RSE (relative standard error) are measures of the variability of the average of the runs.

P (probability) is the confidence level associated with the two-tailed Student's t-distribution.

TINV (t-value) is the value of the Student's t-distribution as a function of P (probability) and N-1 (degrees of freedom).

CI (confidence interval) indicates that if the test is conducted again under the same conditions, the average would be expected to fall within the interval (CI- to CI+) about 95% of the time.

TB+ (upper tolerance bound) is the value below which 95% of future runs are expected to fall (assuming testing at the same conditions).

**RESULTS****Table 2-4:  
NH<sub>3</sub> (USEPA CTM-027) – Runs 1-2**

Run No.		1	2	Average
Date (2016)		Aug 30	Aug 30	
Start Time (approx.)		10:45	13:56	
Stop Time (approx.)		11:57	15:06	
<b>Process Conditions</b>				
RP	Coke burn-off rate (lb coke/hr)	24,514	24,371	24,443
P <sub>1</sub>	FCC charge rate (bpd)	41,000	41,000	41,000
P <sub>2</sub>	ESP operation	Both/LPR	Both/LPR	
P <sub>3</sub>	NH <sub>3</sub> injection (lb/hr)	5.47	5.47	5.47
Cap	Capacity factor (hours/year)	8,760	8,760	8,760
<b>Gas Conditions</b>				
O <sub>2</sub>	Oxygen (dry volume %)	1.0	0.6	0.8
CO <sub>2</sub>	Carbon dioxide (dry volume %)	16.5	16.8	16.7
T <sub>s</sub>	Sample temperature (°F)	531	532	532
B <sub>w</sub>	Actual water vapor in gas (% by volume)	11.7	11.5	11.6
<b>Gas Flow Rate<sup>1</sup></b>				
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	155,000	156,000	156,000
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	82,500	82,700	82,600
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	74,800	74,100	74,500
<b>Sampling Data</b>				
V <sub>mstd</sub>	Volume metered, standard (dscf)	39.69	40.99	40.34
%I	Isokinetic sampling (%) <sup>2</sup>	96.1	99.7	97.9
<b>Laboratory Data</b>				
m <sub>n</sub>	Total NH <sub>3</sub> collected (mg)	6.31537	6.21117	
<b>Ammonia (NH<sub>3</sub>) Results</b>				
C <sub>sd</sub>	Ammonia Concentration (lb/dscf)	3.51E-07	3.34E-07	3.42E-07
C <sub>sd</sub>	Ammonia Concentration (ppmdv)	7.94	7.56	7.75
E <sub>lb/hr</sub>	Ammonia Rate (lb/hr)	1.57	1.49	1.53
E <sub>T/yr</sub>	Ammonia Rate (Ton/yr)	6.90	6.51	6.70
E <sub>Rp</sub>	Ammonia Rate - Production-based (lb/Mlb coke)	0.0642	0.0609	0.0626

Average includes 2 runs.

091616 144047

<sup>1</sup> Gas flow rates obtained from concurrent Method 2F test runs combined with the WAF determined by Method 2H.<sup>2</sup> Sample flow rates as determined by EPA Method 2 were used to calculate isokinetic sampling conditions.*End of Section 2 – Results*

**DESCRIPTION OF INSTALLATION**

3-1

**PROCESS DESCRIPTION**

MPC's facility in Detroit, Michigan, produces refined petroleum products from crude oil. MPC must continue to demonstrate that select process units are in compliance with permitted emission limits.

The Fluid Catalytic Cracking Unit (EU11-FCCU-S1) utilizes a primary reactor, a distillation column and a catalyst regeneration unit to continuously generate light hydrocarbon products from heavy oil feeds. The FCCU is equipped with an ESP with two (2) bays and variable aqueous NH<sub>3</sub> injection to control emissions. Emissions are vented to the atmosphere via the FCCU Regenerator Stack (SVFCCU).

The testing described in this document was performed at the FCCU Regenerator Stack.

**DESCRIPTION OF SAMPLING LOCATIONS**

Sampling point locations were determined according to USEPA Method 1 and 2H.

Table 3-1 outlines the sampling point configurations. The figures shown on pages 3-2 and 3-3 illustrate the sampling points and orientation of sampling ports.


**Table 3-1:  
Sampling Points**

<u>Source</u> Constituent	Method	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
<u>FCCU Regenerator Stack</u>							
Flow Rate	USEPA 2F	1-9	2	12	varied	varied	3-1
Velocity Decay	USEPA 2H	1	2	6	varied	varied	3-2
NSFPM / CPM	USEPA 5F / 202	1-8	2	12	2.5	60	3-1
NH <sub>3</sub>	USEPA CTM-027	1-2	2	12	2.5	60	3-1

100716 161227

**DESCRIPTION OF INSTALLATION**

3-2




Note: Ports on the lower plane were used for these points.

<u>Traverse Point</u>	<u>Port to Point Distance (in.)</u>
1	80.5
2	76.7
3	72.5
4	67.7
5	61.7
6	53.0
7	29.3
8	20.6
9	14.6
10	9.7
11	5.5
12	1.7

Duct diameters upstream from flow disturbance (A):	2.2	Limit: 0.5
Duct diameters downstream from flow disturbance (B):	3.4	Limit: 2.0

**Figure 3-1: USEPA Method 2F, 5F/202 and CTM-027 Traverse/Sampling Points**

**DESCRIPTION OF INSTALLATION**



Note: Ports on the lower plane were used for these points.

<u>Traverse Point</u>	<u>Port to Point Distance (in.)</u>
1	81.25
2	80.25
3	79.25
4	3.0
5	2.0
6	1.0

Duct diameters upstream from flow disturbance (A): 2.2 Limit: 0.5  
 Duct diameters downstream from flow disturbance (B): 3.4 Limit: 2.0

**Figure 3-2: USEPA Method 2H Traverse Points**

*End of Section 3 – Description of Installation*



**METHODOLOGY**

4-1

Clean Air Engineering followed procedures as detailed in USEPA Methods 1, 2, 2F, 2H, 3, 3A, 4, 5F, 202 and CTM-027. The following table summarizes the methods and their respective sources.

**Table 4-1:  
Summary of Sampling Procedures**

<u>Title 40 CFR Part 60 Appendix A</u>	
Method 1	"Sample and Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)"
Method 2F	"Determination of Stack Gas Velocity And Volumetric Flow Rate with Three-Dimensional Probes"
Method 2H	"Determination of Stack Gas Velocity Taking into Account Velocity Decay near the Stack Wall"
Method 3	"Gas Analysis for the Determination of Dry Molecular Weight"
Method 3A	"Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)"
Method 4	"Determination of Moisture Content in Stack Gases"
Method 5F	"Determination of Nonsulfate Particulate Matter Emissions from Stationary Sources"
<u>Title 40 CFR Part 51 Appendix M</u>	
Method 202	"Dry Impinger Method for Determining Condensable Particulate Emissions from Stationary Sources"
<u>Conditional Test Methods (CTM)</u>	
CTM-027	"Procedure for Collection and Analysis of Ammonia in Stationary Sources"

These methods appear in detail in Title 40 of the Code of Federal Regulations (CFR) and are located on the internet at <http://ecfr.gpoaccess.gov>.

Diagrams of the sampling apparatus and major specifications of the sampling, recovery and analytical procedures are summarized for each method in Appendix A.

CleanAir followed specific quality assurance and quality control (QA/QC) procedures as outlined in the individual methods and as prescribed in CleanAir's internal Quality Manual. Results of all QA/QC activities performed by CleanAir are summarized in Appendix D.

**METHODOLOGY**

4-2

*PM and PM<sub>10</sub> Testing - USEPA Method 5F/202*

PM and PM<sub>10</sub> emissions were determined using USEPA Method 5F/202.

- For this test program, PM is assumed equivalent to non-sulfate filterable particulate matter (NSFPM). Per 40 CFR Subpart Ja §60.104a, USEPA Method 5F is permitted for measuring front-half PM emissions from FCCUs.
- PM<sub>10</sub> is equivalent to the sum of filterable particulate matter less than 10 micrometers (µm) in diameter (FPM<sub>10</sub>) and condensable particulate matter (CPM). The Method 5F/202 sample train yields a front-half, non-sulfate FPM result and a back-half, CPM result. The total non-sulfate PM result (NSFPM plus CPM) from Method 5F/202 can be used as a worst-case estimation of Total PM<sub>10</sub> since Method 5F will collect all non-sulfate filterable particulate matter present in the flue gas (regardless of particle size).

The front-half (Method 5F portion) of the sampling train consisted of a glass nozzle, glass liner and filter holder heated to 320°F, and a quartz fiber filter heated to 320°F. Flue gas samples were extracted isokinetically; nozzle and probe liner recoveries were performed using de-ionized water (DI H<sub>2</sub>O) as the recovery solvent.

The back-half (Method 202 portion) of the sampling train is designed to mimic ambient conditions and collect only the particles that would truly form CPM in the atmosphere by minimizing the sulfur dioxide (SO<sub>2</sub>) and nitrogen oxide (NO<sub>x</sub>) interferences observed with earlier versions of the method, in which flue gas was bubbled through cold water and SO<sub>2</sub> and NO<sub>x</sub> were absorbed and partially oxidized before they could be purged out with nitrogen (N<sub>2</sub>).

Flue gas exiting the front-half heated filter passed through a coiled condenser and dry impinger system jacketed by water continually circulated at ambient temperature. Moisture was removed from the flue gas without bubbling through the condensed water. Flue gas then passed through a tetrafluoroethane (TFE) membrane filter at ambient temperature. The temperature of the flue gas at the exit of the filter was directly measured with an in-line thermocouple and maintained in the temperature range of 65 to 85°F.

After exiting the ambient filter, the flue gas passed through two (2) additional impingers surrounded by ice in a "cold" section of the impinger bucket. The moisture collected in these impingers was not analyzed for CPM and was only collected to determine the flue gas moisture and thoroughly dry the gas. The sample gas then flowed into a calibrated dry gas meter where the collected sample gas volume was determined.

**METHODOLOGY**

4-3

The front-half portion of the sample train (nozzle, probe and heated filter) was recovered per Method 5F requirements. The back-half of the sample train (heated filter outlet, condenser, dry impingers and TFE membrane filter) was recovered per Method 202 requirements. The impinger train was purged with nitrogen (N<sub>2</sub>) at a rate of 14 liters per minute (lpm) for one (1) hour following each test run and prior to recovery.

A field train blank was assembled, purged and recovered as if it were an actual test sample; analysis of the field train blank was used to blank-correct the test run results. Reagent blanks were also collected to quantify background contamination. All samples and blanks were returned to CleanAir Analytical Services for gravimetric analysis. Method 202 samples were maintained at a temperature < 85°F during transport to the laboratory.

*NH<sub>3</sub> Testing – USEPA CTM-027*

NH<sub>3</sub> emissions were determined using a CTM-027 and an isokinetic, multi-point sample train. The sampling system consisted of a glass nozzle, in-stack quartz filter, glass-lined heated probe, impinger train (for NH<sub>3</sub> collection and H<sub>2</sub>O removal and measurement) and a dry gas meter. The NH<sub>3</sub>-collecting impingers were charged with 0.1 N sulfuric acid (H<sub>2</sub>SO<sub>4</sub>) solution.

The sampling system traversed all of the Method 1 points during each run. A minimum volume of 0.9 dry standard cubic meters (dscm), or 31.8 dry standard cubic feet (dscf), were sampled during each sixty (60) minute run.

The sample train was recovered per CTM-027 requirements. The front-half assembly (components prior to the in-stack filter) was not recovered or analyzed, as gaseous NH<sub>3</sub> passed through without reacting or changing state. The three (3) NH<sub>3</sub>-collecting impingers were recovered separately per CTM-027 requirements. The back-half of the sample train prior to Impinger 1 (heated probe and connecting glassware) was rinsed into Impinger 1.

Samples from Runs 1 and 2 were analyzed by CleanAir Analytical Services using ion chromatography (IC) analysis.

## METHODOLOGY

4-4

### *General Considerations*

A traditional verification of the absence of cyclonic flow following Method 1 specifications was not performed. However, absence of cyclonic flow was demonstrated by measuring the resultant angle of flow during each Method 2F flow traverse which yielded less than 20° in all instances. Data is included in Appendix G.

H<sub>2</sub>O data used for moisture correction of concentration data was obtained (when required) for Method 5F/202 and CTM-027 by Method 4 measurements incorporated into the sampling and recovery procedures.

O<sub>2</sub>, CO<sub>2</sub>, H<sub>2</sub>O data used for Method 2H and Method 2F flow calculations was obtained from the most concurrently operated Method 5F/202 sample trains.

---

*End of Section 4 – Methodology*