

RECEIVED

AUG 01 2022

AIR QUALITY DIVISION



*Relative Accuracy Test Audit  
and Performance Testing*

*for*  
**Marathon Petroleum Company LP**

*at the*  
**Marathon Detroit Refinery in Detroit, MI**

*on the*  
**CCR Charge Heater (CCRPLCHARHTR)**  
**Unit: EU14-CCRPLCHARHTR-S1**  
**Permit No. MI-ROP-A9831-2012c**

*Prepared for:*



**Marathon  
Petroleum Company LP**

**Test Date: June 1, 2022**  
**Erthwrks Project No. 9049.1.B3**

*A9831-test\_20220601*



STACK TESTING ACCREDITATION COUNCIL



## Endorsement Page

This report was developed in accordance with the requirements designated in the applicable regulatory permit(s) and or regulatory rules. To the best of my knowledge the techniques, instrumentation, and calculations presented in this report will serve to accurately and efficiently detail the results of the test campaign requirements.

### Erthwrks, Inc.

Name: Jason Dunn

Title: QC Specialist


Signature: 

This report has been reviewed for accuracy and completeness. The actions presented in this report are, to the best of my knowledge, an accurate representation of the results and findings of the test campaign. Erthwrks, Inc. operates in conformance with the requirements on ASTM D7036-04 Standard Practice for Competence of Air Emission Testing Bodies and is accredited as such by the Stack Testing Accreditation Council (STAC) and the American Association for Laboratory Accreditation (A2LA).

### Erthwrks, Inc.

Name: Trey Chapman

Title: CEO

Signature: 



## Table of Contents

1.0	INTRODUCTION .....	4
1.1	Identification, location and dates of tests .....	4
1.2	Purpose of Testing.....	4
1.3	Description of Source.....	4
1.4	Contact Information .....	5
2.0	SUMMARY OF RESULTS .....	6
3.0	SOURCE DESCRIPTION.....	6
3.1	Description of the process .....	6
3.2	Applicable permit and source designation .....	7
3.3	Type and quantity of materials processed during tests .....	7
4.0	SAMPLING AND ANALYTICAL PROCEDURES.....	7
4.1	Gaseous Emissions – NO <sub>x</sub> , CO, O <sub>2</sub> , and CO <sub>2</sub> .....	7
4.2	Filterable Particulate Matter Sampling – EPA Method 5 .....	8
4.3	Condensable Particulate Matter Sampling – EPA Method 202.....	9
4.4	EPA Method CTM-013 (ALT-133 Analysis) H <sub>2</sub> SO <sub>4</sub> Determination .....	10
4.5	RATA Procedures .....	11
4.6	Discussion of sampling procedure or operational variances .....	12

### ATTACHMENTS

- A. Detailed Results of Emissions Test
- B. Quality Control Documentation
- C. Sampling Datasheets
- D. Example Calculations
- E. Raw Datalog Records
- F. Calibrations and Certifications
- G. CEMS Logs and Operational Data
- H. Laboratory Analysis

## **1.0 INTRODUCTION**

### **1.1 Identification, location and dates of tests**

Erthwrks, Inc. was contracted to conduct emission testing on the CCR Charge Heater (CCRPLCHARHTR) in operation at the Marathon Detroit Refinery, located in Detroit Michigan. The testing program was conducted on June 1, 2022.

### **1.2 Purpose of Testing**

The exhaust from Crude/Vac Heater Stack was sampled and analyzed to determine the relative accuracy of the associated carbon monoxide (CO), oxides of nitrogen (NOx), and oxygen (O<sub>2</sub>) continuous emissions monitoring system (CEMS) in accordance with the requirements in the Marathon Permit No. MI-ROP-A9831-2012c and the Title 40 CFR Part 60, Appendix F. In addition, compliance testing was conducted to determine the compliance status of the units' emission for sulfuric acid (H<sub>2</sub>SO<sub>4</sub>), and particulate matter (PM). The carbon dioxide (CO<sub>2</sub>) concentration was also measured in order to determine stack gas molecular weight.

### **1.3 Description of Source**

Marathon Petroleum Company LP operates the CCR Charge Heater designated as EU14-CCRPLCHARHTR-S1 in the refinery. This report addresses the RATA for the CEMS associated with the unit as well as the required compliance test for H<sub>2</sub>SO<sub>4</sub> and PM. Table 1.1 below details the CEMS analyzer information.

**Table 1.1—Marathon CCR Charge Heater Stack CEMS Details**

Crude/Vac Heater Stack CEMS	Manufacturer	Model No.	S/N	Install Date
NOx	ABB	Uras 26	3.345725.1	2012
CO	ABB	Uras 26	3.248567.4	2012
O <sub>2</sub>	ABB	Magnos 106	3.248610.4	2012

## 1.4 Contact Information

### **Marathon Petroleum Company LP**

Addie Koerner  
Michigan Refining Division  
330-479-5662 office  
419-306-5162 cell  
[akoerner@marathonpetroleum.com](mailto:akoerner@marathonpetroleum.com)

### **Erthwrks, Inc.**

John Wood  
Technical Director  
P.O. Box 150549  
Austin, TX 78745  
512-585-1685 office  
888-573-9994 fax  
[jwood@erthwrks.com](mailto:jwood@erthwrks.com)

### **Erthwrks, Inc.**

Jarrod Hoskinson  
Senior Project Manager  
P.O. Box 150549  
Austin, TX 78745  
512-994-7487 office  
888-573-9994 fax  
[jhoskinson@erthwrks.com](mailto:jhoskinson@erthwrks.com)

### **Erthwrks, Inc.**

Jason Dunn  
QC Specialist  
P.O. Box 150549  
Austin, TX 78745  
614-565-9177 office  
888-573-9994 fax  
[jdunn@erthwrks.com](mailto:jdunn@erthwrks.com)

### **Facility Location:**

Marathon Petroleum Company LP  
Detroit Refinery  
1300 South Fort Street  
Detroit, MI 48217



## 2.0 SUMMARY OF RESULTS

**Table 2.1—Marathon Crude/Vac Heater Stack (SV04-H1-05-H1) CEMS RATA Results**

Pollutant Measured	Performance Specification	Relative Accuracy	Applicable Limit	Pass/Fail
NOx	Performance Spec. 2	13.5% $RA_{RM}$	20%	Pass
CO	Performance Spec. 4A	0.5 ppm $RA_{4A}$	<5 ppm	Pass
O <sub>2</sub>	Performance Spec. 3	0.3% $MD$	1%	Pass

**Table 2.2—Marathon Crude/Vac Heater Stack (SV04-H1-05-H1) Compliance Test Results**

Pollutant Measured	Methodology	Measured Results	Applicable Limit	Pass/Fail
PM	EPA Method 5	0.0012 lb/MMBtu	0.0019 lb/MMBtu	Pass
PM/PM <sub>10</sub>	EPA Method 5/202	0.0040 lb/MMBtu	0.0076 lb/MMBtu	Pass
H <sub>2</sub> SO <sub>4</sub>	EPA Method CTM-013	0.02 ppm	n/a	n/a
H <sub>2</sub> SO <sub>4</sub>	EPA Method CTM-013	0.0001 lb/MMBtu	n/a	n/a

## 3.0 SOURCE DESCRIPTION

### 3.1 Description of the process

Marathon Petroleum Company LP produces refined petroleum products from crude oil and is required to demonstrate that select process emission sources are operating in compliance with permitted emissions limits.

The Naphtha Hydrotreater unit uses hydrogen to remove sulfur and nitrogen from straight-run and coker naphthas. This process, known as hydrotreating, uses a catalyst to promote the desulfurization reaction. The desulfurized or sweet naphtha is blended into gasoline or used for platformer feed. The NHT unit consists of process vessels (including exchangers, reactors, receivers, separators, and a stripper column), heaters, tanks, containers, pumps, piping, drains, and various components (pump seals, process valves, pressure relief valves, flanges, connectors, etc.).

The CCR Charge Heater (CCRPLCHARHTR) (EU14-CCRPLCHARHTR-S1) heats the liquid from the bottom of the stripper column. The vapors that form are returned to the top of the stripper column; the liquid vapor is removed as a product stream.

### **3.2 Applicable permit and source designation**

Marathon Petroleum Company LP operates the CCR Charge Heater (CCRPLCHARHTR) (EU14-CCRPLCHARHTR-S1) under EGLE Renewable Operating Permit No. MI-ROP-A9831-2012c.

### **3.3 Type and quantity of materials processed during tests**

During the emission testing on June 1, 2022, at the Marathon Petroleum Company LP Refinery, the CCR Charge Heater (CCRPLCHARHTR) was tested while operating at the maximum achievable load condition. This operational data was provided by MPC and is located in Attachment G of this report.

## **4.0 SAMPLING AND ANALYTICAL PROCEDURES**

### **4.1 Gaseous Emissions – NO<sub>x</sub>, CO, O<sub>2</sub>, and CO<sub>2</sub>**


For the gaseous sampling, Erthwrks utilized a stainless-steel probe, of sufficient length to reach all sampling points, inserted into a sampling port that is located on the stack in accordance with EPA Method 1. The sample is extracted through the probe, a heated Teflon sampling line, to a heating filter. The sample then enters a minimum contact sample conditioner that cools and removes moisture from the gas matrix prior to entering the Erthwrks sampling manifold.

Erthwrks followed all quality assurance and quality control procedures as defined in US EPA 40 CFR 60 Appendix A. The Calibration Error (CE) Test was conducted as specified in EPA Method 7E §8.2.3. In accordance with this requirement, a three-point analyzer calibration error test was conducted prior to sampling. The CE test was conducted by introducing the low, mid, and high-level calibration gasses (as defined in EPA Method 7E §3.3.1-3) sequentially and the response was recorded. The results of the CE test are acceptable if the calculated calibration error is within  $\pm 2.0\%$  of calibration span (or  $\leq 0.5$  ppmv).

The Initial System Bias and System Calibration Error Check was conducted in accordance with EPA Method 7E §8.2.5. The upscale calibration gas was introduced at the probe upstream of all sample system components and the response recorded. The procedure will be repeated with the low-level gas and the response recorded. During this activity, the sample system response time was also be recorded. This specification is acceptable if the calculated values of the system calibration error check are within  $\pm 5.0\%$  of the calibration span value (or  $\leq 0.5$  ppmv).

After each test run, the sample system bias check is conducted to validate the run data. The low-level and upscale drift are calculated using Equation 7E-4. The run data is valid if the calculated drift is within  $\pm 3.0\%$  of the calibration span value (or  $\leq 0.5$  ppmv).

After each test run, the corrected effluent gas concentration was calculated as specified in EPA Method 7E §12.6. The arithmetic average of all valid concentration values are adjusted for bias using equation 7E-5B.




**Figure 1: Example Erthwrks Gaseous Sampling System Diagram**

#### 4.2 Filterable Particulate Matter Sampling – EPA Method 5

EPA Test Method 1 will be used for the selection of sampling points. Stack dimensions, number of sample ports and sample port locations were confirmed prior to testing to determine the appropriate number of traverse points for the test.

EPA Test Method 5 was used to determine filterable particulate matter emission rates. Method 5 is the method at which particulate matter is withdrawn isokinetically from the source and collected on a glass fiber filter and on the lining of the isokinetic probe maintained at a temperature of  $120 \pm 14^{\circ}\text{C}$ . Upon completion of each test run, the nozzle and probe liner were rinsed and brushed with acetone. The acetone rinse catch will be collected and combined with the filter holder rinse and labeled as “front half rinse”. The total PM mass, which includes any material that condenses at or above the filtration temperature, is determined gravimetrically. Filterable PM will be calculated by combining the net gravimetric gain of the filter and the net gravimetric gain of the evaporated front half rinse. Figure 2 below shows the Method 5 sampling system components.



**Figure 2: Example Erthwrks PM System Diagram**

#### 4.3 Condensable Particulate Matter Sampling – EPA Method 202

For the determination of PM/PM<sub>10</sub>, condensable particulate matter (CPM) was measured via EPA Method 202. The Method 202 components begin at the back half of the Method 5 filter housing. The filterable particulate matter is removed in these “front half” components. The condensable particulate matter is then collected by drawing the filtered gas through a water jacketed, spiral condenser maintained at 65° – 85° F. The cooled effluent gas is then passed through two empty impingers and finally through a hexane extracted Teflon filter. Upon completion of each test run, the moisture collected in this portion of the sampling train is purged with ultra-high purity (UHP) nitrogen gas for one hour to remove any dissolved sulfur dioxide. The moisture is collected in a container and combined with the deionized water used to rinse all Method 202 sampling glassware two times.

The glassware is next rinsed with hexane and acetone. These rinses are collected and combined in an additional container. The Teflon filter is removed from the filter housing, labeled, and collected. Gravimetric analysis is then conducted on the extracted, evaporated samples for each run.

#### 4.4 EPA Method CTM-013 (ALT-133 Analysis) H<sub>2</sub>SO<sub>4</sub> Determination

The H<sub>2</sub>SO<sub>4</sub> emissions were determined utilizing the conditional test method 13 (CTM-013). The sample was extracted at a constant rate through a quartz lined heated probe (>350 °F), A heated quartz filter holder and filter (>500 °F), and through a Modified Grahm condenser (H<sub>2</sub>SO<sub>4</sub> Condenser) with Type C glass frit and 200 cm of 5-mmID glass tubing condenser coil. The H<sub>2</sub>SO<sub>4</sub> condenser is maintained between 167 to 185 °F. Because SO<sub>2</sub> was not to be determined via this method, the sample was then passed through four impingers with the specifications delineated in EPA Method 4.

The sampling was conducted at a single point at a constant rate of about 10 L/min and the DGM readings and all temperatures were recorded every five minutes. After the completion of the test run, the samples were recovered in accordance with the test method and the samples were sent to Enthalpy Analytical for analysis via Ion Chromatography (ALT-133). See the figure below that details the CTM-013 Sampling Train.




Figure 3: Example Erthwrks H<sub>2</sub>SO<sub>4</sub> System Diagram

## 4.5 RATA Procedures

The RATA testing was conducted following the sampling and measurement procedures found in the EPA Part 60, Appendix B, Performance Specifications which requires that EPA Reference Methods, from EPA Part 60, Appendix A, be utilized to conduct independent stack emissions measurements for comparison with installed CEMS readings. The following performance specifications will be used during this testing program.

- EPA Performance Specification 2 for NO<sub>x</sub> relative accuracy
- EPA Performance Specification 3 for O<sub>2</sub> relative accuracy
- EPA Performance Specification 4/4A for CO relative accuracy

As required by these methods, the use EPA Protocol 1 gases are mandatory and were used for this portion of the project.

A minimum of nine (9) RATA test runs were conducted at each exhaust stack for a minimum duration of twenty-one (21) minutes for each run. A 3-point traverse located at 16.7%, 50.0%, and 83.3% of the way across the stack (or 0.4, 1.2, and 2.0 meters from the stack wall) was conducted during each RATA test run (7 minutes per point). A maximum of twelve (12) RATA test runs will be conducted and up to three test runs may be discarded and not used to determine relative accuracy. The results of the reference method tests were compared to CEMS measurement data from the same time periods to determine the relative accuracy of the CEMS.

For NO<sub>x</sub>, the results of the RATA test are considered acceptable if the calculated relative accuracy does not exceed 20.0% as calculated by Equation 2-6 in Performance Specification 2. Alternatively, for affected units where the average of the reference method measurements is less than 50 percent of the emission standard (emission limit), the relative accuracy must not exceed 10% when the applicable emission standard is used in the denominator of Eq. 2-6.

For O<sub>2</sub>, the results of the RATA test are considered acceptable if the calculated relative accuracy does not exceed 20.0% as calculated by Equation 3.1 in Performance Specification 3. The results are also acceptable if the result of Equation 3-2 is less than or equal to 1.0 percent.

For CO, the results of the RATA test are considered acceptable if the calculated relative accuracy does not exceed 10.0% as calculated by Equation 2-6 in Performance Specification 2. Alternatively, for affected units where the average of the reference method measurements is less than 50 percent of the emission standard (emission limit), the relative accuracy must not exceed 5% when the applicable emission standard is used in the denominator of Eq. 2-6. Performance Specification 4A criteria may be used to determine relative accuracy for CEMS with low emission standards (less than 200 ppmv). In these cases, the results of the RATA test are considered acceptable if the absolute average difference between the RM and CEMS is within 5 ppmv.

RECEIVED  
AUG 01 2022



#### **4.6 Discussion of sampling procedure or operational variances**

Erthwrks, Inc. conducted the emissions testing with no sampling or procedural variances.



**Attachment A**  
**Detailed Results of Emission Test**

**Erthwrks Relative Accuracy Test Audit--NOx RATA  
Performance Specification 2**

CCR Charge Htr											NO <sub>x</sub> CEMS RATA - lb/MMBtu	
Test Run	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Run 7	Fuel F-Factor	8604	scf/MMBtu	Run 9	Run 10
Date	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022
Start Time	10:11	10:39	11:11	14:56	15:25	15:55	16:28		17:14	17:46		18:17
End Time	10:32	11:00	11:32	15:17	15:46	16:16	16:49		17:35	18:07		18:38
RM NOx (ppmvd)	24.23	23.79	23.91	23.04	23.74	23.53	23.86		23.71	24.74		23.77
RM O <sub>2</sub> Results (%vd)	6.71	6.63	6.55	6.80	6.70	6.79	6.85		6.82	6.85		6.96
RM NOx (lb/MMBtu)	<b>0.0367</b>	<b>0.0358</b>	<b>0.0358</b>	<b>0.0351</b>	<b>0.0359</b>	<b>0.0357</b>	<b>0.0365</b>		<b>0.0362</b>	<b>0.0378</b>		<b>0.0366</b>
CEMS NOx (lb/MMBtu)	<b>0.0408</b>	<b>0.0409</b>	<b>0.0404</b>	<b>0.0404</b>	<b>0.0403</b>	<b>0.0402</b>	<b>0.0406</b>		<b>0.0416</b>	<b>0.0422</b>		<b>0.0410</b>
Difference	-0.0041	-0.0051	-0.0046	-0.0053	-0.0044	-0.0045	-0.0041		-0.0054	-0.0044		-0.0044
Accept or Reject	Accept		Reject	Accept		Accept						

Applicable Standard (lb/MMBtu)

0.05
-0.0046
0.0004
0.0003
<b>13.45%</b>

← Pass

Mean of the Difference ( $d_{avg}$ )

Standard Deviation ( $S_d$ )

Confidence Coefficient (CC)

**Relative Accuracy via RM, RA<sub>RM</sub>** \*

\*RA<sub>RM</sub> (Reference Method) must be less than 20%



Erthwrks, Inc. EPA 40CFR60 RATA Worksheet  
Version 2.1 (Rev. 5/26/2021)

**Erthwrks Relative Accuracy Test Audit--CO RATA**  
**Performance Specification 4A**

CCR Charge Htr	CO CEMS RATA at Stack Conditions									
----------------	----------------------------------	--	--	--	--	--	--	--	--	--

Test Run	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Run 7	Run 8	Run 9	Run 10
Date	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022
Start Time	10:11	10:39	11:11	14:56	15:25	15:55	16:28	17:14	17:46	18:17
End Time	10:32	11:00	11:32	15:17	15:46	16:16	16:49	17:35	18:07	18:38
RM CO Result (ppmvd)	-0.32	0.04	0.23	-0.03	-0.07	0.18	0.05	0.16	0.15	0.03
CEMS CO Data (ppmvd)	-0.37	-0.35	-0.35	-0.35	-0.35	-0.33	-0.35	-0.35	-0.34	-0.34
Difference	0.05	0.39	0.58	0.32	0.28	0.51	0.40	0.51	0.49	0.37
Accept or Reject	Accept	Reject								

Mean of the Difference ( $d_{avg}$ )

0.39
0.16
0.12
0.52

← Pass

Standard Deviation ( $S_d$ )  
Confidence Coefficient (CC)  
Relative Accuracy via M.4A,  $RA_{4A}^*$

\* $RA_{4A}$  must be less than 5 ppmv



**Erthwrks Relative Accuracy Test Audit--O<sub>2</sub> RATA**  
**Performance Specification 3**

CCR Charge Htr										O <sub>2</sub> CEMS RATA	
Test Run	Run 1	Run 2	Run 3	Run 4	Run 5	Run 6	Run 7	Run 8	Run 9	Run 10	
Date	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	6/1/2022	
Start Time	10:11	10:39	11:11	14:56	15:25	15:55	16:28	17:14	17:46	18:17	
End Time	10:32	11:00	11:32	15:17	15:46	16:16	16:49	17:35	18:07	18:38	
RM O <sub>2</sub> Result (%vd)	6.71	6.63	6.55	6.80	6.70	6.79	6.85	6.82	6.85	6.96	
CEMS O <sub>2</sub> Data (%vd)	7.05	7.06	6.91	7.00	6.96	7.04	7.07	7.03	7.06	7.16	
Difference	-0.34	-0.43	-0.36	-0.20	-0.26	-0.25	-0.22	-0.21	-0.21	-0.20	
Accept or Reject	Accept	Reject	Accept								

Mean of the Difference (d<sub>avg</sub>)

-0.25
0.06
0.05
0.25%

← Pass

\*RA<sub>RM-CEMS</sub> (Reference Method - CEMS) Absolute difference must be less than 1.0%



Erthwrks, Inc. EPA 40CFR60 RATA Worksheet  
Version 2.1 (Rev. 5/26/2021)

## Erthwrks Particulate Matter Summary of Results

**Project:** Marathon Petroleum Company  
**Facility:** Detroit Refinery  
**Location:** Detroit, MI  
**Unit ID:** CCR Charge Heater

Run Designation						
Run Number		1	2	3	Average	
Date		6/1/2022	6/1/2022	6/1/2022		mm:dd:yyyy
Run Start Time		10:04	14:52	17:08		hh:mm
Run End Time		11:38	16:25	18:42		hh:mm
Operating Conditions						
Firing Rate (MMbtu/hr)		125.98	128.59	129.48	128.02	MMbtu/hr
Stack Gas Composition						
Oxygen Concentration	(%O <sub>2</sub> )	6.63	6.76	6.88	6.76	%
Carbon Dioxide Concentration	(%CO <sub>2</sub> )	8.56	8.59	8.46	8.54	%
Stack Moisture Content	(B <sub>ws</sub> )	14.57	14.76	13.93	14.42	%
Stack Dry Molecular Weight	(M <sub>d</sub> )	29.63	29.64	29.63	29.64	lb/lb-mole
Stack Wet Molecular Weight	(M <sub>s</sub> )	27.94	27.93	28.01	27.96	lb/lb-mole
Stack Gas Volumetric Flow Calculations						
Absolute Stack Pressure	(P <sub>s</sub> )	29.30	29.30	29.30	29.30	in Hg
Average Stack Temperature	(t <sub>s</sub> ) <sub>avg</sub>	840.5	841.2	840.5	840.7	°R
Average Square Root of ΔP's	(Δp <sup>1/2</sup> ) <sub>avg</sub>	0.2909	0.3004	0.3052	0.2988	%
Average Stack Gas Velocity	(v <sub>s</sub> )	1269.89	1312.37	1330.55	1304.27	ft/min
Average Stack Gas Flow	(Q <sub>aw</sub> )	5.61E+04	5.80E+04	5.88E+04	5.76E+04	acf m <sup>3</sup>
Wet Standard Stack Flow Rate	(Q <sub>sw</sub> )	2.07E+06	2.14E+06	2.17E+06	2.13E+06	wscfh
Dry Standard Stack Flow Rate	(Q <sub>sd</sub> )	1.77E+06	1.82E+06	1.87E+06	1.82E+06	dscfh
Particulate Matter Emission Rate Calculations						
Mass of Filterable PM (M.5)	mg	3.01	2.39	2.80	2.73	mg
Mass of Condensable PM (M.202)	mg	7.75	5.77	5.10	6.21	mg
Total Mass of Particulates	mg	10.76	8.16	7.90	8.94	mg
Filterable PM Mass Concentration	lb/dscf	9.71E-08	7.52E-08	8.58E-08	8.60E-08	lb/dscf
Total PM Mass Concentration	lb/dscf	3.47E-07	2.57E-07	2.42E-07	2.82E-07	lb/dscf
Filterable PM Mass Emission Rate	lb/hr	0.17	0.14	0.16	0.16	lb/hr
Total PM Mass Emission Rate	lb/hr	0.61	0.47	0.45	0.51	lb/hr
Filterable PM Mass Emission Rate	lb/day	4.12	3.29	3.85	3.75	lb/day
Total PM Mass Emission Rate	lb/day	14.74	11.24	10.85	12.27	lb/day
Filterable PM Mass Emission Rate	lb/MMbtu	0.0014	0.0011	0.0012	0.0012	lb/MMbtu
Total PM Mass Emission Rate	lb/MMbtu	0.0049	0.0036	0.0035	0.0040	lb/MMbtu

## Detailed Summary of Results

**Client:** Marathon  
**Facility:** Detroit Refinery  
**Unit ID:** CCR Charge Heater  
**Erthwrks Tech:** John Wood, Luke Morrison

Run Information				
Run Number	Run 1	Run 2	Run 3	
Date	6/1/2022	6/1/2022	6/1/2022	
Run Start Time	10:04	14:52	17:08	
Run End Time	11:04	15:52	18:08	
Unit Fuel Flow Data				
Fuel F Factor ( $F_d$ ) (scf/MMBtu)	8604.0	8604.0	8604.0	<b>8604.0</b>
Emission Concentrations				
$H_2SO_4$ (ug)	122	30.6	12.6	<b>55.07</b>
Train volume (scf)	19.91	20.09	20.60	<b>20.20</b>
$O_2$ (%vd)	6.63	6.76	6.88	<b>6.76</b>
Emission Rates				
$H_2SO_4$ (lb/scf)	1.35E-08	3.36E-09	1.35E-09	<b>6.07E-09</b>
$H_2SO_4$ (ppm)	0.05	0.01	0.01	<b>0.02</b>
$H_2SO_4$ (lb/MMBtu)	0.0002	0.0000	0.0000	<b>0.0001</b>

**Attachment B**  
**Quality Control Documentation**

## Erthwrks Method 1 Traverse Point Location Worksheet

**Client:** MPC  
**Project #:** 9049.1.B3  
**Facility:** Detroit  
**Unit ID:** CCR Charge Htr  
**Technician:** 0

### Stack ID Measurements

Stack ID + Port (inches):  
 Port Extension (inches):  
 Stack Diameter (inches):

101.5
11.5
90


### Port Location Measurements

Distance Upstream (A) (inches):  
 Distance Downstream (B) (inches):  
 Stack Diameters Upstream (A):  
 Stack Diameters Downstream (B):

200
200
2.2
2.2

Total Traverse Points to be used:  
 Traverse Points per Diameter:


3
3



### Traverse Point Locations<sup>(1)(2)</sup>

Point 1:	15.03"
Point 2:	45.00"
Point 3:	74.97"

### Stack Cross Section View



<sup>(1)</sup>For stack diameter >4.0" and <2.4 meters, stratification is measured at 16.7%, 50.0%, and 83.3" of stack diameter (M7E, §8.1.2).

<sup>(2)</sup>For stack diameter >2.4 meters, stratification is measured at 0.4, 1.2, and 2.0 meters from stack wall (M7E, §8.1.2).

## Erthwrks Gaseous Sample Collection and Quality Assurance Worksheet

Date: 6/1/2022  
 Client: MPC  
 Facility: Detroit  
 Project No: 9049.1.B3  
 Unit ID: CCR Charge Htr  
 Erthwrks Tech: \_\_\_\_\_

### Calibration Gas Verification

Pollutant	Low-Level Gas Conc. (C <sub>0</sub> )	Cylinder Serial #	Mid-Level Gas Conc. (C <sub>1</sub> )	Cylinder Serial #	High-Level Gas Conc. (C <sub>0</sub> /C <sub>S</sub> )	Cylinder Serial #	Dilutor Root Gas
NO <sub>x</sub>	n/a	n/a	24.77	CC446268	53.76	CC339873	NA
CO	n/a	n/a	25.43	CC446268	50.83	CC339873	NA
O <sub>2</sub>	n/a	n/a	10.13	CC287657	19.92	ALM038955	NA
CO <sub>2</sub>	n/a	n/a	10.00	CC287657	19.69	ALM038955	NA

### Reference Method Analyzer Info

Make	Model	Serial No.
Teledyne	T200H	802
Teledyne	T300M	734
Teledyne	T200H	802
Teledyne	T300M	734

### Direct Calibration Error Test

Pollutant	Zero Gas Response (C <sub>0</sub> )	Calibration Error (ACE)*	Low-Level Response (C <sub>0in</sub> )	Calibration Error (ACE)*	Mid-Level Response (C <sub>0in</sub> )	Calibration Error (ACE)*	High-Level Response (C <sub>0in</sub> )	Calibration Error (ACE)*
NO <sub>x</sub>	0.02	0.04%	n/a	n/a	24.36	-0.76%	53.76	0.01%
CO	0.07	0.14%	n/a	n/a	25.78	0.68%	50.94	0.21%
O <sub>2</sub>	0.03	0.17%	n/a	n/a	9.96	-0.84%	19.95	0.17%
CO <sub>2</sub>	0.00	0.01%	n/a	n/a	10.08	0.38%	19.61	-0.43%

\*Unless otherwise noted in protocol or report, THC's calibration error test is conducted using the entire sample system and must be less than 5% of applicable calibration gas

\*ACE must either be within  $\pm 2.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

NO <sub>2</sub> to NO Conversion Efficiency Test	
NO <sub>2</sub> Cal Gas Cyl. Number	CC502181
NO <sub>2</sub> Cal Gas Concentration	60.52
NO <sub>x</sub> Analyzer Response	54.92
NO <sub>2</sub> -NO Conv. Efficiency (Eff <sub>NO<sub>2</sub></sub> ) <sup>(1)</sup>	90.8%

<sup>(1)</sup> Eff<sub>NO<sub>2</sub></sub> must be  $\geq 90\%$

Method 7E Traverse Point Determination			
Stack ID (inches)		Trav. Location	Inside ID + Port
90	Point 1	15.03	26.53
Port Ext. (inches)	Point 2	45	56.50
11.5	Point 3	74.97	86.47



# Erthwrks Gaseous Sample Collection and Quality Assurance Worksheet

## Initial Sample System Bias and Response Time

Pollutant	Upscale Gas Cert Conc. (C <sub>g,1</sub> )	Upscale Gas Direct (C <sub>g,2</sub> )	Upscale Response (C <sub>r</sub> )	Sample System Bias (SB)*	Response Time (sec)	Downscale Response (C <sub>r</sub> )	Sample System Bias (SB)*	Response Time (sec)
NO <sub>x</sub>	24.77	24.36	24.08	-0.52%	60	0.47	0.84%	60
CO	25.43	25.78	25.03	-1.48%	60	-0.30	-0.74%	60
O <sub>2</sub>	10.13	9.96	9.97	0.03%	60	0.21	0.89%	60
CO <sub>2</sub>	10.00	10.08	9.91	-0.84%	60	0.01	0.02%	60

\*SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

## Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Run #: Run 1  
Start Time: 10:11  
End Time: 10:32

Pollutant	Initial Zero SSC (C <sub>s,1</sub> )	Initial Upscale SSC (C <sub>s,2</sub> )	Raw Results (C <sub>raw</sub> )	Final Zero SSC (C <sub>s,3</sub> )	Final Upscale SSC (C <sub>s,4</sub> )
NO <sub>x</sub>	0.47	24.08	24.08	0.15	25.16
CO	-0.30	25.03	-0.74	-0.53	25.13
O <sub>2</sub>	0.21	9.97	6.62	-0.01	9.92
CO <sub>2</sub>	0.01	9.91	8.52	0.00	10.07

Run #: Run 2  
Start Time: 10:39  
End Time: 11:00

Initial Zero SSC (C <sub>s,1</sub> )	Initial Upscale SSC (C <sub>s,2</sub> )	Raw Results (C <sub>raw</sub> )	Final Zero SSC (C <sub>s,3</sub> )	Final Upscale SSC (C <sub>s,4</sub> )
0.15	25.16	24.16	0.23	25.15
-0.53	25.13	-0.22	0.02	25.66
-0.01	9.92	6.51	0.05	9.96
0.00	10.07	8.63	0.03	9.99

## Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Run #: Run 3  
Start Time: 11:11  
End Time: 11:32

Pollutant	Initial Zero SSC (C <sub>s,1</sub> )	Initial Upscale SSC (C <sub>s,2</sub> )	Raw Results (C <sub>raw</sub> )	Final Zero SSC (C <sub>s,3</sub> )	Final Upscale SSC (C <sub>s,4</sub> )
NO <sub>x</sub>	0.23	25.15	24.28	0.03	25.15
CO	0.02	25.66	-0.06	-0.61	25.52
O <sub>2</sub>	0.05	9.96	6.42	0.00	9.89
CO <sub>2</sub>	0.03	9.99	8.57	0.00	10.06

Run #: Run 4  
Start Time: 14:56  
End Time: 15:17

Initial Zero SSC (C <sub>s,1</sub> )	Initial Upscale SSC (C <sub>s,2</sub> )	Raw Results (C <sub>raw</sub> )	Final Zero SSC (C <sub>s,3</sub> )	Final Upscale SSC (C <sub>s,4</sub> )
-0.27	25.70	23.91	-0.23	25.74
-0.46	25.34	-0.54	-0.57	25.10
-0.05	9.92	6.66	-0.03	9.94
0.01	10.07	8.65	0.02	10.07

## Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Run #: Run 5  
Start Time: 15:25  
End Time: 15:46

Pollutant	Initial Zero SSC (C <sub>s,1</sub> )	Initial Upscale SSC (C <sub>s,2</sub> )	Raw Results (C <sub>raw</sub> )	Final Zero SSC (C <sub>s,3</sub> )	Final Upscale SSC (C <sub>s,4</sub> )
NO <sub>x</sub>	-0.23	25.74	24.19	-0.20	24.77
CO	-0.57	25.10	-0.55	-0.39	25.44
O <sub>2</sub>	-0.03	9.94	6.59	0.16	9.93
CO <sub>2</sub>	0.02	10.07	8.70	0.01	10.04

Run #: Run 6  
Start Time: 15:55  
End Time: 16:16

Initial Zero SSC (C <sub>s,1</sub> )	Initial Upscale SSC (C <sub>s,2</sub> )	Raw Results (C <sub>raw</sub> )	Final Zero SSC (C <sub>s,3</sub> )	Final Upscale SSC (C <sub>s,4</sub> )
-0.20	24.77	23.57	-0.57	24.89
-0.39	25.44	-0.30	-0.58	25.30
0.16	9.93	6.69	-0.04	9.95
0.01	10.04	8.60	0.00	10.08



# Erthwrks Gaseous Sample Collection and Quality Assurance Worksheet

## Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Pollutant	Initial Zero SSC ( $C_{\text{sp}}$ )	Initial Upscale SSC ( $C_{\text{up}}$ )	Raw Results ( $C_{\text{raw}}$ )	Final Zero SSC ( $C_{\text{sp}}$ )	Final Upscale SSC ( $C_{\text{up}}$ )
NO <sub>x</sub>	-0.57	24.89	24.07	0.32	25.10
CO	-0.58	25.30	-0.55	-0.62	25.18
O <sub>2</sub>	-0.04	9.95	6.72	-0.01	9.94
CO <sub>2</sub>	0.00	10.08	8.55	0.03	10.05

Pollutant	Initial Zero SSC ( $C_{\text{sp}}$ )	Initial Upscale SSC ( $C_{\text{up}}$ )	Raw Results ( $C_{\text{raw}}$ )	Final Zero SSC ( $C_{\text{sp}}$ )	Final Upscale SSC ( $C_{\text{up}}$ )
NO <sub>x</sub>	0.32	25.10	23.82	0.18	24.64
CO	-0.62	25.18	-0.39	-0.48	25.55
O <sub>2</sub>	-0.01	9.94	6.69	-0.03	9.95
CO <sub>2</sub>	0.03	10.05	8.60	0.00	10.10

## Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

Pollutant	Initial Zero SSC ( $C_{\text{sp}}$ )	Initial Upscale SSC ( $C_{\text{up}}$ )	Raw Results ( $C_{\text{raw}}$ )	Final Zero SSC ( $C_{\text{sp}}$ )	Final Upscale SSC ( $C_{\text{up}}$ )
NO <sub>x</sub>	0.18	24.64	24.90	0.20	25.22
CO	-0.48	25.55	-0.42	-0.65	25.34
O <sub>2</sub>	-0.03	9.95	6.74	-0.03	9.99
CO <sub>2</sub>	0.00	10.10	8.59	0.01	10.11

Pollutant	Initial Zero SSC ( $C_{\text{sp}}$ )	Initial Upscale SSC ( $C_{\text{up}}$ )	Raw Results ( $C_{\text{raw}}$ )	Final Zero SSC ( $C_{\text{sp}}$ )	Final Upscale SSC ( $C_{\text{up}}$ )
NO <sub>x</sub>	0.20	25.22	24.18	0.34	25.15
CO	-0.65	25.34	-0.58	-0.56	25.44
O <sub>2</sub>	-0.03	9.99	6.86	-0.02	10.00
CO <sub>2</sub>	0.01	10.11	8.43	0.01	10.10

## Sample Collection Raw Data--Pre and Post Sample System Calibration (SSC) and Raw Run Results

### Run 1 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias ( $C_0$ )	Avg. Upscale Sys. Bias ( $C_M$ )	Zero Drift Assessment (D) <sup>†</sup>	Upscale Drift Assessment (D) <sup>†</sup>	Corrected Results ( $C_{\text{cor}}$ )
NO <sub>x</sub>	0.84%	-0.52%	0.24%	1.48%	0.31	24.62	0.60%	2.00%	24.23
CO	-0.74%	-1.48%	-1.18%	-1.28%	-0.42	25.08	0.44%	0.20%	-0.32
O <sub>2</sub>	0.89%	0.03%	-0.23%	-0.21%	0.10	9.94	1.12%	0.24%	6.71
CO <sub>2</sub>	0.02%	-0.84%	0.00%	-0.02%	0.00	9.99	0.02%	0.82%	8.52

\* SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

<sup>†</sup> D must either be within  $\pm 3.0\%$  or the pre- and post-run bias responses are  $\leq 0.5 \text{ ppmv}$  absolute difference

### Run 2 Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias ( $C_0$ )	Avg. Upscale Sys. Bias ( $C_M$ )	Zero Drift Assessment (D) <sup>†</sup>	Upscale Drift Assessment (D) <sup>†</sup>	Corrected Results ( $C_{\text{cor}}$ )
NO <sub>x</sub>	0.24%	1.48%	0.39%	1.47%	0.19	25.15	0.15%	0.01%	23.79
CO	-1.18%	-1.28%	-0.10%	-0.23%	-0.26	25.39	1.07%	1.05%	0.04
O <sub>2</sub>	-0.23%	-0.21%	0.08%	-0.01%	0.02	9.94	0.31%	0.20%	6.63
CO <sub>2</sub>	0.00%	-0.02%	0.14%	-0.43%	0.02	10.03	0.14%	0.41%	8.60

\* SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

<sup>†</sup> D must either be within  $\pm 3.0\%$  or the pre- and post-run bias responses are  $\leq 0.5 \text{ ppmv}$  absolute difference



## Erthwrks Gaseous Sample Collection and Quality Assurance Worksheet

**Run 3      Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results**

Pollutant	Initial Zero Sys. Bias (SB) <sup>*</sup>	Initial Upscale Sys. Bias (SB) <sup>*</sup>	Final Zero Sys. Bias (SB) <sup>*</sup>	Final Upscale Sys. Bias (SB) <sup>*</sup>	Avg. Zero Sys. Bias (C <sub>0</sub> )	Avg. Upscale Sys. Bias (C <sub>u</sub> )	Zero Drift Assessment (D) <sup>†</sup>	Upscale Drift Assessment (D) <sup>†</sup>	Corrected Results (C <sub>corr</sub> )
NO <sub>x</sub>	0.39%	1.47%	0.02%	1.47%	0.13	25.15	0.38%	0.01%	23.91
CO	-0.10%	-0.23%	-1.33%	-0.50%	-0.30	25.59	1.23%	0.27%	0.23
O <sub>2</sub>	0.08%	-0.01%	-0.16%	-0.35%	0.03	9.93	0.24%	0.34%	6.55
CO <sub>2</sub>	0.14%	-0.43%	0.00%	-0.07%	0.02	10.03	0.14%	0.37%	8.55

\*SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

†D must either be within  $\pm 3.0\%$  or the pre- and post-run bias responses are  $\leq 0.5 \text{ ppmv}$  absolute difference

**Run 4      Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results**

Pollutant	Initial Zero Sys. Bias (SE) <sup>*</sup>	Initial Upscale Sys. Bias (SE) <sup>*</sup>	Final Zero Sys. Bias (SE) <sup>*</sup>	Final Upscale Sys. Bias (SE) <sup>*</sup>	Avg. Zero Sys. Bias (C <sub>0</sub> )	Avg. Upscale Sys. Bias (C <sub>u</sub> )	Zero Drift Assessment (D) <sup>†</sup>	Upscale Drift Assessment (D) <sup>†</sup>	Corrected Results (C <sub>corr</sub> )
NO <sub>x</sub>	-0.53%	2.49%	-0.47%	2.56%	-0.25	25.72	0.06%	0.07%	23.04
CO	-1.04%	-0.86%	-1.25%	-1.33%	-0.51	25.22	0.21%	0.47%	-0.03
O <sub>2</sub>	-0.40%	-0.22%	-0.31%	-0.11%	-0.04	9.93	0.09%	0.11%	6.80
CO <sub>2</sub>	0.02%	-0.01%	0.11%	-0.04%	0.01	10.07	0.09%	0.03%	8.59

\*SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

†D must either be within  $\pm 3.0\%$  or the pre- and post-run bias responses are  $\leq 0.5 \text{ ppmv}$  absolute difference

**Run 5      Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results**

Pollutant	Initial Zero Sys. Bias (SE) <sup>*</sup>	Initial Upscale Sys. Bias (SE) <sup>*</sup>	Final Zero Sys. Bias (SE) <sup>*</sup>	Final Upscale Sys. Bias (SE) <sup>*</sup>	Avg. Zero Sys. Bias (C <sub>0</sub> )	Avg. Upscale Sys. Bias (C <sub>u</sub> )	Zero Drift Assessment (D) <sup>†</sup>	Upscale Drift Assessment (D) <sup>†</sup>	Corrected Results (C <sub>corr</sub> )
NO <sub>x</sub>	-0.47%	2.56%	-0.41%	0.75%	-0.22	25.25	0.07%	1.80%	23.74
CO	-1.25%	-1.33%	-0.91%	-0.66%	-0.48	25.27	0.34%	0.67%	-0.07
O <sub>2</sub>	-0.31%	-0.11%	0.61%	-0.18%	0.06	9.93	0.92%	0.07%	6.70
CO <sub>2</sub>	0.11%	-0.04%	0.06%	-0.16%	0.02	10.06	0.05%	0.13%	8.65

\*SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

†D must either be within  $\pm 3.0\%$  or the pre- and post-run bias responses are  $\leq 0.5 \text{ ppmv}$  absolute difference

**Run 6      Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results**

Pollutant	Initial Zero Sys. Bias (SE) <sup>*</sup>	Initial Upscale Sys. Bias (SE) <sup>*</sup>	Final Zero Sys. Bias (SE) <sup>*</sup>	Final Upscale Sys. Bias (SE) <sup>*</sup>	Avg. Zero Sys. Bias (C <sub>0</sub> )	Avg. Upscale Sys. Bias (C <sub>u</sub> )	Zero Drift Assessment (D) <sup>†</sup>	Upscale Drift Assessment (D) <sup>†</sup>	Corrected Results (C <sub>corr</sub> )
NO <sub>x</sub>	-0.41%	0.75%	-1.10%	0.98%	-0.39	24.83	0.69%	0.23%	23.53
CO	-0.91%	-0.66%	-1.29%	-0.95%	-0.49	25.37	0.38%	0.29%	0.18
O <sub>2</sub>	0.61%	-0.18%	-0.36%	-0.04%	0.06	9.94	0.96%	0.14%	6.79
CO <sub>2</sub>	0.06%	-0.16%	0.01%	0.02%	0.01	10.06	0.05%	0.18%	8.54

\*SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

†D must either be within  $\pm 3.0\%$  or the pre- and post-run bias responses are  $\leq 0.5 \text{ ppmv}$  absolute difference



## Erthwrks Gaseous Sample Collection and Quality Assurance Worksheet

**Run 7      Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results**

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C <sub>0</sub> )	Avg. Upscale Sys. Bias (C <sub>M</sub> )	Zero Drift Assessment (D) <sup>†</sup>	Upscale Drift Assessment (D) <sup>†</sup>	Corrected Results (C <sub>corr</sub> )
NO <sub>x</sub>	-1.10%	0.98%	0.56%	1.37%	-0.13	25.00	1.65%	0.39%	23.86
CO	-1.29%	-0.95%	-1.36%	-1.18%	-0.60	25.24	0.07%	0.23%	0.05
O <sub>2</sub>	-0.36%	-0.04%	-0.23%	-0.11%	-0.02	9.95	0.13%	0.07%	6.85
CO <sub>2</sub>	0.01%	0.02%	0.15%	-0.12%	0.02	10.06	0.14%	0.14%	8.49

\* SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

† D must either be within  $\pm 3.0\%$  or the pre- and post-run bias responses are  $\leq 0.5 \text{ ppmv}$  absolute difference

**Run 8      Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results**

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C <sub>0</sub> )	Avg. Upscale Sys. Bias (C <sub>M</sub> )	Zero Drift Assessment (D) <sup>†</sup>	Upscale Drift Assessment (D) <sup>†</sup>	Corrected Results (C <sub>corr</sub> )
NO <sub>x</sub>	0.56%	1.37%	0.31%	0.52%	0.25	24.87	0.25%	0.85%	23.71
CO	-1.36%	-1.18%	-1.08%	-0.45%	-0.55	25.36	0.28%	0.72%	0.16
O <sub>2</sub>	-0.23%	-0.11%	-0.31%	-0.04%	-0.02	9.95	0.09%	0.07%	6.82
CO <sub>2</sub>	0.15%	-0.12%	0.01%	0.11%	0.02	10.07	0.14%	0.23%	8.54

\* SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

† D must either be within  $\pm 3.0\%$  or the pre- and post-run bias responses are  $\leq 0.5 \text{ ppmv}$  absolute difference

**Run 9      Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results**

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C <sub>0</sub> )	Avg. Upscale Sys. Bias (C <sub>M</sub> )	Zero Drift Assessment (D) <sup>†</sup>	Upscale Drift Assessment (D) <sup>†</sup>	Corrected Results (C <sub>corr</sub> )
NO <sub>x</sub>	0.31%	0.52%	0.34%	1.59%	0.19	24.93	0.03%	1.06%	24.74
CO	-1.08%	-0.45%	-1.41%	-0.87%	-0.56	25.44	0.33%	0.41%	0.15
O <sub>2</sub>	-0.31%	-0.04%	-0.32%	0.12%	-0.03	9.97	0.01%	0.16%	6.85
CO <sub>2</sub>	0.01%	0.11%	0.03%	0.16%	0.01	10.10	0.03%	0.06%	8.51

\* SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

† D must either be within  $\pm 3.0\%$  or the pre- and post-run bias responses are  $\leq 0.5 \text{ ppmv}$  absolute difference

**Run 10      Sample Collection Calculations--Pre- and Post-Run Sample System Bias Check, Drift Assessment, Corrected Results**

Pollutant	Initial Zero Sys. Bias (SB)*	Initial Upscale Sys. Bias (SB)*	Final Zero Sys. Bias (SB)*	Final Upscale Sys. Bias (SB)*	Avg. Zero Sys. Bias (C <sub>0</sub> )	Avg. Upscale Sys. Bias (C <sub>M</sub> )	Zero Drift Assessment (D) <sup>†</sup>	Upscale Drift Assessment (D) <sup>†</sup>	Corrected Results (C <sub>corr</sub> )
NO <sub>x</sub>	0.34%	1.59%	0.59%	1.47%	0.27	25.18	0.25%	0.12%	23.77
CO	-1.41%	-0.87%	-1.24%	-0.67%	-0.61	25.39	0.17%	0.20%	0.03
O <sub>2</sub>	-0.32%	0.12%	-0.26%	0.21%	-0.02	10.00	0.06%	0.09%	6.96
CO <sub>2</sub>	0.03%	0.16%	0.04%	0.14%	0.01	10.10	0.01%	0.03%	8.34

\* SB must either be within  $\pm 5.0\%$  or  $\leq 0.5 \text{ ppmv}$  absolute difference

† D must either be within  $\pm 3.0\%$  or the pre- and post-run bias responses are  $\leq 0.5 \text{ ppmv}$  absolute difference

RECEIVED

AUG 01 2022



**Attachment C**  
**Sampling Datasheets**

### Emissions Method 2 Traverse Point Location Worksheet

**Client:** Marathon Petroleum Company  
**Project #:** 9049.1.B3  
**Facility:** Detroit Refinery  
**Unit ID:** CCR Charge Heater  
**Technician:** John Wood, Adam Loes, Luke Morrison

#### Stack ID Measurements


Stack ID + Port (inches):	101.5
Port Extension (inches):	11.5
Stack Diameter (inches):	90

#### Port Location Measurements


Distance Upstream (A) (inches):	100
Distance Downstream (B) (inches):	300
Stack Diameters Upstream (A):	1.1
Stack Diameters Downstream (B):	3.3

Total Traverse Points to be used:

24
12



Stack Cross Section View



#### Calculated Traverse Point Locations per Diameter

Traverse Point Number per Diameter	Total Number of Traverse Points Used					
	4	8	12	16	20	24
1	24.64	17.53	15.46	14.38	13.84	<b>13.39</b>
2	<b>88.36</b>	34.00	24.64	20.95	18.88	17.53
3	79.00	38.14	28.96	24.64	22.12	
4	95.47	74.86	40.57	31.84	27.43	
5		88.36	72.43	42.28	<b>34.00</b>	
6		97.54	84.04	70.72	43.54	
7			92.05	81.16	69.46	
8			98.62	88.36	79.00	
9				94.12	<b>85.57</b>	
10				99.16	<b>90.88</b>	
11					95.47	
12					99.61	

Measurements in bold will be the traverse points used for the emission test

#### Traverse Point Location Table From EPA Method 1, Table 1-2

Traverse Point Number per Diameter	Total Number of Traverse Points to be Used (from EPA M1 Table 1-2)					
	4	8	12	16	20	24
1	14.60	6.70	4.40	3.20	2.60	2.10
2	<b>85.40</b>	25.00	14.60	10.50	8.20	6.70
3		75.00	29.60	19.40	14.60	11.80
4		93.30	70.40	32.30	22.60	17.70
5			85.40	67.70	34.20	25.00
6			95.60	80.60	65.80	35.60
7				89.50	77.40	64.40
8				<b>96.80</b>	85.40	75.00
9					91.80	82.30
10					97.40	88.20
11						93.30
12						<b>97.90</b>

## Erthwrks Isokinetic Sampling Field Data and Calculation Worksheet

Client: Marathon Petroleum Company  
 Facility: Detroit Refinery  
 Location: Detroit, MI  
 Unit ID: CCR Charge Heater

Run ID: **1**  
 Date: **6/1/22**  
 Amb Temp: **62**  
 Baro. Press: **29.31**

Meterbox ID: **M5-2**  
 DGM Y Factor: **0.989**  
 DGM ΔH @: **1.816**

Pre and Post DGM Leak Checks				
Pre	0.00	ft <sup>3</sup> /min @	15	inHg
Post	0.00	ft <sup>3</sup> /min @	16	inHg
Pitot Not Damaged & Leak Checks Good?				
Pre	Yes	Post	Yes	

Isokinetic Sampling Data				Post Sample Moisture Determination				Post Sampling Moisture and MW Determination			
Meter K Factor	(NA)	21.75	unitless	Impinger Weights (g)				O <sub>2</sub> Concentration	(%O <sub>2</sub> )	6.63	%
Pitot Tube Factor	(C <sub>p</sub> )	0.84	unitless	Impinger ID contents				CO <sub>2</sub> Concentration	(%CO <sub>2</sub> )	8.56	%
Stack Static Pressure	(P <sub>static</sub> )	-0.12	in H <sub>2</sub> O	Impinger 1 Empty				Sample Volume Metered	(V <sub>m</sub> )	73.04	dcf
Dry Gas Fraction	(NA)	0.850	unitless	Impinger 2 Empty				Standard Volume at STP	(V <sub>std</sub> )	68.35	dscf
Stack Gas Wet MW	(M <sub>s</sub> )	27.89	lb/lb-mole	Impinger 3 DI H <sub>2</sub> O				Moisture Content	(B <sub>wc</sub> )	14.574	%
Actual Nozzle Area	(NA)	1.15E-03	ft <sup>2</sup>	Impinger 4 Silica Gel				Final Dry Gas Fraction	(B <sub>wd</sub> )	0.854	unitless
Total Sample Time	(NA)	90	min	Total Weights 2540.8				Stack Gas Wet MW	(M <sub>s</sub> )	27.94	lb/lb-mole
Number of Traverse Points	(NA)	24	points	Filter ID: 51321				Stack Gas Velocity	(v <sub>s</sub> )	21.16	ft/sec
Time per Traverse Point	(NA)	0:03:45	time					Stack Gas Vol. Flow Rate	(Q <sub>d</sub> )	1.77E+06	dscfh
								Final Isokinetic Calc.	(%iso)	98.6	%
								Post -Test Meter Cal (M.5 §16.3)	(Y <sub>cal</sub> )	0.957	

	End Time	Stack Temp	Probe Temp	M.5 Filter Temp	202 Filter Temp	Exit Temp	DGM Temp	Pump Vacuum	ΔP	ΔH	Target DGM Reading	Obs. DGM Reading	% ISO Point	% ISO Total
<b>Port 1 Start →</b>	10:04:00	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(inHg)	in H <sub>2</sub> O	in H <sub>2</sub> O	ft <sup>3</sup>	639.588	unitless	unitless
Point 1	10:07:45	382	253	260	80	64	81	5	0.07	1.56	642.342	642.385	101.6	101.6
Point 2	10:11:30	381	252	268	79	62	81	6	0.08	1.78	645.329	645.195	95.4	98.4
Point 3	10:15:15	381	252	260	80	63	83	7	0.08	1.79	648.150	648.008	95.2	97.3
Point 4	10:19:00	381	252	257	80	61	83	7	0.08	1.79	650.963	650.889	97.5	97.4
Point 5	10:22:45	381	252	258	79	64	84	7	0.09	2.02	654.027	653.912	96.3	97.1
Point 6	10:26:30	382	254	266	83	65	85	8	0.09	2.02	657.054	656.975	97.5	97.2
Point 7	10:30:15	381	252	266	82	65	86	8	0.08	1.80	659.946	660.121	105.9	98.4
Point 8	10:34:00	382	254	268	84	64	87	7	0.07	1.58	662.905	663.145	108.6	99.6
Point 9	10:37:45	382	247	262	82	65	87	7	0.07	1.58	665.929	665.788	94.9	99.1
Point 10	10:41:30	382	242	255	83	65	88	7	0.08	1.81	668.768	668.527	91.9	98.4
Point 11	10:45:15	381	241	248	82	65	89	7	0.07	1.58	671.323	671.214	96.1	98.2
Point 12	10:49:00	381	245	247	83	65	89	7	0.07	1.58	674.010	674.087	102.7	98.6
<b>Port 2 Start →</b>	10:53:00													
Point 13	10:56:45	380	243	245	82	66	90	7	0.09	2.04	677.262	677.054	93.5	98.1
Point 14	11:00:30	380	244	243	83	66	91	7	0.09	2.04	680.234	680.087	95.4	97.9
Point 15	11:04:15	379	245	242	84	66	91	7	0.09	2.04	683.269	683.251	99.4	98.0
Point 16	11:08:00	379	244	241	83	65	91	8	0.10	2.27	686.604	686.628	100.7	98.2
Point 17	11:11:45	379	245	242	83	64	92	8	0.11	2.50	690.149	690.150	100.0	98.3
Point 18	11:15:30	379	244	240	82	65	93	8	0.10	2.28	693.515	693.487	99.2	98.4
Point 19	11:19:15	380	245	239	83	66	94	8	0.10	2.28	696.856	696.875	100.6	98.5
Point 20	11:23:00	379	242	239	82	65	95	8	0.10	2.29	700.252	700.204	98.6	98.5
Point 21	11:26:45	379	244	242	82	64	96	8	0.09	2.06	703.415	703.405	99.7	98.6
Point 22	11:30:30	380	246	247	82	65	96	8	0.09	2.06	706.614	706.610	99.9	98.6
Point 23	11:34:15	380	244	254	83	66	96	8	0.08	1.83	709.637	709.654	100.6	98.7
Point 24	11:38:00	380	243	251	84	65	96	8	0.07	1.60	712.487	712.629	105.0	99.0
<b>Average Values</b>		<b>380.5</b>	<b>246.9</b>	<b>251.7</b>	<b>82.1</b>	<b>64.6</b>	<b>89.3</b>	<b>7.3</b>	<b>0.09</b>	<b>1.92</b>	<b>73.041</b>		<b>99.0</b>	

**Erthworks Isokinetic Sampling Field Data and Calculation Worksheet**

Client: Marathon Petroleum Company  
 Facility: Detroit Refinery  
 Location: Detroit, MI  
 Unit ID: CCR Charge Heater

Run ID: 2  
 Date: 6/1/22  
 Amb Temp: 72  
 Baro. Press: 29.31

Meterbox ID: M5-2  
 DGM Y Factor: 0.989  
 DGM ΔH @: 1.816

Pre and Post DGM Leak Checks:				
Pre	0.00	ft³/min @	15	inHg
Post	0.00	ft³/min @	15	inHg
Pitot Not Damaged & Leak Checks Good?				
Pre	Yes	Post	Yes	

Isokinetic Sampling Data				Post Sample Moisture Determination				Post Sampling Moisture and MW Determination			
Meter K Factor	(NA)	21.75	unitless					O <sub>2</sub> Concentration	(%O <sub>2</sub> )	6.76	%
Pitot Tube Factor	(C <sub>ps</sub> )	0.84	unitless	Impinger ID	contents	Pre Run	Post Run	CO <sub>2</sub> Concentration	(%CO <sub>2</sub> )	8.59	%
Stack Static Pressure	(P <sub>static</sub> )	-0.12	in H2O	Impinger 1	Empty	358.8	572.3	Sample Volume Metered	(V <sub>m</sub> )	74.64	dcf
Dry Gas Fraction	(NA)	0.850	unitless	Impinger 2	Empty	614.6	616.9	Standard Volume at STP	(V <sub>std</sub> )	70.04	dscf
Stack Gas Wet MW	(Ms)	27.89	lb/lb-mole	Impinger 3	DI H2O	732.4	741.8	Moisture Content	(B <sub>ws</sub> )	14.760	%
Actual Nozzle Area	(NA)	1.15E-03	ft <sup>2</sup>	Impinger 4	Silica Gel	819.0	851	Final Dry Gas Fraction	(B <sub>ws</sub> )	0.852	unitless
Total Sample Time	(NA)	90	min	Total Weights		2524.8	2782.0	Stack Gas Wet MW	(Ms)	27.93	lb/lb-mole
Number of Traverse Points	(NA)	24	points	Filter ID:		51320		Stack Gas Velocity	(V <sub>s</sub> )	21.87	ft/sec
Time per Traverse Point	(NA)	0:03:45	time					Stack Gas Vol. Flow Rate	(Qd)	1.82E+06	dscfh
								Final Isokinetic Calc.	(%iso)	98.1	%
								Post -Test Meter Cal (M.5 §16.3)	(Y <sub>eq</sub> )	0.963	

	End Time	Stack Temp	Probe Temp	M.5 Filter Temp	202 Filter Temp	Exit Temp	DGM Temp	Pump Vacuum	ΔP	ΔH	Target DGM Reading	Obs. DGM Reading	% ISO Point	% ISO Total
									(inHg)	(°F)	ft³	713.274	unitless	unitless
<b>Port 1 Start →</b>	14:52:00													
	14:55:45	383	242	239	82	63	78	7	0.09	1.99	716.374	716.178	93.7	93.7
	14:59:30	382	243	245	81	63	79	7	0.08	1.78	719.110	719.119	100.3	96.9
	15:03:15	382	244	241	83	64	80	7	0.09	2.00	722.233	722.195	98.8	97.5
	15:07:00	381	242	244	81	63	82	7	0.10	2.23	725.489	725.412	97.7	97.6
	15:10:45	381	242	252	79	64	83	7	0.10	2.24	728.712	728.742	100.9	98.3
	15:14:30	382	241	252	76	64	85	7	0.09	2.02	731.884	731.651	92.6	97.3
	15:18:15	381	241	251	76	63	84	7	0.08	1.79	734.612	734.503	96.3	97.2
	15:22:00	381	240	247	78	64	86	7	0.08	1.80	737.474	737.541	102.2	97.8
	15:25:45	381	242	248	79	65	87	8	0.09	2.03	740.697	740.653	98.6	97.9
	15:29:30	382	241	245	80	65	87	7	0.09	2.03	743.807	743.851	101.4	98.2
	15:33:15	381	241	244	81	66	88	7	0.08	1.81	746.833	746.902	102.3	98.6
	15:37:00	380	241	243	80	65	89	7	0.08	1.81	749.891	749.750	95.3	98.3
<b>Port 2 Start →</b>	15:40:00													
	15:43:45	380	239	241	78	65	90	7	0.09	2.04	752.925	752.751	94.5	98.0
	15:47:30	381	240	242	79	66	91	7	0.09	2.04	755.930	755.832	96.9	98.0
	15:51:15	381	246	245	76	65	92	7	0.09	2.05	759.016	758.832	94.2	97.7
	15:55:00	382	248	249	75	65	92	8	0.10	2.27	762.185	762.060	96.3	97.6
	15:58:45	381	246	250	75	65	92	8	0.10	2.27	765.415	765.427	100.4	97.8
	16:02:30	381	245	250	76	63	93	7	0.09	2.05	768.617	768.654	101.2	98.0
	16:06:15	380	245	253	78	64	93	8	0.11	2.51	772.179	771.987	94.6	97.8
	16:10:00	381	251	255	79	64	92	8	0.10	2.27	775.342	775.412	102.1	98.0
	16:13:45	380	241	256	78	63	92	7	0.09	2.05	778.598	778.854	108.0	98.5
	16:17:30	381	244	257	76	65	92	7	0.09	2.05	782.038	781.835	93.6	98.3
	16:21:15	381	239	249	77	65	92	7	0.09	2.05	785.019	784.925	97.0	98.2
	16:25:00	382	245	251	76	65	92	7	0.08	1.82	787.927	787.913	99.5	98.3
Average Values	381.2	242.9	247.9	78.3	64.3	88.0	7.2	0.09	2.04		74.639		98.3	

## Erthwrks Isokinetic Sampling Field Data and Calculation Worksheet

Client: Marathon Petroleum Company  
 Facility: Detroit Refinery  
 Location: Detroit, MI  
 Unit ID: CCR Charge Heater

Run ID: 3  
 Date: 6/1/22  
 Amb Temp: 79  
 Baro. Press: 29.31

Meterbox ID: M5-2  
 DGM Y Factor: 0.989  
 DGM ΔH @: 1.816

Pre and Post DGM Leak Checks				
Pre	0.00	ft³/min @	17	inHg
Post	0.00	ft³/min @	15	inHg
Pitot Not Damaged & Leak Checks Good?				
Pre	Yes	Post	Yes	

Isokinetic Sampling Data				Post Sample Moisture Determination				Post Sampling Moisture and MW Determination			
Meter K Factor	(NA)	21.75	unitless	Impinger ID	contents	Pre Run	Post Run	O <sub>2</sub> Concentration	(%O <sub>2</sub> )	6.88	%
Pitot Tube Factor	(C <sub>ps</sub> )	0.84	unitless	Impinger 1	Empty	366.0	568.2	CO <sub>2</sub> Concentration	(%CO <sub>2</sub> )	8.46	%
Stack Static Pressure	(P <sub>static</sub> )	-0.12	in H2O	Impinger 2	Empty	614.2	616.4	Sample Volume Metered	(V <sub>m</sub> )	76.99	dcf
Dry Gas Fraction	(NA)	0.850	unitless	Impinger 3	DI H2O	712.7	732	Standard Volume at STP	(V <sub>std</sub> )	71.95	dscf
Stack Gas Wet MW	(Ms)	27.89	lb/lb-mole	Impinger 4	Silica Gel	907.0	930.2	Moisture Content	(B <sub>wd</sub> )	13.926	%
Actual Nozzle Area	(NA)	1.15E-03	ft <sup>2</sup>	Total Weights				Final Dry Gas Fraction	(B <sub>wd</sub> )	0.861	unitless
Total Sample Time	(NA)	90	min	Filter ID: 51316				Stack Gas Wet MW	(Ms)	28.01	lb/lb-mole
Number of Traverse Points	(NA)	24	points					Stack Gas Velocity	(v <sub>s</sub> )	22.18	ft/sec
Time per Traverse Point	(NA)	0:03:45	time					Stack Gas Vol. Flow Rate	(Q <sub>d</sub> )	1.87E+06	dscfh
								Final Isokinetic Calc.	(%iso)	98.3	%
								Post -Test Meter Cal (M.5 §16.3)	(Y <sub>ca</sub> )	0.953	

	End Time	Stack Temp	Probe Temp	M.5 Filter Temp	202 Filter Temp	Exit Temp	DGM Temp	Pump Vacuum	ΔP	ΔH	Target DGM Reading	Obs. DGM Reading	% ISO Point	% ISO Total
									in H2O	in H2O	ft³	unitless	unitless	unitless
Port 1 Start →	17:08:00	(°F)	(°F)	(°F)	(°F)	(°F)	(°F)	(inHg)			788.877			
Point 1	17:11:45	376	237	245	84	67	86	7	0.09	2.02	792.036	791.958	97.5	97.5
Point 2	17:15:30	380	239	245	82	66	85	7	0.09	2.02	795.104	795.121	100.5	99.0
Point 3	17:19:15	379	243	239	80	65	85	7	0.10	2.25	798.437	798.289	95.5	97.8
Point 4	17:23:00	380	252	241	79	65	87	8	0.10	2.25	801.615	801.384	93.0	96.6
Point 5	17:26:45	380	256	250	79	65	87	9	0.11	2.48	804.871	804.780	97.4	96.8
Point 6	17:30:30	381	252	251	79	66	88	8	0.09	2.03	807.941	808.021	102.5	97.7
Point 7	17:34:15	381	245	246	79	66	89	8	0.09	2.04	811.188	811.241	101.7	98.2
Point 8	17:38:00	380	248	250	75	66	89	8	0.08	1.81	814.230	814.288	101.9	98.7
Point 9	17:41:45	381	249	253	74	66	90	8	0.08	1.81	817.281	817.321	101.3	98.9
Point 10	17:45:30	381	248	251	75	67	91	8	0.09	2.04	820.500	820.324	94.5	98.5
Point 11	17:49:15	381	252	255	76	63	91	8	0.09	2.04	823.503	823.485	99.4	98.6
Point 12	17:53:00	381	242	245	76	76	92	8	0.10	2.27	826.840	826.712	96.2	98.4
Port 2 Start →	17:57:00													
Point 13	18:00:45	382	244	246	76	63	92	8	0.10	2.27	830.065	829.894	94.9	98.1
Point 14	18:04:30	381	252	253	77	62	91	8	0.09	2.04	833.073	833.164	102.9	98.4
Point 15	18:08:15	381	249	249	78	64	92	8	0.11	2.50	836.680	836.551	96.3	98.3
Point 16	18:12:00	381	241	245	79	65	92	8	0.11	2.50	840.067	840.041	99.3	98.4
Point 17	18:15:45	381	246	244	78	63	93	8	0.10	2.28	843.402	843.481	102.4	98.6
Point 18	18:19:30	381	247	246	78	63	93	8	0.09	2.05	846.671	846.771	103.1	98.8
Point 19	18:23:15	381	247	249	79	63	93	8	0.09	2.05	849.961	849.950	99.7	98.9
Point 20	18:27:00	380	247	248	80	64	92	8	0.08	1.82	852.956	853.082	104.2	99.1
Point 21	18:30:45	380	246	247	80	64	92	8	0.08	1.82	856.088	856.175	102.9	99.3
Point 22	18:34:30	380	246	249	81	64	92	8	0.09	2.05	859.361	859.402	101.3	99.4
Point 23	18:38:15	381	245	250	82	65	92	8	0.09	2.05	862.586	862.589	100.1	99.4
Point 24	18:42:00	381	245	251	83	66	92	8	0.10	2.27	865.944	865.863	97.6	99.3
Average Values		380.5	246.6	247.8	78.7	65.2	90.3	7.9	0.09	2.12	76.986		99.3	

## Erthwrks Method 8A (CTM-013) Sampling Worksheet

**Date:** 6/1/2022  
**Client:** Marathon  
**Facility:** Detroit Refinery  
**Unit ID:** CCR Charge Heater  
**Erthwrks Tech:** John Wood, Luke Morrison  
**Run No:** 1

DGM Pre-Test Leak Check			DGM Post-Test Leak Check		
Vac ("H <sub>2</sub> O)	cubic feet	Time (s)	Vac ("H <sub>2</sub> O)	cubic feet	Time (s)
14	0.00	60	13	0.000	60

Start Time:	10:04
Meter Box ID:	M5-5
DGM y-fact:	0.9952
Atm Press ("Hg)	29.163

Sampling Point	Sample Time (min:sec)	ΔH	DGM Reading (ft <sup>3</sup> )	ΔV <sub>m</sub> (ft <sup>3</sup> )	DGM Temp (°F)	Probe Temp (°F)	Filter Temp (°F)	H <sub>2</sub> SO <sub>4</sub> Temp (°F)	Imp Exit Temp (°F)	DGM Vac (inHg)
Start: 10:04	10:04		139.223	<--- Starting Reading	(>350 °F)	(>500 °F)	(167-185 °F)	(<68 °F)		
1	10:09:00	0.42	140.942	1.719	78	378	501	169	67	3
2	10:14:00	0.42	142.715	1.773	78	376	502	169	67	3
3	10:19:00	0.42	144.490	1.775	78	376	502	173	65	3
4	10:24:00	0.42	146.252	1.762	78	376	501	172	65	3
5	10:29:00	0.42	148.006	1.754	79	376	502	175	65	3
6	10:34:00	0.42	149.756	1.750	80	375	505	173	66	3
7	10:39:00	0.42	151.505	1.749	81	374	504	172	67	3
8	10:44:00	0.42	153.254	1.749	82	377	503	169	67	3
9	10:49:00	0.42	155.003	1.749	82	376	502	174	63	3
10	10:54:00	0.42	156.753	1.750	83	374	503	173	62	3
11	10:59:00	0.42	158.495	1.742	84	374	502	169	63	3
12	11:04:00	0.42	160.245	1.750	85	374	502	170	64	3
Totals		0.4	21.022		80.7	375.5	502.4	171.5	65.1	3.0

Sample Gas Volume, V<sub>m(std)</sub>

$$V_{m(\text{std})} = 19.91$$

## Erthwrks Method 8A (CTM-013) Sampling Worksheet

Date: 6/1/2022  
 Client: Marathon  
 Facility: Detroit Refinery  
 Unit ID: CCR Charge Heater  
 Erthwrks Tech: John Wood, Luke Morrison  
 Run No: 2

DGM Pre-Test Leak Check			DGM Post-Test Leak Check		
Vac ("H <sub>2</sub> O)	cubic feet	Time (s)	Vac ("H <sub>2</sub> O)	cubic feet	Time (s)
9	0.00	60	7	0.000	60

Start Time:	14:52
Meter Box ID:	M5-5
DGM y-fact:	0.9952
Atm Press ("Hg)	29.163

Sampling Point	Sample Time (min:sec)	ΔH	DGM Reading (ft <sup>3</sup> )	ΔV <sub>m</sub> (ft <sup>3</sup> )	DGM Temp (°F)	Probe Temp (°F)	Filter Temp (°F)	H <sub>2</sub> SO <sub>4</sub> Temp (°F)	Imp Exit Temp (°F)	DGM Vac (inHg)
Start: 14:52	14:52		167.785	<--- Starting Reading	(>350 °F)	(>500 °F)	(167-185 °F)	(<68 °F)		
1	14:57:00	0.42	169.530	1.745	76	376	501	173	59	3
2	15:02:00	0.42	171.285	1.755	76	376	502	169	59	3
3	15:07:00	0.42	173.045	1.760	78	377	503	169	60	3
4	15:12:00	0.42	174.802	1.757	78	375	500	169	60	3
5	15:17:00	0.42	176.563	1.761	79	376	505	169	60	3
6	15:22:00	0.42	178.327	1.764	80	376	503	169	61	3
7	15:27:00	0.42	180.092	1.765	81	376	503	169	61	3
8	15:32:00	0.42	181.864	1.772	81	377	500	169	62	3
9	15:37:00	0.42	183.635	1.771	82	375	507	169	63	3
10	15:42:00	0.42	185.410	1.775	83	376	504	169	64	3
11	15:47:00	0.42	187.190	1.780	83	377	506	169	65	3
12	15:52:00	0.42	188.970	1.780	83	376	507	169	66	3
Totals		0.4	21.185		80.0	376.1	503.4	169.3	61.7	3.0

Sample Gas Volume, V<sub>m(std)</sub>

V<sub>m(std)</sub> =

## Erthwrks Method 8A (CTM-013) Sampling Worksheet

**Date:** 6/1/2022  
**Client:** Marathon  
**Facility:** Detroit Refinery  
**Unit ID:** CCR Charge Heater  
**Erthwrks Tech:** John Wood, Luke Morrison  
**Run No:** 3

DGM Pre-Test Leak Check			DGM Post-Test Leak Check		
Vac ("H <sub>2</sub> O)	cubic feet	Time (s)	Vac ("H <sub>2</sub> O)	cubic feet	Time (s)
12	0.00	60	9	0.000	60

Start Time:	17:08
Meter Box ID:	M5-5
DGM y-fact:	0.9952
Atm Press ("Hg)	29.163

Sampling Point	Sample Time (min:sec)	ΔH	DGM Reading (ft <sup>3</sup> )	ΔV <sub>m</sub> (ft <sup>3</sup> )	DGM Temp (°F)	Probe Temp (°F)	Filter Temp (°F)	H <sub>2</sub> SO <sub>4</sub> Temp (°F)	Imp Exit Temp (°F)	DGM Vac (inHg)
Start: 17:08	17:08		194.308	<--- Starting Reading	(>350 °F)	(>500 °F)	(167-185 °F)	(<68 °F)		
1	17:13:00	0.42	196.095	1.787	79	374	506	170	54	3
2	17:18:00	0.42	197.895	1.800	80	376	502	173	53	3
3	17:23:00	0.42	199.704	1.809	80	376	511	169	53	3
4	17:28:00	0.42	201.518	1.814	80	375	507	169	54	3
5	17:33:00	0.42	203.333	1.815	81	374	509	169	54	3
6	17:38:00	0.42	205.150	1.817	82	376	510	169	56	3
7	17:43:00	0.42	206.975	1.825	82	375	504	169	57	3
8	17:48:00	0.42	208.800	1.825	83	375	508	169	58	3
9	17:53:00	0.42	210.627	1.827	83	376	507	169	59	3
10	17:58:00	0.42	212.447	1.820	83	375	509	169	61	3
11	18:03:00	0.42	214.268	1.821	83	376	508	169	61	3
12	18:08:00	0.42	216.095	1.827	83	376	502	169	62	3
<b>Totals</b>		0.4	<b>21.787</b>		<b>81.6</b>	<b>375.3</b>	<b>506.9</b>	<b>169.4</b>	<b>56.8</b>	<b>3.0</b>

**Sample Gas Volume, V<sub>m(std)</sub>**

$$V_{m(\text{std})} = 20.60$$

**Attachment D**  
**Example Calculations**

## Erthwrks QAQC Example Calculations

Example Calculations for System QA:	Run 1,	CCR Charge Htr
Example Calculations for Pollutant:	NOx	

Variable:	Description:
$C_0$	Average of the pre- and post-run system cal bias responses from zero gas, ppmv.
$C_{Avg}$	Average unadjusted gas concentration for test run, ppmv.
$C_{Dir}$	Measured concentration of the cal gas when introduced in direct mode, ppmv.
$C_M$	Average of the pre- and post-run system cal bias responses from the upscale gas, ppmv.
$C_{MA}$	Actual concentration of the upscale calibration gas, ppmv.
$CS$	Calibration span, ppmv.
$C_S$	Measured concentration of the cal gas when introduced in the system cal mode, ppmv.
$C_V$	Manufacturer certified concentration of calibration gas, ppmv.
$SB_f$	Post-run system bias, percent of calibration span.
$SB_i$	Pre-run system bias, percent of calibration span.

Analyzer Calibration Error, ACE	Eq. 7E-1
---------------------------------	----------

$$ACE = \frac{C_{Dir} - C_V}{CS} \times 100$$

$ACE = -0.76\%$

$C_{Dir} = 24.36$	ppmv
$C_V = 24.77$	ppmv
$CS = 53.76$	ppmv

Initial Upscale System Bias, SB <sub>i</sub>	Eq. 7E-2
--	----------

$$SB_i = \frac{C_S - C_{Dir}}{CS} \times 100$$

$SB_i = -0.52\%$

$CS = 53.76$	ppmv
$C_S = 24.08$	ppmv
$C_{Dir} = 24.36$	ppmv

Upscale Drift Assessment, D	Eq. 7E-4
-----------------------------	----------

$$D = ABS|SB_f - SB_i|$$

$D = 2.00\%$

$SB_i = -0.52\%$	
$SB_f = 1.48\%$	

Effluent Gas Concentration, C <sub>Gas</sub>	Eq. 7E-5
--	----------

$$C_{Gas} = (C_{Avg} - C_0) \frac{C_{MA}}{C_M - C_0}$$

$C_{Gas} = 24.23$

$C_{Avg} = 24.08$	ppmv
$C_0 = 0.31$	ppmv
$C_{MA} = 24.77$	ppmv
$C_M = 24.62$	ppmv

NO <sub>2</sub> - NO Conversion Efficiency, Eff <sub>NO<sub>2</sub></sub>	Eq. 7E-7
---	----------

$$Eff_{NO_2} = \frac{C_{Dir}}{C_V} \times 100$$

$Eff_{NO_2} = 90.8\%$

$C_{Dir} = 54.92$	ppmv
$C_V = 60.52$	ppmv



# Erthwrks Emission Rate Example Calculations

Example Calculations for Emissions:	Run 1, CCR Charge Htr
Example Calculations for Pollutant:	NOx

Variable:	Description:
%O <sub>2d</sub>	Oxygen concentration measured on a dry basis, %
F <sub>d</sub>	Fuel F Factor for Natural Gas--Method 19 value, scf/MMBtu
MGV	Molar gas volume, volume of gas at standard conditions, scf/lbmol
MW <sub>NOx</sub>	Molecular Weight of NOx, lb/lbmol
n	Moles, lbmol
PPM <sub>NOx</sub>	Parts per million, NOx
p <sub>s</sub>	Standard Pressure, psi
R	Universal gas constant, ft <sup>3</sup> psi / R lbmol
T <sub>s</sub>	Standard Temperature, R
V	Volume, ft <sup>3</sup>

Molar Gas Volume (MGV) calculation at standard conditions	Ideal Gas Law
$MGV = \frac{V}{n} = \frac{R * T_s}{p}$	$T_s = 527.67$ $p = 14.696$ $R = 10.7316$
$MGV = 385.325 \frac{\text{scf}}{\text{lbfmol}}$	$R \text{ psi}$ $(ft^3 * psi) / (R * lbmol)$

Emission Concentration, C <sub>d</sub>	
$C_d = \frac{PPM * MW}{MGV} / 10^6$	PPM - NOx = 24.23 parts per million MW - NOx = 46.0055 lb/lb-mol
$C_d = 2.89E-06 \frac{\text{lb}}{\text{scf}}$	

Emission Rate Calculation, E <sub>(lb/MMBtu)</sub>	Eq. 19-1
$E_{(lb/MMBtu)} = C_d * F_d \frac{20.9}{20.9 - \%O_2d}$	$F_d = 8604 \text{ scf/MMBtu}$ $\%O_2d = 6.71 \text{ %}$
$E_{(lb/MMBtu)} = 0.0367 \frac{\text{lb}}{\text{MMBtu}}$	



## Erthwrks RATA Example Calculations

Example Calculations for Relative Accuracy: CCR Charge Htr  
 Example Calculations for Pollutant : NOx - lb/MMBtu

Variable:	Description:
$d$	Absolute difference between reference method and client CEMS
$i$	Run number
$n$	Number of runs
$d_{avg}$	Mean of the difference between reference method and client CEMS
$RM_{avg}$	Average of the reference method results for each run
AS	The unit's permit limit or applicable standard

Arithmetic Mean,  $d_{avg}$  Eq. 2-3

$$d_{avg} = \frac{1}{n} \sum_{i=1}^n d_i$$

$d_1 =$	-0.0041	$d_4 =$	-0.0053	$d_7 =$	-0.0041	$d_{10} =$	-0.0044
$d_2 =$	-0.0051	$d_5 =$	-0.0044	$d_8 =$	0	$d_{11} =$	0
$d_3 =$	-0.0046	$d_6 =$	-0.0045	$d_9 =$	-0.0044	$d_{12} =$	0
						$n =$	<b>9</b>

$d_{avg} = \mathbf{-0.0046}$

Standard Deviation,  $S_d$  Eq. 2-4

$$S_d = \sqrt{\frac{\sum_{i=1}^n d_i^2 - \frac{[\sum_{i=1}^n d_i]^2}{n}}{n - 1}}$$

$S_d = \mathbf{0.0004}$

Confidence Coefficient, CC Eq. 2-5

$$CC = t_{0.975} \frac{S_d}{n^{1/2}}$$

$t_{0.975} = \mathbf{2.306}$

$CC = \mathbf{0.0003}$

Relative Accuracy,  $RA_{RM}$  Eq. 2-6

$$RA_{RM} = \frac{|d_{avg}| + |CC|}{RM_{avg}} \times 100$$

$RM_1 =$	0.0367	$RM_4 =$	0.0351	$RM_7 =$	0.0365	$RM_{10} =$	0.0366
$RM_2 =$	0.0358	$RM_5 =$	0.0359	$RM_8 =$	0	$RM_{11} =$	0
$RM_3 =$	0.0358	$RM_6 =$	0.0357	$RM_9 =$	0.0378	$RM_{12} =$	0
$RM_{avg} =$	0.0362						

$RA_{RM} = \mathbf{13.45\%}$



**Example Calcs for Run 1 CCR Charge Heater Run 1**

Variable:	Description:
$B_{ws}$	Proportion of water vapor, by volume, in the gas stream
$C_f$	Conversion factor, sec/hr
$C_p$	Pilot coefficient, 0.84
$K_p$	Velocity equation constant, 5129.4 (ft/min) $[(lb/lb\text{-mole})(in\ Hg) / (R)(in\ H_2O)]^{0.5}$
$M_d$	Molecular weight of stack gas, dry
$M_s$	Molecular weight of stack gas, dry, g/g-mole (lb/lb-mole)
$M_w$	Molecular weight of water, g/g-mole (lb/lb-mole)
$P_m$	Absolute pressure at the dry gas meter = Barometric Pressure + $\Delta h_{avg} / 13.6$ , in Hg
$T_m$	Absolute Temperature at Meter, °R
$V_m$	Volume measured by DGM, dcf
$V_{m(std)}$	Dry gas volume measured by the dry gas meter, corrected to standard conditions, dscm (dscf)
$V_s$	Measured concentration of the cal gas when introduced in the system cal mode, ppmv
$V_{wc(std)}$	Volume of water vapor condensed, corrected to standard conditions, scm (scf)
$W_f$	Final imp weight, g
$W_i$	Initial imp weight, g
$Y$	Dry gas meter calibration factor, unitless

**Dry Molecular Weight of Stack Gas,  $M_d$** 

Eq. 3-1

$$M_d = 0.44(\%CO_2) + 0.32(\%O_2) + 0.28(\%N_2 + \%CO)$$

$M_d = \mathbf{29.63} \quad lb/lb\text{-mol}$

$\%O_2 = 6.63$
$\%CO_2 = 8.56$
$\%N_2 = 84.81$
$\%CO = 0.00$

**Volume of Water Vapor Collected,  $V_{wc(std)}$** 

Eq. 4-2

$$V_{wc(std)} = K_3(W_f - W_i)$$

$V_{wc(std)} = \mathbf{11.66} \quad ft^3$

$K_3 = 0.04715 \quad (ft^3/g)$
$W_i = 2540.80 \quad (g)$
$W_f = 2788.10 \quad (g)$

**Sample Gas Volume,  $V_{m(std)}$** 

Eq. 4-3

$$V_{m(std)} = \left( \frac{T_{std}}{P_{std}} * Y \right) \left( \frac{V_m * P_m}{T_m} \right)$$

$V_{m(std)} = \mathbf{68.35} \quad ft^3$

$T_{std} = 528 \quad (^{\circ}R)$
$P_{std} = 29.920 \quad (inHg)$
$V_m = 73.04 \quad (ft^3)$
$P_m = 29.45 \quad (in\ H_2O)$
$T_m = 549.3333 \quad (^{\circ}R)$
$Y = 0.989 \quad (\text{unitless})$

**Moisture Content,  $B_{ws}$** 

Eq. 4-4

$$B_{ws} = \frac{V_{wc(std)}}{V_{wc(std)} + V_{m(std)}}$$

$$B_{ws} = \mathbf{14.57\%}$$

**Molecular Weight of Stack Gas,  $M_s$** 

Eq. 2-6

$$M_s = M_d(1 - B_{ws}) + (M_w * B_{ws})$$

$M_w = 18.00 \quad (lb/lb\text{-mole})$

$$M_s = \mathbf{27.94}$$

Variable:	Description:
$\Delta p_{avg}$	Average velocity head of stack gas, mm H <sub>2</sub> O (in H <sub>2</sub> O)
$A_n$	Cross-sectional area of nozzle, ft <sup>2</sup>
$A$	Cross-sectional area of stack, ft <sup>2</sup>
$B_{ws}$	Proportion of water vapor, by volume, in the gas stream
$C_f$	Conversion factor, sec/hr
$C_p$	Pilot coefficient, 0.84
$K_p$	Velocity equation constant, 5129.4 (ft/min) [(lb/lb-mole)(in Hg) / (R)(in H <sub>2</sub> O)] <sup>0.5</sup>
$K_5$	Constant, 0.09450 for English units
$\Delta H@$	Orifice meter calibration coefficient, in H <sub>2</sub> O
$M_s$	Dry molecular weight of stack gas, lb/lb-mole
$Q$	Dry volumetric stack gas flow rate corrected to standard conditions, dscm/hr (dscf/hr)
$P_s$	Stack Pressure (Pbar + Pg)(in Hg)
$Y_{qa}$	Dry gas meter calibration check value, dimensionless
$P_{bar}$	Barometric pressure at the sampling site, mm Hg (in. Hg)
$P_{std}$	Standard absolute pressure, 760 mm Hg (29.92 in. Hg)
$T_m$	Absolute average DGM temperature, K (°R)
$T_s$	Absolute average stack gas temperature, 293 °K (528 °R)
$T_{s(abs)}$	Average Stack Temperature (°F) + 460, °R
$V_m$	Volume of gas sample as measured by dry gas meter, dcm (dcf)
$V_{m(std)}$	Dry gas volume measured by the dry gas meter, corrected to standard conditions, dscm (dscf)
$\theta$	Total sampling time, min
$V_s$	Measured concentration of the cal gas when introduced in the system cal mode, ppmv.

Average Stack Gas Velocity,  $V_s$ 

Eq. 2-7

$$V_s = K_p * C_p * \sqrt{\Delta p_{avg}} * \sqrt{\frac{T_{s(abs)}}{P_s * M_s}}$$

$K_p = 5129.4$   
 $C_p = 0.84$       unitless  
 $P_s = 29.30$       in H<sub>2</sub>O  
 $T_{s(abs)} = 840.4583$  °R  
 $(\Delta p_{avg})^{1/2} = 0.2909$   
 $M_s = 27.94$       lb/lb-mole

$V_s = 1269.89$  ft/min  
 $V_s = 21.164856$  ft/sec

Average Stack Gas Flow,  $Q_a$ 

$$Q_a = V_s * A$$

$A = 44.18$  ft<sup>2</sup>  
 $V_s = 1269.89$  ft/min

$$Q_a = 5.61E+04 \text{ acfm}$$

Wet Standard Stack Gas Flow,  $Q_{sw}$ 

$$Q_{sw} = Q_a * 60 * \left( \frac{T_{std}}{P_{std}} \right) * \left( \frac{P_s}{T_{s(abs)}} \right)$$

$P_s = 29.30$  in Hg  
 $P_{std} = 29.92$  in Hg  
 $T_{s(abs)} = 840.5$  °R  
 $T_{std} = 528$  °R

$Q_a = 2.07E+06$  wsfcfh

**Average Stack Gas Dry Volumetric Flow Rate, Q**

Eq. 2-8

$$Q = C_f * B_{ws} * A * V_s * \frac{T_{std} * P_s}{P_{std} * T_{s(abs)}}$$

$$Q = 1.77E+06 \text{ dscfh}$$

$$\begin{aligned} C_f &= 3600 \text{ sec/hr} \\ A &= 44.18 \text{ ft}^2 \\ B_{ws} &= 0.854 \text{ unitless} \\ P_s &= 29.30 \text{ in Hg} \\ P_{std} &= 29.92 \text{ in Hg} \\ T_{s(abs)} &= 840.5 \text{ °R} \\ T_{std} &= 528 \text{ °R} \\ V_s &= 21.16 \text{ ft/sec} \end{aligned}$$

**Percent Isokinetic, I**

Eq. 5-8

$$I = \frac{T_s * V_{m(std)} * P_{s(std)} * 100}{T_{(std)} * v_s * \theta * A_n * P_s * 60 * (1 - B_{ws})}$$

$$I = 98.6 \text{ %}$$

$$\begin{aligned} T_s &= 840.4583 \text{ °R} \\ V_{m(std)} &= 68.35 \text{ dscf} \\ P_s &= 29.30 \text{ in Hg} \\ v_s &= 21.16 \text{ ft/sec} \\ A_n &= 1.15E-03 \text{ ft}^2 \\ \theta &= 90 \text{ min} \\ B_{ws} &= 0.854 \text{ unitless} \end{aligned}$$

**Post-Test Metering Calibration**

Eq. 5-15

$$Y_{qa} = \frac{\theta}{V_m} \sqrt{\frac{0.0319 T_m}{\Delta H @ \left( P_{bar} + \frac{\Delta H_{avg}}{13.6} \right)}} \left( \frac{29}{M_s} \right) \sqrt{\Delta H_{avg}}$$

$$Y_{run\ 1} = 0.957$$

$$Y_{run\ 2} = 0.963$$

$$Y_{run\ 3} = 0.953$$

$$Y_{qa\ (avg)} = 0.958$$

$$Y_{pre-cal} = 0.989$$

$$\%difference = 3.1\%$$

$$\text{Run 1: } \Delta H @ = 1.816 \text{ unitless}$$

$$T_m = 549.3333 \text{ °R}$$

$$P_{bar} = 29.31 \text{ in H}_2\text{O}$$

$$V_m = 73.04 \text{ dcf}$$

$$\Delta H_{avg} = 1.92 \text{ in H}_2\text{O}$$

$$\text{Run 2: } \Delta H @ = 1.816 \text{ unitless}$$

$$T_m = 547.9583 \text{ °R}$$

$$P_{bar} = 29.31 \text{ in H}_2\text{O}$$

$$V_m = 74.64 \text{ dfc}$$

$$\Delta H_{avg} = 2.04 \text{ in H}_2\text{O}$$

$$\text{Run 3: } \Delta H @ = 1.816 \text{ unitless}$$

$$T_m = 550.25 \text{ °R}$$

$$P_{bar} = 29.31 \text{ in H}_2\text{O}$$

$$V_m = 76.99 \text{ dcf}$$

$$\Delta H_{avg} = 2.12 \text{ in H}_2\text{O}$$

Example Calcs for Run : CCR Charge Heater Run 1

Variable:	Description:
$m_t$	Total mass of particulates, mg
$V_{std}$	Standard gas volume, %
$Q_{sd}$	Dry standard stack flow rate, dscfh
Clinker Rate	

Particulate Matter Mass Concentration,  $C_m$

$$C_m = \frac{m_t}{453592} * \frac{1}{V_{std}}$$

$m_t = 10.76$  (mg)  
 $V_{std} = 68.35$  (dscf)

$C_m = 3.47E-07$  lb/dscf

Particulate Matter Mass Emission Rate per Hour,  $E_h$

$$E_h = C_m * Q_{sd}$$

$Q_{sd} = 1.77E+06$  (dscfh)

$E_h = 0.61$  lb/hr

Particulate Matter Mass Emission Rate per Day,  $E_d$

$E_d = E_h * 24$

$E_d = 14.74$  lb/day

Particulate Matter Mass Emission Rate,  $E_{TC}$

Firing Rate = 125.98 (MMbtu/hr)

$$E_{TC} = \frac{E_h}{\text{Firing Rate}}$$

$E_{TC} = 0.0049$  lb/MMbtu

# Erthwrks Emission Rate Example Calculations

Example Calculations for Emissions :	Run 1,	CCR Charge Heater
Example Calculations for Pollutant :	$H_2SO_4$	

Variable:	Description:
%O <sub>2</sub> d	Oxygen concentration measured on a dry basis, %
F <sub>d</sub>	Fuel F Factor for Natural Gas--Method 19 value, scf/MMBtu
MGV	Molar gas volume, volume of gas at standard conditions, scf/lbmol
MW	Molecular Weight, lb/lbmol
n	Moles, lbmol
PPM	Parts per million
m <sub>t</sub>	Weight of $H_2SO_4$ , from lab analysis
p <sub>s</sub>	Standard Pressure, psi
R	Universal gas constant, ft <sup>3</sup> psi / R lbmol
T <sub>s</sub>	Standard Temperature, R
V	Volume, ft <sup>3</sup>

Molar Gas Volume (MGV) calculation at standard conditions	Ideal Gas Law
---	---------------

$$MGV = \frac{V}{n} = \frac{R * T_s}{p}$$

$T_s = 527.67 \quad R$   
 $p = 14.696 \quad \text{psi}$   
 $R = 10.7316 \quad (\text{ft}^3 * \text{psi}) / (\text{R} * \text{lbmol})$

$$MGV = 385.325 \quad \frac{\text{scf}}{\text{lbmol}}$$

Emission Concentration, C <sub>d</sub> (lb/scf)	
---	--

$$C_{d-lb/scf} = \frac{m_t(\text{lb})}{\text{Train Volume}}$$

Train Volume = 19.91      scf  
 $m_t(\text{ug}) = 122.0 \quad \text{ug}$   
 $m_t(\text{lb}) 2.69E-07 \quad \text{lb}$

$$C_d(\text{lb}/\text{scf}) = 1.351E-08 \quad \frac{\text{lb}}{\text{scf}}$$

Emission Concentration, C <sub>d</sub> (ppm)	
--	--

$$C_d = \frac{Cd \left( \frac{\text{lb}}{\text{scf}} \right) * 10^6 * MGV}{MW}$$

$Cd(\text{lb}/\text{scf}) 1.35E-08 \quad \text{lb}/\text{scf}$   
 $MGV = 385.325 \quad \text{scf}/\text{lbmol}$   
 $MW = 98.079 \quad \text{lb}/\text{lb-mol}$

$$C_d = 0.05 \quad \text{ppm}$$

Emission Rate Calculation, E <sub>d</sub> (lb/MMBtu)	Eq. 19-1
--	----------

$$E_d(lb/MMBtu) = C_d \left( \frac{lb}{scf} \right) * F_d \frac{20.9}{20.9 - \%O_2d}$$

$Cd(\text{lb}/\text{scf}) 1.35E-08 \quad \text{lb}/\text{scf}$   
 $F_d = 8604.0 \quad \text{scf}/\text{MMBtu}$   
 $\%O_2d = 6.63 \quad \%$

$$E_d(lb/MMBtu) = 0.0002 \quad \frac{\text{lb}}{\text{MMBtu}}$$



**Attachment E**  
**Raw Data Log Records**

## Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 8:20	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.25	-0.40	20.49	0.00
6/1/22 8:21	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.25	-0.38	20.48	0.00
6/1/22 8:22	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.26	-0.37	20.33	0.09
6/1/22 8:23	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.26	-0.67	19.85	17.19
6/1/22 8:24	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.26	-1.26	19.94	20.26
6/1/22 8:25	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.23	-1.07	19.94	20.33
6/1/22 8:26	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.22	-0.98	19.94	20.27
6/1/22 8:27	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.22	-0.94	19.94	20.23
6/1/22 8:28	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.22	-0.90	19.94	20.34
6/1/22 8:29	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.20	-0.88	19.93	20.42
6/1/22 8:30	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.20	-0.83	19.95	20.36
6/1/22 8:31	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.09	-0.28	19.96	20.28
6/1/22 8:32	9049.1.B3	MPC	Detroit	CCR Charge Htr	Direct Cal	0.02	0.07	19.95	19.61
6/1/22 8:33	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.46	23.90	5.53	7.39
6/1/22 8:34	9049.1.B3	MPC	Detroit	CCR Charge Htr		61.61	49.06	0.03	0.02
6/1/22 8:34	9049.1.B3	MPC	Detroit	CCR Charge Htr		59.23	49.72	0.02	0.00
6/1/22 8:35	9049.1.B3	MPC	Detroit	CCR Charge Htr	Direct Cal	53.76	50.94	0.03	0.00
6/1/22 8:36	9049.1.B3	MPC	Detroit	CCR Charge Htr		32.08	22.56	7.82	6.15
6/1/22 8:37	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.33	1.04	9.97	9.69
6/1/22 8:38	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.26	0.88	9.96	9.73
6/1/22 8:39	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.19	0.86	9.96	9.74
6/1/22 8:40	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.15	0.89	9.96	9.73
6/1/22 8:41	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.11	0.89	9.96	9.71
6/1/22 8:42	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.10	0.87	9.97	9.70
6/1/22 8:43	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.09	0.93	9.96	9.80
6/1/22 8:44	9049.1.B3	MPC	Detroit	CCR Charge Htr	Direct Cal	0.03	0.32	9.96	10.08
6/1/22 8:45	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.19	2.44	5.47	6.48
6/1/22 8:46	9049.1.B3	MPC	Detroit	CCR Charge Htr		12.96	22.22	0.11	0.06
6/1/22 8:47	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.03	25.79	0.04	0.00
6/1/22 8:47	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.14	25.78	0.04	0.00
6/1/22 8:48	9049.1.B3	MPC	Detroit	CCR Charge Htr	Direct Cal	24.36	25.78	0.03	0.00
6/1/22 8:49	9049.1.B3	MPC	Detroit	CCR Charge Htr		32.29	19.34	14.92	0.00
6/1/22 8:50	9049.1.B3	MPC	Detroit	CCR Charge Htr		52.96	1.54	20.97	0.00
6/1/22 8:50	9049.1.B3	MPC	Detroit	CCR Charge Htr		54.63	0.44	20.97	0.00
6/1/22 8:51	9049.1.B3	MPC	Detroit	CCR Charge Htr	NOx Conv Eff.	54.92	0.42	20.98	0.00
6/1/22 8:52	9049.1.B3	MPC	Detroit	CCR Charge Htr		55.34	0.42	20.98	0.00
6/1/22 8:53	9049.1.B3	MPC	Detroit	CCR Charge Htr		37.99	7.01	13.62	3.17
6/1/22 8:54	9049.1.B3	MPC	Detroit	CCR Charge Htr		21.40	3.87	6.25	8.46
6/1/22 8:55	9049.1.B3	MPC	Detroit	CCR Charge Htr		14.69	6.53	8.91	8.51
6/1/22 8:55	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.67	0.52	9.97	9.85
6/1/22 8:56	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	0.47	-0.30	9.97	9.91
6/1/22 8:57	9049.1.B3	MPC	Detroit	CCR Charge Htr		1.50	0.46	6.96	8.22
6/1/22 8:58	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.82	18.63	0.28	0.36
6/1/22 8:58	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.33	24.81	0.24	0.03
6/1/22 8:59	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	24.08	25.03	0.21	0.01
6/1/22 9:00	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.95	24.39	1.41	1.16
6/1/22 9:01	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.41	6.97	5.74	8.57
6/1/22 9:02	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.10	-0.33	5.95	9.00
6/1/22 9:03	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.82	-0.48	6.29	8.85
6/1/22 9:04	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.60	-0.50	6.35	8.72
6/1/22 9:05	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.64	-0.52	6.35	8.69
6/1/22 9:06	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.77	-0.49	6.33	8.75
6/1/22 9:07	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.72	-0.52	6.35	8.77



## Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 9:08	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.71	-0.53	6.39	8.71
6/1/22 9:09	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.78	-0.54	6.36	8.71
6/1/22 9:10	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.78	-0.55	6.35	8.75
6/1/22 9:11	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.57	-0.52	6.65	8.62
6/1/22 9:12	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.41	-0.54	6.89	8.45
6/1/22 9:13	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.78	-0.57	7.07	8.38
6/1/22 9:14	9049.1.B3	MPC	Detroit	CCR Charge Htr		21.44	-0.64	7.28	8.22
6/1/22 9:15	9049.1.B3	MPC	Detroit	CCR Charge Htr		21.87	-0.66	7.27	8.17
6/1/22 9:16	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.08	-0.70	7.26	8.17
6/1/22 9:17	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.17	-0.68	7.16	8.22
6/1/22 9:18	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.15	-0.68	7.16	8.27
6/1/22 9:19	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.13	-0.65	7.22	8.25
6/1/22 9:20	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.14	-0.66	7.18	8.24
6/1/22 9:21	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.15	-0.70	7.19	8.24
6/1/22 9:22	9049.1.B3	MPC	Detroit	CCR Charge Htr		21.94	1.02	8.15	8.19
6/1/22 9:23	9049.1.B3	MPC	Detroit	CCR Charge Htr		2.24	0.06	9.91	9.88
6/1/22 9:24	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.21	-0.76	9.94	9.95
6/1/22 9:25	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.18	-0.81	9.95	9.92
6/1/22 9:26	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.15	-0.53	8.38	9.17
6/1/22 9:27	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.45	15.42	0.32	0.75
6/1/22 9:28	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.76	24.51	0.23	0.03
6/1/22 9:29	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.97	24.64	0.24	0.00
6/1/22 9:30	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.17	24.60	0.21	0.00
6/1/22 9:31	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.29	24.19	1.56	0.85
6/1/22 9:32	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.23	7.44	6.92	7.81
6/1/22 9:33	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.57	-0.51	6.95	8.33
6/1/22 9:34	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.79	-0.67	6.89	8.40
6/1/22 9:35	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.64	-0.62	6.84	8.45
6/1/22 9:36	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.60	-0.59	6.80	8.50
6/1/22 9:37	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.64	-0.58	6.87	8.46
6/1/22 9:38	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.65	-0.53	6.85	8.41
6/1/22 9:39	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.67	-0.58	6.81	8.42
6/1/22 9:40	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.63	-0.55	6.82	8.44
6/1/22 9:41	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.57	-0.57	6.83	8.43
6/1/22 9:42	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.49	-0.57	6.83	8.45
6/1/22 9:43	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.44	-0.56	6.80	8.44
6/1/22 9:44	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.42	-0.59	6.80	8.45
6/1/22 9:45	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.45	-0.60	6.79	8.47
6/1/22 9:46	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.56	-0.66	6.72	8.50
6/1/22 9:47	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.60	-0.64	6.70	8.53
6/1/22 9:48	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.50	-0.64	6.79	8.53
6/1/22 9:49	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.42	-0.58	6.84	8.46
6/1/22 9:50	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.45	-0.55	6.83	8.45
6/1/22 9:51	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.49	-0.58	6.80	8.47
6/1/22 9:52	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.52	-0.54	6.73	8.50
6/1/22 9:53	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.51	-0.56	6.79	8.53
6/1/22 9:54	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.47	-0.55	6.80	8.48
6/1/22 9:55	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.35	-0.55	6.79	8.45
6/1/22 9:56	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.37	-0.56	6.74	8.49
6/1/22 9:57	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.40	-0.54	6.71	8.53
6/1/22 9:58	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.49	-0.54	6.75	8.55
6/1/22 9:59	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.55	-0.54	6.77	8.51
6/1/22 10:00	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.60	-0.56	6.72	8.49

## Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 10:01	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.66	-0.55	6.73	8.52
6/1/22 10:02	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.74	-0.56	6.73	8.53
6/1/22 10:03	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.77	-0.57	6.81	8.50
6/1/22 10:04	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.77	-0.58	6.79	8.47
6/1/22 10:05	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.76	-0.64	6.77	8.47
6/1/22 10:06	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.63	-0.66	6.77	8.45
6/1/22 10:07	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.42	-0.69	6.70	8.45
6/1/22 10:08	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.22	-0.67	6.61	8.50
6/1/22 10:09	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.05	-0.65	6.59	8.55
6/1/22 10:10	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.98	-0.69	6.60	8.56
6/1/22 10:11	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.99	-0.70	6.56	8.57
6/1/22 10:11	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.96	-0.70	6.57	8.54
6/1/22 10:12	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	23.96	-0.67	6.59	8.52
6/1/22 10:13	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	23.95	-0.70	6.61	8.53
6/1/22 10:14	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.02	-0.71	6.62	8.52
6/1/22 10:15	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.11	-0.73	6.55	8.54
6/1/22 10:16	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.18	-0.77	6.67	8.52
6/1/22 10:17	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.20	-0.77	6.71	8.46
6/1/22 10:18	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.26	-0.74	6.67	8.47
6/1/22 10:19	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.37	-0.72	6.63	8.49
6/1/22 10:20	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.39	-0.74	6.63	8.51
6/1/22 10:21	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.23	-0.73	6.69	8.51
6/1/22 10:22	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.15	-0.72	6.72	8.46
6/1/22 10:23	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.17	-0.72	6.75	8.43
6/1/22 10:24	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.16	-0.73	6.65	8.50
6/1/22 10:25	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	23.99	-0.77	6.66	8.52
6/1/22 10:26	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	23.99	-0.76	6.59	8.53
6/1/22 10:27	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.07	-0.74	6.51	8.56
6/1/22 10:28	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	24.00	-0.72	6.51	8.58
6/1/22 10:29	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	23.88	-0.78	6.57	8.57
6/1/22 10:30	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	23.89	-0.77	6.53	8.56
6/1/22 10:31	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	23.89	-0.76	6.59	8.56
6/1/22 10:32	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 1	23.91	-0.76	6.65	8.51
					Run Average	24.08	-0.74	6.62	8.52
6/1/22 10:33	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.07	-0.73	7.95	8.73
6/1/22 10:33	9049.1.B3	MPC	Detroit	CCR Charge Htr		11.05	-0.70	9.91	9.91
6/1/22 10:34	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	0.15	-0.53	9.92	10.07
6/1/22 10:35	9049.1.B3	MPC	Detroit	CCR Charge Htr		11.42	8.43	1.75	2.96
6/1/22 10:36	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	25.16	25.13	-0.01	0.00
6/1/22 10:37	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.11	25.81	-0.01	0.00
6/1/22 10:38	9049.1.B3	MPC	Detroit	CCR Charge Htr		26.17	25.87	-0.01	0.00
6/1/22 10:39	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.22	8.89	-0.01	0.00
						3.00			
6/1/22 10:40	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	25.20	-0.29	6.29	8.76
6/1/22 10:41	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	25.10	-0.28	6.32	8.74
6/1/22 10:42	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	24.99	-0.27	6.35	8.72
6/1/22 10:43	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	24.88	-0.27	6.38	8.71
6/1/22 10:44	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	24.77	-0.26	6.41	8.69
6/1/22 10:45	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	24.67	-0.25	6.44	8.68
6/1/22 10:46	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	24.56	-0.24	6.47	8.66
6/1/22 10:47	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	24.45	-0.23	6.50	8.64

# Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>X</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 10:48	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	24.34	-0.23	6.53	8.63
6/1/22 10:49	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	24.24	-0.22	6.56	8.61
6/1/22 10:50	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	24.11	-0.21	6.62	8.57
6/1/22 10:51	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	24.05	-0.19	6.59	8.60
6/1/22 10:52	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	23.92	-0.21	6.64	8.58
6/1/22 10:53	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	23.78	-0.18	6.67	8.56
6/1/22 10:54	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	23.71	-0.18	6.72	8.51
6/1/22 10:55	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	23.78	-0.20	6.62	8.53
6/1/22 10:56	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	23.75	-0.21	6.56	8.56
6/1/22 10:57	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	23.52	-0.20	6.53	8.60
6/1/22 10:58	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	23.26	-0.16	6.52	8.63
6/1/22 10:59	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	23.17	-0.14	6.51	8.62
6/1/22 11:00	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 2	23.15	-0.17	6.45	8.61
					Run Average	24.16	-0.22	6.51	8.63
6/1/22 11:01	9049.1.B3	MPC	Detroit	CCR Charge Htr		18.98	-0.17	6.50	8.53
6/1/22 11:02	9049.1.B3	MPC	Detroit	CCR Charge Htr		18.82	-0.09	6.53	8.49
6/1/22 11:03	9049.1.B3	MPC	Detroit	CCR Charge Htr		18.83	-0.04	6.60	8.48
6/1/22 11:04	9049.1.B3	MPC	Detroit	CCR Charge Htr		9.45	0.02	7.56	9.31
6/1/22 11:05	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	0.23	0.02	9.96	9.99
6/1/22 11:06	9049.1.B3	MPC	Detroit	CCR Charge Htr		3.35	4.44	4.38	6.27
6/1/22 11:07	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.61	24.81	0.12	0.23
6/1/22 11:08	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	25.15	25.66	0.05	0.03
6/1/22 11:09	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.32	18.16	4.42	5.51
6/1/22 11:10	9049.1.B3	MPC	Detroit	CCR Charge Htr		18.89	1.03	6.49	8.54
6/1/22 11:11	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.94	0.05	6.53	8.54
6/1/22 11:12	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	23.97	0.02	6.62	8.46
6/1/22 11:13	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.06	-0.05	6.63	8.44
6/1/22 11:14	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.21	-0.03	6.69	8.43
6/1/22 11:15	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.36	-0.06	6.59	8.44
6/1/22 11:16	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.55	-0.05	6.46	8.53
6/1/22 11:17	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.65	-0.07	6.42	8.57
6/1/22 11:18	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.61	-0.12	6.42	8.59
6/1/22 11:19	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.53	-0.04	6.44	8.57
6/1/22 11:20	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.49	-0.02	6.40	8.60
6/1/22 11:21	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.40	-0.05	6.37	8.62
6/1/22 11:22	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.27	-0.04	6.40	8.61
6/1/22 11:23	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.12	-0.02	6.46	8.58
6/1/22 11:24	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.09	0.00	6.41	8.58
6/1/22 11:25	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.14	-0.05	6.50	8.53
6/1/22 11:26	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.19	-0.05	6.37	8.55
6/1/22 11:27	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.23	-0.04	6.22	8.68
6/1/22 11:28	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.29	-0.08	6.24	8.71
6/1/22 11:29	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.31	-0.11	6.28	8.66
6/1/22 11:30	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.24	-0.12	6.28	8.64
6/1/22 11:31	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.11	-0.12	6.33	8.64
6/1/22 11:32	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 3	24.06	-0.11	6.40	8.60
					Run Average	24.28	-0.06	6.42	8.57
6/1/22 11:33	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.16	-0.09	6.41	8.60
6/1/22 11:34	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.25	-0.09	6.55	8.50
6/1/22 11:35	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.29	-0.11	6.54	8.45

## Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 11:36	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.40	-0.04	6.48	8.52
6/1/22 11:37	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.44	-0.09	6.45	8.53
6/1/22 11:38	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.44	-0.12	6.44	8.57
6/1/22 11:39	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.48	-0.09	6.40	8.58
6/1/22 11:40	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.50	-0.07	6.39	8.60
6/1/22 11:41	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.48	-0.07	6.35	8.59
6/1/22 11:42	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.36	-0.11	6.30	8.63
6/1/22 11:43	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.35	-0.12	6.37	8.65
6/1/22 11:44	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.36	-0.15	6.40	8.60
6/1/22 11:45	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.29	-0.15	6.50	8.55
6/1/22 11:46	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.36	-0.18	6.60	8.49
6/1/22 11:47	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.68	-0.19	6.59	8.48
6/1/22 11:48	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.88	-0.19	6.61	8.49
6/1/22 11:49	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.00	-0.21	6.55	8.49
6/1/22 11:50	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.09	-0.17	6.58	8.49
6/1/22 11:51	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.13	-0.17	6.60	8.46
6/1/22 11:52	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.05	-0.19	6.61	8.42
6/1/22 11:53	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.14	-0.22	6.50	8.49
6/1/22 11:54	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.27	-0.23	6.39	8.59
6/1/22 11:55	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.20	-0.19	6.43	8.58
6/1/22 11:56	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.20	-0.17	6.47	8.54
6/1/22 11:57	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.25	-0.21	6.37	8.57
6/1/22 11:58	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.21	-0.20	6.45	8.58
6/1/22 11:59	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.12	-0.23	6.46	8.55
6/1/22 12:00	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.12	-0.23	6.48	8.54
6/1/22 12:01	9049.1.B3	MPC	Detroit	CCR Charge Htr		20.24	-0.26	6.57	8.51
6/1/22 12:02	9049.1.B3	MPC	Detroit	CCR Charge Htr		17.23	-0.21	8.05	8.78
6/1/22 12:03	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.18	-0.44	9.68	9.90
6/1/22 12:04	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.04	-0.58	9.68	9.98
6/1/22 12:05	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.03	-0.58	9.68	9.98
6/1/22 12:06	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.04	-0.57	9.72	9.97
6/1/22 12:07	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.06	-0.67	9.81	9.96
6/1/22 12:08	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.03	-0.77	9.88	10.02
6/1/22 12:09	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	0.03	-0.61	9.89	10.06
6/1/22 12:10	9049.1.B3	MPC	Detroit	CCR Charge Htr		7.63	7.12	2.32	3.51
6/1/22 12:11	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.66	24.58	-0.01	0.01
6/1/22 12:12	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.74	25.46	-0.01	0.00
6/1/22 12:13	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.93	25.50	-0.01	0.00
6/1/22 12:14	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	25.15	25.52	0.00	0.00
6/1/22 12:15	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.57	19.49	5.23	4.60
6/1/22 12:16	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.12	1.45	6.62	8.43
6/1/22 12:17	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.99	-0.37	6.61	8.52
6/1/22 12:18	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.89	-0.32	6.67	8.47
6/1/22 12:19	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.86	-0.32	6.59	8.44
6/1/22 12:20	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.86	-0.31	6.46	8.51
6/1/22 12:21	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.80	-0.32	6.48	8.57
6/1/22 12:22	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.64	-0.28	6.45	8.54
6/1/22 12:23	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.45	-0.29	6.39	8.56
6/1/22 12:24	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.39	-0.33	6.40	8.63
6/1/22 12:25	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.38	-0.29	6.46	8.57
6/1/22 12:26	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.41	-0.33	6.53	8.53
6/1/22 12:27	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.50	-0.39	6.51	8.51
6/1/22 12:28	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.44	-0.39	6.49	8.54

# Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 12:29	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.28	-0.35	6.54	8.52
6/1/22 12:30	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.21	-0.39	6.61	8.47
6/1/22 12:31	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.25	-0.35	6.58	8.45
6/1/22 12:32	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.32	-0.34	6.56	8.48
6/1/22 12:33	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.31	-0.34	6.64	8.47
6/1/22 12:34	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.38	-0.41	6.67	8.42
6/1/22 12:35	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.61	-0.39	6.83	8.35
6/1/22 12:36	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.85	-0.32	7.12	8.17
6/1/22 12:37	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.14	-0.37	7.36	8.02
6/1/22 12:38	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.46	-0.44	7.20	8.02
6/1/22 12:39	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.80	-0.47	6.95	8.18
6/1/22 12:40	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.62	-0.46	6.77	8.31
6/1/22 12:41	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.12	-0.43	6.86	8.32
6/1/22 12:42	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.81	-0.44	6.78	8.31
6/1/22 12:43	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.77	-0.42	6.82	8.31
6/1/22 12:44	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.57	-0.42	6.81	8.31
6/1/22 12:45	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.33	-0.39	6.79	8.32
6/1/22 12:46	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.12	-0.35	6.77	8.29
6/1/22 12:47	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.07	-0.34	6.74	8.28
6/1/22 12:48	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.12	-0.35	6.71	8.28
6/1/22 12:49	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.18	-0.34	6.73	8.29
6/1/22 12:50	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.15	-0.32	6.76	8.27
6/1/22 12:51	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.18	-0.30	6.82	8.25
6/1/22 12:52	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.22	-0.34	6.82	8.22
6/1/22 12:53	9049.1.B3	MPC	Detroit	CCR Charge Htr		21.41	-0.35	6.96	8.18
6/1/22 12:54	9049.1.B3	MPC	Detroit	CCR Charge Htr		21.62	-0.25	7.02	8.05
6/1/22 12:55	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.88	-0.32	6.71	8.53
6/1/22 12:56	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.50	-0.41	6.69	8.57
6/1/22 12:56	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.24	-0.35	6.66	8.58
6/1/22 12:57	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.95	-0.38	6.66	8.57
6/1/22 12:58	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.86	-0.39	6.69	8.57
6/1/22 12:59	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.85	-0.38	6.71	8.54
6/1/22 13:00	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.92	-0.36	6.65	8.54
6/1/22 13:00	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.96	-0.37	6.63	8.58
6/1/22 13:01	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.06	-0.46	6.65	8.58
6/1/22 13:02	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.17	-0.44	6.68	8.56
6/1/22 13:03	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.77	-0.44	6.65	8.57
6/1/22 13:04	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.71	-0.45	6.65	8.57
6/1/22 13:05	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.64	-0.45	6.65	8.57
6/1/22 13:06	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.58	-0.46	6.64	8.57
6/1/22 13:07	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.49	-0.31	7.01	8.55
6/1/22 13:07	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.75	-0.24	7.00	8.41
6/1/22 13:08	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.53	-0.42	6.88	8.43
6/1/22 13:09	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.56	-0.48	6.88	8.43
6/1/22 13:10	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.29	-0.36	6.88	8.43
6/1/22 13:11	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.95	-0.35	6.92	8.44
6/1/22 13:12	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.88	-0.36	6.91	8.45
6/1/22 13:13	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.97	-0.50	6.95	8.45
6/1/22 13:14	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.97	-0.47	6.98	8.39
6/1/22 13:15	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.98	-0.46	6.96	8.38
6/1/22 13:16	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.99	-0.49	6.99	8.39
6/1/22 13:17	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.02	-0.49	6.97	8.39
6/1/22 13:18	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.04	-0.54	6.96	8.41

RECEIVED  
AUG 01 2022

## Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 13:19	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.99	-0.51	6.94	8.40
6/1/22 13:20	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.86	-0.40	6.88	8.42
6/1/22 13:21	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.82	-0.37	6.88	8.44
6/1/22 13:22	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.86	-0.36	6.90	8.45
6/1/22 13:23	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.89	-0.40	6.92	8.46
6/1/22 13:24	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.87	-0.49	6.79	8.48
6/1/22 13:25	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.87	-0.52	6.71	8.52
6/1/22 13:26	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.88	-0.58	6.75	8.54
6/1/22 13:27	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.80	-0.54	6.79	8.52
6/1/22 13:28	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.74	-0.46	6.78	8.53
6/1/22 13:29	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.77	-0.34	7.38	8.55
6/1/22 13:30	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.38	-0.19	7.45	8.15
6/1/22 13:30	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.35	-0.21	7.36	8.19
6/1/22 13:31	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.32	-0.23	7.27	8.23
6/1/22 13:32	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.18	-0.25	7.07	8.36
6/1/22 13:33	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.26	-0.21	7.12	8.30
6/1/22 13:34	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.31	-0.27	7.08	8.30
6/1/22 13:35	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.27	-0.41	6.98	8.31
6/1/22 13:36	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.16	-0.37	6.88	8.40
6/1/22 13:37	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.03	-0.33	6.75	8.48
6/1/22 13:38	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.07	-0.32	6.56	8.58
6/1/22 13:39	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.49	-0.43	6.86	8.46
6/1/22 13:40	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.51	-0.41	6.84	8.49
6/1/22 13:41	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.54	-0.39	6.79	8.51
6/1/22 13:42	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.46	-0.39	6.79	8.53
6/1/22 13:43	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.34	-0.38	6.81	8.51
6/1/22 13:44	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.32	-0.42	6.78	8.53
6/1/22 13:45	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.41	-0.42	6.77	8.55
6/1/22 13:46	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.52	-0.35	6.84	8.54
6/1/22 13:47	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.47	-0.40	6.79	8.50
6/1/22 13:48	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.39	-0.42	6.78	8.50
6/1/22 13:49	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.42	-0.42	6.78	8.51
6/1/22 13:50	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.49	-0.41	6.80	8.52
6/1/22 13:51	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.54	-0.47	6.84	8.53
6/1/22 13:52	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.57	-0.49	6.91	8.49
6/1/22 13:53	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.68	-0.53	6.80	8.51
6/1/22 13:54	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.79	-0.54	6.71	8.56
6/1/22 13:55	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.86	-0.49	6.63	8.62
6/1/22 13:56	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.83	-0.48	6.70	8.66
6/1/22 13:57	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.72	-0.55	6.64	8.64
6/1/22 13:58	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.73	-0.57	6.63	8.64
6/1/22 13:59	9049.1.B3	MPC	Detroit	CCR Charge Htr		19.77	1.11	8.05	8.39
6/1/22 13:59	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.20	1.00	9.90	9.92
6/1/22 14:00	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	-0.27	-0.46	9.92	10.07
6/1/22 14:01	9049.1.B3	MPC	Detroit	CCR Charge Htr		-0.36	-0.41	8.73	9.71
6/1/22 14:02	9049.1.B3	MPC	Detroit	CCR Charge Htr		12.55	14.95	0.08	0.77
6/1/22 14:03	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.62	25.18	-0.02	0.03
6/1/22 14:04	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	25.70	25.34	-0.05	0.01
6/1/22 14:05	9049.1.B3	MPC	Detroit	CCR Charge Htr		27.24	15.95	5.68	5.70
6/1/22 14:06	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.65	0.24	6.72	8.46
6/1/22 14:07	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.45	-0.47	6.56	8.65
6/1/22 14:08	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.41	-0.56	6.56	8.69
6/1/22 14:09	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.29	-0.53	6.61	8.65

## Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 14:10	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.13	-0.49	6.62	8.59
6/1/22 14:11	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.12	-0.51	6.65	8.61
6/1/22 14:12	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.10	-0.50	6.73	8.57
6/1/22 14:13	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.13	-0.49	6.78	8.55
6/1/22 14:14	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.29	-0.50	6.76	8.57
6/1/22 14:15	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.53	-0.53	6.69	8.59
6/1/22 14:16	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.60	-0.56	6.66	8.63
6/1/22 14:17	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.59	-0.45	6.64	8.64
6/1/22 14:18	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.52	-0.49	6.59	8.68
6/1/22 14:19	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.48	-0.48	6.52	8.70
6/1/22 14:20	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.38	-0.42	6.50	8.72
6/1/22 14:21	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.26	-0.45	6.53	8.73
6/1/22 14:22	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.10	-0.43	6.58	8.70
6/1/22 14:23	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.99	-0.41	6.65	8.64
6/1/22 14:24	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.92	-0.45	6.65	8.62
6/1/22 14:25	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.99	-0.46	6.64	8.63
6/1/22 14:26	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.96	-0.47	6.67	8.59
6/1/22 14:27	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.88	-0.44	6.61	8.60
6/1/22 14:28	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.92	-0.41	6.55	8.68
6/1/22 14:29	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.86	-0.37	6.61	8.68
6/1/22 14:30	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.76	-0.41	6.72	8.62
6/1/22 14:31	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.88	-0.41	6.78	8.55
6/1/22 14:32	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.05	-0.44	6.83	8.52
6/1/22 14:33	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.07	-0.43	6.88	8.49
6/1/22 14:34	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.10	-0.43	6.76	8.53
6/1/22 14:35	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.06	-0.52	6.75	8.61
6/1/22 14:36	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.99	-0.51	6.80	8.59
6/1/22 14:37	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.95	-0.45	6.84	8.55
6/1/22 14:38	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.05	-0.43	6.86	8.53
6/1/22 14:39	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.13	-0.44	6.76	8.55
6/1/22 14:40	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.17	-0.39	6.60	8.65
6/1/22 14:41	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.13	-0.42	6.52	8.74
6/1/22 14:42	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.01	-0.47	6.59	8.72
6/1/22 14:43	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.88	-0.47	6.61	8.65
6/1/22 14:44	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.87	-0.55	6.62	8.63
6/1/22 14:45	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.92	-0.47	6.77	8.58
6/1/22 14:46	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.89	-0.48	6.86	8.52
6/1/22 14:47	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.92	-0.46	6.85	8.52
6/1/22 14:48	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.03	-0.49	6.77	8.52
6/1/22 14:49	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.12	-0.50	6.72	8.57
6/1/22 14:50	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.08	-0.52	6.71	8.61
6/1/22 14:51	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.03	-0.53	6.66	8.64
6/1/22 14:52	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.06	-0.56	6.74	8.63
6/1/22 14:53	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.04	-0.56	6.80	8.58
6/1/22 14:54	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.03	-0.51	6.76	8.58
6/1/22 14:55	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.07	-0.54	6.60	8.64
6/1/22 14:56	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.15	-0.54	6.57	8.72
6/1/22 14:57	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	24.07	-0.52	6.68	8.69
6/1/22 14:58	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.88	-0.55	6.74	8.60
6/1/22 14:59	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.85	-0.51	6.77	8.59
6/1/22 15:00	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.93	-0.55	6.77	8.58
6/1/22 15:01	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.98	-0.52	6.73	8.60

## Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 15:02	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	24.02	-0.53	6.73	8.60
6/1/22 15:03	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	24.00	-0.51	6.71	8.60
6/1/22 15:04	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.97	-0.50	6.63	8.65
6/1/22 15:05	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.98	-0.56	6.60	8.68
6/1/22 15:06	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.92	-0.55	6.62	8.67
6/1/22 15:07	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.64	-0.55	6.78	8.61
6/1/22 15:08	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.63	-0.53	6.73	8.57
6/1/22 15:09	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.86	-0.53	6.65	8.65
6/1/22 15:10	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	24.00	-0.56	6.65	8.66
6/1/22 15:11	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.97	-0.54	6.58	8.70
6/1/22 15:12	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.88	-0.54	6.53	8.71
6/1/22 15:13	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.79	-0.53	6.42	8.76
6/1/22 15:14	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.77	-0.56	6.45	8.81
6/1/22 15:15	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	23.84	-0.56	6.69	8.70
6/1/22 15:16	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	24.02	-0.58	6.65	8.59
6/1/22 15:17	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 4	24.09	-0.55	6.66	8.64
					Run Average	23.91	-0.54	6.66	8.65
6/1/22 15:18	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.39	0.58	7.44	8.09
6/1/22 15:19	9049.1.B3	MPC	Detroit	CCR Charge Htr		2.18	1.80	9.91	9.80
6/1/22 15:20	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	-0.23	-0.57	9.94	10.07
6/1/22 15:21	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.97	0.25	7.13	8.28
6/1/22 15:21	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.95	17.97	0.03	0.35
6/1/22 15:22	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	25.74	25.10	-0.03	0.02
6/1/22 15:23	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.79	24.76	1.28	0.86
6/1/22 15:24	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.24	7.97	6.50	8.04
6/1/22 15:25	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.88	-0.38	6.58	8.66
6/1/22 15:26	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	17.40	-0.53	6.27	8.73
6/1/22 15:27	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.92	-0.57	6.42	8.81
6/1/22 15:28	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.94	-0.53	6.47	8.82
6/1/22 15:29	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.82	-0.57	6.54	8.78
6/1/22 15:30	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.75	-0.56	6.53	8.79
6/1/22 15:31	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.82	-0.54	6.59	8.75
6/1/22 15:32	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.75	-0.54	6.65	8.71
6/1/22 15:33	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.45	-0.54	6.79	8.61
6/1/22 15:34	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.36	-0.53	6.89	8.56
6/1/22 15:35	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.58	-0.53	6.97	8.51
6/1/22 15:36	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.72	-0.54	7.07	8.45
6/1/22 15:37	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.80	-0.52	7.20	8.39
6/1/22 15:38	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.97	-0.52	7.18	8.34
6/1/22 15:39	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	25.27	-0.55	6.91	8.45
6/1/22 15:40	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	25.30	-0.59	6.61	8.62
6/1/22 15:41	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.93	-0.61	6.27	8.84
6/1/22 15:42	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.49	-0.60	6.11	8.98
6/1/22 15:43	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	24.10	-0.57	6.06	9.01
6/1/22 15:44	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	23.64	-0.54	6.19	8.96
6/1/22 15:45	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	23.19	-0.50	6.32	8.86
6/1/22 15:46	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 5	22.81	-0.48	6.38	8.76
					Run Average	24.19	-0.55	6.59	8.70
6/1/22 15:47	9049.1.B3	MPC	Detroit	CCR Charge Htr		22.58	-0.44	6.33	8.71
6/1/22 15:48	9049.1.B3	MPC	Detroit	CCR Charge Htr		11.53	1.88	9.25	8.76

## Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 15:48	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	-0.11	0.23	9.92	10.00
6/1/22 15:49	9049.1.B3	MPC	Detroit	CCR Charge Htr		-0.20	-0.39	9.93	10.04
6/1/22 15:50	9049.1.B3	MPC	Detroit	CCR Charge Htr		-0.26	-0.24	8.69	9.52
6/1/22 15:51	9049.1.B3	MPC	Detroit	CCR Charge Htr		19.16	15.14	0.09	0.79
6/1/22 15:52	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.15	25.13	-0.02	0.04
6/1/22 15:53	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.77	25.44	0.16	0.01
6/1/22 15:54	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.18	25.36	0.57	0.29
6/1/22 15:55	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.27	10.73	6.70	7.39
6/1/22 15:56	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.25	0.00	6.60	8.56
6/1/22 15:57	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.22	-0.26	6.45	8.74
6/1/22 15:58	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.19	-0.26	6.44	8.78
6/1/22 15:59	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.14	-0.27	6.46	8.81
6/1/22 16:00	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.15	-0.25	6.56	8.74
6/1/22 16:01	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.20	-0.30	6.68	8.61
6/1/22 16:02	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.22	-0.31	6.70	8.59
6/1/22 16:03	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.23	-0.33	6.82	8.54
6/1/22 16:04	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.34	-0.27	6.79	8.51
6/1/22 16:05	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.46	-0.28	6.74	8.54
6/1/22 16:06	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.53	-0.32	6.70	8.55
6/1/22 16:07	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.59	-0.31	6.67	8.57
6/1/22 16:08	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.71	-0.31	6.66	8.63
6/1/22 16:09	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.72	-0.28	6.81	8.58
6/1/22 16:10	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.80	-0.30	6.84	8.51
6/1/22 16:11	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	23.96	-0.34	6.88	8.48
6/1/22 16:12	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	24.07	-0.39	6.86	8.47
6/1/22 16:13	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	24.07	-0.37	6.85	8.48
6/1/22 16:14	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	24.05	-0.38	6.75	8.54
6/1/22 16:15	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	24.02	-0.37	6.61	8.63
6/1/22 16:16	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 6	24.00	-0.43	6.56	8.66
					Run Average	23.57	-0.30	6.69	8.60
6/1/22 16:17	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.01	-0.15	6.36	8.29
6/1/22 16:18	9049.1.B3	MPC	Detroit	CCR Charge Htr		13.82	1.74	9.82	9.36
6/1/22 16:19	9049.1.B3	MPC	Detroit	CCR Charge Htr		-0.35	-0.51	9.94	10.06
6/1/22 16:20	9049.1.B3	MPC	Detroit	CCR Charge Htr		-0.53	-0.59	9.95	10.09
6/1/22 16:21	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	-0.57	-0.58	9.95	10.08
6/1/22 16:22	9049.1.B3	MPC	Detroit	CCR Charge Htr		-0.30	0.15	7.29	8.37
6/1/22 16:23	9049.1.B3	MPC	Detroit	CCR Charge Htr		18.96	18.10	0.03	0.38
6/1/22 16:24	9049.1.B3	MPC	Detroit	CCR Charge Htr		26.22	25.29	-0.02	0.03
6/1/22 16:25	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	24.89	25.30	-0.04	0.00
6/1/22 16:26	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.02	24.53	1.82	1.20
6/1/22 16:27	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.48	6.41	6.82	7.98
6/1/22 16:28	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.71	-0.40	6.91	8.42
6/1/22 16:29	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.25	-0.50	6.90	8.45
6/1/22 16:30	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.27	-0.47	6.86	8.48
6/1/22 16:31	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.24	-0.35	6.77	8.53
6/1/22 16:32	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.11	-0.40	6.75	8.58
6/1/22 16:33	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.01	-0.48	6.72	8.56
6/1/22 16:34	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	23.91	-0.62	6.68	8.57
6/1/22 16:35	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	23.86	-0.61	6.69	8.56
6/1/22 16:36	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	23.87	-0.67	6.72	8.55

## Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 16:37	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	23.87	-0.60	6.67	8.56
6/1/22 16:38	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	23.86	-0.57	6.65	8.59
6/1/22 16:39	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	23.69	-0.57	6.68	8.58
6/1/22 16:40	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	23.67	-0.56	6.67	8.55
6/1/22 16:41	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	23.82	-0.56	6.68	8.55
6/1/22 16:42	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	23.95	-0.54	6.69	8.55
6/1/22 16:43	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.01	-0.61	6.71	8.54
6/1/22 16:44	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.10	-0.62	6.74	8.54
6/1/22 16:45	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.33	-0.60	6.67	8.56
6/1/22 16:46	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.53	-0.68	6.62	8.58
6/1/22 16:47	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.48	-0.56	6.73	8.59
6/1/22 16:48	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.42	-0.54	6.73	8.55
6/1/22 16:49	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 7	24.31	-0.51	6.85	8.52
					Run Average	24.07	-0.55	6.72	8.55
6/1/22 16:50	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.36	-0.54	6.89	8.45
6/1/22 16:51	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.08	0.99	7.94	8.24
6/1/22 16:52	9049.1.B3	MPC	Detroit	CCR Charge Htr		1.44	0.32	9.91	9.96
6/1/22 16:52	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.34	-0.64	9.93	10.02
6/1/22 16:53	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	0.32	-0.62	9.94	10.05
6/1/22 16:54	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.28	-0.43	8.84	9.68
6/1/22 16:55	9049.1.B3	MPC	Detroit	CCR Charge Htr		19.15	14.69	0.11	0.81
6/1/22 16:55	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.86	24.53	0.00	0.07
6/1/22 16:56	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	25.10	25.18	-0.01	0.03
6/1/22 16:57	9049.1.B3	MPC	Detroit	CCR Charge Htr		26.50	24.21	2.10	1.60
6/1/22 16:58	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.88	5.53	6.81	8.11
6/1/22 16:59	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.93	-0.32	6.70	8.51
6/1/22 17:00	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.89	-0.50	6.69	8.55
6/1/22 17:01	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.79	-0.50	6.52	8.62
6/1/22 17:02	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.65	-0.47	6.51	8.65
6/1/22 17:03	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.56	-0.49	6.50	8.66
6/1/22 17:04	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.38	-0.48	6.57	8.67
6/1/22 17:05	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.22	-0.51	6.67	8.60
6/1/22 17:06	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.26	-0.52	6.71	8.54
6/1/22 17:07	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.51	-0.53	6.72	8.53
6/1/22 17:08	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.57	-0.54	6.77	8.52
6/1/22 17:09	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.53	-0.54	6.71	8.54
6/1/22 17:10	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.42	-0.54	6.74	8.54
6/1/22 17:11	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.23	-0.47	6.76	8.54
6/1/22 17:12	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.21	-0.51	6.80	8.54
6/1/22 17:13	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.26	-0.41	6.78	8.53
6/1/22 17:14	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.25	-0.41	6.87	8.49
6/1/22 17:14	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.23	-0.42	6.88	8.46
6/1/22 17:15	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	24.26	-0.41	6.81	8.49
6/1/22 17:16	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	24.31	-0.48	6.77	8.53
6/1/22 17:17	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	24.25	-0.55	6.77	8.55
6/1/22 17:18	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	24.05	-0.54	6.68	8.57
6/1/22 17:19	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.86	-0.50	6.67	8.62
6/1/22 17:20	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.69	-0.45	6.66	8.60
6/1/22 17:21	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.63	-0.38	6.64	8.62
6/1/22 17:22	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.53	-0.34	6.71	8.63
6/1/22 17:23	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.48	-0.34	6.79	8.54


# Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 17:24	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.58	-0.33	6.71	8.57
6/1/22 17:25	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.66	-0.27	6.68	8.60
6/1/22 17:26	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.72	-0.34	6.57	8.65
6/1/22 17:27	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.77	-0.39	6.60	8.68
6/1/22 17:28	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.73	-0.41	6.66	8.64
6/1/22 17:29	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.72	-0.42	6.67	8.59
6/1/22 17:30	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.81	-0.44	6.62	8.64
6/1/22 17:31	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.89	-0.39	6.69	8.63
6/1/22 17:32	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.90	-0.32	6.62	8.63
6/1/22 17:33	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.85	-0.34	6.70	8.66
6/1/22 17:34	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.75	-0.28	6.69	8.61
6/1/22 17:35	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.74	-0.25	6.74	8.60
6/1/22 17:35	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 8	23.82	-0.39	6.69	8.60
6/1/22 17:36	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.90	0.01	6.66	8.22
6/1/22 17:37	9049.1.B3	MPC	Detroit	CCR Charge Htr		7.63	1.90	9.85	9.42
6/1/22 17:38	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.21	-0.38	9.95	10.06
6/1/22 17:38	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.22	-0.49	9.97	10.09
6/1/22 17:39	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	0.18	-0.48	9.95	10.10
6/1/22 17:40	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.27	-0.04	8.09	9.13
6/1/22 17:41	9049.1.B3	MPC	Detroit	CCR Charge Htr		17.47	16.58	0.07	0.65
6/1/22 17:42	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.59	25.43	-0.02	0.03
6/1/22 17:42	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.64	25.51	-0.02	0.01
6/1/22 17:43	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	24.64	25.55	-0.03	0.00
6/1/22 17:44	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.98	25.37	0.80	0.43
6/1/22 17:45	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.75	9.81	6.60	7.73
6/1/22 17:46	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.34	0.08	6.63	8.58
6/1/22 17:47	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.45	-0.27	6.68	8.59
6/1/22 17:48	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.66	-0.38	6.63	8.65
6/1/22 17:49	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.85	-0.41	6.72	8.63
6/1/22 17:50	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.83	-0.48	6.69	8.61
6/1/22 17:51	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.83	-0.47	6.72	8.61
6/1/22 17:52	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.88	-0.38	6.67	8.60
6/1/22 17:53	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.88	-0.44	6.67	8.63
6/1/22 17:54	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.82	-0.41	6.75	8.61
6/1/22 17:55	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.80	-0.34	6.78	8.57
6/1/22 17:56	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.87	-0.34	6.79	8.56
6/1/22 17:57	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.98	-0.38	6.75	8.57
6/1/22 17:58	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.98	-0.38	6.81	8.56
6/1/22 17:59	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.97	-0.43	6.82	8.54
6/1/22 18:00	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	25.01	-0.50	6.81	8.58
6/1/22 18:01	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	25.01	-0.45	6.86	8.56
6/1/22 18:02	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.99	-0.43	6.82	8.53
6/1/22 18:03	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	25.04	-0.47	6.72	8.58
6/1/22 18:04	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	25.01	-0.46	6.76	8.61
6/1/22 18:05	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	25.01	-0.40	6.71	8.60
6/1/22 18:06	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	25.07	-0.46	6.66	8.64
6/1/22 18:07	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	25.04	-0.47	6.68	8.65
6/1/22 18:07	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 9	24.90	-0.42	6.74	8.59
6/1/22 18:08	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.94	-0.16	6.53	8.29
6/1/22 18:09	9049.1.B3	MPC	Detroit	CCR Charge Htr		5.06	1.89	9.84	9.32

## Erthwrks Datalog Records

TimeStamp	Project Number	Client	Facility	Unit	Test Period	NO <sub>x</sub>	CO	O <sub>2</sub>	CO <sub>2</sub>
6/1/22 18:10	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.22	-0.53	9.98	10.12
6/1/22 18:11	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	0.20	-0.65	9.99	10.11
6/1/22 18:12	9049.1.B3	MPC	Detroit	CCR Charge Htr		3.12	2.80	4.54	6.12
6/1/22 18:13	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.02	22.49	0.01	0.15
6/1/22 18:13	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.17	25.29	-0.02	0.03
6/1/22 18:14	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	25.22	25.34	-0.03	0.01
6/1/22 18:15	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.28	25.27	0.79	0.38
6/1/22 18:16	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.25	9.92	6.90	7.57
6/1/22 18:17	9049.1.B3	MPC	Detroit	CCR Charge Htr		24.72	-0.20	7.11	8.32
6/1/22 18:18	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	24.74	-0.52	7.18	8.31
6/1/22 18:19	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	24.93	-0.65	7.19	8.25
6/1/22 18:20	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	25.13	-0.69	7.12	8.28
6/1/22 18:21	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	25.13	-0.72	7.01	8.34
6/1/22 18:22	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	25.04	-0.73	6.91	8.40
6/1/22 18:23	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	24.86	-0.67	6.87	8.44
6/1/22 18:24	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	24.61	-0.61	6.84	8.43
6/1/22 18:25	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	24.44	-0.55	6.73	8.46
6/1/22 18:26	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	24.25	-0.59	6.72	8.49
6/1/22 18:27	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	24.01	-0.56	6.76	8.50
6/1/22 18:28	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.76	-0.59	6.82	8.48
6/1/22 18:29	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.60	-0.59	6.82	8.44
6/1/22 18:30	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.56	-0.63	6.81	8.46
6/1/22 18:31	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.56	-0.64	6.81	8.45
6/1/22 18:32	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.61	-0.59	6.83	8.45
6/1/22 18:33	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.72	-0.48	6.77	8.47
6/1/22 18:34	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.77	-0.46	6.74	8.50
6/1/22 18:35	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.75	-0.43	6.72	8.53
6/1/22 18:36	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.72	-0.45	6.80	8.49
6/1/22 18:37	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.73	-0.46	6.84	8.45
6/1/22 18:38	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	23.88	-0.51	6.73	8.47
6/1/22 18:38	9049.1.B3	MPC	Detroit	CCR Charge Htr	Run 10	24.18	-0.58	6.86	8.43
6/1/22 18:39	9049.1.B3	MPC	Detroit	CCR Charge Htr		23.93	-0.22	6.65	8.11
6/1/22 18:40	9049.1.B3	MPC	Detroit	CCR Charge Htr		5.66	1.59	9.92	9.56
6/1/22 18:40	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.35	-0.41	9.99	10.08
6/1/22 18:41	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	0.34	-0.56	10.00	10.10
6/1/22 18:42	9049.1.B3	MPC	Detroit	CCR Charge Htr		0.28	-0.33	8.65	9.53
6/1/22 18:43	9049.1.B3	MPC	Detroit	CCR Charge Htr		16.03	15.21	0.10	0.84
6/1/22 18:44	9049.1.B3	MPC	Detroit	CCR Charge Htr		25.05	25.31	-0.01	0.04
6/1/22 18:45	9049.1.B3	MPC	Detroit	CCR Charge Htr	Sys Bias	25.15	25.44	-0.02	0.01

**Attachment F**  
**Calibrations and Certifications**



American Association for Laboratory Accreditation

## *Accredited Air Emission Testing Body*

A2LA has accredited

**ERTHWRKS, INC.**

In recognition of the successful completion of the joint A2LA and Stack Testing Accreditation Council (STAC) evaluation process, this laboratory is accredited to perform testing activities in compliance with ASTM D7036:2004 - Standard Practice for Competence of Air Emission Testing Bodies.

Presented this 29<sup>th</sup> day of March 2021.

A handwritten signature in black ink, appearing to read 'John Doe'.

Vice President, Accreditation Services  
For the Accreditation Council  
Certificate Number 6147.01  
Valid to March 31, 2023



*This accreditation program is not included under the A2LA ILAC Mutual Recognition Arrangement.*

## CERTIFICATE OF ANALYSIS

### Grade of Product: EPA PROTOCOL STANDARD

Customer: ERTHWRKS  
 Part Number: E04NI99E15A7104  
 Cylinder Number: CC446268  
 Laboratory: 124 - Pasadena (SG06) - TX  
 PGVP Number: A32021  
 Gas Code: CO,NO,NOX,PPN,BALN

Reference Number: 163-402284893-1  
 Cylinder Volume: 144.4 CF  
 Cylinder Pressure: 2015 PSIG  
 Valve Outlet: 660  
 Certification Date: Dec 09, 2021

**Expiration Date: Dec 09, 2024**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

#### ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	25.00 PPM	24.77 PPM	G1	+/- 1.4% NIST Traceable	11/23/2021, 12/09/2021
CARBON MONOXIDE	25.00 PPM	25.43 PPM	G1	+/- 0.6% NIST Traceable	11/23/2021
NITRIC OXIDE	25.00 PPM	24.59 PPM	G1	+/- 1.7% NIST Traceable	11/23/2021, 12/09/2021
PROPANE	25.00 PPM	25.93 PPM	G1	+/- 1.2% NIST Traceable	11/29/2021
NITROGEN	Balance				

#### CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062106	CC366820	25.24 PPM CARBON MONOXIDE/NITROGEN	+/-0.6%	May 26, 2024
PRM	12402	APEX1324263	10.01 PPM NOx/NITROGEN	+/-0.5%	Dec 23, 2022
NTRM	16101	KAL004115	9.95 PPM NITRIC OXIDE/NITROGEN	+/-1.0%	Oct 16, 2022
GMIS	16101	KAL004115-NOX	9.95 PPM NOx/NITROGEN	+/-0.5%	Oct 16, 2022
NTRM	17061006	ND61234	49.13 PPM PROPANE/AIR	+/-0.4%	Jul 24, 2023

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

#### ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
SIEMENS ULTRA CO 6 M2-529	NDIR	Nov 02, 2021
NO-CAI 600 CLD A12005	CHEMI	Nov 02, 2021
NOX-CAI CLD A12005	CHEMI	Nov 02, 2021
C3H8-XL-NICOLET iS50 AUP2010248	FTIR	Nov 04, 2021

Triad Data Available Upon Request

Signature on file

Approved for Release

## CERTIFICATE OF ANALYSIS

### Grade of Product: EPA PROTOCOL STANDARD

Customer:	ERTHWRKS	Reference Number:	163-402274216-1
Part Number:	E04NI99E15A51Y5	Cylinder Volume:	144.4 CF
Cylinder Number:	CC339873	Cylinder Pressure:	2015 PSIG
Laboratory:	124 - Pasadena (SG06) - TX	Valve Outlet:	660
PGVP Number:	A32021	Certification Date:	Nov 23, 2021
Gas Code:	CO,NO,NOX,PPN,BALN		

**Expiration Date: Nov 23, 2029**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

#### ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NOX	53.00 PPM	53.76 PPM	G1	+/- 1.2% NIST Traceable	11/15/2021, 11/23/2021
CARBON MONOXIDE	50.00 PPM	50.83 PPM	G1	+/- 0.8% NIST Traceable	11/15/2021
PROPANE	50.00 PPM	52.60 PPM	G1	+/- 0.5% NIST Traceable	11/15/2021
NITRIC OXIDE	53.00 PPM	53.64 PPM	G1	+/- 1.2% NIST Traceable	11/15/2021, 11/23/2021
NITROGEN	Balance				

#### CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12062103	CC366817	25.24 PPM CARBON MONOXIDE/NITROGEN	+/-0.6%	May 26, 2024
PRM	12386	D685025	9.91 PPM NITROGEN DIOXIDE/AIR	+/- 2.0%	Feb 20, 2020
NTRM	17061006	ND61234	49.13 PPM PROPANE/AIR	+/-0.4%	Jul 24, 2023
NTRM	20061119	CC708066	49.82 PPM NITRIC OXIDE/NITROGEN	+/-1.0%	Feb 02, 2025
GMIS	401648677102	CC506986	15.21 PPM NITROGEN DIOXIDE/NITROGEN	+/-2.1%	Feb 10, 2023

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

#### ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
CO-XL-NICOLET iS50 AUP2010248	FTIR	Oct 28, 2021
NO-XL-NICOLET iS50 AUP2010248	FTIR	Nov 11, 2021
NO2-NICOLET iS50 AUP2010248	FTIR	Nov 11, 2021
C3H8-XL-NICOLET iS50 AUP2010248	FTIR	Nov 04, 2021

Triad Data Available Upon Request



Signature on file

Approved for Release

Page 1 of 1

**CERTIFICATE OF ANALYSIS****Grade of Product: EPA PROTOCOL STANDARD**

Part Number: E03NI80E15A0138 Reference Number: 163-402334056-1  
Cylinder Number: CC287657 Cylinder Volume: 150.9 CF  
Laboratory: 124 - Pasadena (SG06) - TX Cylinder Pressure: 2015 PSIG  
PGVP Number: A32022 Valve Outlet: 590  
Gas Code: CO2,O2,BALN Certification Date: Jan 26, 2022

**Expiration Date: Jan 26, 2030**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

**ANALYTICAL RESULTS**

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	10.00 %	10.13 %	G1	+/- 0.8% NIST Traceable	01/26/2022
OXYGEN	10.00 %	10.00 %	G1	+/- 0.7% NIST Traceable	01/26/2022
NITROGEN	Balance				

**CALIBRATION STANDARDS**

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	12010106	K005090	17.97 % CARBON DIOXIDE/NITROGEN	+/-0.5%	Jan 11, 2024
NTRM	10010917	K015369	20.89 % OXYGEN/NITROGEN	+/-0.5%	Jun 27, 2022

**ANALYTICAL EQUIPMENT**

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
HORIBA VIA 510 CO2 19GYCXEG	NDIR	Jan 12, 2022
O2 SIEMENS OXYMAT 6 DD550	PARAMAGNETIC	Dec 30, 2021

Triad Data Available Upon Request



Signature on file

Approved for Release

Page 1 of 1

## CERTIFICATE OF ANALYSIS

### Grade of Product: EPA Protocol

Part Number:	E03NI60E15A0286	Reference Number:	163-402126105-1
Cylinder Number:	ALM038955	Cylinder Volume:	159.6 CF
Laboratory:	124 - Pasadena (SG06) - TX	Cylinder Pressure:	2015 PSIG
PGVP Number:	A32021	Valve Outlet:	590
Gas Code:	CO2,O2,BALN	Certification Date:	Jun 02, 2021

**Expiration Date: Jun 02, 2029**

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

<b>ANALYTICAL RESULTS</b>					
<b>Component</b>	<b>Requested Concentration</b>	<b>Actual Concentration</b>	<b>Protocol Method</b>	<b>Total Relative Uncertainty</b>	<b>Assay Dates</b>
CARBON DIOXIDE	20.00 %	19.69 %	G1	+/- 1.0% NIST Traceable	06/02/2021
OXYGEN	20.00 %	19.92 %	G1	+/- 0.6% NIST Traceable	06/02/2021
NITROGEN	Balance				

<b>CALIBRATION STANDARDS</b>					
<b>Type</b>	<b>Lot ID</b>	<b>Cylinder No</b>	<b>Concentration</b>	<b>Uncertainty</b>	<b>Expiration Date</b>
NTRM	12010106	K005090	17.97 % CARBON DIOXIDE/NITROGEN	+/-0.5%	Jan 11, 2024
NTRM	09060239	CC263131	9.961 % OXYGEN/NITROGEN	+/-0.3%	Nov 05, 2024

<b>ANALYTICAL EQUIPMENT</b>					
<b>Instrument/Make/Model</b>	<b>Analytical Principle</b>		<b>Last Multipoint Calibration</b>		
HORIBA VIA-510 CO2 19GYCXEG	NDIR		May 24, 2021		
O2-SIEMENS OXYMAT 6 DD550	PARAMAGNETIC		May 21, 2021		

Triad Data Available Upon Request



Signature on file

Approved for Release

Page 1 of 163-402126105-1

## CERTIFICATE OF ANALYSIS

### Grade of Product: EPA Protocol

Part Number:	E02AI99E15W0020	Reference Number:	54-402196543-1
Cylinder Number:	CC502181	Cylinder Volume:	146.2 CF
Laboratory:	124 - Chicago (SAP) - IL	Cylinder Pressure:	2015 PSIG
PGVP Number:	B12021	Valve Outlet:	660
Gas Code:	NO2,BALA	Certification Date:	Aug 30, 2021

Expiration Date: Aug 30, 2024

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a mole/mole basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

#### ANALYTICAL RESULTS

Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
NITROGEN DIOXIDE AIR	60.00 PPM Balance	60.52 PPM	G1	+/- 1.9% NIST Traceable	08/23/2021, 08/30/2021

#### CALIBRATION STANDARDS

Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
GMIS	1534002020505	EB0130067	59.76 PPM NITROGEN DIOXIDE/NITROGEN	+/- 1.4%	Apr 30, 2024
PRM	12397	D887665	74.2 PPM NITROGEN DIOXIDE/AIR	+/- 1.3%	Feb 02, 2022

The SRM, PRM or RGM noted above is only in reference to the GMIS used in the assay and not part of the analysis.

#### ANALYTICAL EQUIPMENT

Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
MKS FTIR NO2 017707558	FTIR	Aug 19, 2021

Triad Data Available Upon Request



Signature on file

Approved for Release

Page 1 of 54-402196543-1



# Calibration complies with ISO/IEC 17025, ANSI/NCSL Z540-1, and 9001



Cert. No.: 6530-11347485

## Traceable® Certificate of Calibration for Digital Barometer

Manufactured for and distributed by : Traceable® Products 12554 Galveston Rd B230, Webster, TX 77598

### Instrument Identification:

Model: 6530,68000-49

S/N: 200355570

Manufacturer: Control Company

### Standards/Equipment:

Description	Serial Number	Due Date	NIST Traceable Reference
Digital Barometer	D4540001	01 Nov 2020	1000447551
Digital Thermometer	130070752	10 Mar 2021	4000-11170557
Chilled Mirror Hygrometer	44654/2H3737	25 Nov 2021	17811
Climate Chamber	W619.0019		

### Certificate Information:

Technician: 57

Procedure: CAL-31

Cal Date: 14 Jun 2020

Cal Due Date: 14 Jun 2022

Test Conditions: 48.54%RH 23.44°C 1017mBar

### Calibration Data: (New Instrument)

Unit(s)	Nominal	As Found	In Tol	Nominal	As Left	In Tol	Min	Max	±U	TUR
%RH	N.A.	N.A.		50.14	52	Y	47	53	0.74	>4:1
°C	N.A.	N.A.		25.22	24.9	Y	24.82	25.62	0.05	>4:1
mb/hPa	N.A.	N.A.		805.50	805	Y	802	810	0.62	>4:1
mb/hPa	N.A.	N.A.		910.10	911	Y	906	914	0.62	>4:1
mb/hPa	N.A.	N.A.		1013.50	1014	Y	1010	1018	0.62	>4:1

This certificate indicates Traceability to standards provided by (NIST) National Institute of Standards and Technology and/or a National Standards Laboratory.

A Test Uncertainty Ratio of at least 4:1 is maintained unless otherwise stated and is calculated using the expanded measurement uncertainty. Uncertainty evaluation includes the instrument under test and is calculated in accordance with the ISO "Guide to the Expression of Uncertainty in Measurement" (GUM). The uncertainty represents an expanded uncertainty using a coverage factor k=2 to approximate a 95% confidence level. In tolerance conditions are based on test results falling within specified limits with no reduction by the uncertainty of the measurement. The results contained herein relate only to the item calibrated. This certificate shall not be reproduced except in full, without written approval of Control Company.

Nominal=Standard's Reading; As Left=Instrument's Reading; In Tol=In Tolerance; Min/Max=Acceptance Range; ±U=Expanded Measurement Uncertainty; TUR=Test Uncertainty Ratio;  
Accuracy=±(Max-Min)/2; Min=As Left Nominal(Rounded) - Tolerance; Max= As Left Nominal(Rounded) + Tolerance;

Nicol Rodriguez, Quality Manager

Marisa Elms, Technical Manager

Note :

### Maintaining Accuracy:

In our opinion once calibrated your Digital Barometer should maintain its accuracy. There is no exact way to determine how long calibration will be maintained. Digital Barometer change little, if any at all, but can be affected by aging, temperature, shock, and contamination.

### Recalibration:

For factory calibration and re-certification traceable to National Institute of Standards and Technology contact Control Company.

Issue Date : 14 Jun 2020

CONTROL COMPANY 12554 Galveston RD Suite B230 Webster TX USA 77598  
Phone 281 482-1714 Fax 281 482-9448 sales@control3.com www.traceable.com

Control Company is an ISO/IEC 17025:2005 Calibration Laboratory Accredited by (A2LA) American Association for Laboratory Accreditation, Certificate No. 1750.01.  
Control Company is ISO 9001:2015 Quality Certified by DNV GL, Certificate No. CERT-01805-2006-AQ-HOU-ANAB,  
International Laboratory Accreditation Cooperation - Multilateral Recognition Arrangement (ILAC-MRA).

1 of 1

Traceable® is a registered trademark of Control Company

© 2017 Control Company



## S-TYPE PITOT TUBE INSPECTION

Pitot tube No:	2824	Date:	11/3/2020	Technician	TAS
Pitot tube assembly level?	Yes	Pitot tube openings damaged?			NO
					If yes, explain below
	$D_t ("")^1:$	0.375	$(3/16" < D_t < 3/8")$		
	$P_A ("")^2:$	0.472	$P_A =$	1.26	* $D_t (1.05 * D_t < P_A < 1.5 * D_t)$
	$P_B ("")^2:$	0.472	$P_B =$	1.26	* $D_t (1.05 * D_t < P_B < 1.5 * D_t)$
	$\alpha_1^3 :$	1.4°		$\gamma :$	.9°
	$\alpha_2^3 :$	1.7°		$\theta :$	1.9°
	$\beta_1^3 :$	.3°		$A (""):$	0.944
	$\beta_2^3 :$	.8°			
	$z = (A \sin \gamma):$	.015' (< 0.125)	$w = (A \sin \theta):$	.03' (< 0.03125)	

<sup>1</sup>  $D_t$  must be between 0.48 and .95 cm (3/16 and 3/18") per EPA Method 2 Section 10.1

<sup>2</sup>  $P_A$  and  $P_B$  must be equal and between 0.41 and 0.59" per EPA Method 2 Section 10.1

<sup>3</sup> The types of misalignment will not affect the baseline value of  $C_p(s)$  so long as  $a_1$  and  $a_2 < 10^\circ$ ,  $b_1$  and  $b_2 < 5^\circ$  per EPA Method 2 Figure 2-3

Calibration Required?      No

Pitot tube No. 2824 meets Method 2 specifications and is assigned a calibration factor of 0.84.

Comments:

RECEIVED

AUG 01 2022

AIR QUALITY DIVISION

**APEX INSTRUMENTS METHOD 5 PRE-TEST CONSOLE CALIBRATION  
USING CALIBRATED CRITICAL ORIFICES  
5-POINT ENGLISH UNITS**

Meter Console Information	
Console Model Number	522
Console Serial Number	M5-2
DGM Model Number	S-110
DGM Serial Number	1308030

Calibration Conditions			
Date	Time	30-Nov-21	15:04
Barometric Pressure		30.1	in Hg
Theoretical Critical Vacuum <sup>1</sup>		14.2	in Hg
Calibration Technician	AM		

Factors/Conversions		
Std Temp	528	°R
Std Press	29.92	in Hg
K <sub>t</sub>	17.647	oR/in Hg

<sup>1</sup>For valid test results, the Actual Vacuum should be 1 to 2 in. Hg greater than the Theoretical Critical Vacuum shown above.

<sup>2</sup>The Critical Orifice Coefficient, K', must be entered in English units, ( $\text{ft}^3 \cdot \text{R}^{1/2}$ )/(in.Hg\*min).

Run Time	Metering Console					Calibration Data				
	DGM Orifice Elapsed ( $\Delta t$ )	Volume Initial ( $V_m$ )	Volume Final ( $V_{mt}$ )	Outlet Temp Initial ( $t_{mi}$ )	Outlet Temp Final ( $t_{mt}$ )	Serial Number	Coefficient K'	Amb Temp Initial ( $t_{amb}$ )	Amb Temp Final ( $t_{amb}$ )	Actual Vacuum
min	in H <sub>2</sub> O	cubic feet	cubic feet	°F	°F		see above <sup>2</sup>	°F	°F	in Hg
7.0	3.50	883.000	890.543	81	82	RU-73	0.8110	73	73	17
7.0	1.90	875.700	881.192	79	80	RU-63	0.5888	73	73	20
10.0	1.10	868.600	874.626	79	79	RU-55	0.4519	73	73	21
17.0	0.65	859.800	867.520	78	78	RU-48	0.3396	73	73	23
21.4	0.32	851.400	858.100	78	78	RU-40	0.2349	74	73	24


Standardized Data			Dry Gas Meter				
Dry Gas Meter	Critical Orifice		Calibration Factor		Flowrate	$\Delta H @$	
			Value	Variation	Std & Corr	0.75 SCFM	Variation
( $V_{m(\text{std})}$ )	( $Q_{m(\text{std})}$ )	( $V_{cr(\text{std})}$ )	( $Q_{cr(\text{std})}$ )	(Y)	( $\Delta Y$ )	( $Q_{m(\text{std})(\text{corr})}$ )	( $\Delta H @$ )
cubic feet	cfm	cubic feet	cfm			cfm	in H <sub>2</sub> O
7.462	1.066	7.402	1.057	0.992	0.003	1.057	1.758
5.432	0.776	5.374	0.768	0.989	0.000	0.768	1.804
5.954	0.595	5.892	0.589	0.989	0.001	0.589	1.767
7.634	0.449	7.527	0.443	0.986	-0.003	0.443	1.849
6.620	0.310	6.541	0.306	0.988	-0.001	0.306	1.901
Dry Gas Meter			0.989	Y Average		1.816	$\Delta H @$ Average

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is  $\pm 0.02$ .

I certify that the above Dry Gas Meter was calibrated in accordance with USEPA Methods, CFR 40 Part 60, using the Precision Wet Test Meter # 11AE6, which in turn was calibrated using the American Bell Prover # 3785, certificate # F107, which is traceable to the National Bureau of Standards (N.I.S.T.).

Signature Chad

Date 11/30/2021




Console Model: MC-522-O

Calibration Date: 11-30-2021

Calibration Technician: AM

DGM Orifice  $\Delta H$  (in H<sub>2</sub>O)



Flowrate Standardized & Corrected (cfm)

Console Model: MC-522-

## Erthwrks Meterbox Thermocouple Calibration Datasheet

Meterbox ID No. M5-2

Serial No. 1308030

Thermocouple Check		Meter Temp		
Meter Box T.C. °F	Standard T.C. °K	Meter Box T.C. °K	Standard °K	% Average Difference
5	5	258	258	0.00
45	45	280	280	0.00
65	66	291	292	0.19
85	86	303	303	0.18
120	121	322	323	0.17
150	152	339	340	0.33

Average Difference must be +/- 1.5%

Thermocouple Check		Exit Impinger Temp		
Meter Box T.C. °F	Standard T.C. °K	Meter Box T.C. °K	Standard °K	% Average Difference
0	0	255	255	0.00
10	12	261	262	0.42
20	22	266	268	0.42
40	43	278	279	0.60
50	52	283	284	0.39
70	73	294	296	0.56

Average Difference must be +/- 1.5%

Thermocouple Check		Probe Temp		
Meter Box T.C. °F	Standard T.C. °K	Meter Box T.C. °K	Standard °K	% Average Difference
5	5	258	258	0.00
45	45	280	280	0.00
100	98	311	310	0.36
250	249	394	394	0.14
300	301	422	423	0.13
500	499	533	533	0.10

Average Difference must be +/- 1.5%

Thermocouple Check		Gas Inlet Temp		
Meter Box T.C. °F	Standard T.C. °K	Meter Box T.C. °K	Standard °K	% Average Difference
0	1	255	256	0.22
10	11	261	261	0.21
20	20	266	266	0.00
40	41	278	278	0.20
50	49	283	283	0.20
70	71	294	295	0.19

Average Difference must be +/- 1.5%

Thermocouple Check		Filter Oven Temp		
Meter Box T.C. °F	Standard T.C. °K	Meter Box T.C. °K	Standard °K	% Average Difference
5	4	258	258	0.22
50	53	283	285	0.59
100	99	311	310	0.18
250	253	394	396	0.42
300	299	422	421	0.13
500	502	533	534	0.21

Average Difference must be +/- 1.5%

Thermocouple Check		Stack Temp		
Meter Box T.C. °F	Standard T.C. °K	Meter Box T.C. °K	Standard °K	% Average Difference
0	2	255	256	0.43
80	82	300	301	0.37
250	254	394	396	0.56
550	555	561	564	0.49
750	754	672	674	0.33
1000	1003	811	813	0.21

Average Difference must be +/- 1.5%

Signature

Date

5/25/2022



Revised: 2019/12/18

## Certificate of Calibration

Method 5 Pre-Test Console Calibration - Cubic Feet ( $\text{ft}^3$ )

### UUT Meter Console Information

Model #:	XC-522
Serial #:	1404013
DGM Model #:	S-110
DGM Serial #:	626997

### Calibration Conditions

Bar. Pressure (in Hg):	30.23
Ambient Temp. (°F):	80.6
Relative Humidity (%):	53
Altitude (ft):	414.0
Bar. Pressure (Corr.) (in Hg):	29.82

### Factors/Conversions

Std. Temp. (°R):	527.67
Std. Press. (in Hg):	29.92
K <sub>t</sub> (°R/in Hg):	17.636

### Reference Equipment

WTM Model:	W-NKoDa-5B	Serial #:	546258
WTM Cal. Due Date:	Aug. 2021	Gamma:	1.0000
WTM Thermometer:			Internal

### UUT Meter (DGM)

Run Time (minutes)	Orifice, $\Delta H$ (in. $H_2O$ )	Volume ( $\text{ft}^3$ )			Outlet Temperature (°F)	
		Initial	Final	Total	Initial	Final
0	P <sub>m(g)</sub>	V <sub>ml</sub>	V <sub>mf</sub>	V <sub>m</sub>	t <sub>ml</sub>	t <sub>mf</sub>
5.0	5.0	606.335	612.599	6.264	76.0	78.0
6.0	3.0	618.402	624.257	5.855	78.0	80.0
7.0	2.0	624.257	629.784	5.527	80.0	81.0
10.0	1.0	629.784	635.337	5.563	81.0	82.0
15.0	0.5	612.599	618.402	5.803	78.0	78.0

### Reference Meter (WTM)

Meter Pressure (mm $H_2O$ )	Volume (L)			Outlet Temperature (°C)	
	Initial	Final	Total	Initial	Final
P <sub>w</sub>	V <sub>ml</sub>	V <sub>mf</sub>	V <sub>w</sub>	t <sub>ml</sub>	t <sub>mf</sub>
-6.0	487.772	667.119	179.347	24.7	24.9
-4.5	830.243	996.008	165.765	25.0	25.2
-3.0	996.008	1151.585	155.577	25.2	25.3
-1.5	1151.585	1307.128	155.543	25.3	25.4
-0.5	667.119	830.243	163.124	24.9	25.0

### Standardized Data

Test Meter		Reference Meter		Correction Factor	Flow Rate	
Std. Volume	Std. Flow Rate	Std. Volume	Std. Flow Rate	"Gamma"	Variation	Std. & Corr.
V <sub>mstd</sub> ( $\text{ft}^3$ )	Q <sub>mstd</sub> ( $\text{ft}^3/\text{min}$ )	V <sub>wstd</sub> ( $\text{ft}^3$ )	Q <sub>wstd</sub> ( $\text{ft}^3/\text{min}$ )	(Y)	(ΔY)	Q <sub>mstdcorr</sub>
6.213	1.243	6.206	1.241	0.9989	0.004	1.237
5.758	0.960	5.731	0.955	0.9954	0.000	0.955
5.407	0.772	5.377	0.768	0.9945	-0.001	0.769
5.409	0.541	5.375	0.538	0.9937	-0.001	0.538
5.682	0.379	5.645	0.376	0.9935	-0.002	0.377
				0.9952	= Y Avg.	

### Calibration Results

$\Delta H @ (in H_2O)$	
0.75 SCFM	Variance
$\Delta H @$	$\Delta\Delta H @$
1.81	-0.06
1.82	-0.05
1.86	0.00
1.90	0.03
1.94	0.08
1.87	= $\Delta H @ Avg.$

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is  $\pm 0.02$ .

Note: For  $\Delta H_{orifice}$ , orifice pressure differential that equates to 0.75cm (0.0212m<sup>2</sup>/min) at standard temperature and pressure, acceptable tolerance of individual values from the average is  $\pm 0.2$ inches (5.1mm)  $H_2O$ .

Pass/Fail Result: Pass

Technician: Jake Bush

Signature:

Date: June 1, 2021

The instruments listed and described on this certificate have been calibrated against standards traceable to the National Institute of Standards and Technology (N.I.S.T.) and in reference to EPA Method 5, Section 10.3.1.

Apex Instruments - Address: 204 Technology Park Ln., Fuquay-Varina, NC 27526 USA | Tel: (919) 557-7300 Web: www.apexinst.com



## Certificate of Calibration - Supplemental

Method 5 Pre-Test Console Calibration - Cubic Feet (ft<sup>3</sup>)

### Nomenclature

$\Delta H@$  - Orifice press. Diff. that equates to 0.75 CFM (0.0212 CMM) at STP  
 DGM - Dry Gas Meter  
 $K_1$  - Constant based on standard temperature and pressure  
 $\theta$  - Run time, in minutes  
 $P_{m(g)}$  -  $\Delta H$  (Meter Pressure, gauge)  
 $V_{m(std)}$  - Volume collected by test meter, corrected for STP  
 $Q_{m(std)}$  - Calculated flow rate of test meter  
 $K$  - Critical orifice coefficient  
 $P_w$  - Measured pressure of reference meter  
 $t_w$  - Temperature measured in reference meter  
 $t_m$  - Temperature measured in test meter  
 $Y$  - Ratio of volume collected from test meter and orifice  
 $V_{w(std)}$  - Volume collected by reference meter, corrected for STP  
 $Q_{w(std)}$  - Calculated flow rate of reference meter/standard  
 corr - Volume or flow rate for a meter corrected by the scaling factor

### Equations


$$V_{m(std)} = K_1 * \frac{V_m * (P_{bar} + \frac{\Delta H}{13.6})}{T_m} \quad Q_{m(std)} = \frac{V_{m(std)}}{\theta}$$

$$V_{w(std)} = Y * K_1 * \frac{V_w * (P_{bar} + \frac{P_{m(g)}}{13.6})}{T_w} \quad Q_{w(std)} = \frac{V_{w(std)}}{\theta}$$



$$K_1 = \frac{T_{std}}{P_{std}} \quad Y = \frac{V_{w(std)}}{V_{m(std)}}$$

$$\text{English } \Delta H@ = \frac{\Delta H * 0.0319 * (P_{bar} + \frac{\Delta H}{13.6})}{T_m} * \left( \frac{T_w * \theta}{V_w * P_{bar}} \right)^2$$

### Calibration Train



### Calibration Graphs





Revised: 2019/12/18

## Certificate of Calibration

Method 5 Pre-Test Console Calibration - Cubic Feet (ft<sup>3</sup>)

### UUT Meter Console Information

Model #:	XC-522
Serial #:	1404013
DGM Model #:	S-110
DGM Serial #:	626997

### Calibration Conditions

Bar. Pressure (in Hg):	29.96
Ambient Temp. (°F):	78.0
Relative Humidity (%):	53
Altitude (ft):	414.0
Bar. Pressure (Corr.) (in Hg):	29.55

### Factors/Conversions

Std. Temp. (°R):	527.67
Std. Press. (in Hg):	29.92
K <sub>1</sub> (°R/in Hg):	17.636

### Reference Equipment

WTM Model:	W-NKoDa-5B	Serial #:	546258
WTM Cal. Due Date:	Aug. 2022	Gamma:	1.0019
WTM Thermometer:	Internal		

### UUT Meter (DGM)

Run Time (minutes)	Orifice, ΔH (in. H <sub>2</sub> O)	Volume (ft <sup>3</sup> )			Outlet Temperature (°F)	
		Initial	Final	Total	Initial	Final
Θ	P <sub>m(g)</sub>	V <sub>mi</sub>	V <sub>mf</sub>	V <sub>m</sub>	t <sub>mi</sub>	t <sub>mf</sub>
5.0	5.0	289.575	295.851	6.276	75.0	76.0
6.0	3.0	301.631	307.440	5.809	77.0	78.0
7.0	2.0	307.440	312.992	5.552	78.0	80.0
10.0	1.0	312.992	318.564	5.572	80.0	80.0
15.0	0.5	295.851	301.631	5.780	76.0	77.0

### Reference Meter (WTM)

Meter Pressure (mm H <sub>2</sub> O)	Volume (L)			Outlet Temperature (°C)	
	Initial	Final	Total	Initial	Final
P <sub>w</sub>	V <sub>wi</sub>	V <sub>wf</sub>	V <sub>w</sub>	t <sub>wi</sub>	t <sub>wf</sub>
-5.5	240.940	420.430	179.490	24.9	25.1
-4.0	582.959	748.139	165.180	25.3	25.6
-3.0	748.139	905.104	156.965	25.6	25.8
-2.0	905.104	1061.779	156.675	25.8	26.0
-1.0	420.430	582.959	162.529	25.1	25.3

### Standardized Data

Test Meter		Reference Meter		Correction Factor		Flow Rate
Std. Volume	Std. Flow Rate	Std. Volume	Std. Flow Rate	"Gamma"	Variation	Std. & Corr.
V <sub>m</sub> <sub>std</sub> (ft <sup>3</sup> )	Q <sub>m</sub> <sub>std</sub> (ft <sup>3</sup> /min)	V <sub>w</sub> <sub>std</sub> (ft <sup>3</sup> )	Q <sub>w</sub> <sub>std</sub> (ft <sup>3</sup> /min)	(Y)	(ΔY)	Q <sub>m</sub> <sub>std/corr</sub>
6.187	1.237	6.163	1.233	0.9961	0.001	1.232
5.677	0.946	5.664	0.944	0.9977	0.002	0.942
5.397	0.771	5.378	0.768	0.9964	0.001	0.768
5.393	0.539	5.365	0.537	0.9948	-0.001	0.537
5.624	0.375	5.579	0.372	0.9920	-0.003	0.373
				0.9954	= Y Avg.	

### Calibration Results

ΔH@ (in H <sub>2</sub> O)	
0.75 SCFM	Variance
ΔH@	ΔΔH@
1.83	-0.06
1.86	-0.03
1.86	-0.03
1.90	0.01
1.99	0.10
1.89	= ΔH@ Avg.

Note: For Calibration Factor Y, the ratio of the reading of the calibration meter to the dry gas meter, acceptable tolerance of individual values from the average is ±0.02.

Note: For ΔH<sub>Θ</sub>, orifice pressure differential that equates to 0.75cfm (0.0212m<sup>3</sup>/min) at standard temperature and pressure, acceptable tolerance of individual values from the average is ±0.2inches (5.1mm) H<sub>2</sub>O.

Pass/Fail Result: Pass

Technician: Tracy Wilson

Signature:

Date: July 6, 2022

The instruments listed and described on this certificate have been calibrated against standards traceable to the National Institute of Standards and Technology (N.I.S.T.) and in reference to EPA Method 5, Section 10.3.1.

Apex Instruments - Address: 204 Technology Park Ln., Fuquay-Varina, NC 27526 USA | Tel: (919) 557-7300 Web: www.apexinst.com



## Certificate of Calibration - Supplemental

Method 5 Pre-Test Console Calibration - Cubic Feet ( $\text{ft}^3$ )

### Nomenclature

$\Delta H_{@}$  - Orifice press. Diff. that equates to 0.75 CFM (0.0212 CMM) at STP  
 DGM - Dry Gas Meter  
 $K_1$  - Constant based on standard temperature and pressure  
 $\Theta$  - Run time, in minutes  
 $P_{m(g)}$  -  $\Delta H$  (Meter Pressure, gauge)  
 $V_{m(std)}$  - Volume collected by test meter, corrected for STP  
 $Q_{m(std)}$  - Calculated flow rate of test meter  
 $K'$  - Critical orifice coefficient  
 $P_w$  - Measured pressure of reference meter  
 $t_w$  - Temperature measured in reference meter  
 $t_m$  - Temperature measured in test meter  
 $Y$  - Ratio of volume collected from test meter and orifice  
 $V_{w(std)}$  - Volume collected by reference meter, corrected for STP  
 $Q_{w(std)}$  - Calculated flow rate of reference meter/standard  
 corr - Volume or flow rate for a meter corrected by the scaling factor

### Equations


$$V_{m(std)} = K_1 * \frac{V_m * (P_{bar} + \frac{\Delta H}{13.6})}{T_m} \quad Q_{m(std)} = \frac{V_{m(std)}}{\Theta}$$

$$V_{w(std)} = Y * K_1 * \frac{V_w * (P_{bar} + \frac{P_{m(g)}}{13.6})}{T_w} \quad Q_{w(std)} = \frac{V_{w(std)}}{\Theta}$$


$$K_1 = \frac{T_{std}}{P_{std}} \quad Y = \frac{V_{w(std)}}{V_{m(std)}}$$

$$English \Delta H_{@} = \frac{\Delta H * 0.0319 * (P_{bar} + \frac{\Delta H}{13.6})}{T_m} * \left( \frac{T_w * \Theta}{V_w * P_{bar}} \right)^2$$

### Calibration Train



### Calibration Graphs



## Erthwrks Meterbox Thermocouple Calibration Datasheet

Meterbox ID No. M5-5

Serial No. 626997

Thermocouple Check		Meter Temp		
Meter Box	Standard	Meter Box	Standard	% Average Difference
T.C. °F		T.C. °K	°K	
5	5	258	258	0.00
45	46	280	281	0.20
65	66	291	292	0.19
85	88	303	304	0.55
120	123	322	324	0.51
150	154	339	341	0.65

Average Difference must be +/- 1.5%

Thermocouple Check		Exit Impinger Temp		
Meter Box	Standard	Meter Box	Standard	% Average Difference
T.C. °F		T.C. °K	°K	
0	0	255	255	0.00
10	9	261	260	0.21
20	19	266	266	0.21
40	44	278	280	0.79
50	53	283	285	0.59
70	72	294	295	0.38

Average Difference must be +/- 1.5%

Thermocouple Check		Probe Temp		
Meter Box	Standard	Meter Box	Standard	% Average Difference
T.C. °F		T.C. °K	°K	
5	7	258	259	0.43
45	46	280	281	0.20
100	103	311	313	0.53
250	255	394	397	0.70
300	304	422	424	0.52
500	505	533	536	0.52

Average Difference must be +/- 1.5%

Thermocouple Check		Gas Inlet Temp		
Meter Box	Standard	Meter Box	Standard	% Average Difference
T.C. °F		T.C. °K	°K	
0	2	255	256	0.43
10	12	261	262	0.42
20	23	266	268	0.62
40	43	278	279	0.60
50	52	283	284	0.39
70	76	294	298	1.12

Average Difference must be +/- 1.5%

Thermocouple Check		Filter Oven Temp		
Meter Box	Standard	Meter Box	Standard	% Average Difference
T.C. °F		T.C. °K	°K	
5	6	258	259	0.21
50	53	283	285	0.59
100	103	311	313	0.53
250	255	394	397	0.70
300	301	422	423	0.13
500	503	533	535	0.31

Average Difference must be +/- 1.5%

Thermocouple Check		Stack Temp		
Meter Box	Standard	Meter Box	Standard	% Average Difference
T.C. °F		T.C. °K	°K	
0	3	255	257	0.65
80	84	300	302	0.74
250	255	394	397	0.70
550	553	561	563	0.30
750	752	672	673	0.17
1000	1004	811	813	0.27

Average Difference must be +/- 1.5%

Signature

Date

5/25/2022

**Attachment G**  
**CEMS Logs and Operational Data**

Sample ID	6031430		
Sample Date	6/1/2021 9:18		
Unit Description	D Gas Con		
Sample Point Description	D Fuel Drum, Cracking Plant		
Analysis	Component	UoM	
Fuel Gas Calculations	Specific Gravity		0.6535
Fuel Gas Calculations	Gross BTU per Cubic Foot	BTU/scf	1123.1
Fuel Gas Calculations	Net BTU per Cubic Foot	BTU/scf	1019.1
Fuel Gas Calculations	Gross BTU per Pound	BTU/lb	22519
Fuel Gas Calculations	Net BTU per Pound	BTU/lb	20434
Fuel Gas Calculations	F-Value	dscf/mmBtu	8604
Fuel Gas Calculations	Average Molecular Weight	g/mol	18.93
Fuel Gas Calculations	Carbon	wt. %	73.8
Fuel Gas Calculations	Hydrogen	wt. %	22.09
Fuel Gas Calculations	Oxygen	wt. %	0.24
Fuel Gas Calculations	Nitrogen	wt. %	3.88
Fuel Gas Calculations	Sulfur	wt. %	0
Refinery Gas (Normalized, mol%), GC D7833	Un-Normalized Total (raw)		97.1104
Refinery Gas (Normalized, mol%), GC D7833	Hydrogen (mole%)	mol %	11.97
Refinery Gas (Normalized, mol%), GC D7833	Carbon Dioxide (mole%)	mol %	0.1
Refinery Gas (Normalized, mol%), GC D7833	Carbon Monoxide (mole%)	mol %	0
Refinery Gas (Normalized, mol%), GC D7833	Methane (mole%)	mol %	60.08
Refinery Gas (Normalized, mol%), GC D7833	Ethane (mole%)	mol %	16.26
Refinery Gas (Normalized, mol%), GC D7833	Ethylene (mole%)	mol %	4.46
Refinery Gas (Normalized, mol%), GC D7833	Hydrogen Sulfide (mole%)	mol %	0
Refinery Gas (Normalized, mol%), GC D7833	Oxygen (mole%)	mol %	0.04
Refinery Gas (Normalized, mol%), GC D7833	Nitrogen (mole%)	mol %	2.62
Refinery Gas (Normalized, mol%), GC D7833	Propane (mole%)	mol %	2.19
Refinery Gas (Normalized, mol%), GC D7833	Propylene (mole%)	mol %	1.32
Refinery Gas (Normalized, mol%), GC D7833	i-Butane (mole%)	mol %	0.33
Refinery Gas (Normalized, mol%), GC D7833	n-Butane (mole%)	mol %	0.23
Refinery Gas (Normalized, mol%), GC D7833	1-Butene (mole%)	mol %	0.06
Refinery Gas (Normalized, mol%), GC D7833	t-2-Butene (mole%)	mol %	0.07
Refinery Gas (Normalized, mol%), GC D7833	c-2-Butene (mole%)	mol %	0.05
Refinery Gas (Normalized, mol%), GC D7833	Isobutylene (i-Butene) (mole%)	mol %	0.07
Refinery Gas (Normalized, mol%), GC D7833	1,3-Butadiene (mole%)	mol %	0
Refinery Gas (Normalized, mol%), GC D7833	i-Pentane (mole%)	mol %	0.05
Refinery Gas (Normalized, mol%), GC D7833	n-Pentane (mole%)	mol %	0.01
Refinery Gas (Normalized, mol%), GC D7833	Pentene-1 (mole%)	mol %	0
Refinery Gas (Normalized, mol%), GC D7833	>=C6 (mole%)	mol %	0.1
Refinery Gas (Normalized, mol%), GC D7833	Propane+Propylene (mole%)	mol %	3.51
Refinery Gas (Normalized, mol%), GC D7833	Hydrogen Sulfide (ppmw)	ppm (wt.)	0











**Attachment H**  
**Laboratory Analysis**

# **Erthwrks, Inc.**

P.O. Box 150549  
Austin, TX 78715


**MPC Detroit**  
**CCR Charge Heater May 2022**  
**Client Project # 9049.1.B3**

**Analytical Report**  
**(0622-914)**

***EPA Method 5***  
Particulate Matter

***EPA Method 202***  
Condensable Particulate Matter

***EPA Method 8A***  
Sulfuric acid mist



**Enthalpy Analytical, LLC**

Phone: (281) 984 - 7021 / [www.enthalpy.com](http://www.enthalpy.com)  
931 Seaco Ct. Deer Park, TX 77536-3187

I certify that to the best of my knowledge all analytical data presented in this report:


- Have been checked for completeness
- Are accurate, error-free, and legible
- Have been conducted in accordance with approved protocol, and that all deviations and analytical problems are summarized in the appropriate narrative(s)

This analytical report was prepared in Portable Document Format (.PDF) and contains 61 pages.




QA Review Performed by: James Haynes, Quality Assurance Director

Report Issued: 06/28/2022



# Summary of Results



# **Enthalpy Analytical**

Company: Erthwrks, Inc

Job No.: 0622-914-1 EPA Method 5 Analysis

Client No.: 9049.1.B3 MPC Detroit May 2022 Site: CCR Charge Heater

## **Summary Report**

Sample ID	Net Filter Catch (mg)	Net Front Rinse (mg)	Total Particulate (mg)
CCR Charge Htr Run 1	0.44	2.56	3.01
CCR Charge Htr Run 2	-0.15	2.39	2.39
CCR Charge Htr Run 3	0.69	2.11	2.80

# **Enthalpy Analytical**

Company: Erthwrks, Inc

Job No.: 0622-914-3 EPA Method 202 Analysis

Client No.: 9049.1.B3 MPC Detroit May 2022 Site: CCR Charge Heater

## **Summary Report**

Sample ID	Net Organic Catch (mg)	Net Inorganic Catch (mg)	CPM (mg)	TB Corrected CPM (mg)
CCR Charge Htr Run 1	1.89	7.79	9.68	7.75
CCR Charge Htr Run 2	1.09	6.61	7.70	5.77
CCR Charge Htr Run 3	1.48	5.56	7.04	5.10

# **Enthalpy Analytical**

Company: Erthwrks, Inc


Job No.: 0622-914-5 EPA Method CTM-013 (EPA Method 8A / ALT-133) Analysis

Client No.: 9049.1.B3 MPC Detroit May 2022 Site: CCR Charge Heater

## **Summary Table**

Sample ID	Sulfuric Acid Catch Weight (ug)
CCR Charge Htr Run 1	122
CCR Charge Htr Run 2	30.6
CCR Charge Htr Run 3	12.6
Reagent Blank	4.40 ND

# Results



# Enthalpy Analytical

Company: Erthrwrks, Inc

Job No.: 0622-914-1 EPA Method 5 Analysis

Client No.: 9049.1.B3 MPC Detroit May 2022 Site: CCR Charge Heater

## Results

	CCR Charge Htr Run 1		CCR Charge Htr Run 2		CCR Charge Htr Run 3	
Filter ID	51321		51320		51316	
Final Weight 1 (g)	0.342858	6/20/22 12:12	0.339747	6/20/22 12:10	0.342110	6/20/22 12:09
Final Weight 2 (g)	0.342808	6/21/22 10:32	0.339858	6/21/22 10:34	0.342060	6/21/22 10:33
Tare (g)	0.342364	2/22/22 09:44	0.340009	2/22/22 09:47	0.341369	2/22/22 09:58
Net Filter Catch (mg)	0.44		-0.15		0.69	
Beaker No.	DP0400		DP0401		DP0402	
Weight 1 (g)	2.321666	6/20/22 12:03	2.300052	6/20/22 12:05	2.322224	6/20/22 12:07
Weight 2 (g)	2.321657	6/21/22 10:26	2.299946	6/21/22 10:28	2.322143	6/21/22 10:30
Tare (g)	2.319094	6/6/22 10:27	2.297555	6/7/22 14:13	2.320033	6/7/22 14:17
Acetone Volume (mL)	130		152		130	
Acetone Blank (g)	0.00000		0.00000		0.00000	
Net Front Rinse (mg)	2.56		2.39		2.11	
Total Particulate (mg)	3.01		2.39		2.80	

# Enthalpy Analytical

Company: Erthwrks, Inc

Job No.: 0622-914-1 EPA Method 5 Analysis

Client No.: 9049.1.B3 MPC Detroit May 2022 Site: CCR Charge Heater

## In-House Blank

Acetone		
Beaker	DP0366	
Weight 1 (g)	2.285907	6/20/22 11:56
Weight 2 (g)	2.285728	6/21/22 10:11
Tare	2.285903	5/20/22 17:27
Residue (g)	-0.00018	
Vol. (mL)	200	
Max. Residue	0.00158	

## Reagent Blank

Acetone		
Beaker	DP0395	
Weight 1 (g)	2.329307	6/20/22 12:00
Weight 2 (g)	2.329112	6/21/22 10:17
Tare	2.329220	6/5/22 13:36
Residue (g)	-0.00011	
Vol. (mL)	132	
Max. Residue	0.00104	

# Enthalpy Analytical

Company: Erthrks, Inc

Job No.: 0622-914-3 EPA Method 202 Analysis

Client No.: 9049.1.B3 MPC Detroit May 2022 Site: CCR Charge Heater

## Results

	CCR Charge Htr Run 1		CCR Charge Htr Run 2		CCR Charge Htr Run 3		FTRB	
Organic Beaker Number	DP0404		DP0406		DP0408		DP0410	
Initial Solvent Volume (mL)	224		220		218		158	
Org. Final Weight 1 (g)	2.293508	6/20/22 12:27	2.309305	6/20/22 12:18	2.320741	6/20/22 13:28	2.325472	6/20/22 12:21
Org. Final Weight 2 (g)	2.293348	6/21/22 10:38	2.309343	6/21/22 10:40	2.320581	6/21/22 10:43	2.325472	6/21/22 10:47
Tare (g)	2.291461	6/7/22 14:22	2.308249	6/7/22 17:02	2.319105	6/7/22 17:10	2.324203	6/7/22 17:17
Organic Catch (mg)	1.89		1.09		1.48		1.27	
Inorganic Beaker Number	DP0403		DP0405		DP0407		DP0409	
Weight 1 (g)	2.305409	6/20/22 13:21	2.308669	6/21/22 14:52	2.350356	6/20/22 13:16	2.322621	6/20/22 13:26
Weight 2 (g)	2.305464	6/21/22 10:37	2.308369	6/22/22 11:21	2.350157	6/21/22 10:41	2.322574	6/21/22 10:45
Tare (g)	2.297671	6/7/22 14:19	2.301762	6/7/22 14:24	2.344597	6/7/22 17:05	2.321909	6/7/22 17:13
Initial Water Vol. (mL)	467		395		389		290	
Net Inorganic Catch (mg)	7.79		6.61		5.56		0.67	
Condensable Particulate (mg)	9.68		7.70		7.04		1.93	
TB Corrected CPM (mg)	7.75		5.77		5.10			

# Enthalpy Analytical

Company: Erthwrks, Inc

Job No.: 0622-914-3 EPA Method 202 Analysis

Client No.: 9049.1.B3 MPC Detroit May 2022 Site: CCR Charge Heater

FTPB		
Organic Beaker Number	DP0412	
Initial Solvent Volume (mL)	176	
Org. Final Weight 1 (g)	2.327357	6/20/22 12:23
Org. Final Weight 2 (g)	2.327455	6/21/22 10:52
Tare (g)	2.327408	6/7/22 17:23
Organic Catch (mg)	0.05	
Inorganic Beaker Number	DP0411	
Weight 1 (g)	2.309880	6/20/22 13:23
Weight 2 (g)	2.309882	6/21/22 10:49
Tare (g)	2.309601	6/7/22 17:20
Initial Water Vol. (mL)	145	
Net Inorganic Catch (mg)	0.28	
Condensable Particulate (mg)	0.33	
TB Corrected CPM (mg)	0.00	

AIR QUALITY DIVISION

RECEIVED  
AUG 01 2022

# Enthalpy Analytical

Company: Erthwrks, Inc

Job No.: 0622-914-3 EPA Method 202 Analysis

Client No.: 9049.1.B3 MPC Detroit May 2022 Site: CCR Charge Heater

## In-House Blank

	Water	Acetone		Hexane	
Beaker	DP0393		DP0366		DP0394
Weight 1 (g)	2.304660	6/20/22 11:02	2.285907	6/20/22 11:56	2.295949 6/20/22 11:04
Weight 2 (g)	2.304695	6/21/22 09:36	2.285728	6/21/22 10:11	2.296000 6/21/22 09:38
Tare (g)	2.304652	6/5/22 13:30	2.285903	5/20/22 17:27	2.295877 6/5/22 13:33
Residue (g)	0.00004		-0.00018		0.00012
Vol. (mL)	200		200		200
Max. Residue (g)	0.00020		0.00016		0.00013

## Reagent Blank

	Water	Acetone		Hexane	
Beaker	DP0396		DP0395		DP0397
Weight 1 (g)	2.314811	6/20/22 12:14	2.329307	6/20/22 12:00	2.320653 6/20/22 12:02
Weight 2 (g)	2.314743	6/21/22 10:20	2.329112	6/21/22 10:17	2.320518 6/21/22 10:23
Tare (g)	2.314548	6/5/22 13:39	2.329220	6/5/22 13:36	2.320601 6/6/22 10:17
Residue (g)	0.00020		-0.00011		-0.00008
Vol. (mL)	127		132		156
Max. Residue (g)	0.00013		0.00010		0.00010

**Enthalpy Analytical**

Company: Erthwrks, Inc

Job No.: 0622-914-5 EPA Method CTM-013 (EPA Method 8A / ALT-133) Analysis

Client No.: 9049.1.B3 MPC Detroit May 2022 Site: CCR Charge Heater

**Sulfuric Acid as Sulfate**

Sample ID	Filename #1	Filename #2	MDL (ug/mL)	Ret. Time (min.)	Ret. Time (min.)	%diff. RT	Conc. # 1 (ug/mL)	Conc. # 2 (ug/mL)	%diff. conc.	Avg. Conc. (ug/mL)	DF	Liquid Vol. (mL)	Conv. Factor	Catch Weight (ug)	Flag
CCR Charge Htr Run 1	042	043	0.0525	12.11	12.11	0.0	2.48	2.49	0.2	2.48	1	48	1.021	122	
CCR Charge Htr Run 2	044	045	0.0525	12.12	12.12	0.0	0.463	0.472	1.0	0.468	1	64	1.021	30.6	
CCR Charge Htr Run 3	060	061	0.0525	12.10	12.11	0.0	0.220	0.239	4.1	0.229	1	54	1.021	12.6	
Reagent Blank	040	041	0.0525				0.0525	0.0525		0.0525	1	82	1.021	4.40	ND

# Narrative Summary

