



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
DETROIT



DAN WYANT
DIRECTOR

August 1, 2014

Mr. C.T. Case, Deputy Assistant Secretary
Marathon Petroleum Company, LP
1300 South Fort Street
Detroit, MI 48217

SRN: A9831, Wayne County

Dear Mr. Case:

VIOLATION NOTICE

On July 7, 2014, the Department of Environmental Quality (DEQ), Air Quality Division (AQD), received a report summarizing a stack test conducted at Marathon Petroleum Company, LP located at 1300 South Fort Street, Detroit, Michigan. Staff reviewed the results from the May 6, 2014 Zurn Boiler stack testing.

Based on a review of the stack test results, the following air pollution violation was observed:

Process Description	Rule/Permit Condition Violated	Comments
Zurn Boiler (EU27-ZURNBOILER-S1)	PTI 63-08D, EU27-ZURNBOILER-S1, Condition 1.3 R 336.1205 R 336.2802 40 CFR 52.21	The Particulate Matter permit limit is 0.0019 lb/MMBtu. The stack test result was 0.0024 lb/MMBtu.


Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by August 22, 2014 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If Marathon Petroleum Company, LP believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Mr. C.T. Case
Page 2
August 1, 2014

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Jorge Acevedo
Senior Environmental Engineer
Air Quality Division
313-456-4679

cc: Ms. LaReina Wheeler, City of Detroit, Department of Environmental Affairs
cc via email: Ms. Lynn Fiedler, DEQ
Ms. Teresa Seidel, DEQ
Mr. Thomas Hess, DEQ
Ms. Wilhemina McLemore, DEQ