

STATE OF MICHIGAN

DEPARTMENT OF ENVIRONMENT, GREAT LAKES, AND ENERGY



SRN: A9831, Wayne County

DETROIT DISTRICT OFFICE

September 27, 2022

David Leaver Marathon Petroleum Company LP 1001 S. Oakwood Detroit. MI 48217

Dear David Leaver:

VIOLATION NOTICE

On August 23, 2022, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), received a stack test report from Marathon Petroleum Company, LP (Marathon) located at 1001 South Oakwood, Detroit, Michigan. Staff reviewed the results from the Gas Oil Hydrotreater (GOHT) Charge Heater stack test to determine Marathon's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the administrative rules; and the conditions of Renewable Operating Permit (ROP) number MI-ROP-A9831-2012c.

Based on a review of the stack test results, the following air pollution violation was observed:

	Rule/Permit	
Process Description	Condition Violated	Comments
GOHT Charge Heater	MI-ROP-A9831-2012c,	The Particulate Matter
(EU08-GOHTCHARHTR-S1)	FGHEATERS-S1, Condition	permit limit is 0.0019
	I.19	lb/MMBTU. The stack test
		result was 0.0039
	R 336.1205	lb/MMBTU.
	R 336.2802	
	40 CFR 52.21	

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by October 18, 2022 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

David Leaver Marathon Petroleum Company LP Page 2 September 27, 2022

Please submit the written response to EGLE, AQD, Detroit District, at 3058 West Grand Boulevard, Suite 2-300, Detroit, Michigan 48202 and submit a copy to Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

If Marathon Petroleum Company LP believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,

Jorge Acevedo

Senior Environmental Engineer

Air Quality Division 313-418-0187

cc: Hosam Hossanien, City of Detroit BSEED
Crystal Rogers, City of Detroit BSEED
Mary Ann Dolehanty, EGLE
Annette Switzer, EGLE
Christopher Ethridge, EGLE
Brad Myott, EGLE
Jenine Camilleri, EGLE
Dr. April Wendling, EGLE
Jeff Korniski, EGLE