

Relative Accuracy Test Audit (RATA) 2023

Graphic Packaging, International, LLC

Boiler 9 (EUBOILER#9)

Project number: 60703778

May 17, 2023

RECEIVED

JUL 18 2023

AIR QUALITY DIVISION

Delivering a better world

Quality information

Prepared by



Matt McDivitt
Air Quality Scientist III

Checked by



Rob Sava, QSTI
Env. Engineering IV

Reviewed by



James Edmister
Project Manager

Prepared for:

Graphic Packaging, International, LLC
1500 N Pitcher Street
Kalamazoo, Michigan 49007

Prepared by:

AECOM
564 White Pond Dr
Akron, OH 44320

aecom.com

Project Manager
James Edmister
james.edmister@aecom.com

Copyright © 2023 by AECOM

All rights reserved. No part of this copyrighted work may be reproduced, distributed, or transmitted in any form or by any means without the prior written permission of AECOM.

Table of Contents

| | | |
|-----|---|------|
| 1. | Executive Summary..... | 1-1 |
| 1.1 | Summary of Test Program..... | 1-1 |
| 1.2 | Key Personnel | 1-1 |
| 2. | Plant and Sampling Location Description | 2-1 |
| 2.1 | Facility Description..... | 2-1 |
| 2.2 | Flue Gas Sampling Locations..... | 2-1 |
| 3. | Sampling and Analysis Procedures | 3-1 |
| 3.1 | Objectives and Test Matrix | 3-1 |
| 3.2 | Facility Operations | 3-1 |
| 3.3 | Comments / Exceptions | 3-1 |
| 3.4 | Summary of Results..... | 3-1 |
| 4. | Sampling and Analytical Procedures | 4-1 |
| 4.1 | Test Methods | 4-1 |
| 4.2 | Procedures | 4-1 |
| 4.3 | List of Sampling Equipment..... | 4-2 |
| 5. | Calculations..... | 5-1 |
| 5.1 | Calibration Error - Equation 7E-1..... | 5-1 |
| 5.2 | System Bias - Equation 7E-2 | 5-2 |
| 5.3 | System Drift - Equation 7E-4..... | 5-3 |
| 5.4 | Effluent Concentration - Equation 7E-5b..... | 5-4 |
| 5.5 | Relative Accuracy | 5-5 |
| 6. | Relative Accuracy Test Data..... | 6-1 |
| 6.1 | Oxygen Calibration Data Summary | 6-1 |
| 6.2 | Nitrogen Oxides Calibration Data Summary | 6-2 |
| 6.3 | Response Time..... | 6-3 |
| 6.4 | Relative Accuracy Corrected Concentration | 6-4 |
| 6.5 | Oxygen Relative Accuracy Results..... | 6-5 |
| 6.6 | Nitrogen Oxides Relative Accuracy Results..... | 6-6 |
| 6.7 | Summary Data..... | 6-7 |
| 7. | Stack Traverse Diagrams..... | 7-1 |
| 7.1 | Three-Point Traverse | 7-1 |
| 7.2 | Twelve-Point Traverse..... | 7-2 |
| 8. | Field Data..... | 8-1 |
| 9. | Process Data..... | 9-1 |
| 10. | Certificates of Analysis..... | 10-1 |

1.2 Key Personnel

Names and affiliations of personnel, including their roles in the test program, are summarized in the following table (Table 1-2).

Table 1-2. Key Personnel

| Role | Name | Address | Contact Information |
|----------------------|----------------|---------------------------------------|--|
| Process Focal Point | Steven Smock | Graphic Packaging, International, LLC | 269-491-6055 steven.smock@graphicpkg.com |
| Regulatory Agency | Trevor Drost | EGL | 517-245-5781 Drostt@michigan.gov |
| Field Team Leader | Rob Sava | AECOM | 234-425-8440 Rob.sava@aecom.com |
| Test Project Manager | James Edmister | AECOM | (585) 721-9128 James.Edmister@aecom.com |

2. Plant and Sampling Location Description

2.1 Facility Description

Boiler 9 is a natural gas fired boiler equipped with low NO_x burners and flue gas recirculation with a maximum heat input of approximately 227 MMBtu/hr.

2.2 Flue Gas Sampling Locations

Sampling is conducted on the Boiler 9 outlet stack. The Reference Test methods for NO_x and O₂ are performed through a port that is in accordance with Performance Specification 2. The samples are withdrawn from the stack for a period of 21 minutes at the three traverse points of the measurement line that passes through the centroidal area of the stack or duct cross section. Prior to utilizing a three point traverse, a twelve point traverse was performed to verify the absence of stratification. The cross-sectional diagrams can be found in Section 7.

3. Sampling and Analysis Procedures

3.1 Objectives and Test Matrix

This testing was performed to meet the requirements of 40 CFR Part 60, Appendix B, Performance Specifications 2 and 3. The specific objectives of this test were:

- Determine the Relative Accuracy of the continuous O₂ monitor system on the Boiler 9 outlet stack.
- Determine the Relative Accuracy of the continuous NO_x monitor system on the Boiler 9 outlet stack.

Tables 3-1 and 3-2 present a summary of the results for the Performance Specification Test for CEMS RATA.

3.2 Facility Operations

During the relative accuracy test, the plant is operated Boiler 9 greater than 50 percent load. The operating rate for this unit is determined based on the steam lb/hr rate presented in Table 3-3.

3.3 Comments / Exceptions

As allowed by 40 CFR Part 60, this Performance Specification Test consisted of a minimum of 9 RM tests used for RA calculations. Ten sets of RM tests were performed. Since this option was selected, a maximum of one set of the test results may be rejected so long as the total number of test results used to determine the RA was greater than or equal to nine. All data was reported, including the rejected data.

3.4 Summary of Results

Table 3-1. NO_x Monitoring

| Test Type | NO _x Monitor Results (%) | Allowable | Pass/Fail |
|-------------------|-------------------------------------|---|-----------|
| Relative Accuracy | 2.7% | No greater than 20.0% of mean value of RM | Pass |

Table 3-2. O₂ Monitoring

| Test Type | O ₂ Monitor Results (%) | Allowable | Pass/Fail |
|-------------------|------------------------------------|---|-----------|
| Relative Accuracy | 4.8% | No greater than 20.0% of mean value of RM | Pass |

Table 3-3. Boiler 9 Steam Flow

| Boiler 9 | |
|-----------------|---------------------------|
| RATA Run # | Run Average Steam (lb/hr) |
| RATA 1 | 110900.00 |
| RATA 2 | 119800.00 |
| RATA 3 | 117400.00 |
| RATA 4 | 115600.00 |
| RATA 5 | 117000.00 |
| RATA 6 | 117238.00 |
| RATA 7 | 116600.00 |
| RATA 8 | 115800.00 |
| RATA 9 | 119100.00 |
| RATA 10 | 118000.00 |
| Average | 116743.80 |

4. Sampling and Analytical Procedures

4.1 Test Methods

The relative accuracies of Graphic Packaging’s CEMS was determined by comparison to EPA methods for measurement of each component gas. The performance specifications (PS) required the use of the following methods:

- PS 2 – Method 7E for NO_x; and
- PS 3 – Method 3A for O₂.

4.2 Procedures

The above methods were performed using mobile continuous emission monitors. Gas was withdrawn from the stack and transported to monitors located at ground level. A stainless-steel probe was inserted into the stack and used to collect sample gas. A Teflon sample line, heated at an adequate temperature to keep water in vapor form, transported sample gas from the probe to the gas conditioner followed by the analyzers. The analyzers were kept at a constant temperature inside the mobile laboratory.

Sample gas was collected continuously from the stack for a period of 21 minutes per run. Samples were taken at three traverse points of the measurement line that passes through the centroidal area of the stack or duct cross section. At the mobile laboratory, the stack gas was routed to a condenser and then transported to the analyzers for analysis.

The Relative Accuracy Tests were conducted by comparison of the CEMS response to a value measured by a Performance Test Method (PTM) which, in this case, was Method 7E for NO_x and Method 3A for O₂.

EPA Method 3A (Gas Analysis for the Determination of Dry Molecular Weight)

EPA Method 3A (Instrumental Method) was utilized to determine the diluent during each run on the outlet.

An analyzer measured O₂ content on the basis of the strong paramagnetic properties of O₂ relative to other compounds present in combustion gases. In the presence of a magnetic field, O₂ molecules become temporary magnets. The analyzer determines the sample gas O₂ concentration by detecting the displacement torque of the sample test body in the presence of a magnetic field.

EPA Method 7E (Determination of Nitrogen Oxides)

EPA Method 7E was utilized to determine NOx concentrations during each run on the outlet.

A NOx analyzer was used to monitor the concentration of NOx during each run. A sample of the effluent gas was continuously sampled and conveyed to an analyzer for measuring the concentration of NOx. The gas stream was directed through a NO₂ converter to convert NO₂ to NO concentration. The analyzer yielded results of a total result of NOx. See Figure 4-1 for a sampling train schematic.

4.3 List of Sampling Equipment

Tables 4-1 and 4-2 list the reference method analyzers used for the test and Boiler 9 analyzers while Figure 4-1 displays the sample system diagram.


Table 4-1. Reference Method

| Reference Method | Equipment | ID # | Span |
|------------------------------|------------------------|-----------|-----------|
| Method 3A (O ₂) | SERVOMEX 1440 Analyzer | OXC-A1603 | 18.95 % |
| Method 7E (NO _x) | THERMO 42i-HL Analyzer | NOX F1901 | 60.71 ppm |

Table 4-2. Boiler 9 CEMS Analyzers

| Constituent | Unit | Manuf. | Model | Serial # | Span |
|-----------------|-------|--------|-----------|-------------|-------|
| Nitrogen Oxides | ppmv | Horiba | CMA-EC622 | 42108510081 | 0-100 |
| Carbon Dioxide | vol % | Horiba | CMA-EC622 | 42108510081 | 0-25 |

Figure 4-1. Sample Train Schematic



5. Calculations

5.1 Calibration Error - Equation 7E-1

$$ACE = \frac{C_{Dir} - C_V}{CS} \times 100\%$$

C_{dir} = Measured concentration of a calibration gas (low, mid, or high) when introduced in direct calibration mode

C_V = Manufacturer certified concentration of a calibration gas (low, mid, or high)

CS = Calibration span

For oxygen, mid cal gas

| | | | |
|-----------|---|-------|---|
| C_{dir} | = | 9.98 | % |
| C_V | = | 10.00 | % |
| CS | = | 21.41 | % |

$$ACE = \frac{(9.98 - 10.00)}{21.41} \times 100\%$$

$$ACE = -0.1\%$$