

## REPORT ON COMPLIANCE AND RELATIVE ACCURACY TESTING

Carleton, Michigan

Line #1 (EU00079) & Line #2 (EU00080)

Guardian Industries, LLC  
14600 Romine Road  
Carleton, Michigan 48117  
Client Reference No. G000430977


CleanAir Project No. 14903  
A2LA ISO 17025 Certificate No. 4342.01  
A2LA / STAC Certificate No. 4342.02  
Revision 0, Final Report  
July 18, 2023

RECEIVED  
SEP 19 2023  
AIR QUALITY DIVISION

## COMMITMENT TO QUALITY

To the best of our knowledge, the data presented in this report are accurate, complete, error free and representative of the actual emissions during the test program. Clean Air Engineering operates in conformance with the requirements of ASTM D7036-04 Standard Practice for Competence of Air Emission Testing Bodies.

### Report Submittal:



Justin Giel, QSTI  
Project Field Leader  
jgiel@cleanair.com  
(800) 632-1619 ext. 2152

July 18, 2023

Date

I hereby certify that the information contained within the final test report has been reviewed and, to the best of my ability, verified as accurate.

### Independent Report Review:



Robert A. Preksta, QSTI  
Senior Project Manager  
bpreksta@cleanair.com  
(412) 480-6047

July 18, 2023

Date

---

## REPORT REVISION HISTORY

---

<b>Version</b>	<b>Revision</b>	<b>Date</b>	<b>Pages</b>	<b>Comments</b>
Draft	D0a	07/07/23	All	Draft version of original document.
Final	0	07/18/23	All	Final version of original document.

---

## PROJECT PERSONNEL

---

<b>Name</b>	<b>Affiliation</b>	<b>Project Responsibility</b>
Benjamin Kroeger, CPS, FSO	Guardian Industries, LLC	Primary Client Contact
Justin Giel	CleanAir	Project Manager / Report Submittal
Jason McKeever	CleanAir	Project Field Leader
Bob Preksta	CleanAir	Independent Review of Report
Eric Doak	CleanAir	Field Engineer
Kevan Downs	CleanAir	Field Engineer
Ethan Brady	CleanAir	Field Scientist
Brandon Ruzzi	CleanAir	Field Scientist
Jennifer Wright / Isabella Neer	CleanAir	Report Coordinators

---

## TABLE OF CONTENTS

1. Project Overview .....	1
Test Program Summary .....	1
Test Program Details .....	2
Parameters .....	2
Schedule .....	2
Discussion .....	5
2. Results .....	7
3. Description of Installation .....	21
Process Description .....	21
Test Locations .....	21
4. Methodology .....	29
Procedures and Regulations .....	29
Title 40 CFR Part 60, Appendix A .....	29
Title 40 CFR Part 60, Appendix B Performance Specifications .....	29
CTM-013 Controlled Condensation Method (CCM) .....	30
5. Appendix .....	31
Appendix A: Test Method Specifications .....	A
Appendix B: Sample Calculations .....	B
Appendix C: Parameters .....	C
Appendix D: QA/QC Data .....	D
Appendix E: Field Data .....	E
Appendix F: Field Data Printouts .....	F
Appendix G: Reference Method Monitor Data .....	G
Appendix H: Laboratory Data .....	H
Appendix I: Facility Operating Data .....	I
Appendix J: CleanAir Resumes and Certifications .....	J



## LIST OF TABLES

Table 1-1: Summary of Results / Permit Limits .....	1
Table 1-2: Summary of Results / Performance Specification Limits .....	2
Table 1-3: Line #1 (EU00079) Test Schedule .....	3
Table 1-4: Line #2 (EU00080) Test Schedule .....	4
Table 2-1: Line #1 Stack (EU00079) – FPM .....	7
Table 2-2: Line #1 Outlet (EU00079) – Sulfuric Acid Mist .....	8
Table 2-3: Line #1 Stack (EU00079) – SO <sub>2</sub> RATA (lb/hr) .....	9
Table 2-4: Line #1 Stack (EU00079) – SO <sub>2</sub> RATA (lb/ton of Glass Produced) .....	10
Table 2-5: Line #1 Stack (EU00079) – NO <sub>x</sub> RATA (ppm @7% O <sub>2</sub> ) .....	11
Table 2-6: Line #1 Stack (EU00079) – NO <sub>x</sub> RATA (lb/hr) .....	12
Table 2-7: Line #1 Inlet (EU00079) – NO <sub>x</sub> RATA (ppm @7% O <sub>2</sub> ).....	13
Table 2-8: Line #2 Stack (EU00080) – FPM .....	14
Table 2-9: Line #2 Outlet (EU00080) – Sulfuric Acid Mist .....	15
Table 2-10: Line #2 Stack (EU00080) – SO <sub>2</sub> RATA (lb/hr) .....	16
Table 2-11: Line #2 Stack (EU00080) – SO <sub>2</sub> RATA (lb/ton of Glass Produced) .....	17
Table 2-12: Line #2 Stack (EU00080) – NO <sub>x</sub> RATA (ppm @7% O <sub>2</sub> ) .....	18
Table 2-13: Line #2 Stack (EU00080) – NO <sub>x</sub> RATA (lb/hr).....	19
Table 2-14: Line #2 Inlet (EU00080) – NO <sub>x</sub> RATA (ppm @7% O <sub>2</sub> ).....	20
Table 3-1: Sampling Information .....	22

## LIST OF FIGURES

Figure 3-1: EU00079 Stack Sample Point Layout (EPA Method 1) .....	23
Figure 3-2: EU00079 Outlet (Performance Specification 2) .....	24
Figure 3-3: EU00079 Inlet (Performance Specification 2) .....	25
Figure 3-4: EU00080 Stack Sample Point Layout (EPA Method 1) .....	26
Figure 3-5: EU00080 Outlet (Performance Specification 2) .....	27
Figure 3-6: EU00080 Inlet (Performance Specification 2) .....	28

## ACRONYMS & ABBREVIATIONS

AAS (atomic absorption spectrometry)	ft <sup>2</sup> (square feet)	ml (milliliter(s))
acfm (actual cubic feet per minute)	ft <sup>3</sup> (cubic feet)	MMBtu (million British thermal units)
ACI (activated carbon injection)	ft/sec (feet per second)	MW (megawatt(s))
ADL (above detection limit)	FTIR (Fourier Transform Infrared Spectroscopy)	NCASI (National Council for Air and Stream Improvement)
AIG (ammonia injection grid)	FTRB (field train reagent blank)	ND (non-detect)
APC (air pollution control)	g (gram(s))	NDIR (non-dispersive infrared)
AQCS (air quality control system(s))	GC (gas chromatography)	NDO (natural draft opening)
ASME (American Society of Mechanical Engineers)	GFAAS (graphite furnace atomic absorption spectroscopy)	NESHAP (National Emission Standards for Hazardous Air Pollutants)
ASTM (American Society for Testing and Materials)	GFC (gas filter correlation)	ng (nanogram(s))
BDL (below detection limit)	gr/dscf (grains per dry standard cubic feet)	Nm <sup>3</sup> (Normal cubic meter)
Btu (British thermal units)	> (greater than)/ ≥ (greater than or equal to)	% (percent)
CAM (compliance assurance monitoring)	g/s (grams per second)	PEMS (predictive emissions monitoring systems)
CARB (California Air Resources Board)	H <sub>2</sub> O (water)	PFGC (pneumatic focusing gas chromatography)
CCM (Controlled Condensation Method)	HAP(s) (hazardous air pollutant(s))	pg (picogram(s))
CE (capture efficiency)	HI (heat input)	PJFF (pulse jet fabric filter)
°C (degrees Celsius)	hr (hour(s))	ppb (parts per billion)
CEMS (continuous emissions monitoring system(s))	HR GC/MS (high-resolution gas chromatography and mass spectrometry)	PPE (personal protective equipment)
CFB (circulating fluidized bed)	HRVOC (highly reactive volatile organic compounds)	ppm (parts per million)
CFR (Code of Federal Regulations)	HSRG(s) (heat recovery steam generator(s))	ppmdv (parts per million, dry volume)
cm (centimeter(s))	HVT (high velocity thermocouple)	ppmwv (parts per million, wet volume)
COMS (continuous opacity monitoring system(s))	IC (ion chromatography)	PSD (particle size distribution)
CT (combustion turbine)	IC/PCR (ion chromatography with post column reactor)	psi (pound(s) per square inch)
CTI (Cooling Technology Institute)	ICP/MS (inductively coupled argon plasma mass spectrometry)	PTE (permanent total enclosure)
CTM (Conditional Test Method)	ID (induced draft)	PTFE (polytetrafluoroethylene)
CVAAS (cold vapor atomic absorption spectroscopy)	in. (inch(es))	QA/QC (quality assurance/quality control)
CVAFS (cold vapor atomic fluorescence spectrometry)	in. H <sub>2</sub> O (inches water)	QI (qualified individual)
DI H <sub>2</sub> O (de-ionized water)	in. Hg (inches mercury)	QSTI (qualified source testing individual)
%dv (percent, dry volume)	IPA (isopropyl alcohol)	QSTO (qualified source testing observer)
DLL (detection level limited)	ISE (ion-specific electrode)	RA (relative accuracy)
DE (destruction efficiency)	kg (kilogram(s))	RATA (relative accuracy test audit)
DCI (dry carbon injection)	kg/hr (kilogram(s) per hour)	RB (reagent blank)
DGM (dry gas meter)	< (less than)/ ≤ (less than or equal to)	RE (removal or reduction efficiency)
dscf (dry standard cubic feet)	L (liter(s))	RM (reference method)
dscfm (dry standard cubic feet per minute)	lb (pound(s))	scf (standard cubic feet)
dscm (dry standard cubic meter)	lb/hr (pound per hour)	scfm (standard cubic feet per minute)
ESP (electrostatic precipitator)	lb/MMBtu (pound per million British thermal units)	SCR (selective catalytic reduction)
FAMS (flue gas adsorbent mercury speciation)	lb/TBtu (pound per trillion British thermal units)	SDA (spray dryer absorber)
°F (degrees Fahrenheit)	lb/lb-mole (pound per pound mole)	SNCR (selective non-catalytic reduction)
FB (field blank)	LR GC/MS (low-resolution gas chromatography and mass spectrometry)	STD (standard)
FCC (fluidized catalytic cracking)	m (meter)	STMS (sorbent trap monitoring system)
FCCU (fluidized catalytic cracking unit)	m <sup>3</sup> (cubic meter)	TBtu (trillion British thermal units)
FEGT (furnace exit gas temperatures)	MACT (maximum achievable control technology)	TEOM (Tapered Element Oscillating Microbalance)
FF (fabric filter)	MASS® (Multi-Point Automated Sampling System)	TEQ (toxic equivalency quotient)
FGD (flue gas desulfurization)	MATS (Mercury and Air Toxics Standards)	ton/hr (ton per hour)
FIA (flame ionization analyzer)	MDL (method detection limit)	ton/yr (ton per year)
FID (flame ionization detector)	μg (microgram(s))	TSS (third stage separator)
FPD (flame photometric detection)	min. (minute(s))	USEPA or EPA (United States Environmental Protection Agency)
FRB (field reagent blank)	mg (milligram(s))	UVA (ultraviolet absorption)
FSTM (flue gas sorbent total mercury)		WFGD (wet flue gas desulfurization)
ft (feet or foot)		%wv (percent, wet volume)



# 1. PROJECT OVERVIEW

## TEST PROGRAM SUMMARY

Guardian Industries, LLC contracted CleanAir Engineering (CleanAir) to complete testing on Line #1 (EU00079) and Line #2 (EU00080) at Guardian’s facility located in Carleton, Michigan. The objective of the test program was complete testing obligations with respect to Michigan Renewable Operating Permit (MI ROP) Number MI-ROP-B1877-2021b.

A summary of the test program results is presented below. Section 2 Results provides a more detailed account of the test conditions and data analysis.

**Table 1-1:  
 Summary of Results / Permit Limits**

Source Constituent	Sampling Method	Average Emission	Permit Limit <sup>1</sup>
<u>Line #1 Stack (EU00079)</u> FPM (lb/ton of glass produced)	EPA 5	0.04	0.45
<u>Line #1 Outlet (EU00079)</u> Sulfuric Acid Mist (lb/hr) <sup>2</sup>	CTM-013	0.2	1.6
<u>Line #2 Stack (EU00080)</u> FPM (lb/ton of glass produced)	EPA 5	0.01	0.45
<u>Line #2 Outlet (EU00080)</u> Sulfuric Acid Mist (lb/hr)	CTM-013	0.3	1.6

<sup>1</sup> Permit limits obtained from Michigan ROP Number MI-ROP-B1877-2021b.

<sup>2</sup> Sulfuric Acid Mist results based on Ion Chromatography laboratory results.

RECEIVED  
 SEP 19 2023  
 AIR QUALITY DIVISION

**Table 1-2:  
 Summary of Results / Performance Specification Limits**

Source	Constituent	Reference Method	Relative Accuracy (%) <sup>1</sup>	Applicable Specification	Specification Limit <sup>2</sup>
<u>Line #1 (EU00079) Stack</u>					
	SO <sub>2</sub> (lb/hr)	EPA 1-4, 6C	4.7	PS6	≤20% RM
	SO <sub>2</sub> (lb/ton of glass produced)	EPA 1-4, 6C	5.3	PS6	≤20% RM
	NO <sub>x</sub> (ppm @7% O <sub>2</sub> )	EPA 1-4, 7E	9.3	PS2	≤20% RM
	NO <sub>x</sub> (lb/hr)	EPA 1-4, 7E	4.4	PS6	≤20% RM
<u>Line #1 (EU00079) Inlet</u>					
	NO <sub>x</sub> (ppm @7% O <sub>2</sub> )	EPA 1-4, 7E	14.0	PS2	≤20% RM
<u>Line #2 (EU00080) Stack</u>					
	SO <sub>2</sub> (lb/hr)	EPA 1-4, 6C	1.0	PS6	≤10% Std.
	SO <sub>2</sub> (lb/ton of glass produced)	EPA 1-4, 6C	7.4	PS6	≤10% Std.
	NO <sub>x</sub> (ppm @7% O <sub>2</sub> )	EPA 1-4, 7E	6.1	PS2	≤20% RM
	NO <sub>x</sub> (lb/hr)	EPA 1-4, 7E	5.4	PS6	≤20% RM
<u>Line #2 (EU00080) Inlet</u>					
	NO <sub>x</sub> (ppm @7% O <sub>2</sub> )	EPA 1-4, 7E	3.9	PS2	≤20% RM

<sup>1</sup> Relative Accuracy is expressed in terms of comparison to the reference method (% RM) or applicable emission standard (% Std.) The specific expression used depends on the specification limit cited.

<sup>2</sup> Specification limits obtained from 40 CFR 60, Appendix B, Performance Specifications.

<sup>3</sup> Applicable Standards:

Line #2 (EU00080) Stack SO<sub>2</sub>: 134.3 lb/hr and 1.2 lb/ton glass produced

## TEST PROGRAM DETAILS

### PARAMETERS

The test program included the following measurements:

- filterable particulate matter (FPM)
- sulfuric acid mist (H<sub>2</sub>SO<sub>4</sub>)
- sulfur dioxide (SO<sub>2</sub>) – RATA Only
- nitrogen oxide (NO<sub>x</sub>) – RATA Only
- flue gas composition (e.g., O<sub>2</sub>, CO<sub>2</sub>, H<sub>2</sub>O)
- flue gas temperature
- flue gas flow rate

### SCHEDULE

Testing was performed on June 6 through June 9, 2023. Tables 1-3 and 1-4 outline the on-site schedule followed during the test program.



**Table 1-3:  
 Line #1 (EU00079) Test Schedule**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
2	Line #1 Stack	USEPA Method 5	FPM	06/08/23	13:35	14:57
3	Line #1 Stack	USEPA Method 5	FPM	06/08/23	16:00	17:13
4	Line #1 Stack	USEPA Method 5	FPM	06/09/23	07:16	08:27
2	Line #1 Outlet	CTM-013 (Mod.)	H <sub>2</sub> SO <sub>4</sub> , as Sulfuric Acid Mist	06/08/23	13:35	14:35
3	Line #1 Outlet	CTM-013 (Mod.)	H <sub>2</sub> SO <sub>4</sub> , as Sulfuric Acid Mist	06/08/23	16:00	17:00
4	Line #1 Outlet	CTM-013 (Mod.)	H <sub>2</sub> SO <sub>4</sub> , as Sulfuric Acid Mist	06/09/23	07:16	08:16
1	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	14:54	15:15
2	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	15:16	15:37
3	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	15:37	15:58
4	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	16:27	16:48
5	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	16:49	17:10
6	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	17:11	17:32
7	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	17:55	18:16
8	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	18:16	18:37
9	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	18:38	18:59
10	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	19:25	19:46
11	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	19:46	20:07
12	Line #1 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/09/23	20:07	20:28
1	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	14:54	15:15
2	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	15:16	15:37
3	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	15:37	15:58
4	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	16:27	16:48
5	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	16:49	17:10
6	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	17:11	17:32
7	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	17:55	18:16
8	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	18:16	18:37
9	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	18:38	18:59
10	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	19:25	19:46
11	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	19:46	20:07
12	Line #1 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/09/23	20:07	20:28
1	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	14:54	15:07
2	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	15:17	15:31
3	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	15:35	15:48
4	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	16:27	16:43
5	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	16:49	17:00
6	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	17:11	17:28
7	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	17:55	18:06
8	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	18:16	18:27
9	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	18:38	18:48
10	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	19:25	19:36
11	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	19:46	19:56
12	Line #1 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/09/23	20:07	20:17
1	Line #1 Stack	USEPA Method 4	Moisture	06/09/23	14:54	15:54
2	Line #1 Stack	USEPA Method 4	Moisture	06/09/23	16:27	17:27
3	Line #1 Stack	USEPA Method 4	Moisture	06/09/23	17:55	18:55
4	Line #1 Stack	USEPA Method 4	Moisture	06/09/23	19:25	20:25

**Table 1-4:  
 Line #2 (EU00080) Test Schedule**

Run Number	Location	Method	Analyte	Date	Start Time	End Time
1	Line #2 Stack	USEPA Method 5	FPM	06/06/23	09:25	11:05
2	Line #2 Stack	USEPA Method 5	FPM	06/06/23	13:24	14:47
3	Line #2 Stack	USEPA Method 5	FPM	06/06/23	16:02	17:14
1	Line #2 Outlet	CTM-013 (Mod.)	H <sub>2</sub> SO <sub>4</sub> , as Sulfuric Acid Mist	06/06/23	09:25	10:25
2	Line #2 Outlet	CTM-013 (Mod.)	H <sub>2</sub> SO <sub>4</sub> , as Sulfuric Acid Mist	06/06/23	13:24	14:24
3	Line #2 Outlet	CTM-013 (Mod.)	H <sub>2</sub> SO <sub>4</sub> , as Sulfuric Acid Mist	06/06/23	16:02	17:02
1	Line #2 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/07/23	07:47	08:08
2	Line #2 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/07/23	08:08	08:29
3	Line #2 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/07/23	08:57	09:18
4	Line #2 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/07/23	09:56	10:17
5	Line #2 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/07/23	10:18	10:39
6	Line #2 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/07/23	10:39	11:00
7	Line #2 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/07/23	12:11	12:32
8	Line #2 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/07/23	12:33	12:54
9	Line #2 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/07/23	12:55	13:16
10	Line #2 Stack	USEPA Methods 6C, 7E	SO <sub>2</sub> and NO <sub>x</sub>	06/07/23	13:59	14:20
1	Line #2 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/07/23	07:47	08:08
2	Line #2 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/07/23	08:08	08:29
3	Line #2 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/07/23	08:57	09:18
4	Line #2 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/07/23	09:56	10:17
5	Line #2 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/07/23	10:18	10:39
6	Line #2 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/07/23	10:39	11:00
7	Line #2 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/07/23	12:11	12:32
8	Line #2 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/07/23	12:33	12:54
9	Line #2 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/07/23	12:55	13:16
10	Line #2 Inlet	USEPA Method 7E	NO <sub>x</sub>	06/07/23	13:59	14:20
1	Line #2 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/07/23	07:47	08:06
2	Line #2 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/07/23	08:10	08:49
3	Line #2 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/07/23	08:59	09:18
4	Line #2 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/07/23	09:50	10:10
5	Line #2 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/07/23	10:18	10:28
6	Line #2 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/07/23	10:39	10:47
7	Line #2 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/07/23	12:11	12:21
8	Line #2 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/07/23	12:33	12:43
9	Line #2 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/07/23	12:55	13:03
10	Line #2 Stack	USEPA Methods 2 & 4	Velocity, Flow Rate	06/07/23	14:04	14:17
1	Line #1 Stack	USEPA Method 4	Moisture	06/07/23	08:26	09:26
2	Line #1 Stack	USEPA Method 4	Moisture	06/07/23	09:50	10:50
3	Line #1 Stack	USEPA Method 4	Moisture	06/07/23	12:11	13:11
4	Line #1 Stack	USEPA Method 4	Moisture	06/07/23	14:04	14:39



## DISCUSSION

### *EPA Method 5 Compliance*

EPA Method 5, "Determination of Particulate Emissions from Stationary Sources", was followed for the filterable particulate matter (FPM) measurements. This method is contained in Appendix A of 40 CFR 60. Method 5 defines particulate matter as any material that is collected before or on the surface of a quartz fiber filter.

Stack gas was isokinetically withdrawn through a temperature-controlled probe and high-efficiency quartz fiber filter. A minimum of 30 dry standard cubic feet of sample gas was collected over a one-hour test period for each run. A set of impingers were connected to the outlet of the filter. They were gravimetrically measured before and after each test to determine flue gas moisture content. A slipstream of the dry-filtered flue gas exiting the dry gas meter was collected in a flexible bag. This gas sample was analyzed for oxygen and carbon dioxide following Method 3A for each test.

The front-half of the sampling train consisted of a stainless-steel nozzle and probe liner on Line #1 (due to the large diameter of the stack) and a glass nozzle and probe liner on Line #2. These were followed by a filter holder heated to  $120^{\circ}\text{C} \pm 14^{\circ}\text{C}$  ( $248^{\circ}\text{F} \pm 25^{\circ}\text{F}$ ), and a quartz fiber filter.

After exiting the filter, the flue gas passed through a Teflon line into a series of glass impingers surrounded by ice. The purpose of the impingers was to determine the flue gas moisture concentration and thoroughly dry the gas. The sample gas then flowed into a calibrated dry gas meter where the collected sample gas volume was determined.

The front-half portion of the sample train (nozzle, probe, and heated filter) was recovered per Method 5 requirements, using acetone as the recovery solvent. The filters and front-half acetone rinses were sent to CleanAir's laboratory in Palatine, Illinois for gravimetric analysis.

Line #1, Run 1 was invalidated due to a sampling equipment problem. Compliance is based on Runs 2, 3, and 4. Because the CTM-013 testing was performed in tandem with the Method 5 testing, Run 1 was also invalidated for the CTM-013 testing.

### *Sulfuric Acid Mist – CTM-013*

CleanAir followed EPA Conditional Test Method 013 (CTM-013). This method is applicable for the determination of sulfur trioxide ( $\text{SO}_3$ ) and sulfuric acid vapor/mist ( $\text{H}_2\text{SO}_4$ ) using a controlled condensation sampling system.

The key operating parameters for this method included:

- Probe was maintained at a temperature of  $>350^{\circ}\text{F}$ .
- Quartz fiber filter was maintained at a temperature of  $>500^{\circ}\text{F}$ .
- $\text{H}_2\text{SO}_4$  condenser - Modified Graham condenser, filled with water and temperatures were maintained between  $75$  and  $85^{\circ}\text{C}$  ( $167$  to  $185^{\circ}\text{F}$ ).

A second filter, referred to as the sulfuric acid mist (SAM) filter, was located at the condenser outlet for the collection of residual sulfuric acid aerosols not collected by the condenser. The condenser temperature was regulated by a water jacket and the SAM filter was regulated by a closed oven. Both the water jacket and oven were maintained between  $167^{\circ}\text{F}$  to  $185^{\circ}\text{F}$ . The condenser and SAM filter (glass frit) were maintained above the water dew point, which eliminated the problem of oxidation of dissolved  $\text{SO}_2$ .



The condenser collection media, including the coil condenser rinse and glass frit, were extracted with DI water. CleanAir conducted three 1-hour CTM-013 tests for the determination of sulfuric acid mist. At the conclusion of each test, samples were recovered and sent to the on-site laboratory trailer for analysis. CleanAir analyzed the samples on-site with barium-thorin titration procedures on the day of sampling. CleanAir also analyzed the same samples the following day using ion chromatography (IC).

Moisture and flow data from the concurrent EPA Method 5 testing were used to calculate mass emission rates.

### *Relative Accuracy Testing*

Relative accuracy testing consisted of concurrent pollutant emissions measurements using the facility CEMS and a RM monitoring system. The RATA consisted of 12 runs of gaseous measurements for Line #1 and 10 runs for Line #2. The best nine runs were used for the RATA calculations. Each test run was 21 minutes in length.

CleanAir performed a leak check of each sampling system in its entirety prior to performing the initial bias check. The acceptable leak rate for this check is zero liters per minute (lpm) for 30 seconds, as measured on the flow control panel.

In accordance with Performance Specification 2, Paragraph 8.1.3.2, three sample points were located along a measurement line that passed through the centroidal area. The three points were located at 83.3%, 50.0%, and 16.7%.

A calibration error check and an initial system bias were performed successfully. Copies of the RM calibration error and other RM QA/QC information are in Appendix G. Calibration gas certifications are in Appendix D. Additional data reduction and calculated result parameters are in Appendix C.

A passing converter efficiency check was performed on the RM NO<sub>x</sub> analyzer according to Section 16.2 of Method 7E. The converter efficiency check is in Appendix D.

Oxygen (O<sub>2</sub>) and carbon dioxide (CO<sub>2</sub>) data used in the molecular weight calculation was determined using Method 3A and analyzed via a calibrated paramagnetic/IR instrument analyzer.

Twelve Method 2 velocity traverses were performed during the RATA. One Method 4 moisture run was conducted for every three RATA runs for a total of four moisture runs performed. The results from the Methods 2 and 4 testing were used to convert the compliance data concentration-based results into mass-based emission results in units of lb/hr and lb/ton glass produced.

---

*End of Section*

## 2. RESULTS

This section summarizes the test program results. Additional results are available in the report appendices.

**Table 2-1:  
 Line #1 Stack (EU00079) – FPM**

Run No.	2	3	4	Average
Date (2023)	Jun 8	Jun 8	Jun 9	
Start Time (approx.)	13:35	16:00	07:16	
Stop Time (approx.)	14:57	17:13	08:27	
<b>Process Conditions</b>				
R <sub>p</sub> Production rate (ton of glass produced/hr)	16.7	16.7	16.7	16.7
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	11.2	11.0	10.1	10.8
CO <sub>2</sub> Carbon dioxide (dry volume %)	8.1	8.4	7.8	8.1
T <sub>s</sub> Stack temperature (°F)	594	594	591	593
B <sub>w</sub> Actual water vapor in gas (% by volume)	11.6	12.4	12.0	12.0
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	98,500	102,000	102,000	101,000
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	47,900	49,700	49,700	49,100
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	42,400	43,500	43,800	43,200
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	39.19	40.71	41.57	40.49
%I Isokinetic sampling (%)	100.7	101.9	103.4	102.0
<b>Laboratory Data</b>				
m <sub>filter</sub> Matter collected on filter(s) (g)	0.00204	0.00305	0.00191	
m <sub>s</sub> Matter collected in solvent rinse(s) (g)	0.00164	0.00321	0.00244	
m <sub>n</sub> Total FPM (g)	0.00368	0.00626	0.00435	
<b>FPM Results</b>				
C <sub>sd</sub> Particulate Concentration (lb/dscf)	2.07E-07	3.39E-07	2.31E-07	2.59E-07
E <sub>lbhr</sub> Particulate Rate (lb/hr)	0.526	0.884	0.606	0.672
E <sub>RP</sub> Particulate Rate - Production-based (lb/ton of glass produced)	0.0315	0.0529	0.0364	0.0403

Average includes 3 runs.

**Table 2-2:  
Line #1 Outlet (EU00079) – Sulfuric Acid Mist**

Run No. <sup>1</sup>	2	3	4	Average
Date (2023)	Jun 8	Jun 8	Jun 9	
Start Time (approx.)	13:35	16:00	07:16	
Stop Time (approx.)	14:35	17:00	08:16	
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	11.2	11.0	10.1	<b>10.8</b>
CO <sub>2</sub> Carbon dioxide (dry volume %)	8.1	8.4	7.8	<b>8.1</b>
T <sub>s</sub> Stack temperature (°F)	632	623	612	<b>622</b>
B <sub>w</sub> Actual water vapor in gas (% by volume)	11.72	11.67	12.96	<b>12.12</b>
<b>Gas Flow Rate<sup>2</sup></b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	98,500	102,000	102,000	<b>101,000</b>
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	47,900	49,700	49,700	<b>49,100</b>
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	42,400	43,500	43,800	<b>43,200</b>
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	23.78	23.65	24.02	<b>23.82</b>
<b>Laboratory Data (Ion Chromatography)</b>				
m <sub>n</sub> Total H <sub>2</sub> SO <sub>4</sub> collected (mg)	0.5580	0.6758	0.9514	
<b>Laboratory Data (Titration)</b>				
m <sub>n</sub> Total H <sub>2</sub> SO <sub>4</sub> collected (mg)	0.9303	0.8908	1.0224	
<b>Sulfuric Acid Mist (H<sub>2</sub>SO<sub>4</sub>) IC Results</b>				
C <sub>sd</sub> H <sub>2</sub> SO <sub>4</sub> Concentration (ppmdv)	0.203	0.248	0.343	<b>0.265</b>
E <sub>lb/hr</sub> H <sub>2</sub> SO <sub>4</sub> Rate (lb/hr)	0.132	0.164	0.229	<b>0.175</b>
<b>Sulfuric Acid Mist (H<sub>2</sub>SO<sub>4</sub>) Titration Results</b>				
C <sub>sd</sub> H <sub>2</sub> SO <sub>4</sub> Concentration (ppmdv)	0.339	0.326	0.369	<b>0.345</b>
E <sub>lb/hr</sub> H <sub>2</sub> SO <sub>4</sub> Rate (lb/hr)	0.219	0.217	0.246	<b>0.227</b>

<sup>1</sup> Run 1 was invalidated due to a sampling train equipment problem during the concurrently run Method 5 test.<sup>2</sup> Velocity and flow rate data obtained from USEPA Method 5 testing.



**Table 2-3:  
 Line #1 Stack (EU00079) – SO<sub>2</sub> RATA (lb/hr)**

Run No.	Start Time	Date (2023)	RM Data (lb/hr)	CEMS Data (lb/hr)	Difference (lb/hr)	Difference Percent
1 *	14:54	Jun 9	4.46	5.00	-0.54	-12.2%
2 *	15:16	Jun 9	2.68	4.50	-1.82	-67.9%
3 *	15:37	Jun 9	4.33	5.20	-0.87	-20.2%
4	16:27	Jun 9	4.89	5.10	-0.21	-4.3%
5	16:49	Jun 9	5.16	5.30	-0.14	-2.8%
6	17:11	Jun 9	5.09	5.30	-0.21	-4.2%
7	17:55	Jun 9	4.81	5.30	-0.49	-10.2%
8	18:16	Jun 9	4.96	5.40	-0.44	-8.9%
9	18:38	Jun 9	5.16	5.40	-0.24	-4.7%
10	19:25	Jun 9	4.61	4.90	-0.29	-6.3%
11	19:46	Jun 9	4.62	5.00	-0.38	-8.2%
12	20:07	Jun 9	4.66	5.20	-0.54	-11.5%
<b>Average</b>			<b>4.88</b>	<b>5.21</b>	<b>-0.33</b>	<b>-6.7%</b>

**Relative Accuracy Test Audit Results**

Standard Deviation of Differences	0.138956	
Confidence Coefficient (CC)	0.106810	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	<b>8.89%</b>	<b>Limit 20.0%</b>

RM = Reference Method (CleanAir Data) 062323 160415  
 CEMS = Continuous Emissions Monitoring System (Guardian Industries, LLC Data)  
 RATA calculations are based on 9 of 12 runs. \* indicates the excluded runs.

**Table 2-4:  
 Line #1 Stack (EU00079) – SO<sub>2</sub> RATA (lb/ton of Glass Produced)**

Run No.	Start Time	Date (2023)	RM Data (lb/ton of glass produced)	CEMS Data (lb/ton of glass produced)	Difference (lb/ton of glass produced)	Difference Percent
1 *	14:54	Jun 9	0.27	0.30	-0.03	-12.2%
2 *	15:16	Jun 9	0.16	0.27	-0.11	-67.9%
3 *	15:37	Jun 9	0.26	0.31	-0.05	-19.4%
4	16:27	Jun 9	0.29	0.31	-0.02	-5.6%
5	16:49	Jun 9	0.31	0.32	-0.01	-3.4%
6	17:11	Jun 9	0.31	0.32	-0.01	-4.8%
7	17:55	Jun 9	0.29	0.32	-0.03	-10.7%
8	18:16	Jun 9	0.30	0.33	-0.03	-10.8%
9	18:38	Jun 9	0.31	0.33	-0.02	-6.5%
10	19:25	Jun 9	0.28	0.30	-0.02	-8.4%
11	19:46	Jun 9	0.28	0.30	-0.02	-8.0%
12	20:07	Jun 9	0.28	0.31	-0.03	-10.6%
<b>Average</b>			<b>0.29</b>	<b>0.32</b>	<b>-0.02</b>	<b>-7.6%</b>

**Relative Accuracy Test Audit Results**

Standard Deviation of Differences	0.007576	
Confidence Coefficient (CC)	0.005823	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	<b>9.58%</b>	<b>Limit 20.0%</b>

RM = Reference Method (CleanAir Data)

062323 160415

CEMS = Continuous Emissions Monitoring System (Guardian Industries, LLC Data)

RATA calculations are based on 9 of 12 runs. \* indicates the excluded runs.

**Table 2-5:  
 Line #1 Stack (EU00079) – NO<sub>x</sub> RATA (ppm @7% O<sub>2</sub>)**

Run No.	Start Time	Date (2023)	RM Data (ppm@7%O <sub>2</sub> )	CEMS Data (ppm@7%O <sub>2</sub> )	Difference (ppm@7%O <sub>2</sub> )	Difference Percent
1	14:54	Jun 9	166.9	156.2	10.7	6.4%
2	15:16	Jun 9	175.1	162.2	12.9	7.4%
3	15:37	Jun 9	148.8	138.7	10.1	6.8%
4	16:27	Jun 9	157.2	144.0	13.2	8.4%
5 *	16:49	Jun 9	167.7	151.6	16.1	9.6%
6 *	17:11	Jun 9	144.1	143.4	0.7	0.5%
7	17:55	Jun 9	164.3	152.8	11.5	7.0%
8	18:16	Jun 9	151.2	139.9	11.3	7.5%
9	18:38	Jun 9	174.9	161.6	13.3	7.6%
10	19:25	Jun 9	188.0	173.5	14.5	7.7%
11 *	19:46	Jun 9	163.1	148.3	14.8	9.0%
12	20:07	Jun 9	176.6	162.5	14.1	8.0%
<b>Average</b>			<b>167.0</b>	<b>154.6</b>	<b>12.4</b>	<b>7.4%</b>

**Relative Accuracy Test Audit Results**

Standard Deviation of Differences	1.531915	
Confidence Coefficient (CC)	1.177532	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	<b>8.13%</b>	Limit <b>20.0%</b>

RM = Reference Method (CleanAir Data) 062323 160415  
 CEMS = Continuous Emissions Monitoring System (Guardian Industries, LLC Data)  
 RATA calculations are based on 9 of 12 runs. \* indicates the excluded runs.



**Table 2-6:**  
**Line #1 Stack (EU00079) – NO<sub>x</sub> RATA (lb/hr)**

Run No.	Start Time	Date (2023)	RM Data (lb/hr)	CEMS Data (lb/hr)	Difference (lb/hr)	Difference Percent
1	14:54	Jun 9	39.2	39.7	-0.5	-1.4%
2	15:16	Jun 9	39.1	39.0	0.1	0.1%
3	15:37	Jun 9	35.5	35.9	-0.4	-1.0%
4	16:27	Jun 9	39.5	37.9	1.6	4.1%
5 *	16:49	Jun 9	41.7	39.6	2.1	5.0%
6 *	17:11	Jun 9	35.8	37.5	-1.7	-4.7%
7	17:55	Jun 9	40.4	40.1	0.3	0.8%
8	18:16	Jun 9	37.6	36.9	0.7	1.8%
9	18:38	Jun 9	44.0	42.5	1.5	3.4%
10	19:25	Jun 9	45.9	44.1	1.8	4.0%
11 *	19:46	Jun 9	39.8	38.7	1.1	2.9%
12	20:07	Jun 9	44.0	43.4	0.6	1.3%
<b>Average</b>			<b>40.6</b>	<b>39.9</b>	<b>0.6</b>	<b>1.6%</b>

**Relative Accuracy Test Audit Results**

Standard Deviation of Differences	0.868194	
Confidence Coefficient (CC)	0.667352	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	<b>3.21%</b>	<b>Limit 20.0%</b>

RM = Reference Method (CleanAir Data)

062323 1604 15

CEMS = Continuous Emissions Monitoring System (Guardian Industries, LLC Data)

RATA calculations are based on 9 of 12 runs. \* indicates the excluded runs.

**Table 2-7:**  
**Line #1 Inlet (EU00079) – NO<sub>x</sub> RATA (ppm @7% O<sub>2</sub>)**

Run No.	Start Time	Date (2023)	RM Data (ppm@7%O2)	CEMS Data (ppm@7%O2)	Difference (ppm@7%O2)	Difference Percent
1	14:54	Jun 9	1049.1	1179.8	-130.7	-12.5%
2 *	15:16	Jun 9	1097.0	1618.1	-521.1	-47.5%
3	15:37	Jun 9	1046.8	1160.9	-114.1	-10.9%
4	16:27	Jun 9	1062.8	1197.4	-134.6	-12.7%
5	16:49	Jun 9	1072.8	1187.0	-114.2	-10.6%
6	17:11	Jun 9	1079.4	1204.4	-125.0	-11.6%
7	17:55	Jun 9	1085.5	1215.2	-129.7	-12.0%
8 *	18:16	Jun 9	909.4	1194.2	-284.8	-31.3%
9 *	18:38	Jun 9	211.2	1240.5	-1029.3	-487.5%
10	19:25	Jun 9	1117.5	1259.8	-142.3	-12.7%
11	19:46	Jun 9	1072.1	1215.5	-143.4	-13.4%
12	20:07	Jun 9	1078.8	1263.1	-184.3	-17.1%
<b>Average</b>			<b>1073.9</b>	<b>1209.2</b>	<b>-135.4</b>	<b>-12.6%</b>

**Relative Accuracy Test Audit Results**

Standard Deviation of Differences	21.119689	
Confidence Coefficient (CC)	16.234001	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	<b>14.12%</b>	Limit <b>20.0%</b>

RM = Reference Method (CleanAir Data)

062323 160415

CEMS = Continuous Emissions Monitoring System (Guardian Industries, LLC Data)

RATA calculations are based on 9 of 12 runs. \* indicates the excluded runs.

**Table 2-8:**  
**Line #2 Stack (EU00080) – FPM**

Run No.	1	2	3	Average
Date (2023)	Jun 6	Jun 6	Jun 6	
Start Time (approx.)	09:25	13:24	16:02	
Stop Time (approx.)	11:05	14:47	17:14	
<b>Process Conditions</b>				
R <sub>p</sub> Production rate (ton of glass produced/hr)	17.8	17.8	17.8	17.8
<b>Gas Conditions</b>				
O <sub>2</sub> Oxygen (dry volume %)	14.2	14.1	14.1	14.2
CO <sub>2</sub> Carbon dioxide (dry volume %)	4.2	4.3	4.3	4.3
T <sub>s</sub> Stack temperature (°F)	457	461	456	458
B <sub>w</sub> Actual water vapor in gas (% by volume)	9.1	8.6	8.6	8.8
<b>Gas Flow Rate</b>				
Q <sub>a</sub> Volumetric flow rate, actual (acfm)	88,200	93,300	92,800	91,400
Q <sub>s</sub> Volumetric flow rate, standard (scfm)	49,600	52,200	52,200	51,400
Q <sub>std</sub> Volumetric flow rate, dry standard (dscfm)	45,100	47,700	47,700	46,900
<b>Sampling Data</b>				
V <sub>mstd</sub> Volume metered, standard (dscf)	40.90	43.97	45.39	43.42
%I Isokinetic sampling (%)	97.0	98.5	101.7	99.1
<b>Laboratory Data</b>				
m <sub>filter</sub> Matter collected on filter(s) (g)	0.00037	0.00082	0.00029	
m <sub>s</sub> Matter collected in solvent rinse(s) (g)	0.00120	0.00095	0.00130	
m <sub>n</sub> Total FPM (g)	0.00157	0.00177	0.00159	
<b>FPM Results</b>				
C <sub>sd</sub> Particulate Concentration (lb/dscf)	8.46E-08	8.88E-08	7.72E-08	8.35E-08
E <sub>lb/hr</sub> Particulate Rate (lb/hr)	0.229	0.254	0.221	0.235
E <sub>Rp</sub> Particulate Rate - Production-based (lb/ton of glass produced)	0.0129	0.0143	0.0125	0.0132

Average includes 3 runs.



**Table 2-9:  
 Line #2 Outlet (EU00080) – Sulfuric Acid Mist**

Run No.		1	2	3	Average
Date (2023)		Jun 6	Jun 6	Jun 6	
Start Time (approx.)		09:25	13:24	16:02	
Stop Time (approx.)		10:25	14:24	17:02	
<b>Gas Conditions</b>					
O <sub>2</sub>	Oxygen (dry volume %)	14.2	14.1	14.1	14.2
CO <sub>2</sub>	Carbon dioxide (dry volume %)	4.2	4.3	4.3	4.3
T <sub>s</sub>	Stack temperature (°F)	482	489	483	485
B <sub>w</sub>	Actual water vapor in gas (% by volume)	11.21	9.92	9.39	10.17
<b>Gas Flow Rate<sup>1</sup></b>					
Q <sub>a</sub>	Volumetric flow rate, actual (acfm)	88,200	93,300	92,800	91,400
Q <sub>s</sub>	Volumetric flow rate, standard (scfm)	49,600	52,200	52,200	51,400
Q <sub>std</sub>	Volumetric flow rate, dry standard (dscfm)	45,100	47,700	47,700	46,900
<b>Sampling Data</b>					
V <sub>mstd</sub>	Volume metered, standard (dscf)	24.31	23.63	24.05	24.00
<b>Laboratory Data (Ion Chromatography)</b>					
m <sub>n</sub>	Total H2SO4 collected (mg)	0.5987	0.8004	1.0171	
<b>Laboratory Data (Titration)</b>					
m <sub>n</sub>	Total H2SO4 collected (mg)	0.83312	1.39382	1.39242	
<b>Sulfuric Acid Mist (H2SO4) IC Results</b>					
C <sub>sd</sub>	H2SO4 Concentration (ppmdv)	0.213	0.294	0.366	0.291
E <sub>lb/hr</sub>	H2SO4 Rate (lb/hr)	0.147	0.214	0.267	0.209
<b>Sulfuric Acid Mist (H2SO4) Titration Results</b>					
C <sub>sd</sub>	H2SO4 Concentration (ppmdv)	0.29699	0.5113	0.5017	0.437
E <sub>lb/hr</sub>	H2SO4 Rate (lb/hr)	0.20448	0.37264	0.36557	0.314

<sup>1</sup> Velocity and flow rate data obtained from USEPA Method 5 testing.

**Table 2-10:**  
**Line #2 Stack (EU00080) – SO<sub>2</sub> RATA (lb/hr)**

Run No.	Start Time	Date (2023)	RM Data (lb/hr)	CEMS Data (lb/hr)	Difference (lb/hr)	Difference Percent
1	07:47	Jun 7	5.70	7.20	-1.50	-26.4%
2	08:08	Jun 7	7.99	9.20	-1.21	-15.1%
3	08:57	Jun 7	7.34	8.50	-1.16	-15.8%
4	09:56	Jun 7	5.85	6.90	-1.05	-17.9%
5	10:18	Jun 7	6.96	8.10	-1.14	-16.4%
6 *	10:39	Jun 7	5.26	6.60	-1.34	-25.4%
7	12:11	Jun 7	6.20	7.20	-1.00	-16.1%
8	12:33	Jun 7	4.77	6.00	-1.23	-25.8%
9	12:55	Jun 7	6.50	7.20	-0.70	-10.8%
10	13:59	Jun 7	5.30	6.70	-1.40	-26.4%
<b>Average</b>			<b>6.29</b>	<b>7.44</b>	<b>-1.15</b>	<b>-18.3%</b>

**Relative Accuracy Test Audit Results**

Standard Deviation of Differences	0.231835	
Confidence Coefficient (CC)	0.178204	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of Appl. Std.)	<b>0.99%</b>	Limit <b>10.0%</b>
Appl. Std. = 134.3 lb/hr		

RM = Reference Method (CleanAir Data) 062323 160549  
 CEMS = Continuous Emissions Monitoring System (Guardian Industries, LLC Data)  
 RATA calculations are based on 9 of 10 runs. \* indicates the excluded run.

**Table 2-11:**  
**Line #2 Stack (EU00080) – SO<sub>2</sub> RATA (lb/ton of Glass Produced)**

Run No.	Start Time	Date (2023)	RM Data (lb/ton of glass produced)	CEMS Data (lb/ton of glass produced)	Difference (lb/ton of glass produced)	Difference Percent
1	07:47	Jun 7	0.32	0.40	-0.08	-24.3%
2	08:08	Jun 7	0.45	0.50	-0.05	-10.8%
3	08:57	Jun 7	0.41	0.50	-0.09	-20.6%
4	09:56	Jun 7	0.33	0.40	-0.07	-21.0%
5	10:18	Jun 7	0.39	0.50	-0.11	-27.2%
6 *	10:39	Jun 7	0.30	0.40	-0.10	-34.5%
7	12:11	Jun 7	0.35	0.40	-0.05	-14.2%
8	12:33	Jun 7	0.27	0.30	-0.03	-11.4%
9	12:55	Jun 7	0.37	0.40	-0.03	-9.0%
10	13:59	Jun 7	0.30	0.40	-0.10	-33.6%
<b>Average</b>			<b>0.36</b>	<b>0.42</b>	<b>-0.07</b>	<b>-18.8%</b>

**Relative Accuracy Test Audit Results**

Standard Deviation of Differences      0.028091  
 Confidence Coefficient (CC)              0.021593  
 t-Value for 9 Data Sets                    2.306

Relative Accuracy (as % of Appl. Std.)      **7.38%**      Limit **10.0%**  
 Appl. Std. = 1.2 lb/ton of glass produced

RM = Reference Method (CleanAir Data)

062323 60549

CEMS = Continuous Emissions Monitoring System (Guardian Industries, LLC Data)

RATA calculations are based on 9 of 10 runs. \* indicates the excluded run.



**Table 2-12:**  
**Line #2 Stack (EU00080) – NO<sub>x</sub> RATA (ppm @7% O<sub>2</sub>)**

Run No.	Start Time	Date (2023)	RM Data (ppm@7%O2)	CEMS Data (ppm@7%O2)	Difference (ppm@7%O2)	Difference Percent
1	07:47	Jun 7	332.2	354.5	-22.3	-6.7%
2 *	08:08	Jun 7	372.3	392.7	-20.4	-5.5%
3	08:57	Jun 7	330.1	351.8	-21.7	-6.6%
4	09:56	Jun 7	370.0	383.0	-13.0	-3.5%
5	10:18	Jun 7	361.1	387.3	-26.2	-7.2%
6	10:39	Jun 7	369.3	388.1	-18.8	-5.1%
7	12:11	Jun 7	405.6	426.5	-20.9	-5.1%
8	12:33	Jun 7	371.6	391.4	-19.8	-5.3%
9	12:55	Jun 7	393.9	408.6	-14.7	-3.7%
10	13:59	Jun 7	370.5	385.5	-15.0	-4.1%
<b>Average</b>			<b>367.2</b>	<b>386.3</b>	<b>-19.1</b>	<b>-5.2%</b>

**Relative Accuracy Test Audit Results**

Standard Deviation of Differences	4.234677	
Confidence Coefficient (CC)	3.255055	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	<b>6.10%</b>	<b>Limit 20.0%</b>

RM = Reference Method (CleanAir Data)

062323 160549

CEMS = Continuous Emissions Monitoring System (Guardian Industries, LLC Data)

RATA calculations are based on 9 of 10 runs. \* indicates the excluded run.

**Table 2-13:**  
**Line #2 Stack (EU00080) – NO<sub>x</sub> RATA (lb/hr)**

Run No.	Start Time	Date (2023)	RM Data (lb/hr)	CEMS Data (lb/hr)	Difference (lb/hr)	Difference Percent
1	07:47	Jun 7	53.4	57.5	-4.1	-7.7%
2 *	08:08	Jun 7	59.6	64.6	-5.0	-8.4%
3	08:57	Jun 7	53.3	57.1	-3.8	-7.0%
4	09:56	Jun 7	62.8	62.6	0.2	0.3%
5	10:18	Jun 7	58.3	62.2	-3.9	-6.6%
6	10:39	Jun 7	60.3	62.4	-2.1	-3.6%
7	12:11	Jun 7	66.5	68.7	-2.2	-3.3%
8	12:33	Jun 7	60.8	61.7	-0.9	-1.5%
9	12:55	Jun 7	66.4	65.8	0.6	0.9%
10	13:59	Jun 7	61.7	62.1	-0.4	-0.7%
<b>Average</b>			<b>60.4</b>	<b>62.2</b>	<b>-1.8</b>	<b>-3.1%</b>

**Relative Accuracy Test Audit Results**

Standard Deviation of Differences	1.805617	
Confidence Coefficient (CC)	1.387918	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	<b>5.36%</b>	Limit <b>20.0%</b>

RM = Reference Method (CleanAir Data) 062323 160549  
 CEMS = Continuous Emissions Monitoring System (Guardian Industries, LLC Data)  
 RATA calculations are based on 9 of 10 runs. \* indicates the excluded run.

**Table 2-14:**  
**Line #2 Inlet (EU00080) – NO<sub>x</sub> RATA (ppm @7% O<sub>2</sub>)**

Run No.	Start Time	Date (2023)	RM Data (ppm@7%O2)	CEMS Data (ppm@7%O2)	Difference (ppm@7%O2)	Difference Percent
1	07:47	Jun 7	1915.5	1822.4	93.1	4.9%
2	08:08	Jun 7	1975.0	1941.1	33.9	1.7%
3	08:57	Jun 7	1933.9	1877.4	56.5	2.9%
4	09:56	Jun 7	2000.7	1999.5	1.2	0.1%
5 *	10:18	Jun 7	1994.0	1892.0	102.0	5.1%
6	10:39	Jun 7	2024.4	2031.2	-6.8	-0.3%
7	12:11	Jun 7	2111.6	2029.4	82.2	3.9%
8	12:33	Jun 7	2022.4	1932.7	89.7	4.4%
9	12:55	Jun 7	2084.7	2035.1	49.6	2.4%
10	13:59	Jun 7	2051.3	1987.1	64.2	3.1%
<b>Average</b>			<b>2013.3</b>	<b>1961.8</b>	<b>51.5</b>	<b>2.6%</b>

**Relative Accuracy Test Audit Results**

Standard Deviation of Differences	36.336917	
Confidence Coefficient (CC)	27.930977	
t-Value for 9 Data Sets	2.306	
Relative Accuracy (as % of RM)	<b>3.95%</b>	Limit <b>20.0%</b>

RM = Reference Method (CleanAir Data)

062323 160549

CEMS = Continuous Emissions Monitoring System (Guardian Industries, LLC Data)

RATA calculations are based on 9 of 10 runs. \* indicates the excluded run.

*End of Section*



### 3. DESCRIPTION OF INSTALLATION

#### PROCESS DESCRIPTION

---

Guardian’s flat glass manufacturing Line #1 and Line #2 consist of a raw material melting Furnace, glass forming and finishing, and glass cutting. Line #1 and Line #2 produce flat glass using the float method. Materials are weighed and mixed with water in the batch house before entering the natural gas-fired Furnace. Glass then enters the tin bath to be formed and drawn. Next, it enters a lehr to reduce its temperature. The natural gas-fired Furnace portion of the emission unit is controlled by a control device consisting of a Dry Scrubber (DS), Particulate Filter (PF), and Selective Catalytic Reduction (SCR).

The emission unit includes a 4,000 cubic foot Dry Scrubber reagent storage silo equipped with a passive bin vent and a 20,000-gallon pressurized aqueous ammonia storage tank.

The testing reported in this document will be performed at the Stack locations (EU00079 and EU00080).

#### TEST LOCATIONS

---

The sample point placement was determined by EPA Method 1 and Performance Specification 2. Table 3-1 presents the sampling information for the test locations. The figures represent the layout of the test location.


**Table 3-1:  
 Sampling Information**

Source Constituent	Method	Run No.	Ports	Points per Port	Minutes per Point	Total Minutes	Figure
<u>Line #1 Stack (EU00079)</u>							
Flow Rate	EPA 2	1-12	2	6	Varied	Varied	3-1
Moisture	EPA 4	1-3	1	1	60	60	NA
FPM	EPA 5	2-4	2	6	5	60	3-1
<u>Line #1 Outlet (EU00079)</u>							
H <sub>2</sub> SO <sub>4</sub> , as Sulfuric Acid Mist	CTM-013	2-4	1	1	60	60	NA
SO <sub>2</sub> , NO <sub>x</sub>	EPA 6C, 7E	1-12	1	3	7	21	3-2
<u>Line #1 Inlet (EU00079)</u>							
NO <sub>x</sub>	EPA 7E	1-12	1	3	7	21	3-3
<u>Line #2 Stack (EU00080)</u>							
Flow Rate	EPA 2	1-10	2	6	Varied	Varied	3-4
Moisture	EPA 4	1-3	1	1	60	60	NA
Moisture	EPA 4	4	1	1	35	35	NA
FPM	EPA 5	1-3	2	6	5	60	3-4
<u>Line #2 Outlet (EU00080)</u>							
H <sub>2</sub> SO <sub>4</sub> , as Sulfuric Acid Mist	CTM-013	1-3	1	1	60	60	NA
SO <sub>2</sub> , NO <sub>x</sub>	EPA 6C, 7E	1-10	1	3	7	21	3-5
<u>Line #2 Inlet (EU00080)</u>							
NO <sub>x</sub>	EPA 7E	1-10	1	3	7	21	3-6

Note:

Moisture and H<sub>2</sub>SO<sub>4</sub> were sampled at the approximate center of the duct. Readings were taken every five minutes.

**Figure 3-1:**  
**EU00079 Stack Sample Point Layout (EPA Method 1)**




Sampling Point	% of Stack Diameter	Port to Point Distance (inches)
1	95.6	123.3
2	85.4	110.2
3	70.4	90.8
4	29.6	38.2
5	14.6	18.8
6	4.4	5.7

Duct diameters upstream from flow disturbance (A): 11.2  
 Duct diameters downstream from flow disturbance (B): 7.0

Limit: 0.5  
 Limit: 2.0




**Figure 3-2:  
 EU00079 Outlet (Performance Specification 2)**



Sampling Point	% of Stack Diameter	Port to Point Distance (inches)
1	83.3	46.7
2	50.0	28.0
3	16.7	9.4

Equivalent duct diameters upstream from flow disturbance (A): 1.9      Limit: NA  
 Equivalent duct diameters downstream from flow disturbance (B): 5.7      Limit: NA

**Figure 3-3:  
 EU00079 Inlet (Performance Specification 2)**




Sampling Point	% of Stack Diameter	Port to Point Distance (inches)
1	83.3	63.3
2	50.0	38.0
3	16.7	12.7

Duct diameters upstream from flow disturbance (A): ≈0.4  
 Duct diameters downstream from flow disturbance (B): ≈1.9

Limit: 0.5  
 Limit: 2.0

RECEIVED  
 SEP 19 2023  
 AIR QUALITY DIVISION

**Figure 3-4:**  
**EU00080 Stack Sample Point Layout (EPA Method 1)**




Sampling Point	% of Stack Diameter	Port to Point Distance (inches)
1	95.6	75.0
2	85.4	67.0
3	70.4	55.3
4	29.6	23.2
5	14.6	11.5
6	4.4	3.5

Duct diameters upstream from flow disturbance (A): ≈2.3  
 Duct diameters downstream from flow disturbance (B): ≈13

Limit: 0.5  
 Limit: 2.0



**Figure 3-5:  
 EU00080 Outlet (Performance Specification 2)**




Sampling Point	% of Duct Diameter	Port to Point Distance (inches)
1	83.3	63.3
2	50.0	38.0
3	16.7	12.7

Duct diameters upstream from flow disturbance (A): 1.9  
 Duct diameters downstream from flow disturbance (B): 5.7

Limit: 0.5  
 Limit: 2.0

**Figure 3-6:**  
**EU00080 Inlet (Performance Specification 2)**



Sampling Point	% of Duct Width	Port to Point Distance (inches)
1	83.3	70.0
2	50.0	42.0
3	16.7	14.0

Equivalent duct diameters upstream from flow disturbance (A): ≈0.4

Limit: NA

Equivalent duct downstream from flow disturbance (B): ≈1.9

Limit: NA

*End of Section*

## 4. METHODOLOGY

### PROCEDURES AND REGULATIONS

---

The test program sampling measurements followed procedures and regulations outlined by the USEPA and Michigan Department of Environment, Great Lakes, and Energy (EGLE). These methods appear in detail in Title 40 of the CFR and at <https://www.epa.gov/emc>.

Appendix A includes diagrams of the sampling apparatus, as well as specifications for sampling, recovery, and analytical procedures. Any modifications to standard test methods are explicitly indicated in this appendix. In accordance with ASTM D7036 requirements, CleanAir included a description of any such modifications along with the full context of the objectives and requirements of the test program in the test protocol submitted prior to the measurement portion of this project. Modifications to standard methods are not covered by the ISO 17025 and TNI portions of CleanAir's A2LA accreditation.

CleanAir follows specific QA/QC procedures outlined in the individual methods and in USEPA "Quality Assurance Handbook for Air Pollution Measurement Systems: Volume III Stationary Source-Specific Methods," EPA/600/R-94/038C. Appendix D contains additional QA/QC measures, as outlined in CleanAir's internal Quality Manual.

#### TITLE 40 CFR PART 60, APPENDIX A

Method 1	"Sample and Velocity Traverses for Stationary Sources"
Method 2	"Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)"
Method 3A	"Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)"
Method 4	"Determination of Moisture Content in Stack Gases"
Method 5	"Determination of Particulate Matter Emissions from Stationary Sources"
Method 6C	"Determination of Sulfur Dioxide Emissions from Stationary Sources (Instrumental Analyzer Procedure)"
Method 7E	"Determination of Nitrogen Oxide Emissions from Stationary Sources (Instrumental Analyzer Procedure)"

#### TITLE 40 CFR PART 60, APPENDIX B PERFORMANCE SPECIFICATIONS

PS2	"Specifications and Test Procedures for SO <sub>2</sub> and NO <sub>x</sub> Continuous Emission Monitoring Systems in Stationary Sources"
PS3	"Specifications and Test Procedures for O <sub>2</sub> and CO <sub>2</sub> Continuous Emission Monitoring Systems in Stationary Sources"
PS6	"Specifications and Test Procedures for Continuous Emission Rate Monitoring Systems in Stationary Sources"



## CTM-013 CONTROLLED CONDENSATION METHOD (CCM)

“Determination of Sulfur Oxides Including Sulfur Dioxide, Sulfur Trioxide and Sulfuric Acid Vapor and Mist from Stationary Sources Using a Controlled Condensation Sampling Apparatus”

---

*End of Section*

## 5. *APPENDIX*

- Appendix A: Test Method Specifications
- Appendix B: Sample Calculations
- Appendix C: Parameters
- Appendix D: QA/QC Data
- Appendix E: Field Data
- Appendix F: Field Data Printouts
- Appendix G: Reference Method Monitor Data
- Appendix H: Laboratory Data
- Appendix I: Facility Operating Data
- Appendix J: CleanAir Resumes and Certifications

## APPENDIX A: TEST METHOD SPECIFICATIONS



**This Page Intentionally Left Blank**


## Specification Sheet for

## EPA Method 2

Source Location Name(s) Line #1 and Line #2 Stacks  
 Pollutant(s) to be Determined None  
 Other Parameters to be Determined from Train Flow Rate

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Pollutant Sampling Information</b>		
Duration of Run	N/A	Varied
No. of Sample Traverse Points	N/A	12
Sample Time per Point	N/A	Varied
Sampling Rate	N/A	N/A
<b>Sampling Probe</b>		
Nozzle Material	N/A	N/A
Nozzle Design	N/A	N/A
Probe Liner Material	N/A	N/A
Effective Probe Length	Sufficient to Traverse Points	15 feet and 9 feet
Probe Temperature Set-Point	N/A	N/A
<b>Velocity Measuring Equipment</b>		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.84
Pitot Tube Calibration by	Geometric or Wind Tunnel	Geometric
Pitot Tube Attachment	Attached to Probe	Attached to Probe
<b>Metering System Console</b>		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	N/A	N/A
Meter Resolution	N/A	N/A
Meter Size	N/A	N/A
Meter Calibrated Against	N/A	N/A
Pump Type	N/A	N/A
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
<b>Filter Description</b>		
Filter Location	N/A	N/A
Filter Holder Material	N/A	N/A
Filter Support Material	N/A	N/A
Cyclone Material	N/A	N/A
Filter Heater Set-Point	N/A	N/A
Filter Material	N/A	N/A
<b>Other Components</b>		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

## EPA Method 2 Sampling Train Configuration





## Specification Sheet for

## EPA Method 4

Source Location Name(s) Line #1 and Line #2 Stacks  
 Pollutant(s) to be Determined None  
 Other Parameters to be Determined from Train Moisture


	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Pollutant Sampling Information</b>		
Duration of Run	N/A	60 minutes
No. of Sample Traverse Points	N/A	1
Sample Time per Point	N/A	60 minutes
Sampling Rate	Within 10% of Constant Rate	Constant Rate ( $\pm 10\%$ )
<b>Sampling Probe</b>		
Nozzle Material	N/A	None
Nozzle Design	N/A	N/A
Probe Liner Material	Stainless Steel, Glass, Other Metals, Plastic Tubing	Stainless Steel
Effective Probe Length	N/A	10 feet and 8 feet
Probe Temperature Set-Point	Prevent water condensation	None
<b>Velocity Measuring Equipment</b>		
Pitot Tube Design	N/A	None
Pitot Tube Coefficient	N/A	N/A
Pitot Tube Calibration by	N/A	N/A
Pitot Tube Attachment	N/A	N/A
<b>Metering System Console</b>		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	$\pm 2\%$	$\pm 1\%$
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
$\Delta P$ Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
$\Delta H$ Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
<b>Filter Description</b>		
Filter Location	In Stack or Exit of Probe	None
Filter Holder Material	Borosilicate Glass (for probe exit location)	N/A
Filter Support Material	Glass Frit	N/A
Cyclone Material	N/A	None
Filter Heater Set-Point	Prevent condensation	N/A
Filter Material	Glass Wool (in-stack) or Fiberglass Mat (out of stack)	None
<b>Other Components</b>		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

# Specification Sheet for

# EPA Method 4

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Impinger Train Description</b>		
Type of Glassware Connections	Ground Glass or Equivalent	Screw Joint with Silicone Gasket
Connection to Probe or Filter by	Flexible Line	Flexible Teflon Line
Number of Impingers	4	4
Impinger Stem Types		
Impinger 1	Modified-Greenburg Smith	Modified Greenburg-Smith
Impinger 2	Greenburg-Smith	Greenburg-Smith
Impinger 3	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5		
Impinger 6		
Impinger 7		
Impinger 8		
<b>Gas Density Determination</b>		
Sample Collection	N/A	N/A
Sample Collection Medium	N/A	N/A
Sample Analysis	N/A	N/A
<b>Sample Recovery Information</b>		
Probe Brush Material	N/A	N/A
Probe Rinse Reagent	N/A	N/A
Probe Rinse Wash Bottle Material	N/A	N/A
Probe Rinse Storage Container	N/A	N/A
Filter Recovered?	No	No
Filter Storage Container	N/A	N/A
Impinger Contents Recovered?	No	No
Impinger Rinse Reagent	N/A	N/A
Impinger Wash Bottle	N/A	N/A
Impinger Storage Container	N/A	N/A
<b>Analytical Information</b>		
Method 4 H <sub>2</sub> O Determination by	Gravimetric	Gravimetric
Filter Preparation Conditions	N/A	N/A
Front-Half Rinse Preparation	N/A	N/A
Back-Half Analysis	N/A	N/A
Additional Analysis	N/A	None


# EPA Method 4 Sampling Train Configuration



### Impinger Contents


Impinger 1	DI H <sub>2</sub> O
Impinger 2	DI H <sub>2</sub> O
Impinger 3	Empty
Impinger 4	Silica gel

## EPA Method 4 Glassware Preparation Procedures





## EPA Method 4 Analytical Recovery Flowchart



## Specification Sheet for

## EPA Method 5

Source Location Name(s) Line #1 and Line #2 Stacks  
 Pollutant(s) to be Determined Filterable Particulate Matter (FPM)  
 Other Parameters to be Determined from Train Gas Density, Moisture, Flow Rate


	Standard Method Specification	Actual Specification Used
<b>Pollutant Sampling Information</b>		
Duration of Run	N/A	60 minutes
No. of Sample Traverse Points	N/A	12
Sample Time per Point	N/A	5 minutes
Sampling Rate	Isokinetic (90-110%)	Isokinetic (90-110%)
<b>Sampling Probe</b>		
Nozzle Material	Stainless Steel or Glass	Stainless Steel (Line 1); Borosilicate Glass (Line 2)
Nozzle Design	Button-Hook or Elbow	Button-Hook
Probe Liner Material	Borosilicate or Quartz Glass	Stainless Steel (Line 1); Borosilicate Glass (Line 2)
Effective Probe Length	N/A	15 feet and 9 feet
Probe Temperature Set-Point	248°F±25°F	248°F±25°F
<b>Velocity Measuring Equipment</b>		
Pitot Tube Design	Type S	Type S
Pitot Tube Coefficient	N/A	0.84
Pitot Tube Calibration by	Geometric or Wind Tunnel	Geometric
Pitot Tube Attachment	Attached to Probe	Attached to Probe
<b>Metering System Console</b>		
Meter Type	Dry Gas Meter	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	Wet Test Meter or Standard DGM	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	5.4°F	1.0°F
ΔP Differential Pressure Gauge	Inclined Manometer or Equivalent	Digital Manometer
ΔH Differential Pressure Gauge	Inclined Manometer or Equivalent	Inclined Manometer
Barometer	Mercury or Aneroid	Digital Barometer calibrated w/Mercury Aneroid
<b>Filter Description</b>		
Filter Location	After Probe	Exit of Probe
Filter Holder Material	Quartz	Borosilicate Glass
Filter Support Material	Glass Frit	Teflon
Cyclone Material	N/A	None
Filter Heater Set-Point	248°F±25°F	248°F±25°F
Filter Material	Glass Fiber	Quartz Fiber
<b>Other Components</b>		
Description	N/A	N/A
Location	N/A	N/A
Operating Temperature	N/A	N/A

## Specification Sheet for

## EPA Method 5

	Standard Method Specification	Actual Specification Used
<b>Impinger Train Description</b>		
Type of Glassware Connections	Ground Glass or Equivalent	Ground Glass with Silicone O-Ring
Connection to Probe or Filter by	Direct Glass Connection	Direct Glass Connection
Number of Impingers	4	4
Impinger Stem Types		
Impinger 1	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 2	Greenburg-Smith	Greenburg-Smith
Impinger 3	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 4	Modified Greenburg-Smith	Modified Greenburg-Smith
Impinger 5		
Impinger 6		
Impinger 7		
Impinger 8		
<b>Gas Density Determination</b>		
Sample Collection	Multi-point integrated	Multi-Point Integrated
Sample Collection Medium	Flexible Gas Bag	Vinyl Bag
Sample Analysis	Orsat or Fyrite Analyzer	CEM
<b>Sample Recovery Information</b>		
Probe Brush Material	Nylon Bristle	Nylon Bristle
Probe Rinse Reagent	Acetone	Acetone
Probe Rinse Wash Bottle Material	Glass or Polyethylene	Teflon
Probe Rinse Storage Container	Glass or Polyethylene	Glass
Filter Recovered?	Yes	Yes
Filter Storage Container	N/A	Polystyrene
Impinger Contents Recovered?	Provision	Archived
Impinger Rinse Reagent	Deionized Distilled Water	N/A
Impinger Wash Bottle	Glass or Polyethylene	N/A
Impinger Storage Container	Glass or Polyethylene	N/A
<b>Analytical Information</b>		
Method 4 H <sub>2</sub> O Determination by	Gravimetric	Gravimetric
Filter Preparation Conditions	Dessicate 24 hours minimum at ambient temperature	Dessicate 24 hours minimum at ambient temperature
Front-Half Rinse Preparation	Evaporate at ambient temperature and pressure	Evaporate at ambient temperature and pressure
Back-Half Analysis	N/A	N/A
Additional Analysis	N/A	None

## EPA Method 5 Sampling Train Configuration




### Impinger Contents

Impinger 1	DI H <sub>2</sub> O
Impinger 2	DI H <sub>2</sub> O
Impinger 3	Empty
Impinger 4	Silica Gel




## EPA Method 5 Glassware Preparation Procedures




# EPA Method 5 Sample Recovery Flowchart

- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)



# EPA Method 5 Analytical Flowchart



# Specification Sheet for

**CTM-013**

Source Location Name(s) Outlet (EU00079 and EU00080)  
 Pollutant(s) to be Determined Sulfuric Acid (H<sub>2</sub>SO<sub>4</sub>)  
 Other Parameters to be Determined from Train None

	<b>Standard Method Specification</b>	<b>Actual Specification Used</b>
<b>Pollutant Sampling Information</b>		
Duration of Run	60 minutes	60 minutes
No. of Sample Traverse Points	1	1
Sample Time per Point	60 minutes	60 minutes
Sampling Rate	Constant rate of 10.0 Lpm ±10%	Constant rate of 10.0 Lpm ±10%
<b>Sampling Probe</b>		
Nozzle Material	N/A	None
Nozzle Design	N/A	N/A
Probe Liner Material	Borosilicate Glass	Quartz
Effective Probe Length	N/A	10 feet
Probe Temperature Set-Point	>350°F	650°F
<b>Velocity Measuring Equipment</b>		
Pitot Tube Design	N/A	None
Pitot Tube Coefficient	N/A	N/A
Pitot Tube Calibration by	N/A	N/A
Pitot Tube Attachment	N/A	N/A
<b>Metering System Console</b>		
Meter Type	Dry gas meter or controlled orifice	Dry Gas Meter
Meter Accuracy	±2%	±1%
Meter Resolution	N/A	0.01 cubic feet
Meter Size	N/A	0.1 dcf/revolution
Meter Calibrated Against	N/A	Wet Test Meter
Pump Type	N/A	Rotary Vane
Temperature Measurements	N/A	Type K Thermocouple/Pyrometer
Temperature Resolution	±5°F	1.0°F
ΔP Differential Pressure Gauge	N/A	N/A
ΔH Differential Pressure Gauge	N/A	Inclined Manometer
Barometer	Capable of measurement within 0.1 in. Hg	Digital Barometer calibrated w/Mercury Aneroid
<b>Particulate (PM) Filter</b>		
Filter Location	Exit of Probe	Exit of Probe
Connection to probe liner by	Direct glass-to-glass	Direct Quartz-to-Quartz
Filter Holder Material	Quartz	Quartz
Filter Support Material	Glass frit	Quartz
Cyclone Material	N/A	None
Filter Heater Set-Point	>500°F	650°F
Filter Material	Tissuequartz	Quartz Fiber
Filter Conditioning	Pre-rinsed w/ 0.1N H <sub>2</sub> SO <sub>4</sub> ; baked at 600°F	Pre-rinsed w/ 0.1N H <sub>2</sub> SO <sub>4</sub> ; baked at 600°F
<b>SO<sub>3</sub> Coil condenser and Filter</b>		
Description	Condenser Coil (10 coils) with Type C glass frit	Condenser Coil (10 coils) with Type C glass frit
Location	After PM Filter	After PM filter
Connection to PM Filter by	Direct glass-to-glass	Ground Glass with Silicone O-Ring
Water Jacket	Temperature regulated water jacket surrounding coil condenser	Temperature regulated water jacket surrounding coil condenser
Operating Temperature	167 -185°F	167 -185°F




## Specification Sheet for

**CTM-013**

Source Location Name(s) Outlet (EU00079 and EU00080)  
 Pollutant(s) to be Determined Sulfuric Acid (H<sub>2</sub>SO<sub>4</sub>)  
 Other Parameters to be Determined from Train None

	<u>Standard Method Specification</u>	<u>Actual Specification Used</u>
<b>Impinger Train Description</b>		
Type of Glassware Connections	Ground Glass	Flexible Rubber Line
Connection to SAM Filter by	Direct glass-to-glass	Flexible Teflon Line
Number of Impingers	4	4
Impinger Stem Types		
Impinger 1	Midget or Full size impinger	Knock-Out Jar
Impinger 2	Midget or Full size impinger	Knock-Out Jar
Impinger 3	Midget or Full size impinger	Knock-Out Jar
Impinger 4	Midget or Full size impinger	Knock-Out Jar
Impinger 5		
Impinger 6		
Impinger 7		
<b>Gas Density Determination</b>		
Sample Collection	N/A	Single Point Integrated
Sample Collection Medium	N/A	Vinyl Bag
Sample Analysis	N/A	CEM
<b>Sample Recovery Information</b>		
Probe Brush Material	N/A	N/A
Probe Rinse Reagent	N/A	N/A
Probe Rinse Wash Bottle Material	N/A	N/A
Probe Rinse Storage Container	N/A	N/A
PM Filter Recovered?	No	Yes
PM Filter Storage Container	N/A	Polyethylene
SO <sub>3</sub> Condenser Contents Recovered?	Yes	Yes
SO <sub>3</sub> Condenser Rinse Reagent	Sulfate-free water	DI Water
SO <sub>3</sub> Condenser Wash Bottle	Polyethylene	Polyethylene
SO <sub>3</sub> Condenser Storage Container	Polyethylene	Polyethylene
SAM Filter Recovered?	Yes	Yes, placed into SO <sub>3</sub> condenser storage container
SAM Filter Storage Container	Polyethylene	Polyethylene
Impinger Contents Recovered?	Optional	No
Impinger Rinse Reagent	Sulfate-free water	N/A
Impinger Wash Bottle	Polyethylene	N/A
Impinger Storage Container	Polyethylene	N/A
<b>Analytical Information</b>		
Method 4 H <sub>2</sub> O Determination by	Gravimetric	Gravimetric
SO <sub>3</sub> Condenser/SAM Filter Analysis	Ion chromatography for sulfate	Ion chromatography and titration for sulfate
Impinger Analysis (SO <sub>2</sub> )	Ion Chromatography or Titration for sulfate (optional)	N/A
PM Filter Analysis	PM Filter - Not recovered	Not analyzed


# CTM-013 Sampling Train Configuration



### Impinger Contents


Impinger 1	DI Water
Impinger 2	DI Water
Impinger 3	Empty
Impinger 4	Silica Gel

# EPA CTM-013 Glassware Preparation Procedures



# EPA CTM-013 Sample Recovery Flowchart


- Tare all sample containers before sample collection
- Mark all liquid levels and final weights on the outside of each sample container
- Seal all sample containers with Teflon tape
- If recycling, bake silica gel for two hours at 350 degrees F (175 degrees C)





# EPA CTM-013 Analytical Flowchart

- Log each sample in shipment and verify against chain-of-custody sheet
- Note liquid levels in the sample containers and confirm on the chain-of-custody sheet condition



*\*Optional Titration Analysis: Refer to EPA Method 6 Analytical Flowchart*