



RICK SNYDER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF ENVIRONMENTAL QUALITY
DETROIT FIELD OFFICE



DAN WYANT
DIRECTOR

February 28, 2014

Ms. Charlene Hudson
Supervising Engineer
2555 Van Alstyne
Wyandotte, MI 48192

SRN: B2132, Wayne County

Dear Ms. Hudson:

VIOLATION NOTICE

The Department of Environmental Quality (DEQ), Air Quality Division (AQD), reviewed the quarterly excess emission report submitted by Wyandotte Municipal Services located at 2555 Van Alstyne, Wyandotte, Michigan. The Renewable Operating Permit number MI-ROP-B2132-2010 requires the facility to monitor and record carbon monoxide emissions from EUUNIT8BLR on a continuous basis in a manner and with instrumentation acceptable to the AQD.

The fourth quarter 2014 excess emissions report indicated that there was an extended period of monitor downtime. Specifically, the carbon monoxide monitor downtime was reported at 21 % of the operating time for the quarter.

During the report review, staff noted the following:

Process Description	Rule/Permit Condition Violated	Comments
EUUNIT8BLR	EUUNIT8BLR V(2)I	Failure to continuously monitor.


Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by March 21, 2014 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.

If Wyandotte believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Ms. Charlene Hudson
Page 2
February 28, 2014

Thank you for your attention to resolving the violation cited above. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Thomas Maza
Environmental Quality Analyst
Air Quality Division
313.456.4709

cc: Ms. Lynn Fiedler, DEQ
Ms. Teresa Seidel, DEQ
Mr. Thomas Hess, DEQ
Ms. Karen Kajiya-Mills, DEQ
Ms. Wilhemina McLemore, DEQ