

Report of...

# Compliance Emission Sampling

Performed for the...

City of Wyandotte

Municipal Services  
Wyandotte, Michigan

RECEIVED

NOV 10 2021

AIR QUALITY DIVISION

On...

Diesel Engines #1, #2 & #3

September 20-21, 2021

256.19

By...

Network Environmental, Inc.  
Grand Rapids, MI

Performed for:

Wyandotte Municipal Services  
2555 Van Alstyne  
Wyandotte, MI 48192  
Contact: Chris Brohl  
Telephone: (734) 324-7192  
Fax: (734) 324-7178  
E-mail: cbrohl@wyandottemi.gov

Performed by:

Network Environmental, Inc.  
2629 Remico Street, S.W.  
Suite B  
Grand Rapids, MI 49519  
Contact: David D. Engelhardt  
Telephone: (616) 530-6330  
Fax: (616) 530-0001  
E-mail: netenviro@aol.com

## **TABLE OF CONTENTS**

	<b><u>Page</u></b>
I. Introduction	1
II. Presentation of Results	2
II.1 Table 1 – Carbon Monoxide (CO) Destruction Efficiency Results	2
III. Discussion of Results	3
IV. Source Description	3
V. Sampling and Analytical Protocol	3-4
Figure 1 – NO <sub>x</sub> , CO, O <sub>2</sub> & CO <sub>2</sub> Sampling Train Diagram	5

## **Appendices**

Data Acquisition & Calibration Data	A
Analyzer & Calibration Gas Specifications	B
Calculations	C
Raw Data	D
Source Operating Data	E

## **I. INTRODUCTION**

Network Environmental, Inc. was retained by the City of Wyandotte, Department of Municipal Services, to perform an emission study on their Diesel Engines #1, #2 & #3 (permitted as EU-WMSENGINE1, EU-WMSENGINE2 AND EU-WMSENGINE3). The purpose of the study was to document compliance with EGLE Air Quality Division ROP No. MI-ROP-B2132-2017b. MI-ROP-B2132-2017b has established the following emission limits for these engines under flexible group, FGWMSENGINES:

- Carbon Monoxide (CO) reduction (destruction efficiency) of 70% **Or** 23 parts per million (v/v), Dry @ 15% O<sub>2</sub>

The CO reduction was determined by monitoring the CO concentrations at the inlet and outlet of each engine's catalytic oxidation emission control system. The testing was designed to meet the requirements of MI-ROP-B2132-2017b and 40CFR Part 63 Subparts A & ZZZZ. The following reference test methods were employed to conduct the sampling:

- CO – U.S. EPA Method 10
- O<sub>2</sub> – U.S. EPA Method 3A

The sampling was performed over the period of September 20-21, 2021, by Stephan K. Byrd, Richard D. Eerdmans and David D. Engelhardt of Network Environmental, Inc. Assisting with the study were Mr. Nick Hansen and Alex Watzek of Barr Engineering and the operating staff of the facility. Ms. Regina Angellotti and Mr. Stephen Weis of the Michigan Department of the Environment, Great Lakes and Energy (EGLE) - Air Quality Division were present to observe portions of the sampling and source operation.

RECEIVED  
NOV 10 2021  
AIR QUALITY DIVISION

## II. PRESENTATION OF RESULTS

**II.1 TABLE 1  
CO DESTRUCTION EFFICIENCY RESULTS  
DIESEL ENGINES  
CITY OF WYANDOTTE  
WYANDOTTE, MICHIGAN**

Source	Sample	Date	Time	CO Concentration PPM <sup>(1)</sup>		CO % Destruction Efficiency
				Inlet	Outlet	
Diesel Engine #1 (EU-WMSENGINE1)	1	09/20/21	08:57-09:57	109.5	5.6	94.89
	2	09/20/21	10:09-11:09	115.4	6.0	94.80
	3	09/20/21	11:21-12:21	119.0	6.1	94.87
	<b>Average</b>			<b>114.6</b>	<b>6.0</b>	<b>94.85</b>
Diesel Engine #2 (EU-WMSENGINE2)	1	09/20/21	13:40-14:40	103.4	5.2	94.97
	2	09/20/21	14:49-15:49	107.5	5.1	95.26
	3	09/20/21	15:58-16:58	110.4	5.1	95.38
	<b>Average</b>			<b>107.1</b>	<b>5.1</b>	<b>95.20</b>
Diesel Engine #3 (EU-WMSENGINE3)	1	09/21/21	08:49-09:49	148.2	7.0	95.20
	2	09/21/21	09:59-10:59	150.0	7.3	95.13
	3	09/21/21	11:09-12:09	151.8	7.4	95.13
	<b>Average</b>			<b>150.0</b>	<b>7.2</b>	<b>95.15</b>

(1) PPM = Parts Per Million (v/v) On A Dry Basis

(2) The engines were operated at approximately 1800 kW (99% of capacity) during all of the testing.

(3) MI-ROP-B2132-2017b has established an emission limit of 70% CO reduction (destruction efficiency) for these engines.

### **III. DISCUSSION OF RESULTS**

The results of the emission sampling are summarized in Table 1 (Sections II.1). The results are presented as follows:

#### **III.1 Carbon Monoxide (CO) Destruction Efficiency Results (Table 1)**

Table 1 summarizes the CO DE results for the diesel engine catalytic oxidation systems as follows:

- Source
- Sample
- Date
- Time
- Inlet & Outlet CO Concentrations (PPM) – Parts Per Million (v/v) On A Dry Basis
- CO Percent Destruction Efficiency (DE)

### **IV. SOURCE DESCRIPTION**

The engines tested are 1,825 kW standby compression ignition diesel fuel fired engine generators, each equipped with a catalytic oxidation emission control system. Testing was performed at approximately 1800 kW (99% of load capacity) for all the engines. Process operating data collected during the sampling can be found in Appendix F.

### **V. SAMPLING AND ANALYTICAL PROTOCOL**

The sampling methods used for the reference method determinations were as follows:

**V.1 Carbon Monoxide** – The CO sampling was conducted in accordance with U.S. EPA Reference Method 10. A Thermo Environmental Model 48C gas analyzer was used to monitor the catalyst inlets. A Thermo Environmental Model 48 gas analyzer was used to monitor the catalyst outlets. Heated Teflon sample lines were used to transport the inlet and outlet gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzers. The analyzers produce instantaneous readouts of the CO concentrations (PPM).

The analyzers were calibrated by direct injection prior to the testing. Span gases of 168.0 PPM (inlets) and 15.0 PPM (outlets) were used to establish the initial instrument calibrations. Calibration gases of 50.91 PPM & 96.0 PPM for the inlets and 7.1 PPM for the outlets were used to determine the calibration error of the analyzers. The sampling systems (from the back of the stack probes to the analyzers) were injected using the 7.1 PPM, the 50.91 PPM or the 96.0 PPM gases to determine the system bias. After each sample, a system zero and system injection of 7.1 PPM, 50.91 or 96.0 PPM were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.


The analyzers were calibrated to the output of the data acquisition system (DAS) used to collect the data from the engines. A diagram of the CO sampling train is shown in Figure 1.

**V.3 Oxygen (Outlets only)** – The O<sub>2</sub> sampling was conducted in accordance with U.S. EPA Reference Method 3A. A Servomex Model 1400M portable stack gas analyzer was used to monitor the outlets. A heated Teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the O<sub>2</sub> concentrations (%).


The analyzer was calibrated by direct injection prior to the testing. A span gas of 21.0% was used to establish the initial instrument calibration. Calibration gases of 12.06% and 5.97% were used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 12.06% gas to determine the system bias. After each sample, a system zero and system injection of 12.06% were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the outlets. A diagram of the O<sub>2</sub> sampling train is shown in Figure 1.

This report was prepared by:

  
Stephan A. Byrd  
Project Manager

This report was reviewed by:

  
David D. Engelhardt  
Vice President




Figure 1

CO & O<sub>2</sub> Sampling Train