

DTE Energy - St. Clair Power Plant
2021 Compliance Source Test Report

1.0 INTRODUCTION

1.1 SUMMARY OF TEST PROGRAM

DTE Energy-St. Clair Power Plant (SCPP) (State Registration No.: B2796) contracted Montrose Air Quality Services, LLC (Montrose) to perform a compliance test program on Coal-Fired Boiler No. 6 (EU-BOILER6-SC) at the DTE Energy-SCPP facility located in East China Township, Michigan. Testing was performed on August 10, 2021, for the purpose of satisfying the emission testing requirements pursuant to Michigan Department of Environment, Great Lakes, and Energy (EGLE) Renewable Operation Permit No. MI-ROP-B2796-2015c.

The specific objectives were to:

- Verify the emissions of non-sulfuric filterable particulate matter (FPM) at the electrostatic precipitator (ESP) exhaust stack associated with EU-BOILER6-SC
- Conduct the test program with a focus on safety

Montrose performed the tests to measure the emission parameters listed in Table 1-1.

TABLE 1-1
SUMMARY OF TEST PROGRAM

Test Date(s)	Unit ID/ Source Name	Activity/ Parameters	Test Methods	No. of Runs	Duration (Minutes)
8/10/2021	EU-BOILER6-SC	Velocity/Volumetric Flow Rate	EPA 1, 2	3	60
8/10/2021	EU-BOILER6-SC	O ₂ , CO ₂	EPA 3A	3	60
8/10/2021	EU-BOILER6-SC	Moisture	EPA 4	3	60
8/10/2021	EU-BOILER6-SC	Non-sulfuric FPM	EPA 5B	3	60

To simplify this report, a list of Units and Abbreviations is included in Appendix D.1. Throughout this report, chemical nomenclature, acronyms, and reporting units are not defined. Please refer to the list for specific details.

This report presents the test results and supporting data, descriptions of the testing procedures, descriptions of the facility and sampling locations, and a summary of the quality assurance procedures used by Montrose. The average emission test results are summarized and compared to their respective permit limits in Table 1-2. Detailed results for individual test runs can be found in Section 4.0. All supporting data can be found in the appendices.

The testing was conducted by the Montrose personnel listed in Table 1-3. The tests were conducted according to the Test Plan dated March 4, 2021 that was submitted to the EGLE.

DTE Energy - St. Clair Power Plant
2021 Compliance Source Test Report

TABLE 1-2
SUMMARY OF AVERAGE COMPLIANCE RESULTS -
EU-BOILER6-SC
AUGUST 10, 2021

Parameter/Units	Average Results	Emission Limits
Non-Sulfuric Filterable Particulate Matter (FPM) lb/10 ³ lb-wet exhaust gas @ 50% EA	0.0084	0.15

1.2 KEY PERSONNEL

A list of project participants is included below:

Facility Information

Source Location: DTE Energy - St. Clair Power Plant
4901 Pointe Drive
East China Township, MI 48054

Project Contact: Jason Logan
Role: Environmental Specialist
Company: DTE Energy
Telephone: 734-548-2128
Email: jason.logan@dteenergy.com

Dominic Vendittelli
Environmental Engineer
DTE Energy
810-326-6355
Dominic.Vendittelli@dteenergy.com

Agency Information

Regulatory Agency: EGLE
Agency Contact: Karen Kajiya-Mills
Telephone: 517-335-3122
Email: kajiyamillk@michigan.gov

Mark Dziadosz
586-854-1611
dziadoszm@michigan.gov

Testing Company Information

Testing Firm: Montrose Air Quality Services, LLC
Contact: Matthew Young
Title: District Manager
Telephone: 248-548-8070
Email: myoung@montrose-env.com

David Trahan
Field Project Manager
248-548-8070
dtrahan@montrose-env.com

Laboratory Information

Laboratory: Montrose Royal Oak
City, State: Royal Oak, MI 48073
Method: EPA Method 5B

DTE Energy - St. Clair Power Plant
2021 Compliance Source Test Report

Test personnel and observers are summarized in Table 1-3.

TABLE 1-3
TEST PERSONNEL AND OBSERVERS

Name	Affiliation	Role/Responsibility
Matthew Young	Montrose	District Manager, QI
Michael Nummer	Montrose	Field Technician
Shane Rabideau	Montrose	Field Technician
Jason Logan	DTE Energy - St. Clair Power Plant	Observer/Client Liaison/Test Coordinator
Dominic Vendittelli	DTE Energy - St. Clair Power Plant	Observer/Client Liaison/Test Coordinator

DTE Energy - St. Clair Power Plant
2021 Compliance Source Test Report

2.0 PLANT AND SAMPLING LOCATION DESCRIPTIONS

2.1 PROCESS DESCRIPTION, OPERATION, AND CONTROL EQUIPMENT

The DTE Energy-SCPP employs the use of four coal-fired boilers (EU-BOILER2-SC, EU-BOILER4-SC, EU-BOILER6-SC, and EU-BOILER7-SC) to produce power throughout SE Michigan. Boiler No. 6 (EU-BOILER6-SC) is a combustion engineering boiler which operates as a base loaded unit capable of producing 2,100,000 pounds of steam per hour. The boiler's turbine generator was manufactured by Westinghouse and has a nominally rated capability of 350 MW.

EU-BOILER6-SC emissions are controlled by a Research Corporation ESP which has a collection efficiency of 99.6%. EU-BOILER6-SC was in operation for this test event.

2.2 FLUE GAS SAMPLING LOCATIONS

Information regarding the sampling locations is presented in Table 2-1.

TABLE 2-1
SAMPLING LOCATIONS

Sampling Location	Stack Inside Diameter (in.)	Distance from Nearest Disturbance		Number of Traverse Points
		Downstream EPA "B" (in./dia.)	Upstream EPA "A" (in./dia.)	
EU-BOILER6-SC ESP Exhaust Stack	228.0	1,332.0 / 5.8	3,180.0 / 14.0	Isokinetic: 24 (6/port); Gaseous: 1

The sampling locations were verified in the field to conform to EPA Method 1. Acceptable cyclonic flow conditions were confirmed prior to testing using EPA Method 1, Section 11.4. See Appendix A.1 for more information.

2.3 OPERATING CONDITIONS AND PROCESS DATA

Emission tests were performed while EU-BOILER6-SC was operating at maximum routine operating conditions (> 80% of maximum power output), and the ESP was operating at the conditions required by the permit.

Plant personnel were responsible for establishing the test conditions and collecting all applicable unit-operating data. The process data that was provided is presented in Appendix B.

DTE Energy - St. Clair Power Plant
2021 Compliance Source Test Report

3.0 SAMPLING AND ANALYTICAL PROCEDURES

3.1 TEST METHODS

The test methods for this test program were presented previously in Table 1-1. Additional information regarding specific applications or modifications to standard procedures is presented below.

3.1.1 EPA Method 1, Sample and Velocity Traverses for Stationary Sources

EPA Method 1 is used to assure that representative measurements of volumetric flow rate are obtained by dividing the cross-section of the stack or duct into equal areas, and then locating a traverse point within each of the equal areas. Acceptable sample locations must be located at least two stack or duct equivalent diameters downstream from a flow disturbance and one-half equivalent diameter upstream from a flow disturbance.

The sample port and traverse point locations are detailed in Appendix A.

3.1.2 EPA Method 2, Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)

EPA Method 2 is used to measure the gas velocity using an S-type pitot tube connected to a pressure measurement device, and to measure the gas temperature using a calibrated thermocouple connected to a thermocouple indicator. Typically, Type S (Stausscheibe) pitot tubes conforming to the geometric specifications in the test method are used, along with an inclined manometer. The measurements are made at traverse points specified by EPA Method 1.


The typical sampling system is detailed in Figure 3-2.

3.1.3 EPA Method 3A, Determination of Oxygen and Carbon Dioxide Concentrations in Emissions from Stationary Sources (Instrumental Analyzer Procedure)

EPA Method 3A is an instrumental test method used to measure the concentration of O₂ and CO₂ in stack gas. The effluent gas is continuously or intermittently sampled and conveyed to analyzers that measure the concentration of O₂ and CO₂. The performance requirements of the method must be met to validate data.

For the purpose of this test event, Tedlar bags were utilized to collect exhaust gas from each ESP exhaust stack. Then, the Tedlar bags were analyzed using EPA Method 3A. The typical sampling system is detailed in Figure 3-1.

FIGURE 3-1
EPA METHOD 3A (O₂/CO₂) TEDLAR BAG SAMPLING TRAIN



3.1.4 EPA Method 4, Determination of Moisture Content in Stack Gas

EPA Method 4 is a manual, non-isokinetic method used to measure the moisture content of gas streams. Gas is sampled at a constant sampling rate through a probe and impinger train. Moisture is removed using a series of pre-weighed impingers containing methodology-specific liquids and silica gel immersed in an ice water bath. The impingers are weighed after each run to determine the percent moisture.


The typical sampling system is detailed in Figure 3-2.

3.1.5 EPA Method 5B, Determination of Nonsulfuric Acid Particulate Matter Emissions from Stationary Sources

EPA Method 5B is a manual, isokinetic method used to measure nonsulfuric acid FPM emissions. Particulate matter is withdrawn isokinetically from the source and collected on a glass fiber filter maintained at a temperature of $160 \pm 14^\circ\text{C}$ ($320 \pm 25^\circ\text{F}$). The collected sample is then heated in an oven at 160°C (320°F) for 6 hours to volatilize any condensed sulfuric acid that may have been collected, and the nonsulfuric acid particulate mass is determined gravimetrically.

The typical sampling system is detailed in Figure 3-2.

FIGURE 3-2
EPA METHOD 5B SAMPLING TRAIN



3.2 PROCESS TEST METHODS

The test plan did not require that process samples be collected during this test program; therefore, no process sample data are presented in this test report.

DTE Energy - St. Clair Power Plant
2021 Compliance Source Test Report

4.0 TEST DISCUSSION AND RESULTS

4.1 FIELD TEST DEVIATIONS AND EXCEPTIONS

No field deviations or exceptions from the test plan or test methods occurred during this test program.

4.2 PRESENTATION OF RESULTS

The average results are compared to the permit limits in Table 1-2. The results of individual compliance test runs performed are presented in Table 4-1. Emissions are reported in units consistent with those in the applicable regulations or requirements. Additional information is included in the appendices as presented in the Table of Contents.

**TABLE 4-1
NON-SULFURIC FPM EMISSIONS RESULTS -
EU-BOILER6-SC**

Run Number	1	2	3	Average
Date	8/10/2021	8/10/2021	8/10/2021	--
Time	8:04-9:16	9:51-11:01	11:24-12:33	--
Flue Gas Parameters				
O ₂ , % volume dry	8.03	8.23	8.18	8.15
CO ₂ , % volume dry	11.31	11.09	11.31	11.24
flue gas temperature, °F	307.8	308.6	310.9	309.1
moisture content, % volume	10.07	9.91	10.56	10.18
volumetric flow rate, scfm	780,623	759,323	776,798	772,248
volumetric flow rate, dscfm	702,023	684,074	694,798	693,632
excess air, %	60.50	62.99	62.55	62.01
Non-Sulfuric Filterable Particulate Matter (FPM)				
grains/dscf	0.0043	0.0041	0.0051	0.0045
lb/hr	26.0	23.8	30.6	26.8
lb/10 ³ lb-wet exhaust gas @ 50% EA	0.0080	0.0076	0.0095	0.0084

5.0 INTERNAL QA/QC ACTIVITIES

5.1 QA/QC AUDITS

The meter box and sampling train used during sampling performed within the requirements of their respective methods. All post-test leak checks, minimum metered volumes, minimum sample durations, and percent isokinetics met the applicable QA/QC criteria.

EPA Method 3A calibration audits were all within the measurement system performance specifications for the calibration drift checks, system calibration bias checks, and calibration error checks.

EPA Method 5B analytical QA/QC results are included in the laboratory report. The method QA/QC criteria were met, except if noted in Section 5.2. An EPA Method 5 reagent blank was analyzed. The maximum allowable amount that can be subtracted is 0.001% of the weight of the acetone blank. The blank did not exceed the maximum residue allowed.

5.2 QA/QC DISCUSSION

All QA/QC criteria were met during this test program.

5.3 QUALITY STATEMENT

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D 7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is included in the report appendices. The content of this report is modeled after the EPA Emission Measurement Center Guideline Document (GD-043).


DTE Energy - St. Clair Power Plant
2021 Compliance Source Test Report

APPENDIX A FIELD DATA AND CALCULATIONS


DTE Energy - St. Clair Power Plant
2021 Compliance Source Test Report

Appendix A.1 Sampling Locations

EU-BOILER6-SC SAMPLING LOCATION SCHEMATIC



EU-BOILER6-SC ESP EXHAUST STACK TRAVERSE POINT LOCATION DRAWING



DTE Energy - St. Clair Power Plant
2021 Compliance Source Test Report

Appendix A.2

EU-BOILER6-SC ESP Exhaust Stack Data Sheets

TEST DATA

	Number of Test Runs Traverse Points	3 24		
	Run 1	Run 2	Run 3	Average
Stack Cross-Sectional Diameter 1 (circular) (in)	228.0	228.0	228.0	228.0
Stack Cross-Sectional Diameter 2 (circular) (in)	228.0	228.0	228.0	228.0
Pilot Tube Coefficient (Cp)	0.84	0.84	0.84	0.84
Barometric Pressure at Ground Level (Pbar) (in Hg)	29.89	29.91	29.91	29.90
Elevation Difference Between Ground Level and Meter Box Locations (ft)	580	580	580	580
Elevation Difference Between Ground Level and Sampling Locations (ft)	700	700	700	700
Initial Dry Gas Meter Reading (ft3)	922,750	974,510	22,290	
Final Dry Gas Meter Reading (ft3)	974,220	1022,110	70,440	
Dry Gas Meter Calibration Factor (Gamma)	1.020	1.020	1.020	1.020
Dry Gas Meter Calibration Coefficient (Delta H@)	1.83	1.83	1.83	1.83
Total Sampling Run Time (Theta) (min)	60	60	60	60
Volume of Water Vapor Condensed in the Impingers (g)	104.6	100.6	98.7	101.3
Weight of Water Vapor Collected in Silica Gel (g)	15.7	9.2	14.9	13.3
Air Percent by Volume Oxygen in Stack Gas (%-dry)	8.03	8.23	8.18	8.15
Air Percent by Volume Carbon Dioxide in Stack Gas (%-dry)	11.31	11.09	11.31	11.24
Air Percent by Volume Nitrogen in Stack Gas (%-dry)	80.66	80.68	80.51	80.62
Average Pitot Rotation Angle	3.3			
Test Run Start Time (hr:min)	8/10/2021 8:04	8/10/2021 9:51	8/10/2021 11:24	
Test Run Stop Time (hr:min)	8/10/2021 9:16	8/10/2021 11:01	8/10/2021 12:33	

DETAILED RESULTS

Stack Gas Conditions

	Run 1	Run 2	Run 3	Average
Stack Cross-Sectional Area (A) (ft ²)	283.53	283.53	283.53	283.53
Barometric Pressure at Sampling Location (in Hg)	29.19	29.21	29.21	29.20
Dry Molecular Weight of Stack Gas (Md) (lb/lb-mole)	30.13	30.10	30.14	30.12
Wet Molecular Weight of Stack Gas (Ms) (lb/lb-mole)	28.91	28.91	28.86	28.89
Average Absolute Stack Gas Pressure (Ps) (in Hg)	29.20	29.22	29.22	29.22
Average Stack Gas Static Pressure (ps) (in H ₂ O)	0.20	0.20	0.20	0.20
Average Stack Gas Temperature (Ts) (°F)	307.8	308.6	310.9	309.1
Average Stack Gas Temperature (Ts) (°R)	767.8	768.6	770.9	769.1
Average Stack Gas Velocity (Vs) (ft/sec)	68.11	66.27	68.00	67.46
Average Stack Gas Velocity (Vs) (ft/min)	4,086	3,976	4,080	4,047
Wet Volumetric Stack Gas Flow at Actual Conditions (Qaw) (acfmin)	1,158,621	1,127,396	1,156,718	1,147,578
Wet Volumetric Stack Gas Flow at Standard Conditions* (scfm)	780,623	759,323	776,798	772,248
Dry Volumetric Stack Gas Flow at Standard Conditions* (Qstd) (dscfm)	702,023	684,074	694,798	693,632
Percent by Volume Moisture as measured in Stack Gas (%H ₂ O)	10.07	9.91	10.56	10.18
Percent Excess Air (%)	60.50	62.99	62.55	62.01

Test Results

	Run 1	Run 2	Run 3	Average
Volume of Dry Gas Sampled at Standard Conditions* (Vmstd) (dscf)	50,672	47,074	45,394	47,713
Rate of Dry Gas Sampled at Standard Conditions* (dscfm)	0.845	0.785	0.757	0.795
Dry Mole Fraction of Flue Gas (Mfd)	0.899	0.901	0.894	0.898
Average Velocity Pressure (Delta P) (in H ₂ O)	0.99	0.95	0.99	0.97
Average Square Root of Delta P	0.99	0.97	0.99	0.98
Average Pressure Differential of Orifice Meter (Delta H) (in H ₂ O)	2.48	2.15	2.14	2.26
Average DGM Temperature (Tm) (°F)	81.3	78.8	86.8	82.3
Average Dry Gas Meter Temperature (Tm) (°R)	541.3	538.8	546.8	542.3
Volume of Metered Gas Sample (Vm) (dry) (acf)	51,470	47,600	48,150	49,073

SAMPLING QA

	Run 1	Run 2	Run 3	Average
Post-Test Meter Calibration Check Value (Yqa)	1.009	1.013	1.007	1.010
Post-Test/Pre-Test Calibration Factor Difference (%)	1.03	0.64	1.26	0.98
Allowable Post-Test Leak Rate (dscfm)	0.020	0.020	0.020	0.020
Current Sampling Rate Status	Too High	Too High	Too High	
1-Hour Sample Volume Based on Current Sampling Rate (dscf)	50,672	47,074	45,394	47,713
Probe Nozzle Diameter (in)	0.241	0.241	0.241	0.241
Percent Isokinetic of Sampling Rate (% I)	108.1	103.1	97.9	103.0
In Field Isokinetic QA	GOOD	GOOD	GOOD	
Count of Velocity Pressure Readings Below 0.05 in H ₂ O	0	0	0	0
Sensitivity Factor for Differential Pressure Gauge (T)	1.003	1.003	1.003	1.003
Is Meter Box Manometer Adequate (Yes / No) ?	YES	YES	YES	

* Standard Conditions defined as 70°F and 29.92 in-Hg.

MEASURED DATA FROM TEST RUNS

Point Count	Run #	Run Time (min)	Pitot Delta P (in H2O)	Square Root of Delta P (in H2O)	Orifice Delta H (in H2O)	DGM Temp IN (°F)	DGM Temp OUT (°F)	Average DGM Temp (°F)	Stack Pressure (in H2O)	Stack Temp (°F)
1	1	0	0.88	0.938	2.25	86	86	86.00	0.2	306
2	1	2.5	0.86	0.927	2.20	82	84	83.00		308
3	1	5	0.87	0.933	2.20	81	84	82.50		308
4	1	7.5	0.93	0.964	2.35	81	83	82.00		309
5	1	10	0.91	0.954	2.30	81	82	81.50		309
6	1	12.5	0.89	0.943	2.25	81	82	81.50		309
7	1	15	0.92	0.959	2.30	80	80	80.00		308
8	1	17.5	0.95	0.975	2.40	81	80	80.50		308
9	1	20	1.00	1.000	2.50	82	80	81.00		309
10	1	22.5	1.10	1.049	2.75	82	80	81.00		309
11	1	25	1.20	1.095	3.00	82	80	81.00		310
12	1	27.5	1.20	1.095	3.00	83	80	81.50		310
13	1	30	1.00	1.000	2.50	81	79	80.00		309
14	1	32.5	1.00	1.000	2.50	82	79	80.50		308
15	1	35	1.10	1.049	2.75	82	79	80.50		306
16	1	37.5	1.10	1.049	2.75	82	79	80.50		306
17	1	40	1.10	1.049	2.75	83	79	81.00		306
18	1	42.5	1.05	1.025	2.65	83	79	81.00		307
19	1	45	0.77	0.877	1.95	81	79	80.00		308
20	1	47.5	0.98	0.990	2.45	82	79	80.50		307
21	1	50	1.05	1.025	2.65	83	79	81.00		307
22	1	52.5	1.10	1.049	2.75	83	79	81.00		307
23	1	55	0.95	0.975	2.40	84	79	81.50		307
24	1	57.5	0.90	0.949	2.00	84	79	81.50		307
25	2	0	0.63	0.794	1.50	76	76	76.00	0.2	306
26	2	2.5	0.68	0.825	1.60	76	75	75.50		306
27	2	5	0.48	0.693	1.10	76	75	75.50		306
28	2	7.5	0.84	0.917	2.00	76	75	75.50		306
29	2	10	1.30	1.140	2.95	77	75	76.00		306
30	2	12.5	0.95	0.975	2.15	78	75	76.50		307
31	2	15	1.00	1.000	2.25	77	78	77.50		307
32	2	17.5	1.10	1.049	2.50	80	77	78.50		307
33	2	20	1.20	1.095	2.70	80	76	78.00		306
34	2	22.5	1.05	1.025	2.35	80	76	78.00		306
35	2	25	1.05	1.025	2.35	81	77	79.00		308
36	2	27.5	0.90	0.949	2.00	81	77	79.00		308
37	2	30	0.95	0.975	2.15	80	78	79.00		308
38	2	32.5	0.90	0.949	2.05	81	77	79.00		310
39	2	35	1.10	1.049	2.56	81	78	79.50		310
40	2	37.5	1.00	1.000	2.25	82	78	80.00		310
41	2	40	1.10	1.049	2.50	82	78	80.00		311
42	2	42.5	1.05	1.025	2.35	83	78	80.50		311
43	2	45	0.81	0.900	1.85	80	78	79.00		310
44	2	47.5	0.86	0.927	1.95	83	79	81.00		311
45	2	50	0.95	0.975	2.15	83	79	81.00		311
46	2	52.5	0.98	0.990	2.20	84	80	82.00		312
47	2	55	0.92	0.959	2.10	84	80	82.00		312
48	2	57.5	0.88	0.938	2.00	84	80	82.00		312

MEASURED DATA FROM TEST RUNS

Point Count	Run #	Run Time (min)	Pitot Delta P (in H2O)	Square Root of Delta P (in H2O)	Orifice Delta H	DGM Temp IN (°F)	DGM Temp OUT (°F)	Average DGM Temp (°F)	Stack Pressure (in H2O)	Stack Temp (°F)
49	3	0	0.85	0.922	1.85	82	79	80.50	0.2	311
50	3	2.5	0.87	0.933	1.90	81	80	80.50		311
51	3	5	0.87	0.933	1.90	83	80	81.50		311
52	3	7.5	0.92	0.959	2.00	84	81	82.50		312
53	3	10	0.85	0.922	1.85	85	81	83.00		313
54	3	12.5	0.75	0.866	1.65	86	82	84.00		313
55	3	15	0.90	0.949	1.95	86	82	84.00		312
56	3	17.5	0.93	0.964	2.00	87	83	85.00		311
57	3	20	0.96	0.980	2.10	87	83	85.00		312
58	3	22.5	0.96	0.980	2.10	88	83	85.50		311
59	3	25	1.10	1.049	2.40	89	84	86.50		312
60	3	27.5	0.90	0.949	1.95	90	84	87.00		312
61	3	30	1.00	1.000	2.00	89	85	87.00		311
62	3	32.5	0.98	0.990	2.15	90	85	87.50		310
63	3	35	1.10	1.049	2.40	91	85	88.00		309
64	3	37.5	1.05	1.025	2.30	92	86	89.00		309
65	3	40	1.00	1.000	2.20	93	86	89.50		309
66	3	42.5	0.82	0.906	1.80	93	87	90.00		310
67	3	45	1.15	1.072	2.50	92	87	89.50		310
68	3	47.5	1.10	1.049	2.40	93	88	90.50		310
69	3	50	1.20	1.095	2.65	93	88	90.50		310
70	3	52.5	1.26	1.122	2.65	95	89	92.00		311
71	3	55	1.25	1.118	2.75	95	89	92.00		311
72	3	57.5	0.88	0.938	1.95	96	89	92.50		310

TEST DATA - EPA Method 3A (O₂)

Number of Concentration Runs 3

Analyzer Calibration

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Actual Concentration of the Mid-Level Calibration Gas (%)	9.73	9.73	9.73	9.73
Actual Concentration of the High-Level Calibration Gas (%)	20.48	20.48	20.48	20.48
Analyzer Span During Test Run (%)	20.48	20.48	20.48	20.48
Calibration Gas QA	GOOD	GOOD	GOOD	
Analyzer Calibration Response for Zero Gas (%)	0.00	0.00	0.00	0.00
Analyzer Calibration Response for Mid-Level Gas (%)	9.78	9.78	9.78	9.78
Analyzer Calibration Response for High Level Gas (%)	20.49	20.49	20.49	20.49
Initial System Calibration Response for Zero Gas (%)	0.00	0.00	0.00	0.00
Initial System Calibration Response for Upscale Gas (%)	9.78	9.78	9.78	9.78
Final System Calibration Response for Zero Gas (%)	0.04	0.04	0.04	0.04
Final System Calibration Response for Upscale Gas (%)	9.73	9.73	9.73	9.73

Analyzer Calibration QA

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Initial System Calibration Bias for Zero Gas (% of Span)	0.00	0.00	0.00	0.00
Initial System Calibration Bias for Upscale Gas (% of Span)	0.00	0.00	0.00	0.00
Final System Calibration Bias for Zero Gas (% of Span)	0.20	0.20	0.20	0.20
Final System Calibration Bias for Upscale Gas (% of Span)	-0.24	-0.24	-0.24	-0.24
System Drift for Zero Gas (% of Span)	0.20	0.20	0.20	0.20
System Drift for Upscale Gas (% of Span)	-0.24	-0.24	-0.24	-0.24
Analyzer Calibration Error for Zero Gas (% of Span)	0.00	0.00	0.00	0.00
Analyzer Calibration Error for Mid-Level Gas (% of Span)	0.23	0.23	0.23	0.23
Analyzer Calibration Error for High-Level Gas (% of Span)	0.05	0.05	0.05	0.05

CONCENTRATION CALCULATIONS - DRY SYSTEM**Calculate the Average Effluent Oxygen O₂ Concentration**

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Average O ₂ Concentration Indicated by Gas Analyzer, dry basis (%-dry)	8.05	8.25	8.20	8.17
Average of Initial and Final System Calibration Bias Check Responses for the Zero Gas (%)	0.02	0.02	0.02	0.02
Average of Initial and Final System Calibration Bias Check Responses for the Upscale Calibration Gas (%)	9.76	9.76	9.76	9.76
Average Effluent O ₂ Concentration, dry basis (%-dry)	8.03	8.23	8.18	8.15

TEST DATA - EPA Method 3A (CO₂)Number of Concentration Runs 3**Analyzer Calibration**

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Actual Concentration of the Mid-Level Calibration Gas (%)	10.10	10.10	10.10	10.10
Actual Concentration of the High-Level Calibration Gas (%)	20.65	20.65	20.65	20.65
Analyzer Span During Test Run (%)	20.65	20.65	20.65	20.65
Calibration Gas QA	GOOD	GOOD	GOOD	
Analyzer Calibration Response for Zero Gas (%)	0.01	0.01	0.01	0.01
Analyzer Calibration Response for Mid-Level Gas (%)	10.45	10.45	10.45	10.45
Analyzer Calibration Response for High Level Gas (%)	20.66	20.66	20.66	20.66
Initial System Calibration Response for Zero Gas (%)	0.01	0.01	0.01	0.01
Initial System Calibration Response for Upscale Gas (%)	10.45	10.45	10.45	10.45
Final System Calibration Response for Zero Gas (%)	0.00	0.00	0.00	0.00
Final System Calibration Response for Upscale Gas (%)	10.47	10.47	10.47	10.47

Analyzer Calibration QA

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Initial System Calibration Bias for Zero Gas (% of Span)	0.00	0.00	0.00	0.00
Initial System Calibration Bias for Upscale Gas (% of Span)	0.00	0.00	0.00	0.00
Final System Calibration Bias for Zero Gas (% of Span)	-0.05	-0.05	-0.05	-0.05
Final System Calibration Bias for Upscale Gas (% of Span)	0.10	0.10	0.10	0.10
System Drift for Zero Gas (% of Span)	-0.05	-0.05	-0.05	-0.05
System Drift for Upscale Gas (% of Span)	0.10	0.10	0.10	0.10
Analyzer Calibration Error for Zero Gas (% of Span)	0.05	0.05	0.05	0.05
Analyzer Calibration Error for Mid-Level Gas (% of Span)	1.69	1.69	1.69	1.69
Analyzer Calibration Error for High-Level Gas (% of Span)	0.05	0.05	0.05	0.05

CONCENTRATION CALCULATIONS - DRY SYSTEM**Calculate the Average Effluent Carbon Dioxide CO₂ Concentration**

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Average CO ₂ Concentration Indicated by Gas Analyzer, dry basis (%)	11.71	11.49	11.72	11.64
Average of Initial and Final System Calibration Bias Check Responses for the Zero Gas (%)	0.01	0.01	0.01	0.01
Average of Initial and Final System Calibration Bias Check Responses for the Upscale Calibration Gas (%)	10.46	10.46	10.46	10.46
Average Effluent CO ₂ Concentration, dry basis (%)	11.31	11.09	11.31	11.24

TEST DATA - EPA Method 5B

<u>Gravimetric Weights</u>		<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
	Nonsulfuric Acid Particulate Weight in Probe Rinse (mg)	1.4	2.3	2.5	2.1
	Nonsulfuric Acid Particulate Weight in Filter Catch (mg)	12.8	10.1	12.6	11.8

DETAILED RESULTS

<u>Stack Conditions</u>		<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
	Wet Air Flow Rate at Standard Conditions*, 1000 lb-wet exhaust gas/hr	3500.8	3404.7	3477.2	3460.9
<u>Emission Results</u>		<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
	Nonsulfuric Acid Particulate Matter Emission Rate (lbs/hr)	26.0	23.8	30.6	26.8
	Nonsulfuric Acid Particulate Matter Emission Rate, (lb/1,000 lb-wet exhaust gas @50% excess air)	0.0080	0.0076	0.0095	0.0084
<u>Concentration Results</u>		<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
	Nonsulfuric Acid Particulate Matter Concentration (grains/dscf)	0.0043	0.0041	0.0051	0.0045

* Standard Conditions defined as 70°F and 29.92 in-Hg.


MAQS

USEPA METHOD 2 GAS VELOCITY TRAVERSE
AND VOLUMETRIC FLOWRATE DATA SHEET

Client DTE SCPP
 Sampling Location Unit G
 Run Number: pre flow
 Date 8-9-21 Time 11:41 = 12:09
 Port and Stack 236 in.
 Port 8 in.
 Nipple Protrusion - in.
 Stack Diameter 228 in.
 Bar. Pressure 24.97 in Hg
 Static Pressure 0.7 in H₂O
 Moisture % ~10
 % CO₂ ~16 % CO
 % O₂ ~9 % N₂

Operators MN/M4 Manometer ID: MB 3
 Pitot Tube number 8 C Umbilical ID: JMB 12
 Pitot Tube factor, Cp .84 Pitot Line ID: -
 Leak Check- Positive: Pre: @ 3.2 Post: @ 3.1 Negative: Pre: @ 3.4 Post: @ 3.3

Stack Diagram



Weather conditions:

SUNNY, WARM

Site Elevation 582 ft. Upstream ~265 ft.
 Port Height ~126 ft. Downstream ~111 ft.

% of Stack Diameter	Point Distance (in.)	Traverse Point Number	Velocity Head (ΔP) in H ₂ O	Stack Temp °F	Null Angle (zero ΔP angle)	Flow Angle θ (90° from null angle)
		1	.84	310	0	
		2	.88	310	0	
		3	.90	310	0	
		4	.93	310	0	
		5	.91	310	-10	
		6	.88	310	-10	
		1	.88	311	0	
		2	.89	311	0	
		3	1.06	311	0	
		4	1.20	311	5	
		5	1.15	311	-5	
		6	1.05	311	-5	
		1	.90	307	5	
		2	.92	307	5	
		3	1.05	307	0	
		4	1.10	307	0	
		5	1.100	307	-5	
		6	.93	307	-5	
		1	1.05	308	5	
		2	1.10	308	5	
		3	1.20	308	-5	
		4	1.30	308	-5	
		5	1.20	308	-5	
		6	1.16	308	-5	

US EPA Method 1 Traverse Point Determination

Relative Port Location
 From Far Wall to Outside of Port (in.)

N	E	S	W
236.0	236.0	236.0	236.0
8.0	8.0	8.0	8.0
0.0	0.0	0.0	0.0

Port Protrusion Length (opt) (in.)
 Depth of Stack or Duct (in.)

228.0 228.0 228.0 228.0

Stack or Duct Type

Circular

Port Hole Inner Diameter (in.)

-

Stack or Duct Width (if Rectangular) (in.)

Stack Outer Circumference (in.)

Number of Ports Traversed

4

Elevation of Meter Box from Ground Level (ft)

580

Elevation of Ports from Ground Level (ft)

700

Stack Build-up (in.)

0.0

Stack Cross-Sectional Diameter 1 (in.)

228.0

Stack Cross-Sectional Diameter 2 (in.)

228.0

"Vertical" or "Horizontal" Flow	Vertical
Direction of Flow	Up
"Velocity" or "Isokinetic" Traverse	Isokinetic

Port Distance Upstream from Flow Disturbance (in.)	3180.0
Diameters Upstream from Flow Disturbance (≥ 0.5 De)	14.0
Minimum Traverse Points Needed for a Velocity Traverse *	12
Minimum Traverse Points Needed for a Isokinetic Traverse *	12

Port Distance Downstream from Flow Disturbance (in.)	1332.0
Diameters Downstream from Flow Disturbance (≥ 2.0 De)	5.8
Minimum Traverse Points Needed for a Velocity Traverse *	16
Minimum Traverse Points Needed for a Isokinetic Traverse *	20

Minimum Traverse Points per Method 1	20
Number of Traverse Points for this Circular Stack or Duct	24
Point Overide	24

Duct Area - in² 40828.14
 Duct Area - ft² 283.5287

Note:

Add nipple protrusion length to Point 1 only.
 Actual nipple length = (length - protrusion)

Relocate to a distance equal to the inside diameter of the nozzle being used or to the above minimum distances, whichever is larger.

This Stack having a diameter greater than 24-inches, shall have no traverse points located within 1.0-inch of the stack wall.

New Method 1 verified on 8/9/2021 by: MN/MY

Port	Point	% of Duct Depth	Dist. From Inside Wall (Decimal)	Dist. From Outside Wall (Decimal)
1	1	2.1	4.8	12.8
1	2	6.7	15.3	23.3
1	3	11.8	26.9	34.9
1	4	17.7	40.4	48.4
1	5	25.0	57.0	65.0
1	6	35.6	81.2	89.2
2	1	2.1	4.8	12.8
2	2	6.7	15.3	23.3
2	3	11.8	26.9	34.9
2	4	17.7	40.4	48.4
2	5	25.0	57.0	65.0
2	6	35.6	81.2	89.2
3	1	2.1	4.8	12.8
3	2	6.7	15.3	23.3
3	3	11.8	26.9	34.9
3	4	17.7	40.4	48.4
3	5	25.0	57.0	65.0
3	6	35.6	81.2	89.2
4	1	2.1	4.8	12.8
4	2	6.7	15.3	23.3
4	3	11.8	26.9	34.9
4	4	17.7	40.4	48.4
4	5	25.0	57.0	65.0
4	6	35.6	81.2	89.2

Project Information								Equipment Identification			
Date: <u>8-10-21</u> Project #: <u>008915</u>				Ref. Thermometer: _____							
Customer / Facility: <u>DTE SCPP</u>				Hygrometer: _____							
Unit ID / Sample Location: <u>Unit 6</u>				Field Balance: <u>4</u>							
Run #: <u>1,2,3</u> Operator: <u>Matt Young</u>				Check Weights: <u>5</u>							
				Calipers: <u>2</u>							
Balance Audit: (Field balance must be within 0.5g of check weight mass)								Ambient Conditions (Mobile Lab)			
Date: <u>8-10-21</u>								Relative humidity, %: _____			
Standard mass, g		<u>500.0</u>	<u>500.0</u>	<u>500.0</u>	<u>500.0</u>	Temperature, °F: _____					
Field balance mass, g		<u>499.8</u>	<u>499.8</u>	<u>499.8</u>	<u>499.8</u>	Mobile lab #: _____					
Moisture Determination											
	Contents	Run 1			Run 2			Run 3			
		Initial	Final	Net Gain	Initial	Final	Net Gain	Initial	Final	Net Gain	
Knockout											
Impinger 1		<u>167.2</u>	<u>858.5</u>	<u>91.3</u>	<u>858.5</u>	<u>951.2</u>	<u>92.7</u>	<u>951.2</u>	<u>971.8</u>	<u>20.6</u>	
Impinger 2		<u>778.5</u>	<u>787.6</u>	<u>9.1</u>	<u>787.6</u>	<u>794.0</u>	<u>6.4</u>	<u>794.0</u>	<u>870.5</u>	<u>76.5</u>	
Impinger 3		<u>666.2</u>	<u>670.9</u>	<u>4.2</u>	<u>670.9</u>	<u>671.9</u>	<u>1.5</u>	<u>671.9</u>	<u>673.5</u>	<u>1.6</u>	
Impinger 4				<u>104.6</u>				<u>100.6</u>			
Impinger 5											
Impinger 6											
Impinger 7											
Impinger 8											
Silica Gel		<u>972.5</u>	<u>988.2</u>	<u>15.7</u>	<u>988.2</u>	<u>997.4</u>	<u>9.2</u>	<u>977.7</u>	<u>992.6</u>	<u>14.9</u>	
Train Net Gain (Vlc)			<u>120.3</u>			<u>107.8</u>				<u>113.6</u>	
Nozzle Measurements (Difference between any two measurements must not be more than 0.004 in (0.1 mm))											
Nozzle 1 diameters	<u>.741</u>	D1	<u>.741</u>	D2	<u>.741</u>	D3	<u>.741</u>	Average			
Nozzle 2 diameters		D1		D2		D3		Average			
Nozzle 3 diameters		D1		D2		D3		Average			
Nozzle Material:	<input type="checkbox"/> quartz	<input type="checkbox"/> glass	<input checked="" type="checkbox"/> steel	<input type="checkbox"/> titanium	<input type="checkbox"/> inconel	<input type="checkbox"/> other					
Probe Type:	<input checked="" type="checkbox"/> heated	<input type="checkbox"/> unheated	<input type="checkbox"/> air-cooled	<input type="checkbox"/> water-cooled	<input type="checkbox"/> other						
Probe Liner:	<input checked="" type="checkbox"/> quartz	<input type="checkbox"/> glass	<input type="checkbox"/> steel	<input type="checkbox"/> Teflon	<input type="checkbox"/> other						
Filter Information											
Front Half:	<input type="checkbox"/> Quartz Fiber	<input checked="" type="checkbox"/> Glass Fiber	<input type="checkbox"/> Teflon	<input type="checkbox"/> Teflon/Quartz	<input type="checkbox"/> Other:						
Filter Number:	Run 1: <u>H-702</u>	Run 2: <u>H-759</u>	Run 3: <u>H-701</u>	Run 4: _____							
Back Half:	<input type="checkbox"/> Quartz Fiber	<input checked="" type="checkbox"/> Glass Fiber	<input type="checkbox"/> Teflon	<input type="checkbox"/> Teflon/Quartz	<input type="checkbox"/> Other:						
Reagent Information				Sample Observations							
Type	Lot Number			Run 1							
				Run 2							
				Run 3							

 QA/QC Check: Completeness: ✓ Legibility: ✓ Accuracy: ✓ Specifications: ✓

 Checked by: Mike Nunner Team Leader: Matt Young

001AS-OPS-RBETA

US EPA Method 4 Gravimetric Determination for Moisture
US EPA Method 5B Sampling Train

RUN 1

	Initial Tare	Final Tare	Net Weights
Impinger No. 1	767.2	858.5	91.3
Impinger No. 2	778.5	787.6	9.1
Impinger No. 3	666.2	670.4	4.2
Total Condensed:			104.6
Silica Gel	972.5	988.2	15.7
Total Absorbed:			15.7
Overall Total:			120.3

RUN 2

	Initial Tare	Final Tare	Net Weights
Impinger No. 1	858.5	951.2	92.7
Impinger No. 2	787.6	794.0	6.4
Impinger No. 3	670.4	671.9	1.5
Total Condensed:			100.6
Silica Gel	988.2	997.4	9.2
Total Absorbed:			9.2
Overall Total:			109.8

RUN 3

	Initial Tare	Final Tare	Net Weights
Impinger No. 1	951.2	971.8	20.6
Impinger No. 2	794.0	870.5	76.5
Impinger No. 3	671.9	673.5	1.6
Total Condensed:			98.7
Silica Gel	977.7	992.6	14.9
Total Absorbed:			14.9
Overall Total:			113.6

M049AS-008915-RT-800

29 of 110

Project Information				Sampling Conditions							ALT 011			
Date	8-10-21	Project #	008915	Static Pressure, in. H ₂ O	0.20	Ambient Temp, °F	72	TC ID:	Ambient °F	Ref. °F				
Customer/Facility	DTE SCPP			Barometric Pressure, in. Hg	29.89	Ref. Barometer ID	NOAA	Stack	8'C - 1	72	72			
Unit ID/Sample Location	Unit 6			Wind Speed / Direction	5-7 mph	Precipitation, Y/N type		Probe	8'C - 2	72	72			
Run #	1	Operator	Mike Numm	Probe / Filter Temp Range, °F	320 ± 25			Filter Box						
Sampling Equipment IDs				Calibration		Equipment Checks		Pre	Mid	Post				
Meterbox ID	M3	Meterbox Y	1.026	Pitot (+), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ 3.2	<input type="checkbox"/> @	<input checked="" type="checkbox"/> @ 3.5							
Umbilical ID	JM3 12	Meterbox ΔH@, in. H ₂ O	1.83	Pitot (-), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ 3.4	<input type="checkbox"/> @	<input checked="" type="checkbox"/> @ 3.3							
Nozzle ID	SS 4-9	Nozzle diameter, D _n , in.	.241	Pitot visual inspection		<input checked="" type="checkbox"/> pass		pass						
Pitot / Probe ID	8'C	Pitot coefficient, Cp	.91	Nozzle visual inspection		<input checked="" type="checkbox"/> pass		pass						
Manometer ID	M3	Manometer zero and level	<input checked="" type="checkbox"/> yes	Meter, cfm @ in. Hg	0.005 @ 15		@	0.005 @ 9						
Sensitivity	0-10"	K-Factor	2.50	Intermediate leak check volume, ft ³			/	/						
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, V _m , ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F		Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F		Pump Vacuum, in. Hg
					Target	Actual			Box	Exit		Inlet	Outlet	
i	0	8:04	922.75	-88	2.20	2.25	306	317	322	66	86	86	6	
2	2.5		924.87	-86	2.15	2.20	308	321	329	62	82	84	6	
3	5		926.93	-87	2.18	2.20	308	317	326	61	81	84	6	
4	7.5		928.96	-93	2.33	2.35	307	319	321	60	81	83	6	
5	10		931.05	91	2.28	2.30	309	315	324	59	81	82	6	
6	12.5		933.10	89	2.23	2.25	309	316	323	60	81	82	6	
	15	8:19	935.14											
1	15	8:23	935.14	-92	2.30	2.30	308	312	309	64	80	80	6	
2	17.5		937.22	-95	2.38	2.40	308	316	317	64	81	80	6	
3	20		939.33	1.00	2.50	2.50	309	313	327	64	82	83	6.5	
4	22.5		941.48	1.10	2.75	2.75	309	311	329	64	82	88	7	
5	25		943.76	1.20	3.00	3.00	310	317	326	61	82	86	8	
6	27.5		946.09	1.20	3.00	3.00	310	318	330	59	83	80	8	
	30	8:38	948.45											
1	30	8:42	948.45	1.00	2.52	2.52	309	329	311	63	81	79	6.5	
2	32.5		950.59	1.00	2.50	2.52	308	323	312	59	82	79	6.5	
3	35		952.74	1.10	2.75	2.75	306	321	326	58	82	79	7	
4	37.5		955.02	1.10	2.75	2.75	306	315	325	57	82	79	7	
5	40		957.36	1.10	2.75	2.75	306	317	325	58	83	79	7	
6	42.5		959.57	1.05	2.63	2.65	307	312	321	58	83	79	7	
	45	8:57	961.78											
Averages														

 QA/QC Check: Completeness Legibility Accuracy Specifications Checked By Mike Numm Team Leader Matt Young

001AS-QMS-FM-225RB



EPA Method 5b Field Datasheet (Isokinetic)

Page 2 of 2

M049AS-008915-RT-800

30 of 110

Project Information					Sampling Conditions					ALT 011 TC ID: Ambient °F Ref. °F				
Date 8-10-21 Project # 008915 Customer/Facility DTE SCP P Unit ID/Sample Location UNIT G Run # 1 Operator Mike Nummer					Static Pressure, in. H ₂ O 0.20 Ambient Temp, °F 72 Barometric Pressure, in. Hg 29.89 Ref. Barometer ID NOAA Wind Speed / Direction 5 mph Precipitation, Y/N type Probe / Filter Temp Range, °F 320 ± 25									
Sampling Equipment IDs					Calibration					Equipment Checks				
Meterbox ID	mB 3	Meterbox Y	1.020	Pitot (+), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ 3.2	<input type="checkbox"/> @	<input checked="" type="checkbox"/> @ 3.5	Pre	Mid	Post	Stack			
Umbilical ID	UMB 12	Meterbox ΔH, in. H ₂ O	1.83	Pitot (-), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ 3.4	<input type="checkbox"/> @	<input checked="" type="checkbox"/> @ 3.3				Probe			
Nozzle ID	SS 4-9	Nozzle diameter, D _n , in.	.241	Pitot visual inspection	<input checked="" type="checkbox"/> pass	<input type="checkbox"/> pass	<input checked="" type="checkbox"/> pass				Filter Box			
Pitot / Probe ID	8°C	Pitot coefficient, C _p	-8.1	Nozzle visual inspection	<input checked="" type="checkbox"/> pass	<input type="checkbox"/> pass	<input checked="" type="checkbox"/> pass				Filter Exit			
Manometer ID	mB 3	Manometer zero and level	<input checked="" type="checkbox"/> yes	Meter, cfm @ in. Hg	0.024 @ 15	@	0.022 @ 9				Meter outlet			
Sensitivity	0-10"	K-Factor	2.56	Intermediate leak check volume, ft ³	/	/	/				Impinger Exit			
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, V _m , ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F	Inlet	Outlet	Pump Vacuum, in. Hg
1	45	9:01	961.78	.77	Target	Actual	308	324	325	61	81	79		5.5
2	47.5		963.67	-0.98	2.45	2.45	307	329	323	59	82	79		7
3	50		965.81	1.05	2.63	2.65	307	321	324	52	83	79		7
4	52.5		967.99	1.10	2.75	2.75	307	314	324	56	83	79		7
5	55		970.22	-0.95	2.38	2.40	307	319	320	54	84	79		6.5
6	57.5		972.31	-0.90	2.25	2.00	307	318	321	57	84	79		5.5
	60	9:16	974.22											
Averages														

QA/QC Check: Completeness ✓ Legibility ✓ Accuracy ✓ Specifications ✓ Checked By Mike Nummer Team Leader Matt Young

001AS-QMS-FM-225RB



EPA Method 5b Field Datasheet (Isokinetic)

Page 1 of 2

M049AS-008915-RT-800

31 of 110

Project Information					Sampling Conditions					ALT 011 TC ID: Ambient °F Ref. °F				
Date <u>8-10-21</u> Project # <u>008915</u> Customer/Facility <u>DTE SCPP</u> Unit ID/Sample Location <u>Unit 6</u> Run # <u>2</u> Operator <u>Mike Nummer</u>					Static Pressure, in. H ₂ O <u>0.26</u> Ambient Temp, °F <u>74</u> Barometric Pressure, in. Hg <u>29.91</u> Ref. Barometer ID <u>NOAA</u> Wind Speed / Direction <u>5.8 mph</u> Precipitation, Y/N type <u>N</u> Probe / Filter Temp Range, °F <u>320 ± 25</u>					Stack Probe Filter Box Filter Exit Meter outlet Impinger Exit Other Ref. Thermometer ID _____ Continuity Check <input type="checkbox"/> Continuity w/ Proper Polarity				
Sampling Equipment IDs		Calibration			Equipment Checks			Pre		Mid		Post		
Meterbox ID	<u>MB 3</u>	Meterbox Y	<u>1.026</u>	Pitot (+), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ <u>3.5</u>	<input type="checkbox"/> @ <u></u>	<input checked="" type="checkbox"/> @ <u>3.2</u>							
Umbilical ID	<u>UMB 12</u>	Meterbox ΔH@, in. H ₂ O	<u>1.83</u>	Pitot (-), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ <u>3.3</u>	<input type="checkbox"/> @ <u></u>	<input checked="" type="checkbox"/> @ <u>3.3</u>							
Nozzle ID	<u>SS 4-9</u>	Nozzle diameter, D _n , in.	<u>.241</u>	Pitot visual inspection	<input checked="" type="checkbox"/> pass	<input type="checkbox"/> pass	<input checked="" type="checkbox"/> pass							
Pitot / Probe ID	<u>8°C</u>	Pitot coefficient, Cp	<u>-82</u>	Nozzle visual inspection	<input checked="" type="checkbox"/> pass	<input type="checkbox"/> pass	<input checked="" type="checkbox"/> pass							
Manometer ID	<u>MB 3</u>	Manometer zero and level	<input checked="" type="checkbox"/> yes	Meter, cfm @ in. Hg	<u>0.085 @ 15</u>	<u>@</u>	<u>0.085 @ 10</u>							
Sensitivity	<u>0-10"</u>	K-Factor	<u>2.25</u>	Intermediate leak check volume, ft ³				<u>1</u>	<u>1</u>			Notes: _____		
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, Vm, ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH	Stack Temp, °F	Probe Temp, °F	Filter Temp, °F	Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F	Inlet	Outlet	Pump Vacuum, in. Hg	
					Target	Actual		Box	Exit					
1	0	9:51	974.51	-63	1.42	1.50	306	309	321	67	76	76	4.5	
2	2.5		976.19	-68	1.53	1.66	306	304	321	64	76	75	4.5	
3	5		977.96	-48	1.08	1.16	306	725	717	54	76	75	4	
4	7.5		979.34	-84	2.00	2.00	306	730	323	56	76	75	5.5	
5	10		981.27	-1.30	2.92	2.95	306	326	327	51	77	75	7	
6	12.5		983.61	.95	2.14	2.15	307	316	317	49	78	75	5.5	
	15	10:06	985.59											
1	15	10:09	985.59	1.00	2.25	2.25	307	319	323	60	77	78	6	
2	17.5		987.63	1.10	2.47	2.50	307	322	721	53	80	77	6.5	
3	20		989.79	1.20	2.70	2.70	306	318	322	52	80	76	7	
4	22.5		992.02	1.05	2.36	2.35	306	321	320	52	80	76	6.5	
5	25		994.11	1.05	2.36	2.35	308	317	320	53	81	77	6.5	
6	27.5		996.21	.90	2.02	2.00	308	322	319	54	81	77	5.5	
	30	10:24	998.11											
1	30	10:27	998.11	-95	2.14	2.15	308	320	311	62	80	78	5.5	
2	32.5		1000.12	.90	2.02	2.05	310	326	323	58	81	77	5.5	
3	35		1002.07	1.10	2.47	2.50	310	322	326	58	81	78	6.5	
4	37.5		1004.21	1.00	2.25	2.25	310	314	320	59	82	78	6	
5	40		1006.22	1.10	2.47	2.50	311	320	328	59	82	78	6.5	
6	42.5		1008.36	1.05	2.36	2.35	311	317	319	59	83	78	6	
	45	10:42	1010.45											
Averages														

QA/QC Check: Completeness Legibility Accuracy Specifications Checked By Mike Nummer Team Leader Matt Young

001AS-QMS-FM-225RB

M049AS-008915-RT-800

32 of 110

Project Information				Sampling Conditions								ALT 011 TC ID: Ambient °F Ref. °F			
Date	8-10-21	Project #	008915	Static Pressure, in. H ₂ O	0.26	Ambient Temp, °F	74	Stack							
Customer/Facility	DTE	SCPP		Barometric Pressure, in. Hg	29.91	Ref. Barometer ID	NATA	Probe							
Unit ID/Sample Location	Unit 6			Wind Speed / Direction	S 8 mph	Precipitation, Y/N	Y	Filter Box							
Run #	2	Operator	Mike Nummer	Probe / Filter Temp Range, °F	320 ± 25			Filter Exit							
Sampling Equipment IDs				Calibration		Equipment Checks		Pre	Mid	Post					
Meterbox ID	MB 3	Meterbox Y	1.026	Pitot (+), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ 3.5	<input type="checkbox"/> @	<input checked="" type="checkbox"/> @ 3.2					Meter outlet			
Umbilical ID	UMB 12	Meterbox ΔH, in. H ₂ O	1.83	Pitot (-), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ 3.3	<input type="checkbox"/> @	<input checked="" type="checkbox"/> @ 3.3					Impinger Exit			
Nozzle ID	S 3 4-9	Nozzle diameter, D _n , in.	.241	Pitot visual inspection	<input checked="" type="checkbox"/> pass	<input type="checkbox"/> pass	<input checked="" type="checkbox"/> pass					Other			
Pitot / Probe ID	S 1 C	Pitot coefficient, Cp	.84	Nozzle visual inspection	<input checked="" type="checkbox"/> pass	<input type="checkbox"/> pass	<input checked="" type="checkbox"/> pass					Ref. Thermometer ID			
Manometer ID	MB 3	Manometer zero and level	<input checked="" type="checkbox"/> yes	Meter, cfm @ in. Hg	0.005 @ 15	@	0.005 @ 10					Continuity Check	<input type="checkbox"/> Continuity w/ Proper Polarity		
Sensitivity	0-10"	K-Factor	2.25	Intermediate leak check volume, ft ³		/	/					Notes:			
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, Vm, ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F		Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F	Pump Vacuum, in. Hg		
					Target	Actual			Box	Exit				Inlet	Outlet
1	45	10:46	1010.45	.81	1.82	1.85	710	320		331	66	82	78	5-	
2	47.5		1012.29	.86	1.93	1.95	311	322		323	67	83	79	5-	
3	56		1014.18	.95	2.14	2.15	311	318		328	61	83	79	6	
4	52.5		1016.26	.98	2.26	2.26	312	322		322	62	84	80	6	
5	55		1018.24	.92	2.07	2.10	312	316		313	62	84	88	5.5	
6	57.5		1020.22	.88	1.98	2.10	312	319		318	62	84	80	5.5	
GC	11:01		1022.11												
Averages															

 QA/QC Check: Completeness Legibility Accuracy Specifications Checked By Mike Nummer Team Leader Matt Young

001AS-QMS-FM-225RB

M049AS-008915-RT-800

33 of 110

Project Information				Sampling Conditions								ALT 011 TC ID: Ambient °F Ref. °F			
Date	8-10-11	Project #	008915	Static Pressure, in. H ₂ O	0.26	Ambient Temp, °F	77	Stack							
Customer/Facility	DTE	SCPP		Barometric Pressure, in. Hg	29.91	Ref. Barometer ID	NOAA	Probe							
Unit ID/Sample Location	UNIT G			Wind Speed / Direction	SSW 7 mph	Precipitation, Y/N type		Filter Box							
Run #	3	Operator	Mike Nummer	Probe / Filter Temp Range, °F	320 ± 25			Filter Exit							
Sampling Equipment IDs				Calibration		Equipment Checks		Pre	Mid	Post					
Meterbox ID	MB 3	Meterbox Y	1.020	Pitot (+), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ 3.2	<input type="checkbox"/> @	<input checked="" type="checkbox"/> @ 3.1				Meter outlet				
Umbilical ID	UMB 12	Meterbox ΔH@, in. H ₂ O	1.83	Pitot (-), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ 3.3	<input type="checkbox"/> @	<input checked="" type="checkbox"/> @ 3.5				Impinger Exit				
Nozzle ID	SS 4-9	Nozzle diameter, D _n , in.	.241	Pitot visual inspection	<input checked="" type="checkbox"/> pass	<input type="checkbox"/> pass	<input checked="" type="checkbox"/> pass				Other				
Pitot / Probe ID	81C	Pitot coefficient, Cp	.84	Nozzle visual inspection	<input checked="" type="checkbox"/> pass	<input type="checkbox"/> pass	<input checked="" type="checkbox"/> pass				Ref. Thermometer ID				
Manometer ID	MB 3	Manometer zero and level	<input checked="" type="checkbox"/> yes	Meter, cfm @ in. Hg	0.085 @ 15	@	0.00 @ 8				Continuity Check	<input type="checkbox"/>	Continuity w/ Proper Polarity		
Sensitivity	6-10"	K-Factor	2.26	Intermediate leak check volume, ft ³							Notes:				
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, V _m , ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F		Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F		Pump Vacuum, in. Hg	
					Target	Actual			Box	Exit		Inlet	Outlet		
1	6	11:24	22.29	.85	1.87	1.85	311	307	321	67	82	79	4.5		
2	2.5		24.18	.87	1.91	1.90	311	310	322	66	81	80	4.5		
3	5		26.07	.87	1.91	1.90	311	324	317	59	83	80	4.5		
4	7.5		27.95	.92	2.02	2.00	312	324	323	57	84	81	4.5		
5	10		29.86	.85	1.87	1.85	313	321	320	58	85	81	4.5		
6	12.5		31.71	.75	1.65	1.65	313	320	321	57	86	82	4.5		
7	15	11:39	33.46												
8	15	11:42	33.46	.90	1.98	1.95	312	326	319	62	84	82	4.5		
9	17.5		35.36	.93	2.04	2.00	311	320	322	60	87	83	4.5		
10	20		37.30	.96	2.11	2.10	312	319	312	59	87	83	5		
11	22.5		39.24	.96	2.11	2.10	311	320	324	60	88	83	5		
12	25		41.27	1.10	2.42	2.40	312	319	332	60	89	84	5.5		
13	27.5		43.41	.90	1.98	1.95	312	319	316	61	90	84	4.5		
14	30	11:57	45.33												
15	30	11:59	45.33	1.00	2.20	2.00	311	326	311	63	89	85	5		
16	32.5		47.37	.98	2.15	2.15	310	319	320	58	90	85	5		
17	35		49.37	1.10	2.42	2.40	309	320	319	58	91	85	5.5		
18	37.5		51.49	1.05	2.31	2.30	309	321	324	58	92	86	5		
19	40		53.54	1.00	2.20	2.20	309	319	324	58	93	86	5		
20	42.5		55.54	.82	1.82	1.80	310	320	321	59	93	87	4.5		
21	45	12:14	57.44												
Averages															

QA/QC Check: Completeness Legibility Accuracy Specifications Checked By Mike Nummer Team Leader Matt Young

M049AS-008915-RT-800

34 of 110

Project Information					Sampling Conditions					ALT 011 TC ID: Ambient °F Ref. °F				
Date	8-10-11	Project #	008915	Static Pressure, in. H ₂ O	0.20	Ambient Temp, °F	77	Stack						
Customer/Facility	DTE	SCPP		Barometric Pressure, in. Hg	29.91	Ref. Barometer ID	NOAA	Probe						
Unit ID/Sample Location	Unit 6			Wind Speed / Direction	SSW 7 mph	Precipitation, Y/N	type	Filter Box						
Run #	3	Operator	Mike Nummer	Probe / Filter Temp Range, °F	320 ± 25			Filter Exit						
Sampling Equipment IDs					Calibration		Equipment Checks			Pre	Mid	Post		
Meterbox ID	MB 3	Meterbox Y	1.026	Meterbox ΔH@, in. H ₂ O	1.83	Pitot (+), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ 3.2	<input type="checkbox"/> @	<input checked="" type="checkbox"/> @ 3.1				Meter outlet	
Umbilical ID	VMB 12	Nozzle ID	35 4-9	Nozzle diameter, D _n , in.	.241	Pitot (-), pass @ in. H ₂ O	<input checked="" type="checkbox"/> @ 3.3	<input type="checkbox"/> @	<input checked="" type="checkbox"/> @ 3.5				Impinger Exit	
Pitot / Probe ID	8°C			Pitot coefficient, C _p	.821	Pitot visual inspection	<input type="checkbox"/> pass	<input type="checkbox"/> pass	<input type="checkbox"/> pass				Other	
Manometer ID	MB 3			Manometer zero and level	<input checked="" type="checkbox"/> yes	Nozzle visual inspection	<input type="checkbox"/> pass	<input type="checkbox"/> pass	<input type="checkbox"/> pass				Ref. Thermometer ID	
Sensitivity	0 - 16"	K-Factor	2.20	Meter, cfm @ in. Hg	0.025 @ 15		<input type="checkbox"/> @	0.020 @ 8					Continuity Check	<input type="checkbox"/> Continuity w/ Proper Polarity
					Intermediate leak check volume, ft ³			/	/				Notes:	
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, Vm, ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F		Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F		Pump Vacuum, in. Hg
					Target	Actual			Box	Exit		Inlet	Outlet	
1	45	12:18	57.44	1.15	2.53	2.50	310	310	324	62	92	87	5.5	
2	47.5		59.61	1.16	2.42	2.40	310	319	322	58	93	88	5	
3	50		61.74	1.20	2.64	2.65	310	320	317	57	93	88	6	
4	52.5		63.99	1.26	2.64	2.65	311	320	324	57	95	89	6	
5	55		66.22	1.25	2.75	2.75	311	319	324	57	95	89	6	
6	57.5		68.51	.88	1.93	1.95	310	319	314	58	96	89	4.5	
60		12:33	76.44											
Averages														

QA/QC Check: Completeness Legibility Accuracy Specifications Checked By Mike Nummer Team Leader Matt Young

001AS-QMS-FM-225RB

MAQS CEM Calibration Field Data Sheet

Client DTE
Date 8/10/21, 8/11/21
Analyzer #'s 9

Operator Sampling Location

Page 1 of 4




My
DTE SCPP unit 6+7

Cylinder Serial Numbers

20 centos 9.27654

10 combo SC-915363BA1

Revision 3.0
KL 1/6/14

EU-BOILER6-SC Exhaust Stack - O₂ Concentration - Run 1**EU-BOILER6-SC Exhaust Stack - O₂ Concentration - Run 2****EU-BOILER6-SC Exhaust Stack - O₂ Concentration - Run 3**

EPA Methods 1, 2, 3A, 4, and 5B Nomenclature and Sample Calculations

Run No. - 1

Constants

$\text{CO}_2\text{F}_{\text{wt}}= 44.0$	$\text{in wg}= 0.073529$	$\text{NO}_2\text{F}_{\text{wt}}= 46.01$	$\text{HClF}_{\text{wt}}= 36.46$
$\text{O}_2\text{F}_{\text{wt}}= 32.0$	$\text{gr}= 0.000142857$	$\text{COF}_{\text{wt}}= 28.01$	$\text{SO}_2\text{F}_{\text{wt}}= 64.06$
$\text{CON}_2\text{F}_{\text{wt}}= 28.0$	$\text{mmBlu}= 1000000 \text{ Btu}$	$\text{H}_2\text{SO}_4\text{F}_{\text{wt}}= 98.08$	$\text{Cl}_2\text{F}_{\text{wt}}= 70.91$
$\text{H}_2\text{OF}_{\text{wt}}= 18.015$	$\text{CF}_{\text{wt}}= 12.011$	$T_{\text{std}}= 530.00$	$P_{\text{std}}= 29.92$
$\text{ArF}_{\text{wt}}= 40.0$	$\text{PF}_{\text{wt}}= 44.0962$		

Stack Variables

$C_p = 0.84$	pitot tube coefficient (dimensionless)
$P_{\text{bar}} = 29.89 \text{ in. Hg}$	barometric pressure
$E_{\text{box}} = 580 \text{ ft}$	elevation difference between ground level and meter box
$E_{\text{sam}} = 700 \text{ ft}$	elevation difference between ground level and sampling ports
$\gamma = 1.0200$	gamma, dry gas meter calibration factor (dimensionless)
$\theta = 60.0 \text{ min}$	net run time (minutes)
$V_{\text{lc}} = 120.3 \text{ g}$	total mass of liquid collected in impingers (g)
$\% \text{CO}_2 = 11.31 \%$	percent CO_2 by volume (dry basis) (dimensionless)
$\% \text{O}_2 = 8.03 \%$	percent O_2 by volume (dry basis) (dimensionless)
$\% \text{N}_2 = 80.66 \%$	percent N_2 by volume (dry basis) (dimensionless)
$A = 283.53 \text{ ft}^2$	stack cross-sectional area
$P_g = 0.20 \text{ in. H}_2\text{O}$	flue gas static pressure
$T_{\text{avg}} = 767.83 \text{ R}$	average absolute flue gas temperature ($460\text{R}+t_{\text{avg}}$ °F)
$\text{SQAP}_{\text{avg}} = 0.99 \text{ in. wg}$	average square root ΔP
$\Delta H = 2.48 \text{ in. wg}$	average pressure differential of orifice meter
$T_m = 541.27 \text{ R}$	dry gas meter temperature ($460\text{R}+t_{\text{avg}}$ °F)
$V_m = 51.47 \text{ ft}^3$	volume of metered gas sample (dry actual cubic feet)
$D_n = 0.241 \text{ in.}$	sampling nozzle diameter

Calculated Stack Variables

Barometric pressure at sampling location

NOTE: Barometric pressure recorded at ground level

$$P_{\text{sam}} = P_{\text{bar}} - [(E_{\text{sam}} / 100 \text{ ft}) * 0.1 \text{ in. Hg}]$$

$$P_{\text{sam}} = 29.89 - ((700.0 / 100) * 0.1)$$

$$P_{\text{sam}} = 29.19 \text{ in. Hg}$$

Volume of dry gas sampled at standard conditions (dscf)

$$V_{\text{mstd}} = \gamma * V_m * [P_{\text{bar}} - ((E_{\text{box}} / 100 \text{ ft}) * 0.1 \text{ in. Hg}) + (\Delta H / 13.6)] / P_{\text{std}} * (T_{\text{std}} / T_m)$$

$$V_{\text{mstd}} = 1.0200 * 51.470 * ((29.89 - ((580.0 / 100) * 0.1) + (2.4833 / 13.6)) / 29.92 * (530.0 / 541.271))$$

$$V_{\text{mstd}} = 50.672 \text{ ft}^3$$

Volume of water vapor at standard conditions (68 °F, scf)

$$V_{\text{wstd}} = (0.04716 \text{ ft}^3/\text{g}) * V_{\text{lc}}$$

$$V_{\text{wstd}} = (0.04716 * 120.3)$$

$$V_{\text{wstd}} = 5.7 \text{ ft}^3$$

Percent moisture by volume as measured in flue gas

$$\%H_2O \text{ (Measured)} = 100 * [V_{wstd} / (V_{wstd} + V_{msid})]$$

$$\%H_2O \text{ (Measured)} = 100 * (5.673 / (5.673 + 50.672))$$

$$\%H_2O \text{ (Measured)} = 10.07$$

$$\%H_2O \text{ (Saturated)} = (100 / P_{sat}) * 10 ^ { (6.6911 - (3144 / (T_{avg} + 390.86 - 460))) }$$

$$\%H_2O \text{ (Saturated)} = (100 / 29.204706) * 10 ^ { (6.6911 - (3144 / (767.833333 + 390.86 - 460))) }$$

$$\%H_2O \text{ (Saturated)} = 532.01$$

$$\%H_2O = 10.07$$

Absolute flue gas pressure

$$P_s = P_{sat} + (P_g / 13.6)$$

$$P_s = 29.19 + (0.20 / 13.6)$$

$$P_s = 29.20 \text{ in. Hg}$$

Dry mole fraction of flue gas (dimensionless)

$$M_{fd} = 1 - (\%H_2O / 100)$$

$$M_{fd} = 1 - (10.07 / 100)$$

$$M_{fd} = 0.899$$

Dry molecular weight of flue gas (lb/lb-mole)

$$M_d = [(\%CO_2 / 100) * 44.0] + [(\%O_2 / 100) * 32.0] + [((100 - \%CO_2 - \%O_2) / 100) * 28.0]$$

$$M_d = ((11.31 / 100) * 44.0) + ((8.03 / 100) * 32.0) + (((100 - 11.31 - 8.03) / 100) * 28.0)$$

$$M_d = 30.13 \text{ lb/lb-mole}$$

$$M_d = 30.13$$

Wet molecular weight of flue gas (lb/lb-mole)

$$M_w = M_d * M_{fd} + (H_2O F_{wt} * (\%H_2O / 100))$$

$$M_w = 30.131 * 0.899 + 18.02 * (10.07 / 100)$$

$$M_w = 28.9107 \text{ lb/lb-mole}$$

Average flue gas velocity (ft/sec)

$$v_a = 85.49 * C_p * (SQ\Delta P_{avg}) * (T_{avg} / (P_s * M_w))^{0.5}$$

$$v_a = 85.49 * 0.84 * (0.9945) * (767.83 / (29.205 * 28.911))^{0.5}$$

$$v_a = 68.1072 \text{ ft/sec}$$

Wet volumetric flue gas flow rate at actual conditions (acfm)

$$Q_{aw} = v_s * A * 60 \text{ sec/min}$$

$$Q_{aw} = 68.107 * 283.529 * 60$$

$$Q_{aw} = 1,158,621 \text{ ft}^3/\text{min}$$

Wet volumetric flue gas flow rate at standard conditions (scfm)

$$Q_{sdw} = v_s * A * (T_{std} / T_{avg}) * (P_s / P_{std}) * 60 \text{ sec/min}$$

$$Q_{sdw} = 68.107 * 283.529 * (530.0 / 767.833) * (29.205 / 29.92) * 60$$

$$Q_{sdw} = 780,623 \text{ ft}^3/\text{min}$$

Dry volumetric flue gas flow rate at standard conditions (dscfm)

$$Q_{sd} = M_{fd} * v_s * A * (T_{std} / T_{avg}) * (P_s / P_{std}) * 60 \text{ sec/min}$$

$$Q_{sd} = 0.899 * 68.1072 * 283.5287 * (530.0 / 767.833) * (29.205 / 29.92) * 60$$

$$Q_{sd} = 702,023 \text{ ft}^3/\text{min}$$

Percent Excess Air

$$\%EA = [\%O_2 - (0.5) * \%CO] / [0.264 * (100 - \%CO_2 - \%O_2) - (\%O_2 - 0.5 * \%CO)]$$

$$\%EA = ((8.03 - (0.5) * 0.00) / (0.264 * (100 - 11.31 - 8.03) - (8.03 - 0.5 * 0.00))) * 100$$

$$\%EA = 60.50 \%$$

Isokinetic Calculations**Percent Isokinetic of sampling rate (%)**

$$\%I = (P_{std} / T_{std}) * (T_{avg} / P_s) * [V_{mstd} / (v_s * M_{fd} * \theta) * (\pi * (D_n / 2)^2 / 144)] * (100 / 60)$$

$$\%I = (29.92 / 530.0) * (767.833 / 29.205) * (50.672 / (68.1072 * 0.899 * 60.0 * 3.141593 * (0.241 / 2)^2 / 144)) * (100 / 60)$$

$$\%I = 107.7 \%$$

Method 5B Calculations**Wet Air Flow Rate at Standard Conditions, 1,000 lb-wet exhaust gas/hr**

$$\text{WetFlow} (Q_{sdw} * M_s * (60 / 386.8)) / 1000$$

$$\text{WetFlow} 780,623 * 28.91 * (60 / 386.8) / 1000$$

$$\text{WetFlow} 3500.8 \text{ 1,000 lb-wet exhaust gas/hr}$$

Nonsulfuric Acid PM total catch weight (mg)

$$mg_{quan} = 14.2 \text{ mg}$$

Nonsulfuric Acid PM concentration (grains/dscf)

$$C_{grcm} = 0.0154322 * mg_{quan} / V_{mstd}$$

$$C_{grcm} = 0.0154322 * 14.20 / 50.672$$

$$C_{grcm} = 0.0043 \text{ gr/ft}^3$$

Nonsulfuric Acid PM mass emission rate (lb/hr)

$$EMR_{lbhr} = (mg_{quan} / V_{mstd}) * Q_{sd} * (60 / 453592)$$

$$EMR_{lbhr} = 14.20 / 50.672 * 702,023.2 * (60 / 453592)$$

$$EMR_{lbhr} = 26.0 \text{ lb/hr}$$

Nonsulfuric Acid PM mass emission rate (lb/1,000 lb of wet exhaust gas @ 50% excess air)

$$EMR_{lbhr} = EMR_{lbhr} / WetFlow * ((100 + %EA) / 150)$$

$$EMR_{lbhr} = 26.02 / 3,500.8 * (100 * 60.50) / 150$$

$$EMR_{lbhr} = 0.0080 \text{ lb/1,000 lb-wet exhaust gas}$$