

RECEIVED

FEB 09 2022

**SOURCE TEST REPORT
2021 COMPLIANCE EMISSIONS TESTING**

AIR QUALITY DIVISION

**UNITED STATES GYPSUM COMPANY
RIVER ROUGE FACILITY
RIVER ROUGE, MICHIGAN**

No. 1 CALCINING KETTLE (EU-36)

Prepared For:

United States Gypsum Company-River Rouge
10090 West Jefferson Avenue
River Rouge, MI 48218

For Submittal To:

EGLE
525 W. Allegan Street
Lansing, MI 48933

Prepared By:

Montrose Air Quality Services, LLC
4949 Fernlee Avenue
Royal Oak, MI 48073

Document Number: **MW049AS-009677-RT-918**
Test Date: **December 21, 2021**
Submittal Date: **February 7, 2022**



B3518 Test - 2021/221



REVIEW AND CERTIFICATION

All work, calculations, and other activities and tasks performed and presented in this document were carried out by me or under my direction and supervision. I hereby certify that, to the best of my knowledge, Montrose operated in conformance with the requirements of the Montrose Quality Management System and ASTM D7036-04 during this test project.

Signature: David Trahan Date: 01 / 07 / 2022

Name: David Trahan Title: Field Project Manager

I have reviewed, technically and editorially, details, calculations, results, conclusions, and other appropriate written materials contained herein. I hereby certify that, to the best of my knowledge, the presented material is authentic, accurate, and conforms to the requirements of the Montrose Quality Management System and ASTM D7036-04.

Signature: Todd Wessel Date: 01 / 07 / 2022

Name: Todd Wessel Title: Client Project Manager

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE</u>
1.0 INTRODUCTION	5
1.1 SUMMARY OF TEST PROGRAM	5
1.2 KEY PERSONNEL.....	6
2.0 PLANT AND SAMPLING LOCATION DESCRIPTIONS	8
2.1 PROCESS DESCRIPTION, OPERATION, AND CONTROL EQUIPMENT	8
2.2 FLUE GAS SAMPLING LOCATION.....	8
2.3 OPERATING CONDITIONS AND PROCESS DATA.....	8
3.0 SAMPLING AND ANALYTICAL PROCEDURES	9
3.1 TEST METHODS.....	9
3.1.1 EPA Method 1.....	9
3.1.2 EPA Method 2.....	9
3.1.3 EPA Method 3.....	9
3.1.4 EPA Method 4.....	10
3.1.5 EPA Method 5.....	10
3.1.6 EPA Method 9.....	11
3.2 PROCESS TEST METHODS.....	11
4.0 TEST DISCUSSION AND RESULTS.....	12
4.1 FIELD TEST DEVIATIONS AND EXCEPTIONS	12
4.2 PRESENTATION OF RESULTS.....	12
5.0 INTERNAL QA/QC ACTIVITIES	13
5.1 QA/QC AUDITS	13
5.2 QA/QC DISCUSSION	13
5.3 QUALITY STATEMENT	13

LIST OF APPENDICES

A FIELD DATA AND CALCULATIONS.....	14
A.1 Sampling Locations	15
A.2 EU-36 Data Sheets.....	18
A.3 Example Calculations	39
B FACILITY PROCESS DATA.....	44
C LABORATORY ANALYSIS DATA.....	47
D QUALITY ASSURANCE/QUALITY CONTROL	52
D.1 Units and Abbreviations.....	53
D.2 Manual Test Method QA/QC Data	62
D.3 Accreditation Information/Certifications.....	77

United States Gypsum Company-River Rouge
2021 Compliance Source Test Report

E REGULATORY INFORMATION82
 E.1 Regulatory Correspondence83
 E.2 Intent-to-Test Notification86

LIST OF TABLES

1-1 SUMMARY OF TEST PROGRAM5
1-2 SUMMARY OF AVERAGE COMPLIANCE RESULTS - EU-366
1-3 TEST PERSONNEL AND OBSERVERS7
2-1 SAMPLING LOCATION8
4-1 FPM AND VISIBLE EMISSIONS RESULTS - EU-3612

LIST OF FIGURES

3-1 EPA METHOD 3 (FYRITE ANALYZER) SAMPLING TRAIN10
3-2 EPA METHOD 5 SAMPLING TRAIN11

United States Gypsum Company-River Rouge
2021 Compliance Source Test Report

1.0 INTRODUCTION

1.1 SUMMARY OF TEST PROGRAM

United States Gypsum Company-River Rouge (State Registration No.: B3518) contracted Montrose Air Quality Services, LLC (Montrose) to perform a compliance test program on the No. 1 Calcining Kettle (EU-36) at the United States Gypsum Company facility located in River Rouge, Michigan. Testing was performed on December 21, 2021, for the purpose of satisfying the emission testing requirements pursuant to Michigan Department of Environment, Great Lakes, and Energy (EGLE) Renewable Operating Permit No. MI-ROP-B3518-2021.

The specific objectives were to:

- Verify the emissions of filterable particulate matter (FPM) and the percent opacity of visible emissions (VE) at the SV-36 Exhaust Stack, which is associated with the baghouse serving EU-36
- Conduct the test program with a focus on safety

Montrose performed the tests to measure the emission parameters listed in Table 1-1.

**TABLE 1-1
SUMMARY OF TEST PROGRAM**

Test Date(s)	Unit ID/ Source Name	Activity/ Parameters	Test Methods	No. of Runs	Duration (Minutes)
12/21/2021	EU-36 / SV-36	Velocity/Volumetric Flow Rate	EPA 1 & 2	3	60
12/21/2021	EU-36 / SV-36	O ₂ , CO ₂	EPA 3	3	60
12/21/2021	EU-36 / SV-36	Moisture	EPA 4	3	60
12/21/2021	EU-36 / SV-36	FPM	EPA 5	3	60
12/21/2021	EU-36 / SV-36	Opacity	EPA 9	3	60

To simplify this report, a list of Units and Abbreviations is included in Appendix D.1. Throughout this report, chemical nomenclature, acronyms, and reporting units are not defined. Please refer to the list for specific details.

This report presents the test results and supporting data, descriptions of the testing procedures, descriptions of the facility and sampling locations, and a summary of the quality assurance procedures used by Montrose. The average emission test results are summarized and compared to their respective permit limits in Table 1-2. Detailed results for individual test runs can be found in Section 4.0. All supporting data can be found in the appendices.

RECEIVED

FEB 09 2022

AIR QUALITY DIVISION

United States Gypsum Company-River Rouge
2021 Compliance Source Test Report

The testing was conducted by the Montrose personnel listed in Table 1-3. The tests were conducted according to the Intent-to-Test notification dated November 2, 2021 that was submitted to the EGLE.

**TABLE 1-2
SUMMARY OF AVERAGE COMPLIANCE RESULTS -
EU-36
DECEMBER 21, 2021**

Parameter/Units	Average Results	Emission Limits
Filterable Particulate Matter (FPM)		
g/dscm	0.0026	0.05
lb/hr	0.077	6.8
Visible Emissions (VE)		
% opacity (Highest 6-Minute Average)	0.0	7

1.2 KEY PERSONNEL

A list of project participants is included below:

Facility Information

Source Location:	United States Gypsum Company-River Rouge 10090 West Jefferson Avenue River Rouge, MI 48218	
Project Contact:	Brent Wyatt	Johnnie Robinson
Role:	MFG, IT Supervisor	QC Supervisor
Company:	United States Gypsum Company- River Rouge	United States Gypsum Company- River Rouge
Telephone:	313-655-1448	313-624-4278
Email:	bnwyatt@usg.com	jrobinson@usg.com

Agency Information

Regulatory Agency: EGLE
Agency Contact: Karen Kajiya-Mills
Telephone: 517-335-3122
Email: kajiya-millsk@michigan.gov

Testing Company Information

Testing Firm:	Montrose Air Quality Services, LLC	
Contact:	Todd Wessel	David Trahan
Title:	Client Project Manager	Field Project Manager
Telephone:	248-548-8070	248-548-8070
Email:	twessell@montrose-env.com	dtrahan@montrose-env.com

United States Gypsum Company-River Rouge
2021 Compliance Source Test Report

Laboratory Information

Laboratory: Montrose Royal Oak
City, State: Royal Oak, MI 48073
Method: EPA Method 5

Test personnel and observers are summarized in Table 1-3.

**TABLE 1-3
TEST PERSONNEL AND OBSERVERS**

Name	Affiliation	Role/Responsibility
David Trahan	Montrose	Field Project Manager, QI
David Koponen	Montrose	Field Technician, Certified VE Observer
Michael Nummer	Montrose	Senior Field Technician
Brent Wyatt	United States Gypsum Company-River Rouge	Client Liaison/Test Coordinator
Johnnie Robinson	United States Gypsum Company-River Rouge	Observer
Regina Angelotti	EGLE	Observer
John Lamb	EGLE	Observer

2.0 PLANT AND SAMPLING LOCATION DESCRIPTIONS

2.1 PROCESS DESCRIPTION, OPERATION, AND CONTROL EQUIPMENT

United States Gypsum Company-River Rouge manufactures a variety of gypsum products. The facility operates two calcining kettles (FG-Kettles), No. 1 Calcining Kettle (EU-36) and No. 3 Calcining Kettle (EU-38). Finely ground gypsum is fed into a kettle and then heated to the calcining temperature. Once the steam fluidizes the gypsum, it is ready for processing. Dust emissions from the kettles are controlled by baghouses. EU-36 was in operation for this test event.

2.2 FLUE GAS SAMPLING LOCATION

Information regarding the sampling location is presented in Table 2-1.

**TABLE 2-1
SAMPLING LOCATION**

Sampling Location	Stack Inside Diameter (in.)	Distance from Nearest Disturbance		Number of Traverse Points
		Downstream EPA "B" (in./dia.)	Upstream EPA "A" (in./dia.)	
EU-36 Baggouse SV-36 Exhaust Stack	25.8	480.0 / 18.6	720.0 / 28.0	Isokinetic: 12 (6/port)

The sampling location was verified in the field to conform to EPA Method 1. Acceptable cyclonic flow conditions were confirmed prior to testing using EPA Method 1, Section 11.4. See Appendix A.1 for more information.

2.3 OPERATING CONDITIONS AND PROCESS DATA

Emission tests were performed during normal EU-36 and baghouse operations.

Plant personnel were responsible for establishing the test conditions and collecting all applicable unit-operating data. The process data that was provided is presented in Appendix B. Data collected includes the following parameters:

- Average total throughput, ton/hr
- Pressure drop, in-H₂O

3.0 SAMPLING AND ANALYTICAL PROCEDURES

3.1 TEST METHODS

The test methods for this test program were presented previously in Table 1-1. Additional information regarding specific applications or modifications to standard procedures is presented below.

3.1.1 EPA Method 1, Sample and Velocity Traverses for Stationary Sources

EPA Method 1 is used to assure that representative measurements of volumetric flow rate are obtained by dividing the cross-section of the stack or duct into equal areas, and then locating a traverse point within each of the equal areas. Acceptable sample locations must be located at least two stack or duct equivalent diameters downstream from a flow disturbance and one-half equivalent diameter upstream from a flow disturbance.

The sample port and traverse point locations are detailed in Appendix A.

3.1.2 EPA Method 2, Determination of Stack Gas Velocity and Volumetric Flow Rate (Type S Pitot Tube)

EPA Method 2 is used to measure the gas velocity using an S-type pitot tube connected to a pressure measurement device, and to measure the gas temperature using a calibrated thermocouple connected to a thermocouple indicator. Typically, Type S (Stausscheibe) pitot tubes conforming to the geometric specifications in the test method are used, along with an inclined manometer. The measurements are made at traverse points specified by EPA Method 1.


The typical sampling system is detailed in Figure 3-2.

3.1.3 EPA Method 3, Gas Analysis for the Determination of Dry Molecular Weight

EPA Method 3 is used to calculate the dry molecular weight of the stack gas using one of three methods. The first choice is to measure the percent O₂ and CO₂ in the gas stream. A gas sample is extracted from a stack by one of the following methods: (1) single-point, grab sampling; (2) single-point, integrated sampling; or (3) multi-point, integrated sampling. The gas sample is analyzed for percent CO₂ and percent O₂ using either an Orsat or a Fyrite analyzer. The second choice is to use stoichiometric calculations to calculate dry molecular weight. The third choice is to use an assigned value of 30.0, in lieu of actual measurements, for processes burning natural gas, coal, or oil.

The typical sampling system is detailed in Figure 3-1.

**FIGURE 3-1
EPA METHOD 3 (FYRITE ANALYZER) SAMPLING TRAIN**



3.1.4 EPA Method 4, Determination of Moisture Content in Stack Gas

EPA Method 4 is a manual, non-isokinetic method used to measure the moisture content of gas streams. Gas is sampled at a constant sampling rate through a probe and impinger train. Moisture is removed using a series of pre-weighed impingers containing methodology-specific liquids and silica gel immersed in an ice water bath. The impingers are weighed after each run to determine the percent moisture.


The typical sampling system is detailed in Figure 3-2.

3.1.5 EPA Method 5, Determination of Particulate Matter from Stationary Sources

EPA Method 5 is a manual, isokinetic method used to measure FPM emissions. The samples are analyzed gravimetrically. This method is performed in conjunction with EPA Methods 1 through 4. The stack gas is sampled through a nozzle, probe, filter, and impinger train. FPM results are reported in emission concentration and emission rate units.

The typical sampling system is detailed in Figure 3-2.

**FIGURE 3-2
EPA METHOD 5 SAMPLING TRAIN**



3.1.6 EPA Method 9, Visual Determination of the Opacity of Emissions

EPA Method 9 is used to observe the visual opacity of emissions (opacity). The observer stands at a distance sufficient to provide a clear view of the emissions with the sun oriented in the 140° sector to their back. The line of vision is perpendicular to the plume direction and does not include more than one plume diameter. Observations are recorded at 15-second intervals and are made to the nearest 5% opacity. The qualified observer is certified according to the requirements of EPA Method 9, section 3.1.

3.2 PROCESS TEST METHODS

The test plan did not require that process samples be collected during this test program; therefore, no process sample data are presented in this test report.

4.0 TEST DISCUSSION AND RESULTS

4.1 FIELD TEST DEVIATIONS AND EXCEPTIONS

Following Run 1 at the EU-36 Baghouse SV-36 Exhaust Stack, it was observed that the EPA Method 4 moisture recovery was higher than expected and the sample had not been collected at a rate isokinetic to that of the stack gas stream. The isokinetic sampling rate during Run 1 was 120.6% which was outside the acceptable range of 100±10% as specified by EPA Method 5, Section 8.5. Run 1 was voided, and an additional run (Run 4) was performed. Run 1 data is provided in the appendix of this report for informational purposes only.

4.2 PRESENTATION OF RESULTS

The average results are compared to the permit limits in Table 1-2. The results of individual compliance test runs performed are presented in Table 4-1. Emissions are reported in units consistent with those in the applicable regulations or requirements. Additional information is included in the appendices as presented in the Table of Contents.

**TABLE 4-1
FPM AND VISIBLE EMISSIONS RESULTS -
EU-36**

Run Number	2	3	4	Average
Date	12/21/2021	12/21/2021	12/21/2021	--
Time	9:20-10:22	10:40-11:41	12:00-13:01	--
Process Data				
Average total throughput, ton/hr *	16.939	16.939	16.939	16.939
Flue Gas Parameters				
O ₂ , % volume dry	21.00	21.00	21.00	21.00
CO ₂ , % volume dry	0.00	0.00	0.00	0.00
flue gas temperature, °F	188.9	190.2	194.8	191.3
moisture content, % volume	25.33	26.97	28.06	26.79
volumetric flow rate, dscfm	8,098	7,819	7,586	7,834
Filterable Particulate Matter (FPM)				
gr/dscf	0.0014	0.0012	0.0008	0.0011
g/dscm	0.0033	0.0027	0.0018	0.0026
lb/hr	0.099	0.080	0.052	0.077
Visible Emissions (VE)				
% opacity (High 6-Minute Average)	0.0	0.0	0.0	0.0

* Process data was provided by United States Gypsum personnel.

5.0 INTERNAL QA/QC ACTIVITIES

5.1 QA/QC AUDITS

The meter box and sampling trains used during sampling performed within the requirements of their respective methods. All post-test leak checks, minimum metered volumes, minimum sample durations, and percent isokinetics met the applicable QA/QC criteria.

Fyrite analyzer audits were performed during this test in accordance with EPA Method 3, Section 10.1 requirements. The results were within $\pm 0.5\%$ of the respective audit gas concentrations.

EPA Method 9 was performed by a certified Visible Emissions Evaluator. For quality assurance, the observer obtained a view of the emissions with the best available contrasting background and with the sun oriented in the 140° sector to their back. Readings were taken every 15 seconds and made to the nearest 5% opacity.

EPA Method 5 analytical QA/QC results are included in the laboratory report. The method QA/QC criteria were met, except if noted in Section 5.2. An EPA Method 5 reagent blank was analyzed. The maximum allowable amount that can be subtracted is 0.001% of the weight of the acetone blank. The blank did not exceed the maximum residue allowed.

5.2 QA/QC DISCUSSION

All QA/QC criteria were met during this test program.


5.3 QUALITY STATEMENT

Montrose is qualified to conduct this test program and has established a quality management system that led to accreditation with ASTM Standard D7036-04 (Standard Practice for Competence of Air Emission Testing Bodies). Montrose participates in annual functional assessments for conformance with D7036-04 which are conducted by the American Association for Laboratory Accreditation (A2LA). All testing performed by Montrose is supervised on site by at least one Qualified Individual (QI) as defined in D7036-04 Section 8.3.2. Data quality objectives for estimating measurement uncertainty within the documented limits in the test methods are met by using approved test protocols for each project as defined in D7036-04 Sections 7.2.1 and 12.10. Additional quality assurance information is included in the report appendices. The content of this report is modeled after the EPA Emission Measurement Center Guideline Document (GD-043).


APPENDIX A
FIELD DATA AND CALCULATIONS

Appendix A.1 Sampling Locations

EU-36 SAMPLING LOCATION SCHEMATIC



EU-36 BAGHOUSE EXHAUST STACK TRAVERSE POINT LOCATION DRAWING



Appendix A.2
EU-36 Data Sheets

TEST DATA

Number of Test Runs	3			
Traverse Points	12			
	<u>Run 2</u>	<u>Run 3</u>	<u>Run 4</u>	<u>Average</u>
Stack Cross-Sectional Diameter 1 (circular) (in)	25.8	25.8	25.8	25.8
Stack Cross-Sectional Diameter 2 (circular) (in)	25.8	25.8	25.8	25.8
Pitot Tube Coefficient (Cp)	0.84	0.84	0.84	0.84
Barometric Pressure at Ground Level (Pbar) (in Hg)	30.09	30.09	30.09	30.09
Elevation Difference Between Ground Level and Meter Box Locations (ft)	600	600	600	600
Elevation Difference Between Ground Level and Sampling Locations (ft)	700	700	700	700
Initial Dry Gas Meter Reading (ft3)	623.000	667.346	711.352	
Final Dry Gas Meter Reading (ft3)	667.120	711.150	753.330	
Dry Gas Meter Calibration Factor (Gamma)	0.994	0.994	0.994	0.994
Dry Gas Meter Calibration Coefficient (Delta H@)	1.78	1.78	1.78	1.78
Total Sampling Run Time (Theta) (min)	60	60	60	60
Volume of Water Vapor Condensed in the Impingers (g)	301.5	326.1	329.2	318.9
Weight of Water Vapor Collected in Silica Gel (g)	9.7	8.6	8.1	8.8
Air Percent by Volume Oxygen in Stack Gas (%-dry)	21.00	21.00	21.00	21.00
Air Percent by Volume Carbon Dioxide in Stack Gas (%-dry)	0.00	0.00	0.00	0.00
Air Percent by Volume Nitrogen in Stack Gas (%-dry)	79.00	79.00	79.00	79.00
Average Pitot Rotation Angle	5.8			
Test Run Start Time (hrmin)	12/21/2022 9:20	12/21/2022 10:40	12/21/2022 12:00	
Test Run Stop Time (hrmin)	12/21/2022 10:22	12/21/2022 11:41	12/21/2022 13:01	

DETAILED RESULTS

Stack Gas Conditions	Run 2	Run 3	Run 4	Average
Stack Cross-Sectional Area (A) (ft2)	3.63	3.63	3.63	3.63
Barometric Pressure at Sampling Location (in Hg)	29.39	29.39	29.39	29.39
Dry Molecular Weight of Stack Gas (Md) (lb/lb-mole)	28.84	28.84	28.84	28.84
Wet Molecular Weight of Stack Gas (Ms) (lb/lb-mole)	26.10	25.92	25.80	25.94
Average Absolute Stack Gas Pressure (Ps) (in Hg)	29.34	29.34	29.34	29.34
Average Stack Gas Static Pressure (ps) (in H2O)	-0.70	-0.70	-0.70	-0.70
Average Stack Gas Temperature (ts) (°F)	188.9	190.2	194.8	191.3
Average Stack Gas Temperature (Ts) (°R)	648.9	650.2	654.8	651.3
Average Stack Gas Velocity (Vs) (ft/sec)	62.44	61.76	61.26	61.82
Average Stack Gas Velocity (Vs) (ft/min)	3,746	3,706	3,676	3,709
Wet Volumetric Stack Gas Flow at Actual Conditions (Qaw) (acfm)	13,601	13,454	13,345	13,467
Wet Volumetric Stack Gas Flow at Standard Conditions (scfm)	10,845	10,707	10,544	10,699
Dry Volumetric Stack Gas Flow at Standard Conditions (Qstd) (dscfm)	8,098	7,819	7,586	7,834
Percent by Volume Moisture as measured in Stack Gas (%H2O)	25.33	26.97	28.06	26.79

Test Results	Run 2	Run 3	Run 4	Average
Volume of Dry Gas Sampled at Standard Conditions (Vmstd) (dscf)	43.256	42.741	40.783	42.260
Rate of Dry Gas Sampled at Standard Conditions (dscfm)	0.721	0.712	0.680	0.704
Dry Mole Fraction of Flue Gas (Mfd)	0.747	0.730	0.719	0.732
Average Velocity Pressure (Delta P) (in H2O)	0.89	0.87	0.84	0.87
Average Square Root of Delta P	0.94	0.93	0.92	0.93
Average Pressure Differential of Orifice Meter (Delta H) (in H2O)	1.68	1.65	1.48	1.61
Average DGM Temperature (tm) (°F)	69.5	72.0	74.1	71.9
Average Dry Gas Meter Temperature (Tm) (°R)	529.5	532.0	534.1	531.9
Volume of Metered Gas Sample (Vm) (dry) (acf)	44.120	43.804	41.978	43.301

SAMPLING QA

	Run 2	Run 3	Run 4	Average
Post-Test Meter Calibration Check Value (Yqa)	0.9916	0.9911	0.9828	0.9885
Post-Test/Pre-Test Calibration Factor Difference (%)	0.25	0.29	1.13	0.55
Allowable Post-Test Leak Rate (dscfm)	0.020	0.020	0.020	0.020
Current Sampling Rate Status	OK	OK	OK	
1-Hour Sample Volume Based on Current Sampling Rate (dscf)	43.256	42.741	40.783	42.260
Probe Nozzle Diameter (in)	0.241	0.241	0.241	0.241
Percent Isokinetic of Sampling Rate (% I)	102.0	104.4	102.7	103.0
In Field Isokinetic QA	GOOD	GOOD	GOOD	
Count of Velocity Pressure Readings Below 0.05 in H2O	0	0	0	0
Sensitivity Factor for Differential Pressure Gauge (T)	1.003	1.003	1.003	1.003
Is Meter Box Manometer Adequate (Yes / No) ?	YES	YES	YES	

MEASURED DATA FROM TEST RUNS

Point Count	Run #	Run Time (min)	Pitot Delta P (in H2O)	Square Root of Delta P	Orifice Delta H (in H2O)	DGM Temp IN (°F)	DGM Temp OUT (°F)	Average DGM Temp (°F)	Stack Pressure (in H2O)	Stack Temp (°F)
1	2	0	0.99	0.995	1.90	68	68	68.00	-0.7	188
2	2	5	0.94	0.970	1.80	68	68	68.00		190
3	2	10	0.95	0.975	1.80	69	69	69.00		192
4	2	15	0.85	0.922	1.60	69	69	69.00		191
5	2	20	0.86	0.927	1.60	69	69	69.00		193
6	2	25	0.86	0.927	1.60	70	70	70.00		191
7	2	30	0.92	0.959	1.70	70	70	70.00		186
8	2	35	0.96	0.980	1.80	70	70	70.00		193
9	2	40	0.95	0.975	1.80	70	70	70.00		194
10	2	45	0.87	0.933	1.60	70	70	70.00		195
11	2	50	0.75	0.866	1.40	70	70	70.00		188
12	2	55	0.82	0.906	1.60	71	71	71.00		166
13	3	0	0.88	0.938	1.70	71	71	71.00	-0.7	197
14	3	5	0.99	0.995	1.90	71	71	71.00		198
15	3	10	0.95	0.975	1.80	71	71	71.00		196
16	3	15	0.85	0.922	1.60	72	72	72.00		196
17	3	20	0.77	0.877	1.50	72	72	72.00		185
18	3	25	0.74	0.860	1.40	72	72	72.00		163
19	3	30	0.95	0.975	1.80	72	72	72.00		161
20	3	35	0.89	0.943	1.70	72	72	72.00		200
21	3	40	0.90	0.949	1.70	72	72	72.00		200
22	3	45	0.81	0.900	1.50	73	73	73.00		202
23	3	50	0.83	0.911	1.60	73	73	73.00		200
24	3	55	0.84	0.917	1.60	73	73	73.00		184
25	4	0	0.92	0.959	1.60	73	73	73.00	-0.7	200
26	4	5	0.90	0.949	1.60	73	73	73.00		200
27	4	10	0.85	0.922	1.50	74	74	74.00		202
28	4	15	0.85	0.922	1.50	74	74	74.00		200
29	4	20	0.81	0.900	1.40	74	74	74.00		201
30	4	25	0.80	0.894	1.40	74	74	74.00		198
31	4	30	0.88	0.938	1.60	74	74	74.00		186
32	4	35	0.91	0.954	1.60	74	74	74.00		184
33	4	40	0.92	0.959	1.60	74	74	74.00		194
34	4	45	0.78	0.883	1.40	75	75	75.00		187
35	4	50	0.74	0.860	1.30	75	75	75.00		196
36	4	55	0.75	0.866	1.30	75	75	75.00		190

RECEIVED
 FEB 09 2022
 AIR QUALITY DIVISION

2022 Compliance Source Test Report

United States Gypsum Company
No. 1 Calcining Kettle (EU-36)
Baghouse
Exhaust Stack

TEST DATA - EPA Method 5

Gravimetric Weights

	<u>Run 2</u>	<u>Run 3</u>	<u>Run 4</u>	<u>Average</u>
Total Particulate Weight in Sample (mg)	4.0	3.3	2.1	3.1

DETAILED RESULTS

Emission Results

	<u>Run 2</u>	<u>Run 3</u>	<u>Run 4</u>	<u>Average</u>
Filterable Particulate Matter Emission Rate (lb/hr)	0.099	0.080	0.052	0.077

Concentration Results

	<u>Run 2</u>	<u>Run 3</u>	<u>Run 4</u>	<u>Average</u>
Filterable Particulate Matter Concentration (grains/dscf)	0.0014	0.0012	0.0008	0.0011
Filterable Particulate Matter Concentration (g/dscm)	0.0033	0.0027	0.0018	0.0026

Sample Volume Conversions

	<u>Run 1</u>	<u>Run 2</u>	<u>Run 3</u>	<u>Average</u>
Volume of Dry Gas Sampled at Standard Conditions, dscm	1.225	1.210	1.155	1.197

MAQS

USEPA METHOD 2 GAS VELOCITY TRAVERSE AND VOLUMETRIC FLOWRATE DATA SHEET

Client US GYPSUM

Sampling Location KETLOW BRGTHOUSE

Run Number: PREFLOW

Date 11-20-21 Time 12:45

Port and Stack 27.5 in.

Port 3.5 in.

Nipple Protrusion 1.75 in.

Stack Diameter 24 in.

Bar. Pressure 30.13 in Hg


Static Pressure -.10 in H₂O

Moisture % ~2

% CO₂ 0 % CO 0

% O₂ 21 % N₂ 79

Stack Diagram



Operators DT/MW Manometer ID: M812

Pitot Tube number 51C Umbilical ID: UM35

Pitot Tube factor, Cp .84 Pitot Line ID: -

Site Elevation ~600 ft. Upstream ~60' in.

Port Height ~100 ft. Downstream ~40' in.

Leak Check- Positive: Pre: @ 4" Post: @ 5" Negative: Pre: @ 4" Post: @ 5"

% of Stack Diameter	Point Distance (in.)	Traverse Point Number	Velocity Head (ΔP) in H ₂ O	Stack Temp °F	Null Angle (zero ΔP angle)	Flow Angle Ø (90° from null angle)
		1	.81	185	+5	
		2	.83	190	+5	
		3	.85	194	-5	
		4	.85	195	-5	
		5	.80	194	-10	
		6	.80	192	-5	
		1	.81	181	+10	
		2	.85	187	+10	
		3	.89	191	+5	
		4	.83	195	-5	
		5	.79	197	-5	
		6	.74	194	0	

US EPA Method 1 Traverse Point Determination

Relative Port Location	Left	Right
From Far Wall to Outside of Port (in.)	27.5	27.5
Nipple Length or Wall Thickness (in.)	3.5	3.5
Port Protrusion Length (opt) (in.)	1.8	1.8
Depth of Stack or Duct (in.)	25.8	25.8
Stack or Duct Type	Circular	
Port Hole Inner Diameter (in.)	--	
Stack or Duct Width (If Rectangular) (in.)		
Stack Outer Circumference (in.)		
Number of Ports Traversed	2	
Elevation of Meter Box from Ground Level (ft)	600	
Elevation of Ports from Ground Level (ft)	700	
Stack Build-up (in.)	0.0	
Stack Cross-Sectional Diameter 1 (in)	25.8	
Stack Cross-Sectional Diameter 2 (in)	25.8	

"Vertical" or "Horizontal" Flow	Vertical
Direction of Flow	Up
"Velocity" or "Isokinetic" Traverse	Isokinetic

Port Distance Upstream from Flow Disturbance (in.)	720.0
Diameters Upstream from Flow Disturbance (³ 0.5 De)	28.0
Minimum Traverse Points Needed for a Velocity Traverse *	12
Minimum Traverse Points Needed for a Isokinetic Traverse *	12

Port Distance Downstream from Flow Disturbance (in.)	480.0
Diameters Downstream from Flow Disturbance (³ 2.0 De)	18.6
Minimum Traverse Points Needed for a Velocity Traverse *	12
Minimum Traverse Points Needed for a Isokinetic Traverse *	12

Minimum Traverse Points per Method 1	12
Number of Traverse Points for this Circular Stack or Duct	12
Point Override	

Duct Area - in² **520.77**
 Duct Area - ft² **3.6164**

Note:

Add nipple protrusion length to Point 1 only.
 Actual nipple length = (length - protrusion)

Relocate to a distance equal to the inside diameter of the nozzle being used or to the above minimum distances, whichever is larger.

This Stack having a diameter greater than 24-inches, shall have no traverse points located within 1.0-inch of the stack wall.

'Pt. Adj.' denotes that the traverse point has been adjusted to 1-inch from the stack wall.

New Method 1 verified on 12/20/2021 by: **DT/MN**

	Port	Point	% of Duct Depth	Dist. From Inside Wall (Decimal)	Dist. From Outside Wall (Decimal)
<i>Pt. Adj</i>	1	1	4.4	2.9	4.7
	1	2	14.6	3.8	5.5
	1	3	29.6	7.6	9.4
<i>Pt. Adj</i>	1	4	70.4	18.1	19.9
	1	5	85.4	22.0	23.7
	1	6	95.6	24.6	26.4
	2	1	4.4	2.9	4.7
	2	2	14.6	3.8	5.5
	2	3	29.6	7.6	9.4
	2	4	70.4	18.1	19.9
	2	5	85.4	22.0	23.7
	2	6	95.6	24.6	26.4

Method 3 Fyrite Field Data

Effective Date: 11/2/15
Rev No. 2
Issued by: Quality Manager

Plant Name: US GYPSUM

Test Location: WETLE MOUTHSE

CO₂ Zero: Y/N

O₂ Zero: Y/N

15 pumps to purge
18 pumps to sample

EPA Method 3 Fyrite Analysis Audit Analyzed by: ST 11-20-22

Time of Analysis	%CO ₂ Audit Gas Conc (%) <u>10.11</u>	%O ₂ Audit Gas Conc (%) <u>21.776</u>
<u>8:30</u>	<u>10</u>	<u>21</u>
<u>8:35</u>	<u>10</u>	<u>21</u>
<u>8:40</u>	<u>10</u>	<u>21</u>

Analyzer I.D. - A - FYR - 2 Audit Gas Cylinder I.D.: CC85775

***NOTE:** The average of the three passes of %CO₂ and %O₂ must agree within ± 0.5% of the audit gas concentration value.

Run Number: 1 VBIP Analyzed by: MN

Time of Sample Collection	Time of Analysis	%CO ₂ (A)	%O ₂ (B)	%N ₂ (100 - (A + B))
<u>GRAB</u>	<u>8:04</u>	<u>0</u>	<u>21</u>	<u>79</u>
	<u>8:17</u>	<u>0</u>	<u>21</u>	<u>79</u>
	<u>8:38</u>	<u>0</u>	<u>21</u>	<u>79</u>

Analyzer I.D. - A - FYR - 2 Tedlar Bag I.D.: - - M3/TB

Run Number: 2 Analyzed by: MN

Time of Sample Collection	Time of Analysis	%CO ₂ (A)	%O ₂ (B)	%N ₂ (100 - (A + B))
<u>GRAB</u>	<u>9:22</u>	<u>0</u>	<u>21</u>	<u>79</u>
	<u>9:42</u>	<u>0</u>	<u>21</u>	<u>79</u>
	<u>9:59</u>	<u>0</u>	<u>21</u>	<u>79</u>

Analyzer I.D. - A - FYR - 2 Tedlar Bag I.D.: - - M3/TB

Run Number: 3 Analyzed by: MN

Time of Sample Collection	Time of Analysis	%CO ₂ (A)	%O ₂ (B)	%N ₂ (100 - (A + B))
<u>GRAB</u>	<u>10:42</u>	<u>0</u>	<u>21</u>	<u>79</u>
	<u>11:03</u>	<u>0</u>	<u>21</u>	<u>79</u>
	<u>11:19</u>	<u>0</u>	<u>21</u>	<u>79</u>

Analyzer I.D. - A - FYR - 2 Tedlar Bag I.D.: - - M3/TB

Method 3 Fyrite Field Data

Effective Date: 11/2/15
Rev No. 2
Issued by: Quality Manager

Plant Name: US GYPSUM

Test Location: LITTLE MAHONIE

CO₂ Zero: Y / N

O₂ Zero: Y / N

15 pumps to purge
18 pumps to sample

EPA Method 3 Fyrite Analysis Audit			Analyzed by::	
Time of Analysis	%CO ₂ Audit Gas Conc (%)	%O ₂ Audit Gas Conc (%)	_____	

Analyzer I.D. - <u>A - FYR -</u>			Audit Gas Cylinder I.D.:	
*NOTE: The average of the three passes of %CO ₂ and %O ₂ must agree within ± 0.5% of the audit gas concentration value.				
Run Number: <u>4</u>			Analyzed by:: <u>MN</u>	
Time of Sample Collection	Time of Analysis	%CO ₂ (A)	%O ₂ (B)	%N ₂ (100 - (A + B))
<u>GRAB</u>	<u>12:02</u>	<u>0</u>	<u>21</u>	<u>79</u>
	<u>12:12</u>	<u>0</u>	<u>21</u>	<u>79</u>
	<u>12:22</u>	<u>0</u>	<u>21</u>	<u>79</u>
Analyzer I.D. - <u>A - FYR - 2</u>			Tedlar Bag I.D.: - - <u>M3/TB</u>	
Run Number:			Analyzed by::	
Time of Sample Collection	Time of Analysis	%CO ₂ (A)	%O ₂ (B)	%N ₂ (100 - (A + B))
Analyzer I.D. - <u>A - FYR -</u>			Tedlar Bag I.D.: - - <u>M3/TB</u>	
Run Number:			Analyzed by::	
Time of Sample Collection	Time of Analysis	%CO ₂ (A)	%O ₂ (B)	%N ₂ (100 - (A + B))
Analyzer I.D. - <u>A - FYR -</u>			Tedlar Bag I.D.: - - <u>M3/TB</u>	

US EPA Method 3 Dry Molecular Weight Calculation

Run 2

	%CO2	%O2	%N2	Molecular Weight	Mean Difference
	0.00	21.00	79.0	28.84	0.000
	0.00	21.00	79.0	28.84	0.000
	0.00	21.00	79.0	28.84	0.000
Average	0.00	21.00	79.00	28.84	

Run 3

	%CO2	%O2	%N2	Molecular Weight	Mean Difference
	0.00	21.00	79.0	28.84	0.000
	0.00	21.00	79.0	28.84	0.000
	0.00	21.00	79.0	28.84	0.000
Average	0.00	21.00	79.00	28.84	

Run 4

	%CO2	%O2	%N2	Molecular Weight	Mean Difference
	0.00	21.00	79.0	28.84	0.000
	0.00	21.00	79.0	28.84	0.000
	0.00	21.00	79.0	28.84	0.000
Average	0.00	21.00	79.00	28.84	

Project Information Date: <u>12-21-21</u> Project #: <u>PROJ-009677</u> Customer / Facility: <u>US Gypsum - River Rouge</u> Unit ID / Sample Location: <u>KETLE BATHHOUSE</u> Run #: <u>1,2,3</u> Operator: <u>DL</u>	Equipment Identification Ref. Thermometer: <u>CAL 127 2</u> Hygrometer: _____ Field Balance: <u>SCALE 6</u> Check Weights: <u>CAL 127 2</u> Calipers: <u>MN</u>
--	---

Balance Audit: (Field balance must be within 0.5g of check weight mass) Date: <u>12-20-21 12-21-21</u> <table border="1" style="width:100%"> <tr> <td>Standard mass, g</td> <td><u>500.0</u></td> <td><u>500.0</u></td> <td></td> <td></td> </tr> <tr> <td>Field balance mass, g</td> <td><u>500.0</u></td> <td><u>500.0</u></td> <td></td> <td></td> </tr> </table>	Standard mass, g	<u>500.0</u>	<u>500.0</u>			Field balance mass, g	<u>500.0</u>	<u>500.0</u>			Ambient Conditions (Mobile Lab) Relative humidity, %: _____ Temperature, °F: _____ Mobile lab #: _____
Standard mass, g	<u>500.0</u>	<u>500.0</u>									
Field balance mass, g	<u>500.0</u>	<u>500.0</u>									

Moisture Determination									
Contents	Run 1 VOID			Run 2			Run 3		
	Initial	Final	Net Gain	Initial	Final	Net Gain	Initial	Final	Net Gain
Knockout									
Impinger 1	<u>739.3</u>	<u>913.8</u>	<u>174.5</u>	<u>755.5</u>	<u>975.2</u>	<u>219.7</u>	<u>737.1</u>	<u>927.4</u>	<u>190.3</u>
Impinger 2	<u>756.0</u>	<u>863.5</u>	<u>107.5</u>	<u>760.5</u>	<u>845.0</u>	<u>76.5</u>	<u>760.0</u>	<u>892.6</u>	<u>130.6</u>
Impinger 3	<u>650.7</u>	<u>703.9</u>	<u>45.2</u>	<u>656.8</u>	<u>662.1</u>	<u>5.3</u>	<u>659.0</u>	<u>664.2</u>	<u>5.2</u>
Impinger 4			<u>327.2</u>			<u>301.5</u>			<u>326.1</u>
Impinger 5									
Impinger 6									
Impinger 7									
Impinger 8									
Silica Gel	<u>934.6</u>	<u>970.6</u>	<u>36</u>	<u>966.6</u>	<u>976.3</u>	<u>9.7</u>	<u>1007.5</u>	<u>1016.1</u>	<u>8.6</u>
Train Net Gain (Vlc)			<u>363.2</u>			<u>311.2</u>			<u>334.7</u>

Nozzle Measurements (Difference between any two measurements must not be more than 0.004 in (0.1 mm))

Nozzle 1 diameters .241 D1 .241 D2 .241 D3 .241 Average

Nozzle 2 diameters _____ D1 _____ D2 _____ D3 _____ Average

Nozzle 3 diameters _____ D1 _____ D2 _____ D3 _____ Average

Nozzle Material: quartz glass steel titanium inconel other _____

Probe Type: heated unheated air-cooled water-cooled other _____

Probe Liner: quartz glass steel Teflon other _____

Filter Information

Front Half: Quartz Fiber Glass Fiber Teflon Teflon/Quartz Other: _____

Filter Number: Run 1: H-828 Run 2: H-826 Run 3: H-825 Run _____: _____

Back Half: Quartz Fiber Glass Fiber Teflon Teflon/Quartz Other: _____

Reagent Information	Sample Observations
Type	Run 1 _____
Lot Number	Run 2 _____
	Run 3 _____

RECEIVED

FEB 09 2022

QA/QC Check: Completeness: Legibility: Accuracy: Specifications:

Checked by: DL Team Leader: DL

AIR QUALITY DIVISION
001AS-OPS-RBETA

Project Information Date: <u>12-21-21</u> Project #: <u>PROJ-009677</u> Customer / Facility: <u>US GYPSUM</u> Unit ID / Sample Location: <u>LETTLE BAGHOUSE</u> Run #: <u>4</u> Operator: <u>BT</u>	Equipment Identification Ref. Thermometer: <u>CAL 1272</u> Hygrometer: _____ Field Balance: <u>SCALE 6</u> Check Weights: <u>CAL 1272</u> Calipers: <u>MW</u>
--	---

Balance Audit: (Field balance must be within 0.5g of check weight mass) Date: <u>12-21-21</u> <table border="1" style="width:100%"> <tr> <td>Standard mass, g</td> <td><u>500.0</u></td> <td></td> <td></td> <td></td> </tr> <tr> <td>Field balance mass, g</td> <td><u>500.0</u></td> <td></td> <td></td> <td></td> </tr> </table>	Standard mass, g	<u>500.0</u>				Field balance mass, g	<u>500.0</u>				Ambient Conditions (Mobile Lab) Relative humidity, %: _____ Temperature, °F: _____ Mobile lab #: _____
Standard mass, g	<u>500.0</u>										
Field balance mass, g	<u>500.0</u>										

Contents	Run 1			Run 2			Run 3		
	Initial	Final	Net Gain	Initial	Final	Net Gain	Initial	Final	Net Gain
Knockout									
Impinger 1	<u>767.4</u>	<u>948.3</u>	<u>180.9</u>						
Impinger 2	<u>778.0</u>	<u>922.6</u>	<u>144.6</u>						
Impinger 3	<u>661.6</u>	<u>665.3</u>	<u>3.7</u>						
Impinger 4			<u>=329.2</u>						
Impinger 5									
Impinger 6									
Impinger 7									
Impinger 8									
Silica Gel	<u>476.1</u>	<u>984.2</u>	<u>8.1</u>						
Train Net Gain (Vlc)			<u>337.3</u>						

Nozzle Measurements (Difference between any two measurements must not be more than 0.004 in (0.1 mm))

Nozzle 1 diameters	<u>.241</u> D1	<u>.241</u> D2	<u>.241</u> D3	<u>.241</u> Average
Nozzle 2 diameters	_____ D1	_____ D2	_____ D3	_____ Average
Nozzle 3 diameters	_____ D1	_____ D2	_____ D3	_____ Average

Nozzle Material: quartz glass steel titanium inconel other _____
Probe Type: heated unheated air-cooled water-cooled other _____
Probe Liner: quartz glass steel Teflon other _____

Filter Information

Front Half: Quartz Fiber Glass Fiber Teflon Teflon/Quartz Other: _____
 Filter Number: Run 4: 1-829 Run 2: _____ Run 3: _____
 Back Half: Quartz Fiber Glass Fiber Teflon Teflon/Quartz Other: _____

Reagent Information	Sample Observations
Type	Lot Number
	Run 1 _____
	Run 2 _____
	Run 3 _____

QA/QC Check: Completeness: K Legibility: K Accuracy: K Specifications: K

Checked by: BT Team Leader: BT 001AS-OPS-RBETA

**US EPA Method 4 Gravimetric Determination for Moisture
 US EPA Method 5 Sampling Train**

		RUN 2		
		Initial (g)	Final (g)	Net (g)
Impinger No. 1		755.5	975.2	219.7
Impinger No. 2		768.5	845.0	76.5
Impinger No. 3		656.8	662.1	5.3
		Total Condensed (g):		301.5
Silica Gel		966.6	976.3	9.7
		Total Absorbed (g):		9.7
		Overall Total (g):		311.2

		RUN 3		
		Initial (g)	Final (g)	Net (g)
Impinger No. 1		737.1	927.4	190.3
Impinger No. 2		762.0	892.6	130.6
Impinger No. 3		659.0	664.2	5.2
		Total Condensed (g):		326.1
Silica Gel		1007.5	1016.1	8.6
		Total Absorbed (g):		8.6
		Overall Total (g):		334.7

		RUN 4		
		Initial (g)	Final (g)	Net (g)
Impinger No. 1		767.4	948.3	180.9
Impinger No. 2		778.0	922.6	144.6
Impinger No. 3		661.6	665.3	3.7
		Total Condensed (g):		329.2
Silica Gel		976.1	984.2	8.1
		Total Absorbed (g):		8.1
		Overall Total (g):		337.3

MM049AS-009677-RT-918

30 of 121

Project Information				Sampling Conditions				ALT 011 TC ID: Ambient °F Ref. °F					
Date <u>12-21-21</u> Project # <u>8203-009677</u>				Static Pressure, in. H ₂ O <u>-1.70</u> Ambient Temp, °F <u>28</u>				Stack <u>5' C 1</u> <u>28</u> <u>28</u>					
Customer/Facility <u>US Gypsum</u>				Barometric Pressure, in. Hg <u>30.09</u> Ref. Barometer ID <u>NONE</u>				Probe <u>5' C 2</u> <u>28</u> <u>28</u>					
Unit ID/Sample Location <u>KETTLE BAGHOUSE</u>				Wind Speed / Direction <u>NONE SE</u> Precipitation, Y / N, type <u>NO</u>				Filter Box <u>NB6</u> <u>28</u> <u>28</u>					
Run # <u>1</u> Operator <u>GT/AN</u>				Probe / Filter Temp Range, °F <u>240 ± 25°F</u>				Filter Exit <u>FE56</u> <u>28</u> <u>28</u>					
Sampling Equipment IDs		Calibration		Equipment Checks						Meter outlet <u>MW26</u> <u>28</u> <u>28</u>		Impinger Exit <u>FC8</u> <u>28</u> <u>28</u>	
Meterbox ID <u>NB 12</u>		Meterbox Y <u>994</u>		Pitot (+), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot (-), pass @ in. H ₂ O <input type="checkbox"/> @ 4"		Pitot visual inspection <input checked="" type="checkbox"/> pass		Nozzle visual inspection <input checked="" type="checkbox"/> pass		Ref. Thermometer ID <u>CAL 1422</u>	
Umbilical ID <u>WB5</u>		Meterbox ΔH@, in. H ₂ O <u>1.78</u>		Pitot coefficient, Cp <u>.84</u>		Meter, cfm @ in. Hg <u>300 @ 15"</u>		Intermediate leak check volume, ft ³ <u>1</u>		Continuity Check <input type="checkbox"/> Continuity w/ Proper Polarity		Notes:	
Nozzle ID <u>S-1-4</u>		Nozzle diameter, Dn, in. <u>.241</u>		Manometer zero and level <input checked="" type="checkbox"/> yes		K-Factor							
Pitot / Probe ID <u>5' C</u>													
Manometer ID <u>NB12</u>													
Sensitivity <u>10:1420</u>													

Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, Vm, ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F		Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F		Pump Vacuum, in. Hg
					Target	Actual			Box	Exit		Inlet	Outlet	
1	0	8:00	567.60	1.10	3.28	3.30	133	250		250	32	62	62	3.5
2	5		572.74	.90	2.68	2.70	146	250		249	34	62	62	3
3	10		577.48	.82	2.44	2.50	150	248		250	47	63	63	3
4	15		581.80	1.00	2.96	3.00	158	250		250	50	64	64	4
5	20		586.85	.93	2.75	2.80	159	250		250	52	65	65	3.5
6	25		591.63	.98	2.90	2.90	150	250		250	54	66	66	3.5
	30	8:30	596.42											
1	30	8:31	596.42	1.00	2.95	3.00	155	250		250	57	66	66	3.5
2	35		601.38	1.00	2.94	3.00	176	251		251	56	67	67	3.5
3	40		606.11	.95	2.78	2.80	180	250		250	65	67	67	3.5
4	45		610.73	.92	2.69	2.70	181	250		250	67	67	67	3
5	50		615.14	.87	2.53	2.60	183	250		250	66	68	68	3
6	55		619.26	.89	2.59	2.60	173	250		250	65	68	68	3
	60	9:01	622.78											
VOID														
Averages														

MMW049AS-009677-RT-918

31 of 121

Project Information				Sampling Conditions				ALT 011 TC ID: Ambient °F Ref. °F						
Date <u>12-21-21</u> Project # <u>PROJ-009677</u>		Customer/Facility <u>US Gypsum</u>		Static Pressure, in. H ₂ O <u>-0.70</u> Ambient Temp, °F <u>27</u>		Barometric Pressure, in. Hg <u>30.39</u> Ref. Barometer ID <u>NONA</u>		Stack						
Unit ID/Sample Location <u>CECILE RAIGHOUSE</u>		Run # <u>2</u> Operator <u>MLW</u>		Wind Speed / Direction <u>CALM</u> Precipitation, Y / N, type <u>NO</u>		Probe		Filter Box						
Probe / Filter Temp Range, °F <u>24.8 ± 0.5°F</u>		Sampling Equipment IDs		Calibration		Equipment Checks		Filter Exit						
Meterbox ID <u>M812</u>	Meterbox Y <u>.994</u>	Pitot (+), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot (-), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot visual inspection <input checked="" type="checkbox"/> pass		Meter outlet						
Umbilical ID <u>W85</u>	Meterbox ΔH@, in. H ₂ O <u>1.78</u>	Pitot (+), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot (-), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot visual inspection <input checked="" type="checkbox"/> pass		Impinger Exit						
Nozzle ID <u>S-1-4</u>	Nozzle diameter, Dn, in. <u>.251</u>	Pitot (+), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot (-), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot visual inspection <input checked="" type="checkbox"/> pass		Other						
Pitot / Probe ID <u>S1C</u>	Pitot coefficient, Cp <u>.84</u>	Pitot (+), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot (-), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot visual inspection <input checked="" type="checkbox"/> pass		Ref. Thermometer ID						
Manometer ID <u>M812</u>	Manometer zero and level <input checked="" type="checkbox"/> Yes	Pitot (+), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot (-), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot visual inspection <input checked="" type="checkbox"/> pass		Continuity Check <input type="checkbox"/> Continuity w/ Proper Polarity						
Sensitivity <u>10' H₂O</u>	K-Factor	Pitot (+), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot (-), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot visual inspection <input checked="" type="checkbox"/> pass		Notes:						
Intermediate leak check volume, ft ³ <u>0.00 @ 15'</u>		Pitot (+), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot (-), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pitot visual inspection <input checked="" type="checkbox"/> pass								
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, Vm, ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F		Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F		Pump Vacuum, in. Hg
					Target	Actual			Box	Exit		Inlet	Outlet	
1	0	9:20	633.00	.99	1.83	1.90	188	244		250	34	68	68	3.5
2	5		626.97	.94	1.73	1.80	190	250		251	32	68	68	3
3	10		630.66	.95	1.75	1.80	192	250		250	33	69	69	3
4	15		634.37	.85	1.56	1.60	191	250		250	34	69	69	3
5	20		637.90	.86	1.58	1.60	193	250		250	35	69	69	3
6	25		641.63	.86	1.58	1.60	191	250		250	36	70	70	3
	30	9:50	645.27											
1	30	9:52	645.27	.92	1.69	1.70	186	250		250	36	70	70	3.5
2	35		649.01	.96	1.77	1.80	193	250		249	36	70	70	3.5
3	40		652.77	.95	1.75	1.80	194	250		250	36	70	70	3.5
4	45		656.52	.87	1.60	1.60	195	250		250	37	70	70	3.5
5	50		660.20	.75	1.38	1.40	188	250		250	38	70	70	3.5
6	55		663.60	.82	1.51	1.60	166	250		250	38	71	71	3.5
	60	10:02	667.12											
Averages														

MMW049AS-009677-RT-918

32 of 121

Project Information				Sampling Conditions				ALT 011 TC ID:				Ambient °F		Ref. °F	
Date <u>12-21-21</u> Project # <u>PROJ-009677</u>				Static Pressure, in. H ₂ O <u>-2.70</u> Ambient Temp. °F <u>29</u>				Stack							
Customer/Facility <u>US GPSW</u>				Barometric Pressure, in. Hg <u>30.09</u> Ref. Barometer ID <u>NDA</u>				Probe							
Unit ID/Sample Location <u>LETTER RAGHOUSE</u>				Wind Speed / Direction <u>~2MPH ESE</u> Precipitation, Y / N, type <u>NO</u>				Filter Box							
Run # <u>3</u> Operator <u>DL/MW</u>				Probe / Filter Temp Range, °F <u>.248 ± 25°F</u>				Filter Exit							
Sampling Equipment IDs				Calibration				Equipment Checks							
Meterbox ID <u>M312</u>				Meterbox Y <u>994</u>				Pitot (+), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4" <input type="checkbox"/> @ <input checked="" type="checkbox"/> @ 4"				Meter outlet			
Umbilical ID <u>WMB5</u>				Meterbox ΔH@, in. H ₂ O <u>1.78</u>				Pitot (-), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4" <input type="checkbox"/> @ <input checked="" type="checkbox"/> @ 4"				Impinger Exit			
Nozzle ID <u>S-1-4</u>				Nozzle diameter, Dn, in. <u>.241</u>				Pitot visual inspection <input checked="" type="checkbox"/> pass <input type="checkbox"/> pass <input checked="" type="checkbox"/> pass				Other			
Pitot / Probe ID <u>S/C</u>				Pitot coefficient, Cp <u>.84</u>				Nozzle visual inspection <input checked="" type="checkbox"/> pass <input type="checkbox"/> pass <input checked="" type="checkbox"/> pass				Ref. Thermometer ID			
Manometer ID <u>M312</u>				Manometer zero and level <input checked="" type="checkbox"/> yes				Meter, cfm @ in. Hg <u>100 @ 15"</u> <input type="checkbox"/> @ <u>1000 @ 5"</u>				Continuity Check <input type="checkbox"/> Continuity w/ Proper Polarity			
Sensitivity <u>10" H₂O</u>				K-Factor				Intermediate leak check volume, ft ³ <u>/</u> <u>/</u>				Notes:			
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, Vm, ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F		Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F		Pump Vacuum, in. Hg	
					Target	Actual			Box	Exit		Inlet	Outlet		
1	0	10:40	667.546	.80	1.61	1.70	197	239		251	36	71	71	2	
2	5		671.07	.99	1.81	1.90	198	250		251	37	71	71	2.5	
3	10		674.97	.95	1.74	1.80	196	250		250	36	71	71	2.5	
4	15		678.74	.85	1.56	1.60	196	250		250	37	72	72	2.5	
5	20		682.36	.77	1.42	1.50	185	250		249	37	72	72	2	
6	25		685.80	.74	1.37	1.40	163	250		251	38	72	72	2	
	30	11:40	689.15												
1	30	11:11	689.15	.95	1.77	1.80	161	249		250	39	72	72	3	
2	35		693.01	.89	1.66	1.70	200	251		250	39	72	72	3	
3	40		696.75	.90	1.67	1.70	200	251		251	39	72	72	2.5	
4	45		700.43	.81	1.50	1.50	202	250		250	40	73	73	2.9	
5	50		704.02	.83	1.54	1.60	200	250		250	42	73	73	2.9	
6	55		707.61	.84	1.56	1.60	184	251		250	43	73	73	2.5	
	60	11:41	711.15												
Averages															

MW049AS-009677-RT-918

33 of 121


Project Information				Sampling Conditions				ALT 011						
Date <u>12-21-21</u>		Project # <u>PROJ-009677</u>		Static Pressure, in. H ₂ O <u>-0.70</u>		Ambient Temp, °F <u>201</u>		TC ID:		Ambient °F		Ref. °F		
Customer/Facility <u>US ETPSW1</u>				Barometric Pressure, in. Hg <u>30.09</u>		Ref. Barometer ID <u>NOAA</u>		Stack						
Unit ID/Sample Location <u>IC071E WAGTAUSE</u>				Wind Speed / Direction <u>4 mph SE</u>		Precipitation, Y / N, type <u>NO</u>		Probe						
Run # <u>4</u>		Operator <u>DL/MW</u>		Probe / Filter Temp Range, °F <u>248 ± 25 °F</u>				Filter Box						
Sampling Equipment IDs				Calibration				Equipment Checks						
Meterbox ID <u>M312</u>		Meterbox Y <u>.994</u>		Pitot (+), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		Pre		Mid		Post		Filter Exit		
Umbilical ID <u>W35</u>		Meterbox ΔH@, in. H ₂ O <u>1.78</u>		Pitot (-), pass @ in. H ₂ O <input checked="" type="checkbox"/> @ 4"		<input checked="" type="checkbox"/> @ 4"		<input type="checkbox"/> @		<input checked="" type="checkbox"/> @ 4"		Meter outlet		
Nozzle ID <u>S-1-4</u>		Nozzle diameter, Dn, in. <u>.241</u>		Pitot visual inspection <input checked="" type="checkbox"/> pass		<input checked="" type="checkbox"/> pass		<input type="checkbox"/> pass		<input checked="" type="checkbox"/> pass		Impinger Exit		
Pitot / Probe ID <u>51</u>		Pitot coefficient, Cp <u>.87</u>		Nozzle visual inspection <input checked="" type="checkbox"/> pass		<input checked="" type="checkbox"/> pass		<input type="checkbox"/> pass		<input checked="" type="checkbox"/> pass		Other		
Manometer ID <u>M312</u>		Manometer zero and level <input checked="" type="checkbox"/> yes		Meter, cfm @ in. Hg <u>.000 @ 15"</u>		<input checked="" type="checkbox"/> @		<input type="checkbox"/> @		<u>.000 @ 5"</u>		Ref. Thermometer ID		
Sensitivity <u>10" H₂O</u>		K-Factor		Intermediate leak check volume, ft ³ <u>/</u>		<u>/</u>		<u>/</u>		<u>/</u>		Continuity Check <input type="checkbox"/> Continuity w/ Proper Polarity		
Notes:														
Traverse Point #	Elapsed Time	Clock Time 24hr	DGM Reading, Vm, ft ³	Velocity Head, ΔP in H ₂ O	Orifice Pressure Differential, ΔH		Stack Temp, °F	Probe Temp, °F	Filter Temp, °F		Impinger Exit Temp, °F	Dry Gas Meter Temperature, °F		Pump Vacuum, in. Hg
					Target	Actual			Box	Exit		Inlet	Outlet	
1	0	12:00	711.352	.92	1.57	1.60	200	242		247	39	73	75	3
2	5		714.93	.90	1.54	1.60	200	250		251	37	73	73	3
3	10		718.47	.85	1.45	1.50	202	250		251	37	74	74	3
4	15		721.99	.85	1.45	1.50	200	250		251	38	74	74	3
5	20		725.49	.81	1.38	1.40	201	250		249	39	74	74	3
6	25		728.92	.80	1.37	1.40	198	250		249	39	74	74	3
	30	12:30	732.37											
1	30	12:31	732.37	.88	1.51	1.60	186	245		249	40	74	74	3
2	35		736.00	.91	1.57	1.60	184	250		250	38	74	74	3
3	40		739.65	.92	1.58	1.60	194	250		250	39	74	74	3
4	45		743.30	.78	1.34	1.40	187	250		250	39	75	75	3
5	50		746.75	.74	1.28	1.30	196	250		250	39	75	75	3
6	55		750.04	.75	1.29	1.30	190	251		250	40	75	75	3
	60	13:01	753.33											
Averages														

MONTROSE AIR QUALITY SERVICES, LLC

Method 9, Opacity Datasheet

Run No. 1 VOID Project No. 09677

Client	<u>US Gypsum</u>	Start Time	<u>8:00</u>
Address	<u>10040 W Jefferson</u>	Stop Time	<u>3:00</u>
Location	<u>R. Rouge MI</u>	Date	<u>12-21-21</u>



Process	Unit
Control Equipment	<u>Baghouse</u>

Describe Emission Point Spinny silver stack closest to door on roof

Height of Emission Point (ft)	Height Relative to Observer (ft)
Start <u>160</u> Stop <u>160</u>	Start <u>20</u> Stop <u>20</u>

Distance to Emission Point. (ft)	Direction to Emiss. Point. (Degrees)
Start <u>80</u> Stop <u>80</u>	Start <u>260</u> Stop <u>260</u>

Vertical Angle to Observation Pt.	Direction to Observation Point
Start <u>30</u> Stop <u>4</u>	Start <u>WSW</u> Stop <u>WSW</u>

Describe Emissions
Start Steam, none Stop 4

Emission Color	Water Plume
Start <u>---</u> Stop <u>---</u>	Attached <input type="checkbox"/> Detached <input checked="" type="checkbox"/> None <input type="checkbox"/>

Point in plume at which observations were made:
After steam plume

Describe Plume Background
Start sky Stop sky

Background Color	Sky Conditions
Start <u>Blue</u> Stop <u>Blue</u>	Start <u>Clear</u> Stop <u>Clear</u>

Wind Speed (mph)	Wind Direction
Start <u>1</u> Stop <u>1</u>	Start <u>SSE</u> Stop <u>S</u>

Ambient Temperature (°F)	Wet Bulb	RH Percent
Start <u>24</u> Stop <u>26</u>	<u>---</u>	<u>88</u>

Observers Name David Johnson
Observers Signature [Signature]

Certified By W. H. Green Date of Certification 9-29-21

Additional Comments:

Sec	0	15	30	45	0	15	30	45
Min					30			
0	0	0	0	0	0	0	0	0
1	0	0	0	0	31	0	0	0
2	0	0	0	0	32	0	0	0
3	0	0	0	0	33	0	0	0
4	0	0	0	0	34	0	0	0
5	0	0	0	0	35	0	0	0
6	0	0	0	0	36	0	0	0
7	0	0	0	0	37	0	0	0
8	0	0	0	0	38	0	0	0
9	0	0	0	0	39	0	0	0
10	0	0	0	0	40	0	0	0
11	0	0	0	0	41	0	0	0
12	0	0	0	0	42	0	0	0
13	0	0	0	0	43	0	0	0
14	0	0	0	0	44	0	0	0
15	0	0	0	0	45	0	0	0
16	0	0	0	0	46	0	0	0
17	0	0	0	0	47	0	0	0
18	0	0	0	0	48	0	0	0
19	0	0	0	0	49	0	0	0
20	0	0	0	0	50	0	0	0
21	0	0	0	0	51	0	0	0
22	0	0	0	0	52	0	0	0
23	0	0	0	0	53	0	0	0
24	0	0	0	0	54	0	0	0
25	0	0	0	0	55	0	0	0
26	0	0	0	0	56	0	0	0
27	0	0	0	0	57	0	0	0
28	0	0	0	0	58	0	0	0
29	0	0	0	0	59	0	0	0

MONTROSE AIR QUALITY SERVICES, LLC

Method 9, Opacity Datasheet

Run No. 2

Project No. Proj-0091667

Client	<u>US Gypsum</u>	Start Time	<u>9:20</u>
Address	<u>6090 W Taffan</u>	Stop Time	<u>10:20</u>
Location	<u>R. Rouge MI</u>	Date	<u>12-21-21</u>

Sketch of Location

North Arrow

Emission Point

Sun Shadow Line

Process _____ Unit _____

Control Equipment Baghouse

Describe Emission Point Sk. any silver stack closest to door, on roof

Height of Emission Point (ft)	Height Relative to Observer (ft)
Start <u>160</u> Stop <u>160</u>	Start <u>20</u> Stop <u>20</u>

Distance to Emission Point. (ft)	Direction to Emiss. Point. (Degrees)
Start <u>80</u> Stop <u>"</u>	Start <u>260</u> Stop <u>260</u>

Vertical Angle to Observation Pt.	Direction to Observation Point.
Start <u>30</u> Stop <u>"</u>	Start <u>WSW</u> Stop <u>M</u>

Describe Emissions

Start none, steam Stop "

Emission Color	Water Plume
Start <u>-</u> Stop <u>-</u>	Attached <input checked="" type="checkbox"/> Detached <input type="checkbox"/> None <input type="checkbox"/>

Point in plume at which observations were made:

After steam plume

Describe Plume Background

Start sky Stop sky

Background Color	Sky Conditions
Start <u>blue</u> Stop <u>grey</u>	Start <u>clear</u> Stop <u>cloud</u>

Wind Speed (mph)	Wind Direction
Start <u>1</u> Stop <u>4</u>	Start <u>S</u> Stop <u>SE</u>

Ambient Temperature (°F)	Wet Bulb	RH Percent
Start <u>27</u> Stop <u>34</u>	<u>-</u>	<u>90</u>

Observers Name David Koppen

Observers Signature [Signature]

Certified By Whitlow Green Date of Certification 9-24-21

Additional Comments:

Sec	0	15	30	45	0	15	30	45
Min					30			
0	0	0	0	0	0	0	0	0
1	0	0	0	0	31	0	0	0
2	0	0	0	0	32	0	0	0
3	0	0	0	0	33	0	0	0
4	0	0	0	0	34	0	0	0
5	0	0	0	0	35	0	0	0
6	0	0	0	0	36	0	0	0
7	0	0	0	0	37	0	0	0
8	0	0	0	0	38	0	0	0
9	0	0	0	0	39	0	0	0
10	0	0	0	0	40	0	0	0
11	0	0	0	0	41	0	0	0
12	0	0	0	0	42	0	0	0
13	0	0	0	0	43	0	0	0
14	0	0	0	0	44	0	0	0
15	0	0	0	0	45	0	0	0
16	0	0	0	0	46	0	0	0
17	0	0	0	0	47	0	0	0
18	0	0	0	0	48	0	0	0
19	0	0	0	0	49	0	0	0
20	0	0	0	0	50	0	0	0
21	0	0	0	0	51	0	0	0
22	0	0	0	0	52	0	0	0
23	0	0	0	0	53	0	0	0
24	0	0	0	0	54	0	0	0
25	0	0	0	0	55	0	0	0
26	0	0	0	0	56	0	0	0
27	0	0	0	0	57	0	0	0
28	0	0	0	0	58	0	0	0
29	0	0	0	0	59	0	0	0


MONTROSE AIR QUALITY SERVICES, LLC

Method 9, Opacity Datasheet

Run No. 3

Project No. PCOJ-009667

Client	<u>CS Gypsum</u>	Start Time	<u>10:40</u>
Address	<u>10090 W Jefferson</u>	Stop Time	<u>11:40</u>
Location	<u>R. Dwyer, MI</u>	Date	<u>12-21-21</u>



Process	Unit
Control Equipment	<u>Baghouse</u>

Describe Emission Point 22 in. river stack closest to door, on roof

Height of Emission Point (ft)	Height Relative to Observer (ft)
Start <u>160</u> Stop <u>160</u>	Start <u>20</u> Stop <u>20</u>

Distance to Emission Point. (ft)	Direction to Emiss. Point. (Degrees)
Start <u>80</u> Stop <u>"</u>	Start <u>260</u> Stop <u>"</u>

Vertical Angle to Observation Pt.	Direction to Observation Point.
Start <u>30</u> Stop <u>"</u>	Start <u>WSW</u> Stop <u>W</u>

Describe Emissions

Start steam, none Stop "

Emission Color	Water Plume
Start <u>-</u> Stop <u>-</u>	Attached <input type="checkbox"/> Detached <input checked="" type="checkbox"/> None <input type="checkbox"/>

Point in plume at which observations were made:

After steam

Describe Plume Background

Start sky Stop sky

Background Color	Sky Conditions
Start <u>Grey</u> Stop <u>"</u>	Start <u>cloudy</u> Stop <u>"</u>

Wind Speed (mph)	Wind Direction
Start <u>4</u> Stop <u>6</u>	Start <u>SE</u> Stop <u>SSE</u>

Ambient Temperature (°F)	Wet Bulb	RH Percent
Start <u>34</u> Stop <u>35</u>	<u>-</u>	<u>81</u>

Observers Name David Kipponen

Observers Signature [Signature]

Certified By Walter Green Date of Certification 9-29-21

Additional Comments:

Sec	0	15	30	45	0	15	30	45
Min	0	0	0	0	30	0	0	0
0	0	0	0	0	30	0	0	0
1	0	0	0	0	31	0	0	0
2	0	0	0	0	32	0	0	0
3	0	0	0	0	33	0	0	0
4	0	0	0	0	34	0	0	0
5	0	0	0	0	35	0	0	0
6	0	0	0	0	36	0	0	0
7	0	0	0	0	37	0	0	0
8	0	0	0	0	38	0	0	0
9	0	0	0	0	39	0	0	0
10	0	0	0	0	40	0	0	0
11	0	0	0	0	41	0	0	0
12	0	0	0	0	42	0	0	0
13	0	0	0	0	43	0	0	0
14	0	0	0	0	44	0	0	0
15	0	0	0	0	45	0	0	0
16	0	0	0	0	46	0	0	0
17	0	0	0	0	47	0	0	0
18	0	0	0	0	48	0	0	0
19	0	0	0	0	49	0	0	0
20	0	0	0	0	50	0	0	0
21	0	0	0	0	51	0	0	0
22	0	0	0	0	52	0	0	0
23	0	0	0	0	53	0	0	0
24	0	0	0	0	54	0	0	0
25	0	0	0	0	55	0	0	0
26	0	0	0	0	56	0	0	0
27	0	0	0	0	57	0	0	0
28	0	0	0	0	58	0	0	0
29	0	0	0	0	59	0	0	0

RECEIVED
FEB 09 2022


MONTROSE AIR QUALITY SERVICES, LLC

Method 9, Opacity Datasheet

Run No. 41

Project No. 019677

Client	CIS Gypsum	Start Time	12:00
Address	1090 W Jefferson	Stop Time	13:00
Location	L-Rouge, M	Date	12-21-21



Process	Unit
Control Equipment	Baghouse

Describe Emission Point shiny silver stack closest to door, an roof

Height of Emission Point (ft)	Height Relative to Observer (ft)
Start <u>160</u> Stop <u>160</u>	Start <u>20</u> Stop <u>20</u>

Distance to Emission Point (ft)	Direction to Emiss. Point. (Degrees)
Start <u>80</u> Stop <u>80</u>	Start <u>260</u> Stop <u>260</u>

Vertical Angle to Observation Pt.	Direction to Observation Point.
Start <u>30</u> Stop <u>30</u>	Start <u>WSW</u> Stop <u>WSW</u>

Describe Emissions
Start Steam, none Stop ✓

Emission Color	Water Plume
Start <u>—</u> Stop <u>—</u>	Attached <input type="checkbox"/> Detached <input checked="" type="checkbox"/> None <input type="checkbox"/>

Point in plume at which observations were made:
After steam plume

Describe Plume Background
Start sky Stop sky

Background Color	Sky Conditions
Start <u>Grey</u> Stop <u>Grey</u>	Start <u>cloud</u> Stop <u>cloud</u>

Wind Speed (mph)	Wind Direction
Start <u>6</u> Stop <u>10</u>	Start <u>SSE</u> Stop <u>S</u>

Ambient Temperature (°F)	Wet Bulb	RH Percent
Start <u>35</u> Stop <u>37</u>	—	<u>78</u>

Observers Name David Kuperan
Observers Signature [Signature]

Certified By William Green Date of Certification 9-21-21

Additional Comments:

Sec	0	15	30	45		0	15	30	45
Min	0	0	0	0	30	0	0	0	0
0	0	0	0	0	30	0	0	0	0
1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0

THIS PAGE LEFT INTENTIONALLY BLANK.

Appendix A.3 Example Calculations

**EPA Methods 1, 2, 3, 4, and 5 Nomenclature and
Sample Calculations**

Run No. - 1

Constants

CO ₂ F _{wt} = 44.0	in wg= 0.073529	NO ₂ F _{wt} = 46.01	HClF _{wt} = 36.46
O ₂ F _{wt} = 32.0	gr= 0.000142857	COF _{wt} = 28.01	SO ₂ F _{wt} = 64.06
CON ₂ F _{wt} = 28.0	mmBtu= 1000000 Btu	H ₂ SO ₄ F _{wt} = 98.08	Cl ₂ F _{wt} = 70.91
H ₂ O F _{wt} = 18.015	CF _{wt} = 12.011	T _{std} = 527.67	P _{std} = 29.92
ArF _{wt} = 40.0	PF _{wt} = 44.0962		

Stack Variables

C _p = 0.84	pitot tube coefficient (dimensionless)
P _{bar} = 30.09 in. Hg	barometric pressure
E _{box} = 600 ft	elevation difference between ground level and meter box
E _{sam} = 700 ft	elevation difference between ground level and sampling ports
γ = 0.9940	gamma, dry gas meter calibration factor (dimensionless)
θ = 60.0 min	net run time (minutes)
V _{lc} = 311.2 g	total mass of liquid collected in Impingers (g)
%CO ₂ = 0.00 %	percent CO ₂ by volume (dry basis) (dimensionless)
%O ₂ = 21.00 %	percent O ₂ by volume (dry basis) (dimensionless)
%N ₂ = 79.00 %	percent N ₂ by volume (dry basis) (dimensionless)
A = 3.6305 ft ²	stack cross-sectional area
P _g = -0.70 in. H ₂ O	flue gas static pressure
T _{savg} = 648.92 R	average absolute flue gas temperature (460R+tsavg °F)
SQΔP _{avg} = 0.94 in. wg	average square root ΔP
ΔH = 1.68 in. wg	average pressure differential of orifice meter
T _m = 529.50 R	dry gas meter temperature (460R+tsavg °F)
V _m = 44.12 ft ³	volume of metered gas sample (dry actual cubic feet)
D _n = 0.241 in.	sampling nozzle diameter

Calculated Stack Variables**Barometric pressure at sampling location**

NOTE: Barometric pressure recorded at ground level

$$P_{sam} = P_{bar} - [(E_{sam} / 100 \text{ ft}) * 0.1 \text{ in. Hg}]$$

$$P_{sam} = 30.09 - ((700.0 / 100) * 0.1)$$

$$P_{sam} = 29.39 \text{ in. Hg}$$

Volume of dry gas sampled at standard conditions (dscf)

$$V_{mstd} = \gamma * V_m * [P_{bar} - ((E_{box} / 100 \text{ ft}) * 0.1 \text{ in. Hg}) + (\Delta H / 13.6)] / P_{std} * (T_{std} / T_m)$$

$$V_{mstd} = 0.9940 * 44.120 * ((30.09 - ((600.0 / 100) * 0.1) + (1.6833 / 13.6)) / 29.92) * (527.7 / 529.500)$$

$$V_{mstd} = 43.256 \text{ ft}^3$$

Volume of water vapor at standard conditions (68 °F, scf)

$$V_{wstd} = (0.04716 \text{ ft}^3/\text{g}) * V_{lc}$$

$$V_{wstd} = (0.04716 * 311.2)$$

$$V_{wstd} = 14.7 \text{ ft}^3$$

Percent moisture by volume as measured in flue gas

$$\%H_2O \text{ (Measured)} = 100 * [V_{\text{wetd}} / (V_{\text{wetd}} + V_{\text{mstd}})]$$

$$\%H_2O \text{ (Measured)} = 100 * (14.676 / (14.676 + 43.256))$$

$$\%H_2O \text{ (Measured)} = 25.33$$

$$\%H_2O \text{ (Saturated)} = (100 / P_{\text{sam}}) * 10^{\wedge} (6.6911 - (3144 / (T_{\text{avg}} + 390.86 - 460)))$$

$$\%H_2O \text{ (Saturated)} = (100 / 29.338529) * 10^{\wedge} (6.6911 - (3144 / (648.916667 + 390.86 - 460)))$$

$$\%H_2O \text{ (Saturated)} = 63.24$$

$$\%H_2O = 25.33$$

Absolute flue gas pressure

$$P_s = P_{\text{sam}} + (P_g / 13.6)$$

$$P_s = 29.39 + (-0.70 / 13.6)$$

$$P_s = 29.34 \text{ in. Hg}$$

Dry mole fraction of flue gas (dimensionless)

$$M_{\text{fd}} = 1 - (\%H_2O / 100)$$

$$M_{\text{fd}} = 1 - (25.33 / 100)$$

$$M_{\text{fd}} = 0.747$$

Dry molecular weight of flue gas (lb/lb-mole)

$$M_d = [(\%CO_2 / 100) * 44.0] + [(\%O_2 / 100) * 32.0] + [((100 - \%CO_2 - \%O_2) / 100) * 28.0]$$

$$M_d = ((0.00 / 100) * 44.0) + ((21.00 / 100) * 32.0) + (((100 - 0.00 - 21.00) / 100) * 28.0)$$

$$M_d = 28.84 \text{ lb/lb-mole}$$

$$M_d = 28.84$$

Wet molecular weight of flue gas (lb/lb-mole)

$$M_w = M_d * M_{\text{fd}} + (H_2O_{\text{wt}} * (\%H_2O / 100))$$

$$M_w = 28.840 * 0.747 + 18.02 * (25.33 / 100)$$

$$M_w = 26.10 \text{ lb/lb-mole}$$

Average flue gas velocity (ft/sec)

$$v_s = 85.49 * C_p * (SQ\Delta P_{\text{avg}})^{\wedge} (T_{\text{avg}} / (P_s * M_w))^{\wedge} 0.5$$

$$v_s = 85.49 * 0.84 * (0.9445)^{\wedge} (648.92 / (29.339 * 26.098))^{\wedge} 0.5$$

$$v_s = 62.44 \text{ ft/sec}$$

Wet volumetric flue gas flow rate at actual conditions (acfm)

$$Q_{\text{aw}} = v_s * A * 60 \text{ sec/min}$$

$$Q_{\text{aw}} = 62.440 * 3.631 * 60$$

$$Q_{\text{aw}} = 13,601 \text{ ft}^3/\text{min}$$

Wet volumetric flue gas flow rate at standard conditions (scfm)

$$Q_{sdw} = v_s * A * (T_{std} / T_{savg}) * (P_s / P_{std}) * 60 \text{ sec/min}$$

$$Q_{sdw} = 62.440 * 3.631 * (527.7 / 648.917) * (29.339 / 29.92) * 60$$

$$Q_{sdw} = 10,845 \text{ ft}^3/\text{min}$$

Dry volumetric flue gas flow rate at standard conditions (dscfm)

$$Q_{sd} = M_{fd} * v_s * A * (T_{std} / T_{savg}) * (P_s / P_{std}) * 60 \text{ sec/min}$$

$$Q_{sd} = 0.747 * 62.4402 * 3.6305 * (527.7 / 648.917) * (29.339 / 29.92) * 60$$

$$Q_{sd} = 8,098 \text{ ft}^3/\text{min}$$

Percent Excess Air

$$\%EA = [\%O_2 - (0.5) * \%CO] / [0.264 * (100 - \%CO_2 - \%O_2) - (\%O_2 - 0.5 * \%CO)]$$

$$\%EA = ((21.00 - (0.5) * 0.00) / (0.264 * (100 - 0.00 - 21.00) - (21.00 - 0.5 * 0.00))) * 100$$

$$\%EA = -14583.33 \%$$

Isokinetic Calculations**Percent isokinetic of sampling rate (%)**

$$\%I = (P_{std} / T_{std}) * (T_{savg} / P_s) * [V_{mstd} / (v_s * M_{fd} * \theta) * (\pi * (D_n / 2)^2 / 144)] * (100 / 60)$$

$$\%I = (29.92 / 527.7) * (648.917 / 29.339) * (43.256 / (62.4402 * 0.747 * 60.0 * 3.141593 * (0.241 / 2)^2 / 144)) * (100 / 60)$$

$$\%I = 102.0 \%$$

Method 5 Calculations**Filterable PM total catch weight (mg)**

$$mg_{quan} = 4.0 \text{ mg}$$

Filterable PM concentration (grains/dscf)

$$C_{grcm} = 0.0154322 * mg_{quan} / V_{mstd}$$

$$C_{grcm} = 0.0154322 * 4.00 / 43.256$$

$$C_{grcm} = 0.0014 \text{ gr/ft}^3$$

Filterable PM concentration (g/dscm)

$$C_{gdscm} = (mg_{quan} / 1000) / (V_{mstd} * 0.02832)$$

$$C_{gdscm} = (4.0 / 1000) / (43.256 / 0.02832)$$

$$C_{gdscm} = 0.0033 \text{ g/dscm}$$

Filterable PM mass emission rate (lb/hr)

$$EMR_{lbhr} = (mg_{quan} / V_{mstd}) * Q_{sd} * (60 / 453592)$$

$$EMR_{lbhr} = 4.00 / 43.256 * 8,097.6 * (60 / 453592)$$

$$EMR_{lbhr} = 0.099 \text{ lb/hr}$$

THIS PAGE LEFT INTENTIONALLY BLANK.