CEMSOURCE

NOV 02 2022

AIR QUALITY DIVISION

One Source for Continuous Emission Measurement Systems | Training | Audits | Service

Third Quarter 2022

Annual RATA Report

Test Dates: September 20th & 21st, 2022

Tilden Mining Company LC 1 Tilden Mine Road Ishpeming, MI 49849

Emission Units: Tilden 1 North Tilden 1 South Air Emission Permit No: 148-12A

Contact: Ryan Korpela VP/GM of Tilden Mining Company LC Ph: 906-475-3400 E-Mail: <u>Ryan.Korpela@clevelandcliffs.com</u>

> Prepared By: CEMSOURCE, Inc. 18178 Minnetonka Blvd. Suite 18 Wayzata, MN 55391 sales@cemsource.com

& Network Environmental, Inc. 2629 Remico S.W. Suite B Grand Rapids, MI 49509

1885-fest_ 20220920

INDEX

Tilden 1 North RATA Results	Section 1
Tilden 1 South RATA Results	Section 2
Process Data	Appendix A
Network Environmental's complete RATA report	Appendix B

Section 1

Tilden 1 North RATA Results **Relative Accuracy Test Audit Report For:**

Tilden Mining Company LC 1 Tilden Mine Road Ishpeming, MI 49849

Tilden 1 North

Teledyne Monitor Labs T200H/O2 NO_x/O₂ Monitor Serial Number: 149

Teledyne Monitor Labs T100H SO₂ Monitor Serial Number: 147

Teledyne Monitor Labs UF150 Flow Monitor Serial Number: 1501325 On 09/20/2022 the Relative Accuracy Test Audit (RATA) was conducted on the Tilden 1 North stack at the Tilden Mining Company in Ishpeming, MI. All the analyzers in the system are installed on the Tilden 1 North stack.

The test was performed in accordance with the procedures in the Federal Register 40 CFR 60, Appendix B, Performance Specifications 2, 3 and 6.

Relative Accuracy Test Audit:

Result:

After calculating all differences, the Relative Accuracy was within the performance requirements for SO₂, NO_x, flow, and moisture.

A complete copy of Network Environmental's RATA report appears in Appendix B.

10/18/2022 Page 1

Facility Name:	Tilden Mine	Test Date/Number:	09/20/2022, Test 1
Unit/Stack:	TlN	Reason for Test:	Periodic Quality Assurance
Parameter:	S02	Primary Spec:	20 % of Reference Mean
Units:	LbPerHr	Alternate Spec:	10 % of LbPerHr
Relative Accuracy:	3.3 %	Std Deviation:	1.3
Performance Spec:	20 % of Reference Mean (Primary Spec)	Conf Coeff:	1.0
Test Result:	Pass	T Value:	2.306

Run	Start Date/Time	Duration	Use Run	Load	CEM Value	Reference Value	Difference	
1	09/20/22 11:27	25	-		37.8	32.0	-5.8	
2	09/20/22 14:20	25	Yes		31.2	28.4	-2.8	
3	09/20/22 15:06	25	Yes		31.7	31.4	-0.3	
4	09/20/22 15:50	25	Yes		33.0	32.8	-0.2	
5	09/20/22 16:33	25	Yes		33.1	32.2	-0.9	
6	09/20/22 17:25	25	Yes		33.2	32.9	-0.3	
7	09/20/22 18:08	25	Yes		32.1	32.5	0.4	
8	09/20/22 18:57	25	Yes		32.1	33.0	0.9	
9	09/20/22 19:45	25	Yes		33.5	34.8	1.3	
10	09/20/22 20:35	25	Yes		32.0	33.3	1.3	

Mean Values 32.4 32.4

-0.1

10/18/2022 Page 1

Facility Name:	Tilden Mine	Test Date/Number:	09/20/2022, Test 1
Unit/Stack:	TlN	Reason for Test:	Periodic Quality Assurance
Parameter:	NOx	Primary Spec:	20 % of Reference Mean
Units:	LbPerHr	Alternate Spec:	10 % of LbPerHr
Relative Accuracy.	2.8.%	Std Deviation.	4 3
Refutive needidey.	2.0	bed beviation.	1.5
Performance Spec:	20 % of Reference Mean (Primary Spec)	Conf Coeff:	3.3
Test Result:	Pass	T Value:	2.306

					CEM	Reference		
Run	Start Date/Time	Duration	Use Run	Load	Value	Value	Difference	
1	09/20/22 11:27	25	-		234.2	199.0	-35.2	
2	09/20/22 14:20	25	Yes		199.2	209.6	10.4	
3	09/20/22 15:06	25	Yes		191.6	191.5	-0.1	
4	09/20/22 15:50	25	Yes		196.6	193.9	-2.7	
5	09/20/22 16:33	25	Yes		197.1	194.0	-3.1	
6	09/20/22 17:25	25	Yes		196.3	195.6	-0.7	
7	09/20/22 18:08	25	Yes		187.8	189.8	2.0	
8	09/20/22 18:57	25	Yes		174.6	179.0	4.4	
9	09/20/22 19:45	25	Yes		183.2	188.2	5.0	
10	09/20/22 20:35	25	Yes		184.7	187.7	3.0	

Mean Values

190.1 192.1 2.0

.0

10/18/2022 Page 1

Facility Name:	Tilden Mine	Test Date/Number:	09/20/2022, Test 1
Unit/Stack:	TlN	Reason for Test:	Periodic Quality Assurance
Parameter:	StackFlow	Primary Spec:	20 % of Reference Mean
Units:	Kscfh	Alternate Spec:	10 % of Kscfh
Relative Accuracy:	1.9 %	Std Deviation:	210.4
Performance Spec:	20 % of Reference Mean (Primary Spec)	Conf Coeff:	161.7
Test Result:	Pass	T Value:	2.306

15681.3

Run	Start Date/Time	Duration	Use Run	Load	CEM Value	Reference Value	Difference
1	09/20/22 11:27	25	-		18790.0	15719.0	-3071.0
2	09/20/22 14:20	25	Yes		15771.6	15831.0	59.4
3	09/20/22 15:06	25	Yes		15668.9	15691.0	22.1
4	09/20/22 15:50	25	Yes		15846.1	15728.0	-118.1
5	09/20/22 16:33	25	Yes		15686.5	15507.0	-179.5
6	09/20/22 17:25	25	Yes		15721.2	15805.0	83.8
7	09/20/22 18:08	25	Yes		15750.3	16053.0	302.7
8	09/20/22 18:57	25	Yes		15640.9	16052.0	411.1
9	09/20/22 19:45	25	Yes		15472.8	15848.0	375.2
10	09/20/22 20:35	25	Yes		15573.4	15798.0	224.6

Mean Values

ues

15812.6 13

131.3

10/18/2022 Page 1

Facility Name: Tilde	en Mine	Test Date/Number:	09/20/2022, Test 1
Unit/Stack: T1N		Reason for Test:	Periodic Quality Assurance
Parameter: Moist	ture	Primary Spec:	20 % of Reference Mean
Units: Pct		Alternate Spec:	10 % of Pct
Relative Accuracy: 4.6 %	8	Std Deviation:	0.3
Performance Spec: 20 %	of Reference Mean (Primary Spec)	Conf Coeff:	0.2
Test Result: Pass		T Value:	2.306

					CEM	Reference		
Run	Start Date/Time	Duration	Use Run	Load	Value	Value	Difference	
1	09/20/22 11:27	25	-		8.5	8.0	-0.5	
2	09/20/22 14:20	25	Yes		8.9	8.8	-0.1	
3	09/20/22 15:06	25	Yes		8.2	8.8	0.6	
4	09/20/22 15:50	25	Yes		8.1	8.6	0.5	
5	09/20/22 16:33	25	Yes		8.4	8.8	0.4	
6	09/20/22 17:25	25	Yes		8.6	8.6	0.0	
7	09/20/22 18:08	25	Yes		8.8	8.7	-0.1	
8	09/20/22 18:57	25	Yes		8.7	8.9	0.2	
9	09/20/22 19:45	25	Yes		8.6	8.6	0.0	
10	09/20/22 20:35	25	Yes		8.4	8.7	0.3	

Mean Values

8.5 8.7 0.2

Section 2

Tilden 1 South

RATA Results

Relative Accuracy Test Audit Report For:

Tilden Mining Company LC 1 Tilden Mine Road Ishpeming, MI 49849

Tilden 1 South

Teledyne Monitor Labs T200H/O2 NO_x/O₂ Monitor Serial Number: 148

Teledyne Monitor Labs T100H SO₂ Monitor Serial Number: 146

Teledyne Monitor Labs UF150 Flow Monitor Serial Number: 1501324 On 09/21/2022 the Relative Accuracy Test Audit (RATA) was conducted on the Tilden 1 South stack at the Tilden Mining Company in Ishpeming, MI. All the analyzers in the system are installed on the Tilden 1 South stack.

The tests were performed in accordance with the procedures in the Federal Register 40 CFR 60, Appendix B, Performance Specifications 2, 3 and 6.

Relative Accuracy Test Audit:

Result:

After calculating all differences, the Relative Accuracy was within the performance requirements for SO₂, NO_x, flow, and moisture.

A complete copy of Network Environmental's RATA report appears in Appendix B.

10/18/2022 Page 1

Facility Name:	Tilden Mine	Test Date/Number:	09/21/2022, Test 1
Unit/Stack:	TIS	Reason for Test:	Periodic Quality Assurance
Parameter:	S02	Primary Spec:	20 % of Reference Mean
Units:	LbPerHr	Alternate Spec:	10 % of 1165.14 LbPerHr
Relative Accuracy:	17.4 %	Std Deviation:	4.3
Performance Spec:	20 % of Reference Mean (Primary Spec)	Conf Coeff:	3.3
Test Result:	Pass	T Value:	2.306

54.5

Run	Start Date/Time	Duration	Use Run	Load	CEM Value	Reference Value	Difference	
1	09/21/22 12:37	25	Yes		59.8	64.7	4.9	
2	09/21/22 13:42	25	Yes		57.5	61.3	3.8	
3	09/21/22 14:29	25	Yes		64.3	65.9	1.6	
4	09/21/22 15:23	25	Yes		54.9	61.1	6.2	
5	09/21/22 16:09	25	Yes		59.9	70.7	10.8	
6	09/21/22 16:56	25	Yes		53.1	58.3	5.2	
7	09/21/22 17:42	25	Yes		47.9	62.8	14.9	
8	09/21/22 18:28	25	Yes		48.1	56.4	8.3	
9	09/21/22 19:18	25	Yes		45.0	56.8	11.8	

Mean Values

62.0 7.5

10/18/2022

Page 1

Facility Name:	Tilden Mine	Test Date/Number:	09/21/2022, Test 1
Unit/Stack:	TIS	Reason for Test:	Periodic Quality Assurance
Parameter:	NOx	Primary Spec:	20 % of Reference Mean
Units:	LbPerHr	Alternate Spec:	10 % of LbPerHr
Relative Accuracy:	17.2 %	Std Deviation:	28.5
Performance Spec:	20 % of Reference Mean (Primary Spec)	Conf Coeff:	21.9
Test Result:	Pass	T Value:	2.306

Run	Start Date/Time	Duration	Use Run	Load	CEM Value	Reference Value	Difference	
1	09/21/22 12:37	25	Yes		567.7	648.4	80.7	
2	09/21/22 13:42	25	Yes		563.5	641.2	77.7	
3	09/21/22 14:29	25	Yes		602.0	654.2	52.2	
4	09/21/22 15:23	25	Yes		555.9	631.6	75.7	
5	09/21/22 16:09	25	Yes		588.6	689.6	101.0	
6	09/21/22 16:56	25	Yes		522.6	602.7	80.1	
7	09/21/22 17:42	25	Yes		504.5	637.2	132.7	
8	09/21/22 18:28	25	Yes		521.5	611.4	89.9	
9	09/21/22 19:18	25	Yes		719.2	860.3	141.1	

Mean Values 571.7 664.1 92.3

10/18/2022 Page 1

Facility Name:	Tilden Mine	Test Date/Number:	09/21/2022, Test 1
Unit/Stack:	TIS	Reason for Test:	Periodic Quality Assurance
Parameter:	StackFlow	Primary Spec:	20 % of Reference Mean
Units:	Kscfh	Alternate Spec:	10 % of Kscfh
Relative Accuracy:	14.9 %	Std Deviation:	571.8
Performance Spec:	20 % of Reference Mean (Primary Spec)	Conf Coeff:	439.5
Test Result:	Pass	T Value:	2.306

Run	Start Date/Time	Duration	Use Run	Load	CEM Value	Reference Value	Difference
1	09/21/22 12:37	25	Yes		27217.2	31342.0	4124.8
2	09/21/22 13:42	25	Yes		26862.4	30777.0	3914.6
3	09/21/22 14:29	25	Yes		27954.3	30817.0	2862.7
4	09/21/22 15:23	25	Yes		26930.3	30982.0	4051.7
5	09/21/22 16:09	25	Yes		26410.8	30810.0	4399.2
6	09/21/22 16:56	25	Yes		26382.3	30833.0	4450.7
7	09/21/22 17:42	25	Yes		26026.2	30675.0	4648.8
8	09/21/22 18:28	25	Yes		26705.0	31051.0	4346.0
9	09/21/22 19:18	25	Yes		26134.8	30964.0	4829.2

AIR QUALITY DIVISION

NOV 02 2029

Mean Values

26735.9 30916.8

4180.9

10/18/2022 Page 1

Facility Name:	Tilden Mine	Test Date/Number:	09/21/2022, Test 1
Unit/Stack:	TIS	Reason for Test:	Periodic Quality Assurance
Parameter:	Moisture	Primary Spec:	20 % of Reference Mean
Units:	Pct	Alternate Spec:	10 % of Pct
Relative Accuracy:	3.4 %	Std Deviation:	0.3
Performance Spec:	20 % of Reference Mean (Primary Spec)	Conf Coeff:	0.2
Test Result:	Pass	T Value:	2.306

Run	Start Date/Time	Duration	Use Run	Load	CEM Value	Reference Value	Difference	
1	09/21/22 12:37	25	Yes		12.1	12.9	0.8	
2	09/21/22 13:42	25	Yes		12.3	12.3	0.0	
3	09/21/22 14:29	25	Yes		12.5	12.5	0.0	
4	09/21/22 15:23	25	Yes		12.3	12.5	0.2	
5	09/21/22 16:09	25	Yes		12.3	12.4	0.1	
6	09/21/22 16:56	25	Yes		12.2	12.3	0.1	
7	09/21/22 17:42	25	Yes		12.1	12.5	0.4	
8	09/21/22 18:28	25	Yes		12.1	12.4	0.3	
9	09/21/22 19:18	25	Yes		12.2	12.4	0.2	

Mean Values 12.2 12.5 0.2

Appendix A

Process Data

Tilden Mining Company L.C. EUKILN1: Production Data

	Pellet	Natural Gas	Coal (Short
Date Hour	Production	(MCFH)	Tons)
09/20/22 11:00	524	159	20
09/20/22 12:00	520	155	20
09/20/22 13:00	519	147	20
09/20/22 14:00	530	223	16
09/20/22 15:00	531	148	20
09/20/22 16:00	530	150	20
09/20/22 17:00	531	149	20
09/20/22 18:00	500	134	20
09/20/22 19:00	498	144	20
09/20/22 20:00	508	148	20

	Pellet	Natural Gas	Coal (Short
Date Hour	Production	(MCFH)	Tons)
09/21/22 12:00	572	146	20
09/21/22 13:00	567	144	20
09/21/22 14:00	568	147	20
09/21/22 15:00	564	141	20
09/21/22 16:00	562	203	17
09/21/22 17:00	560	129	20
09/21/22 18:00	562	134	20
09/21/22 19:00	563	180	18

Appendix B

Network Environmental's Complete RATA report

Report of a ...

Relative Accuracy Test Audit

Performed for ...

Cleveland-Cliffs, Inc. Tilden Mining Company, L.C. Ishpeming, Michigan

On...

Unit 1

At the...

Tilden Mine National Mine, Michigan

September 20-21, 2022

Project #: 053.57

By...

Network Environmental, Inc. Grand Rapids, MI

performed for

Cleveland-Cliffs, Inc. Tilden Mining Company, L.C. 1 Tilden Mine Road P.O. Box 2000 Ishpeming, MI 49849-0901 Contact: Tom O'Brien Telephone: (906) 475-3306 e-mail: thomas.obrien@clevelandcliffs.com

Performed at the:

Tilden Mine National Mine, MI

Performed by

Network Environmental, Inc. 2629 Remico Street SW Suite B Grand Rapids, MI 49519 Contact: David D. Engelhardt Telephone: (616) 530-6330 Fax: (616) 530-0001 E-mail: netenviro@aol.com

RECEIVED

NOV 0 2 2022

AIR QUALITY DIVISION

TABLE OF CONTENTS

1

		Page
I.	Introduction	1
II.	Presentation of Results	2-15
	II.1 Table 1 – North NO _x (Lbs/Hr) Relative Accuracy	2
	II.2 Table 2 – North SO ₂ (Lbs/Hr) Relative Accuracy	3
	II.3 Table 3 – North NO _x (PPM) Relative Accuracy	4
	II.4 Table 4 – North SO ₂ (PPM) Relative Accuracy	5
	II.5 Table 5 – North O ₂ (%) Relative Accuracy	6
	II.6 Table 6 – North Air Flow (KSCFH) Relative Accuracy	7
	II.7 Table 7 – North Moisture (%) Relative Accuracy	8
	II.8 Table 8 – South NO _x (Lbs/Hr) Relative Accuracy	9
	II.9 Table 9 – South SO ₂ (Lbs/Hr) Relative Accuracy	10
	II.10 Table 10 – South NO_x (PPM) Relative Accuracy	11
	II.11 Table 11 – South SO ₂ (PPM) Relative Accuracy	12
	II.12 Table 12 – South O ₂ (%) Relative Accuracy	13
	II.13 Table 13 – South Air Flow (KSCFH) Relative Accuracy	14
	II.14 Table 14 – South Moisture (%) Relative Accuracy	15
III.	Discussion of Results	16-17
IV.	CEMS Specifications	17
V.	Sampling and Analytical Protocol	18-20
	Figure 1 - NO _x , SO ₂ , O ₂ & CO ₂ Sampling Train	21
	Figure 2 - Moisture Sampling Train	22
	Figure 3 - Air Flow Sampling Train	23

Appendices

Reference Method DAS & Calibration Data	А
CEM Data	В
Reference Method Air Flow Data	С
Analyzer Specifications & Calibration Gas Certifications	D
Calculations	Е
Raw Data	F

I. INTRODUCTION

Network Environmental, Inc. was retained by the Tilden Mining Company, L.C. of Ishpeming, Michigan to perform a relative accuracy test audit (RATA) at the Tilden Mine located in National Mine, Michigan.

The purpose of the testing was to conduct a Relative Accuracy Test Audit (RATA) on the Continuous Emission Monitoring System (CEMS) that services Unit 1. There are two (2) exhaust stacks (North & South) on Unit 1. Each exhaust stack has it's own CEMS. The CEMS on Unit 1 is for Oxides of Nitrogen (NO_x), Sulfur Dioxide (SO₂), air flow rate, Oxygen (O₂) and moisture.

The RATA's were performed over the period of September 20-21, 2022. Stephan K. Byrd, Richard D. Eerdmans and David D. Engelhardt of Network Environmental, Inc. conducted the RATA's in accordance with Part 60 of Title 40 of the Code of Federal Regulations. The following reference test methods were employed to conduct the RATA sampling:

- Air Flow Rates U.S. EPA Methods 1-2
- Oxygen & Carbon Dioxide (O₂ & CO₂) U.S. EPA Method 3A
- Moisture U.S. EPA Method 4
- Sulfur Dioxide (SO₂) U.S. EPA Method 6C
- Oxides of Nitrogen (NO_x) U.S. EPA Method 7E

Assisting with the RATA's were Mr. Jason Sammon of CEMSOURCE and Mr. Dan McGrath of the Tilden Mine.

II. PRESENTATION OF RESULTS

II.1 TABLE 1 NO _x (LBS/HR) RELATIVE ACCURACY DETERMINATION UNIT 1 NORTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 20, 2022								
Run #	# Time REFERENCE METHOD			CEM	DIFF			
		NO _x ⁽¹⁾	DSCFM (2)	Lbs/Hr ⁽³⁾	Lbs/Hr ⁽³⁾			
1 (4)	11:27-11:52	115.5	241,080	198.98	234.2	-35.22		
2	14:20-14:45	121.9	240,703	209.63	199.2	10.43		
3	15:06-15:31	112.4	238,484	191.50	191.6	-0.10		
4	15:50-16:15	113.2	239,725	193.85	196.6	-2.75		
5	16:33-16:58	115.2	235,711	193.95	197.1	-3.15		
6	17:25-17:50	113.8	240,703	195.62	196.3	-0.68		
7	18:08-18:33	108.8	244,271	189.76	187.8	1.96		
8	18:57-19:22	102.8	243,809	178.99	174.6	4.39		
9	19:45-20:10	109.1	241,556	188.17	183.2	4.97		
10	20:35-21:00	109.3	240,391	187.66	184.7	2.96		

Mean Reference Value = $\underline{192.1256}$

Absolute Value of the Mean of the Differences = 2.0033

Standard Deviation = 4.2895

Confidence Co-efficient = 3.2972

Relative Accuracy = 2.76% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

(1) Concentration in terms of PPM by volume on a dry basis

(2) DSCFM = Dry Standard Cubic Feet Per Minute (Standard Temperature & Pressure = 68 °F & 29.92 in. Hg)

- (3) Lbs/Hr = Pounds Per Hour
- (4) Not used in relative accuracy calculation

II.2 TABLE 2 SO ₂ (LBS/HR) RELATIVE ACCURACY DETERMINATION UNIT 1 NORTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 20, 2022								
Run #	Time	RI	REFERENCE METHOD			DIFF		
		SO ₂ ⁽¹⁾	DSCFM (2)	Lbs/Hr ⁽³⁾	Lbs/Hr ⁽³⁾			
1 (4)	11:27-11:52	13.3	241,080	31.95	37.8	-5.85		
2	14:20-14:45	11.9	240,703	28.42	31.2	-2.78		
3	15:06-15:31	13.3	238,484	31.43	31.7	-0.27		
4	15:50-16:15	13.7	239,725	32.76	33.0	-0.24		
5	16:33-16:58	13.8	235,711	32.24	33.1	-0.86		
6	17:25-17:50	13.7	240,703	32.88	33.2	-0.32		
7	18:08-18:33	13.4	244,271	32.50	32.1	0.40		
8	18:57-19:22	13.6	243,809	33.03	32.1	0.93		
9	19:45-20:10	14.5	241,556	34.80	33.5	1.30		
10	20:35-21:00	14.0	240,391	33.34	32.0	1.34		

Mean Reference Value = 32.3778

Absolute Value of the Mean of the Differences = 0.0556

Standard Deviation = 1.2837

Confidence Co-efficient = 0.9868

Relative Accuracy = 3.22% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

(1) Concentration in terms of PPM by volume on a dry basis

- (2) DSCFM = Dry Standard Cubic Feet Per Minute (Standard Temperature & Pressure = 68 °F & 29.92 in. Hg)
- (3) Lbs/Hr = Pounds Per Hour
- (4) Not used in relative accuracy calculation

II.3 TABLE 3 NO _x (PPM) RELATIVE ACCURACY DETERMINATION UNIT 1 NORTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 20, 2022								
Run # Time		REFERENCE METHOD	CEM	DIFF				
		NO _x ⁽¹⁾ NO _x ⁽¹⁾						
1	11:27-11:52	115.5	114.1	1.4				
2 (2)	14:20-14:45	121.9	116.0	5.9				
3	15:06-15:31	112.4	111.6	0.8				
4	15:50-16:15	113.2	113.1	-0.1				
5	16:33-16:58	115.2	114.9	-0.6				
6	17:25-17:50	113.8	114.4	-0.6				
7	18:08-18:33	108.8	109.5	-0.7				
8	18:57-19:22	102.8	102.4	0.4				
9	19:45-20:10	109.1	108.5	0.6				
10	10 20:35-21:00 109.3 108.4 0.9							
Mea	an Reference Value	e = 111.1111						

Absolute Value of the Mean of the Differences = 0.3556

Standard Deviation = 0.6839

Confidence Co-efficient = 0.5257

Relative Accuracy = 0.79% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

Concentration in terms of PPM by volume on a dry basis
Not used in relative accuracy calculation

II.4 TABLE 4 SO ₂ (PPM) RELATIVE ACCURACY DETERMINATION UNIT 1 NORTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 20, 2022					
Run # Time		REFERENCE METHOD	CEM	DIFF	
		SO ₂ ⁽¹⁾	SO ₂ ⁽¹⁾		
1	11:27-11:52	13.3	13.2	0.1	
2 (2)	14:20-14:45	11.9	13.1	-1.2	
3	15:06-15:31	13.3	13.3	0.0	
4	15:50-16:15	13.7	13.7	0.0	
5	16:33-16:58	13.8	13.9	-0.1	
6	17:25-17:50	13.7	13.9	-0.2	
7	18:08-18:33	13.4	13.5	-0.1	
8	18:57-19:22	13.6	13.5	0.1	
9	19:45-20:10	14.5	14.3	0.2	
10	20:35-21:00	14.0	13.5	0.5	

Mean Reference Value = 13.7000

Absolute Value of the Mean of the Differences = 0.0556

Standard Deviation = 0.2068

Confidence Co-efficient = 0.1590

Relative Accuracy = 1.57% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

Concentration in terms of PPM by volume on a dry basis
Not used in relative accuracy calculation

II.5 TABLE 5 O ₂ (%) RELATIVE ACCURACY DETERMINATION UNIT 1 NORTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 20, 2022					
Run #	Time	REFERENCE METHOD	CEM	DIFF	
		O ₂ ⁽¹⁾	O ₂ ⁽¹⁾		
1 (2)	11:27-11:52	19.0	18.8	0.2	
2	14:20-14:45	19.0	18.9	0.1	
3	15:06-15:31	19.0	18.8	0.2	
4	15:50-16:15	19.0	18.8	0.2	
5	16:33-16:58	19.0	18.8	0.2	
6	17:25-17:50	18.9	18.8	0.1	
7	18:08-18:33	19.0	18.9	0.1	
8	18:57-19:22	19.0	18.9	0.1	
9	19:45-20:10	18.9	18.8	0.1	
10	20:35-21:00	18.9	18.9	0.0	

Mean Reference Value = 18.9667

Absolute Value of the Mean of the Differences = 0.1222

Standard Deviation = 0.0667

Confidence Co-efficient = 0.0512

Relative Accuracy = 0.91% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

Concentration in terms of % by volume on a dry basis
Not used in relative accuracy calculation

	II.6 TABLE 6 AIR FLOW (KSCFH) RELATIVE ACCURACY DETERMINATION UNIT 1 NORTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 20, 2022					
Run #	Time	REFERENCE METHOD	CEM	DIFF		
		KSCFH ⁽¹⁾	KSCFH ⁽¹⁾			
1 (2)	11:27-11:52	15,719	18,790	-3,071		
2	14:20-14:45	15,831	15,772	59		
3	15:06-15:31	15,691	15,669	22		
4	15:50-16:15	15,728	15,846	-118		
5	16:33-16:58	15,507	15,687	-180		
6	17:25-17:50	15,805	15,721	84		
7	18:08-18:33	16,053	15,750	303		
8	18:57-19:22	16,052	15,641	411		
9	19:45-20:10	15,848	15,473	375		
10	20:35-21:00	15,798	15,573	225		
Mean Reference Value = $15,812.556$						

Absolute Value of the Mean of the Differences = 131.222

Standard Deviation = 210.461

Confidence Co-efficient = 161.775

Relative Accuracy = 1.85% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

(1) Thousand Standard Cubic Feet Per Hour

(2) Not used in relative accuracy calculation

II.7 TABLE 7 MOISTURE (%) RELATIVE ACCURACY DETERMINATION UNIT 1 NORTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 20, 2022						
Run #	Time	REFERENCE METHOD	CEM	DIFF		
		Moisture ⁽¹⁾	Moisture ⁽¹⁾			
1 (2)	11:27-11:52	7.98	8.5	-0.52		
2	14:20-14:45	8.77	8.9	-0.13		
3	15:06-15:31	8.81	8.2	0.61		
4	15:50-16:15	8.55	8.1	0.45		
5	16:33-16:58	8.80	8.4	0.40		
6	17:25-17:50	8.62	8.6	0.02		
7	18:08-18:33	8.70	8.8	-0.10		
8	18:57-19:22	8.87	8.7	0.17		
9	19:45-20:10	8.55	8.6	-0.05		
10	10 20:35-21:00 8.70 8.4 0.30					
Mea	Mean Reference Value = $\underline{8.7078}$					

Standard Deviation = 0.2677

Confidence Co-efficient = 0.2058

Relative Accuracy = 4.49% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

Concentration in terms of % by volume on a dry basis
Not used in relative accuracy calculation

II.8 TABLE 8 NO _x (LBS/HR) RELATIVE ACCURACY DETERMINATION UNIT 1 SOUTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 21, 2022						
Run #	Time	RE	REFERENCE METHOD			DIFF
		NO _x ⁽¹⁾	DSCFM (2)	Lbs/Hr ⁽³⁾	Lbs/Hr ⁽³⁾	
1	12:37-13:02	199.5	455,032	648.40	567.7	80.70
2	13:42-14:07	199.6	449,709	641.19	563.5	77.69
3	14:29-14:54	203.8	449,465	654.22	602.0	52.22
4	15:23-15:48	195.8	451,669	631.64	555.9	75.74
5	16:09-16:34	214.9	449,153	689.63	588.6	101.03
6	16:56-17:21	187.1	450,877	602.72	522.6	80.12
7	17:42-18:07	186.9	477,145	637.15	504.5	132.65
8	18:28-18:53	188.8	453,445	611.39	521.5	89.89
9	19:18-19:43	266.4	452,027	860.29	719.2	141.09

Mean Reference Value = 664.0700

Absolute Value of the Mean of the Differences = 92.3478

Standard Deviation = 28.4332

Confidence Co-efficient = 21.8557

Relative Accuracy = 17.20% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

(1) Concentration in terms of PPM by volume on a dry basis

(2) DSCFM = Dry Standard Cubic Feet Per Minute (Standard Temperature & Pressure = 68 °F & 29.92 in. Hg)

(3) Lbs/Hr = Pounds Per Hour

II.9 TABLE 9 SO ₂ (LBS/HR) RELATIVE ACCURACY DETERMINATION UNIT 1 SOUTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 21, 2022						
Run #	Time	REFERENCE METHOD			CEM	DIFF
		SO ₂ ⁽¹⁾	DSCFM (2)	Lbs/Hr ⁽³⁾	Lbs/Hr ⁽³⁾	
1	12:37-13:02	14.3	455,032	64.73	59.8	4.93
2	13:42-14:07	13.7	449,709	61.28	57.5	3.78
3	14:29-14:54	14.8	449,465	65.93	64.3	1.63
4	15:23-15:48	13.6	451,669	61.06	54.9	6.16
5	16:09-16:34	15.8	449,153	70.69	59.9	10.79
6	16:56-17:21	13.0	450,877	58.29	53.1	5.19
7	17:42-18:07	13.3	477,145	62.84	47.9	14.94
8	18:28-18:53	12.5	453,445	56.44	48.1	8.34
9	19:18-19:43	12.6	452,027	56.75	45.0	11.75

Mean Reference Value = 62.0011

Absolute Value of the Mean of the Differences = 7.5011

Standard Deviation = 4.2863

Confidence Co-efficient = 3.2947

Relative Accuracy = 17.41% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

Concentration in terms of PPM by volume on a dry basis
DSCFM = Dry Standard Cubic Feet Per Minute (Standard Temperature & Pressure = 68 °F & 29.92 in. Hg)

(3) Lbs/Hr = Pounds Per Hour

II.10 TABLE 10 NO _x (PPM) RELATIVE ACCURACY DETERMINATION UNIT 1 SOUTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 21, 2022					
Run #	Time	REFERENCE METHOD	CEM	DIFF	
		NO _x ⁽¹⁾	NO _x ⁽¹⁾		
1	12:37-13:02	199.5	198.8	0.7	
2	13:42-14:07	199.6	200.4	-0.8	
3	14:29-14:54	203.8	206.0	-2.2	
4	15:23-15:48	195.8	197.2	-1.4	
5	16:09-16:34	214.9	213.2	1.7	
6	16:56-17:21	187.1	188.9	-1.8	
7	17:42-18:07	186.9	184.7	2.2	
8	18:28-18:53	188.8	186.1	2.7	
9	19:18-19:43	266.4	261.9	4.5	

Mean Reference Value = 204.7556

Absolute Value of the Mean of the Differences = 0.6222

Standard Deviation = 2.3172

Confidence Co-efficient = 1.7812

Relative Accuracy = 1.17% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

(1) Concentration in terms of PPM by volume on a dry basis

II.11 TABLE 11 SO ₂ (PPM) RELATIVE ACCURACY DETERMINATION UNIT 1 SOUTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 21, 2022					
Run #	Time	REFERENCE METHOD	CEM	DIFF	
1	12:37-13:02	14 3	15.1	-0.8	
2	13:42-14:07	13.7	14.7	-1.0	
3	14:29-14:54	14.8	15.8	-1.0	
4	15:23-15:48	13.6	14.0	-0.4	
5	16:09-16:34	15.8	15.6	0.2	
6	16:56-17:21	13.0	13.8	-0.8	
7	17:42-18:07	13.3	12.6	0.7	
8	18:28-18:53	12.5	12.3	0.2	
9	19:18-19:43	12.6	11.8	0.8	

Mean Reference Value = 13.7333

Absolute Value of the Mean of the Differences = 0.2333

Standard Deviation = 0.7211

Confidence Co-efficient = 0.5543

Relative Accuracy = 5.74% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

(1) Concentration in terms of PPM by volume on a dry basis

II.12 TABLE 12 O ₂ (%) RELATIVE ACCURACY DETERMINATION UNIT 1 SOUTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 21, 2022					
		REFERENCE METHOD	CEM	DIFF	
Run #	Ime	O ₂ ⁽¹⁾	O ₂ ⁽¹⁾	DIFF	
1	12:37-13:02	17.0	16.9	0.1	
2	13:42-14:07	17.0	16.9	0.1	
3	14:29-14:54	17.0	16.9	0.1	
4	15:23-15:48	17.0	16.9	0.1	
5	16:09-16:34	17.0	16.8	0.2	
6	16:56-17:21	17.1	17.0	0.1	
7	17:42-18:07	17.1	16.9	0.2	
8	18:28-18:53	17.1	16.9	0.2	
9	19:18-19:43	17.1	16.8	0.3	

Mean Reference Value = 17.0444

Absolute Value of the Mean of the Differences = 0.1556

Standard Deviation = 0.0726

Confidence Co-efficient = 0.0558

Relative Accuracy = 1.24% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

(1) Concentration in terms of % by volume on a dry basis

ALC: NO. OF THE OWNER.							
	II.13 TABLE 13						
	AIR FLOW (KSCFH) RELATIVE ACCURACY DETERMINATION						
	UNIT 1						
	SOUTH WASTE GAS STACK						
	CLEVELAND CLIFFS, INC.						
	TILDEN MINING COMPANY, L.C.						
	NATIONAL MINE, MICHIGAN						
	SEPTEMBER 21, 2022						

Run #	Time		CEM	DIFF
		KSCFH(*)	KSCFH	
1	12:37-13:02	31,342	27,217	4,125
2	13:42-14:07	30,777	26,862	3,915
3	14:29-14:54	30,817	27,954	2,863
4	15:23-15:48	30,982	26,930	4,052
5	16:09-16:34	30,810	26,411	4,399
6	16:56-17:21	30,833	26,382	4,451
7	17:42-18:07	30,675	26,026	4,649
8	18:28-18:53	31,051	26,705	4,346
9	19:18-19:43	30,964	26,135	4,829

Mean Reference Value = 30,916.778

Absolute Value of the Mean of the Differences = 4,181.000

Standard Deviation = 571.646

Confidence Co-efficient = 439.405

Relative Accuracy = 14.94% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

(1) Thousand Standard Cubic Feet Per Hour

II.14 TABLE 14 MOISTURE (%) RELATIVE ACCURACY DETERMINATION UNIT 1 SOUTH WASTE GAS STACK CLEVELAND CLIFFS, INC. TILDEN MINING COMPANY, L.C. NATIONAL MINE, MICHIGAN SEPTEMBER 21, 2022					
Run #	Time	REFERENCE METHOD	CEM	DIFF	
		Moisture ⁽¹⁾	Moisture ⁽¹⁾		
1	12:37-13:02	12.89	12.1	0.79	
2	13:42-14:07	12.33	12.3	0.03	
3	14:29-14:54	12.49	12.5	-0.01	
4	15:23-15:48	12.53	12.3	0.23	
5	16:09-16:34	12.43	12.3	0.13	
6	16:56-17:21	12.26	12.2	0.06	
7	17:42-18:07	12.54	12.1	0.44	
8	18:28-18:53	12.38	12.1	0.28	
9	19:18-19:43	12.41	12.2	0.21	

Mean Reference Value = 12.4733

Absolute Value of the Mean of the Differences = 0.2400

Standard Deviation = 0.2490

Confidence Co-efficient = 0.1914

Relative Accuracy = 3.46% of the mean of the reference method

Relative Accuracy Needs To Be Less Than 20% Of Reference Method

(1) Concentration in terms of % by volume on a dry basis

III. DISCUSSION OF RESULTS

The results of the RATA's are presented in Tables 1 through 14 (Section II.1 through II.14) as follows:

North

- Table 1 NO_x Lbs/Hr
- Table 2 SO₂ Lbs/Hr
- Table 3 NO_x PPM
- Table 4 SO₂ PPM
- Table 5 O₂ %
- Table 6 Air Flow
- Table 7 Moisture

South

- Table 8 NO_x Lbs/Hr
- Table 9 SO₂ Lbs/Hr
- Table 10 NO_x PPM
- Table 11 SO₂ PPM
- Table 12 O₂ %
- Table 13 Air Flow
- Table 14 Moisture

The results of the RATA's are summarized as follows:

Source	Parameter	EPA Performance Actual Specification Performance		RATA Frequency
Unit 1 North	NO _x – Lbs/Hr	≤20% of RM	2.76% of RM	Annual
	SO ₂ – Lbs/Hr	≤20% of RM	3.22% of RM	Annual
	NO _x – PPM	≤20% of RM	0.79% of RM	Annual
	SO ₂ – PPM	≤20% of RM	1.57% of RM	Annual
	O ₂ - %	≤20% of RM or ±1.0% Diff	0.91% RM 0.12 Avg. Diff	Annual
	Air Flow - KSCFH	≤20% of RM	1.85% of RM	Annual
	Moisture – %	≤20% of RM	4.49% of RM	Annual

Source	Parameter	EPA Performance Actual Specification Performance		RATA Frequency
Unit 1 South	NO _x – Lbs/Hr	≤20% of RM	17.20% of RM	Annual
	SO ₂ – Lbs/Hr	≤20% of RM	17.41% of RM	Annual
	NO _x – PPM	≤20% of RM	1.17% of RM	Annual
	SO ₂ – PPM	≤20% of RM	5.74% of RM	Annual
	O ₂ – %	\leq 20% of RM or ±1.0% Diff	1.24% RM 0.16 Avg. Diff	Annual
	Air Flow - KSCFH	≤20% of RM	14.94% of RM	Annual
	Moisture – %	≤20% of RM	3.46% of RM	Annual

IV. CEMS SPECIFICATIONS

Location	Parameter	Manufacturer / Model #	Serial #
	NO _x / O ₂	Teledyne Monitor Labs / T200H/O ₂	148
Unit 1 North	SO ₂	Teledyne Monitor Labs / T100H	146
	Air Flow	Teledyne Monitor Labs / UF150	1501325
Location	Parameter	Manufacturer / Model #	Serial #
	NO _x / O ₂	Teledyne Monitor Labs / T200H/O ₂	149
Unit 1 South	SO ₂	Teledyne Monitor Labs / T100H	147
	Air Flow	Teledyne Monitor Labs / UF150	1501324

V. SAMPLING AND ANALYTICAL PROTOCOL

The RATA's were performed in accordance with 40 CFR Part 60. Sampling was performed on the 161" ID North stack and the 233" ID South stack. Twenty-Four (24) point traverses were used on all stacks for the air flow determinations. The actual sampling point dimensions for the velocity traverses can be found in Appendix F.

The sampling methods used for the reference method determinations were as follows:

V.1 Oxides of Nitrogen – The NO_x sampling was conducted in accordance with U.S. EPA Reference Method 7E. A Thermo Environmental Model 42H gas analyzer was used to monitor the exhaust stacks. A heated Teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the NO_x concentrations (PPM).

The analyzer was calibrated by direct injection prior to the testing. A span gas of 987.0 PPM was used to establish the initial instrument calibration. Calibration gases of 484.0 PPM and 251.0 PPM were used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected, using the 484.0 PPM gas to determine the system bias. After each sample, a system zero and system injection of 484.0 PPM were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified. A 51.0 PPM NO₂ gas was used to determine conversion efficiency for the analyzer. The conversion efficiency was 94.51%.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the unit. All reference method data was corrected using Equation 7E-5 from U.S. EPA Method 7E. A schematic diagram of the sampling train is shown in Figure 1.

V.2 Sulfur Dioxide – The SO₂ sampling was conducted in accordance with U.S. EPA Reference Method 6C. A Bovar Model 721M gas analyzer was used to monitor the exhausts. Sample gas was extracted through a heated probe. A heated teflon sample line was used to transport the exhaust gases to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner stack gases were passed to the analyzer. The analyzer produces instantaneous readouts of the SO₂ concentrations (PPM). The analyzer was calibrated by direct injection prior to the testing. A span gas of 95.2 PPM was used to establish the initial instrument calibration. A calibration gas of 50.2 PPM was used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 50.2 PPM gas to determine the system bias. After each sample, a system zero and system injection of 50.2 PPM were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data from the exhaust.

V.3 Oxygen – The O_2 sampling was conducted in accordance with U.S. EPA Reference Method 3A. A heated Teflon sample line was used to transport the exhaust gases from the exhaust stacks to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner the stack gases were passed to a Servomex Series 1400 O_2 analyzer. This analyzer produces instantaneous readouts of the oxygen concentrations (%).

The analyzer was calibrated by direct injection prior to the testing. A span gas of 20.85% was used to establish the initial instrument calibration. Calibration gases of 5.90% and 12.0% were used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 12.0% gas to determine the system bias. After each sample, a system zero and system injection of 12.0% were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data. All reference method data was corrected using Equation 7E-5 from U.S. EPA Method 7E. A schematic diagram of the sampling train is shown in Figure 1.

V.4 Carbon Dioxide - The CO_2 sampling was conducted in accordance with U.S. EPA Reference Method 3A. A heated Teflon sample line was used to transport the exhaust gases from the exhaust stacks to a gas conditioner to remove moisture and reduce the temperature. From the gas conditioner the stack gases were passed to a Servomex Series 1400 CO_2 analyzer. This analyzer produces instantaneous readouts of the carbon dioxide concentrations (%). The analyzer was calibrated by direct injection prior to the testing. A span gas of 21.1% was used to establish the initial instrument calibration. Calibration gases of 5.95% and 12.06% were used to determine the calibration error of the analyzer. The sampling system (from the back of the stack probe to the analyzer) was injected using the 5.95% gas to determine the system bias. After each sample, a system zero and system injection of 5.95% were performed to establish system drift and system bias during the test period. All calibration gases were EPA Protocol 1 Certified.

The analyzer was calibrated to the output of the data acquisition system (DAS) used to collect the data. All reference method data was corrected using Equation 7E-5 from U.S. EPA Method 7E. A schematic diagram of the sampling train is shown in Figure 1.

V.5 Moisture - Moisture samples were collected in accordance with U.S. EPA Method 4. Samples were withdrawn from the stack and passed through a condensing coil with drop out before being passed through pre-weighed silica gel. The water collected was measured to the nearest 0.5 g and the silica gel was re-weighed to the nearest 0.5 g. The moisture collected along with the sample volume was used to determine the percent moisture in the exhaust. Each sample was twenty five (25) minutes in duration and had a minimum sample volume of twenty-one (21) standard cubic feet. A diagram of the moisture sampling train is shown in Figure 2.

V.6 Air Flows - The air flow rates were determined in conjunction with the other sampling by employing U.S. EPA Reference Methods 1 and 2. Sampling was performed on the 161" ID North stack and the 233" ID South stack. Twenty-Four (24) point traverses were used on all the stacks. The actual sampling point dimensions for the velocity traverses can be found in Appendix F.

Velocity pressures were determined using an S-Type pitot tube. Temperatures were measured using a Type K thermocouple. A diagram of the air flow sampling train is shown in Figure 3.

This report was prepared by:

] Cughatt

David D. Engelhardt Vice President

This report was reviewed by:

Tohan K. Byo

Stephan K. Byrd President







APPENDIX A

REFERENCE METHOD DAS & CALIBRATION DATA