

5440 Alder Drive
Houston, TX 77081

Phone: 800-836-7333

Fax: 713-664-6444

E-mail: emissions@ceconet.com

EMISSION TEST REPORT

REGULATION(S): MDEQ PERMIT

POLLUTANT(S): CO, NOX, AND VOCs

ANR TRANSCANADA PIPELINE COMPANY BLUE LAKE STORAGE COMPANY KALKASKA COUNTY, MI

PERMIT NUMBER: MI-ROP-B7198-2014A

RECEIVED

JUN 15 2018

FRS # / EPA REGISTRY ID: 110013860526
SOURCE CLASSIFICATION CODE (SCC): 20200254

AIR QUALITY DIVISION

SOURCE ID: BLBGEN-A
EMISSION SOURCE: SPARK-IGNITED ENGINE
4-STROKE/2-STROKE: 4-STROKE
RICH/LEAN BURN: LEAN BURN
MAKE & MODEL: CATERPILLAR G3516
UNIT NUMBER: GENERATOR A-3
SERIAL NUMBER: 3RC00642 (10073095)

TEST DATE: MARCH 22, 2018

Pollutant	Permitted Limits				PASS/FAIL
	pounds / hour		g/BHP-hr		
	Permitted	Emitted	Permitted	Emitted	
CO	1.6	0.01	1.4	0.00	PASS
NOx	5.7	1.61	2	1.2	PASS
VOCs	0.9	-0.54	0.55	-0.396	PASS

Limits obtained from Permit MI-ROP-B7198-2014A.

The contents of this document relate only to the items tested. I certify under penalty of law that I believe the information provided in this document is true, accurate and complete. I am aware that there are significant civil and criminal penalties, including the possibility of fine or imprisonment or both, for submitting false, inaccurate or incomplete information.

CECO TEST LEADER:

BART DELATTE
MANAGER OF EMISSIONS TESTING
CECO TRAINING & TECHNICAL SERVICES
713-663-1894

This report may not be reproduced in full, or in part, without the written approval of ANR TransCanada Pipeline Company.

Revision History

Version	Revision Date	Comments
0	<i>original</i>	Original Version of Document.

Project Information

CECO Project No: 20180322-052-1

Contact Information

Facility Information

<u>Facility</u>	<u>Contact</u>
ANR TransCanada Pipeline Company Blue Lake Storage Company Kalkaska County, MI	Roy Cannon 700 Louisiana Street Houston, TX 77002 832-320-5465 roy_cannon@transcanada.com

Testing Group Information

<u>Contact</u>
Bart Delatte CECO Training & Technical Services 5440 Alder Drive Houston, TX 77081 713-663-1894 bart.delatte@ceconet.com

Introduction

CECO Training & Technical Services, a division of Compressor Engineering Corporation, conducted source emission testing at ANR TransCanada Pipeline Company, Blue Lake Storage Company to fulfill the requirements of MDEQ Permit. This report details the test purpose, objectives, testing procedures, sampling and analysis methodology, and results of the source testing conducted on March 22, 2018.

Process Description

The following source was tested:

- Unit Number Generator A-3 (Source ID BLBGEN-A) SN 3RC00642 (10073095) – one (1) Caterpillar G3516 natural gas-fired, 4-Stroke, Lean Burn internal combustion engine, rated to 1125 brake horsepower (BHP) at 1200 revolutions per minute (RPM). This source is equipped with an oxidation catalyst with an air-fuel ratio controller for emission control and drives an electric generator.

Test Purpose and Objectives

The purpose of this test was to fulfill the requirements of MDEQ Permit. The objective of this test was to conduct the required three (3) 60-minute test runs to measure the applicable emission species at the maximum achievable load.

Results

Caterpillar G3516 SN: 3RC00642 (10073095)		Test Run			Average
		1st	2nd	3rd	
Fuel					
HHV (BTU/SCF)		1026			
LHV (BTU/SCF)		928			
F-factor (DSCF/MMBTU)		8619			
Test Date & Time					
Date		3/22/2018	3/22/2018	3/22/2018	
Start Time		2:43 PM	4:09 PM	5:38 PM	
End Time		3:43 PM	5:10 PM	6:39 PM	
Interval (minutes)		60	61	61	61
Measured Concentrations (bias-corrected where applicable)					
O ₂ (%vd)		8.76	8.63	8.69	8.69
CO (ppmvd)		0.5	0.8	1.2	0.8
NO _x (ppmvd)		145.7	156.4	144.4	148.8
VOCs (ppmvd)		-48.2	-56.3	-50.7	-51.7
THC (ppmvd)		742.7	725.0	740.4	736.0
Operating Conditions					
Engine Horsepower (BHP)		611	613	620	615
Engine Load (%)		54.3	54.4	55.0	54.6
Engine Speed (RPM)		1202	1201	1201	1201
Fuel Flow Rate (SCFH)		6403	5743	5887	6011
BSFC (BTU/BHP/hr), LHV		9720	8695	8813	9076
Fuel BTU Consumption (MMBTU/hr)		6.57	5.89	6.04	6.16
Exhaust Flow Rate (SCFH)		97445	86476	89069	90997
Exhaust Flow Rate (SCFM)		1624.1	1441.3	1484.5	1516.6
Calculated Emissions					
CO	(lb/hr)	0.0035	0.0050	0.0078	0.0054
	(ton/year)	0.0155	0.0220	0.0340	0.0238
	(g/BHP-hr)	0.0026	0.0037	0.0057	0.0040
	(ppmvd at 15% O ₂)	0.2430	0.3847	0.5799	0.4025
NO _x	(lb/hr)	1.6944	1.6140	1.5349	1.6144
	(ton/year)	7.4213	7.0695	6.7229	7.0712
	(g/BHP-hr)	1.2571	1.1943	1.1231	1.1915
	(ppmvd at 15% O ₂)	70.8097	75.2046	69.7756	71.9300
VOCs	(lb/hr)	-0.5373	-0.5569	-0.5166	-0.5369
	(ton/year)	-2.3533	-2.4393	-2.2625	-2.3517
	(g/BHP-hr)	-0.3986	-0.4121	-0.3780	-0.3962
	(ppmvd at 15% O ₂)	-23.4250	-27.0717	-24.4988	-24.9985
THC	(lb/hr)	8.2787	7.1716	7.5436	7.6647
	(ton/year)	36.2606	31.4118	33.0411	33.5712
	(g/BHP-hr)	6.1420	5.3068	5.5199	5.6562
	(ppmvd at 15% O ₂)	360.9498	348.6145	357.7690	355.7778

Methodology and Sampling Procedures

Methodology

Parameter	Sampling Method
Oxygen (O ₂)	40 CFR 60, Appendix A, Method 3A
Oxides of Nitrogen (NO _x)	40 CFR 60, Appendix A, Method 7E
Carbon Monoxide (CO)	40 CFR 60, Appendix A, Method 10
Volumetric Exhaust Flow Rate	40 CFR 60, Appendix A, Method 19
Gas Dilution System	40 CFR 60, Appendix A, Method 205
Methane (CH ₄) & Ethane (C ₂ H ₆)	ASTM D6348
Total Hydrocarbons (THC)	40 CFR 60, Appendix A, Method 25A
Volatile Organic Compounds (VOCs)	40 CFR 60, Appendix A, Method 25A & ASTM D6348 Subtraction

Horsepower and Fuel Flow Determination

For this test, horsepower was calculated from generator parameters and fuel flow was obtained from the engine panel. The Engine Torque Load averaged 54.6% for the test. This was the highest achievable load based on the operating parameters during the test, which are included in Appendix A.

Sampling System

Compressor Engineering Corporation designed and assembled a versatile, emission testing unit (ETU), which houses all analyzers, computers and auxiliary equipment. Effluent stack gas enters the ETU through a heated Teflon sample line. A heated head pump with a Teflon diaphragm pulls the sample into the trailer, through a heated filter, and sends the wet gas directly to the inlet of the FTIR. The heated pump, sample lines, and filter have their temperatures maintained at approximately 191 °C. The FTIR analyzer gas cell and gas inlet temperatures are also maintained at approximately 191 °C. The sample is routed from the exit of the FTIR through a heated Teflon line to a gas conditioner for moisture removal. The dry gas exiting the gas conditioner is routed to a gas distribution panel which sends a portion of the gas to the paramagnetic oxygen analyzer.

The MKS Instruments MultiGas 2030 FTIR analyzer is used to determine the CO, NO_x, and VOCs emission concentrations. The FTIR serves as the instrument for Methods 7E and 10, and meets the requirements of Section 13 of Method 7E. All measured concentrations are corrected to a dry basis via the MKS MG2000 operating software. The FTIR analyzer is configured with a fixed optical pathlength of 5.11 meters. The measured concentrations are collected at a 0.5 cm⁻¹ resolution. Each spectrum is derived from the co-addition of 60 scans. Data is collected continuously during each test run. A new data point is generated every 60 seconds.

A software package (CECOTest) is used to collect and processes data. CECOTest continually logs data every 15 seconds from the oxygen analyzer and the FTIR during the 60 minute runs.

Refer to **FIGURE 1** for a schematic of the sampling system.




Figure 1: Sampling System Schematic

Instrument Specifications

Description: Oxygen Analyzer
 Manufacturer: Servomex
 Model: 1440C
 Serial Number: 2594
 Technology Type: Paramagnetic
 Range: 0-25%
 Repeatability: +/- 0.1% O2
 Response Time (90%): Typically less than 10 sec
 Linearity: +/- 0.1% O2

Description: FTIR Analyzer
 Manufacturer: MKS Instruments
 Model: 2030
 Serial Number: 017979534
 Technology Type: FTIR Spectrometry
 Range: between 10ppb and 100% fullscale
 Spectral Resolution: 0.5-128 1/cm
 Scan Speed: 1/sec @ 0.5 1/cm
 Detector Type: LN2-cooled MCT


Manufacturer: Teledyne
 Model: T700
 Serial Number: 577
 Technology Type: Mass Flow Controller
 MFC's: 0LPM, 2LPM, and 200ccm
 Flow Measurement Accuracy: +/-1.0% of Full Scale
 Repeatability of Flow Control: +/-0.2% of full Scale
 Linearity of Flow Measurement: +/-0.5% of Full Scale
 Flow Range of Diluent Air: 0 to 10 SLPM
 Optional Ranges: 0 to 5 SLPM; 0 to 20 SLPM
 Flow Range of Cylinder Gasses: 0 to 100 cc/min
 Optional Ranges: 0 to 50 cc/min; 0 to 200 cc/min
 Zero Air Required: 10 SLPM @ 30 PSIG
 Optional: 20 SLPM @ 30 PSIG
 CAL Gas Input Ports: 4 (configurable)
 Diluent Gas Input Ports: 1
 Response Time: 60 Seconds (98%)

Description: Flame Ionization Analyzer
 Manufacturer: J.U.M. Engineering
 Model: 1440C
 Serial Number: 208483
 Outputs: 0-10V, 4 - 20mA.
 Detection Method: Flame Ionization Detector.

Detection Limit:	1ppm CH4 at full scale.
Ranges:	0-10, 0-100, 0-1,000, 0-10,000, 0-100,000ppm.
Response Time:	0.2 sec.
Sample Flow Rate:	2.5 L/min.
Drift:	Span (24 hours): <1%. Zero (24 hours): <1%.
Linearity:	within 1% of full scale

Description of Sampling Location

Physical Duct Parameters



D =	12	in	Duct Diameter
L =	4	in	Port Length
A =	144	in	Distance to Downstream Disturbance
B =	132	in	Distance to Upstream Disturbance
H =	30	ft	Approximate Height Above Grade
	12.0	D	Distance to Downstream Disturbance (A)
	0.5	D	EPA M1 Requirement
	TRUE		EPA M1 Requirement Met?
	11.0	D	Distance to Upstream Disturbance (B)
	2.0	D	EPA M1 Requirement
	TRUE		EPA M1 Requirement Met?
	TRUE		EPA M1 Requirements Met for Distances to Up/Downstream Disturbances

EPA JJJJ/ZZZ Sampling Point Requirements

Duct Diameter	Ports
D ≤ 6 inches	N/A
6 < D ≤ 12 inches	N/A
D > 12 inches	M1 Ports
D > 12 inches	no M1 Ports

Sampling Strategy

Single Point Located at Duct Centroid
 3 Traverse Points (16.7, 50.0, and 83.3%) across the duct
 3 Traverse Points (16.7, 50.0, and 83.3%) across the duct
 Stratification Check Required

REQUIRED SAMPLING STRATEGY:

10.0 in
 6.0 in
 2.0 in
 14.0 in
 10.0 in
 6.0 in

3 Traverse Points (16.7, 50.0, and 83.3%) across the duct
 Point 1
 Point 2
 Point 3
 Point 1 Probe Mark (Includes port length)
 Point 2 Probe Mark (Includes port length)
 Point 3 Probe Mark (Includes port length)

STRATIFICATION CHECK REQUIREMENTS

For every point (w here Da=Deviation from Average (%) for a given point.)

Da < 5 %
 5% ≤ Da < 10 %
 Otherwise

Single Point Located at Duct Centroid
 3 Traverse Points (16.7, 50.0, and 83.3%) across the duct
 Full M1 Points Required

STRATIFICATION CHECK RESULTS

Point 1	Point 2	Point 3
8.65	8.58	8.51
8.57	8.50	8.49
8.53	8.67	8.43
8.52	8.52	8.39
8.50	8.62	8.39
8.74	8.62	8.36
9.05	8.60	8.32
9.04	8.56	8.49
9.01	8.61	8.96
8.79	9.04	8.98
9.01	9.09	8.77
9.03	9.06	8.82

Point Average (% O2)	8.79	8.71	8.58
Point Deviation from Average (%)	1.12	0.19	- 1.31
Point Deviation from Average (% O2)	0.10	0.02	- 0.11
Average of Point Averages (% O2)	8.69		

STRATIFICATION CHECK RESULTANT STRATEGY

Single Point Located at Duct Centroid