

DEPARTMENT OF ENVIRONMENTAL QUALITY  
AIR QUALITY DIVISION  
ACTIVITY REPORT: Self Initiated Inspection

B722029850

FACILITY: ANR Pipeline Co - Woolfolk Compressor Station		SRN / ID: B7220
LOCATION: 11039 150th Ave., BIG RAPIDS		DISTRICT: Grand Rapids
CITY: BIG RAPIDS		COUNTY: MECOSTA
CONTACT: Brad Stermer, Sr. Environmental Specialist		ACTIVITY DATE: 06/18/2015
STAFF: Steve Lachance	COMPLIANCE STATUS: Compliance	SOURCE CLASS: MAJOR
SUBJECT: DDDDD Inspection		
RESOLVED COMPLAINTS:		

AQD received a 40 CFR 63, Subpart DDDDD Notification of Compliance Status (NOCS) for an existing Gas1 Furnace; the Sorbead Dehy System. The compliance date for this rule is 1/31/16, but 63.7545(e) requires submittal of the NOCS no later than 60 days following completion of the initial compliance demonstration.


Existing Gas1 Units have two basic requirements; initial and periodic tune-ups; and completion of a one-time Energy Assessment.

During SL's site visit on 6/18/15, Mr. Brad Stermer was able to provide tune-up documentation for this boiler. See attached. This demonstrates completion of the major tune-up inspection elements, as well as optimized CO emissions (0 ppm). The Energy Assessment has been completed; SL requested a copy of results from Ms. Tiffany Grady of TransCanada on 6/19/15. No actions are necessary based on the findings and results of the Energy Assessment.

Other small Gas1 Units will be tuned up prior to the compliance date; this NOCS is only for the Sorbead Dehy Furnace.

The facility appears to be in a position to comply with the requirements of 40 CFR 63 DDDDD at this facility and has addressed all requirements for this boiler at this time.

NAME



DATE

6/19/15

SUPERVISOR

