



GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
GRAND RAPIDS DISTRICT OFFICE



LIESL EICHLER CLARK
DIRECTOR

February 3, 2020

Mr. Richard Connor
Trans Canada ANR Pipeline
11039 150th Avenue
Big Rapids, Michigan 49307

SRN: B7220, Mecosta County

Dear Mr. Connor:

VIOLATION NOTICE

On January 14, 2020, the Department of Environment, Great Lakes, and Energy (EGLE), Air Quality Division (AQD), conducted an inspection of ANR Pipeline Company - Woolfolk Compressor Station (Woolfolk) located at 11039 150th Avenue, Big Rapids, Michigan. The purpose of this inspection was to determine Woolfolk's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451); the Air Pollution Control Rules; and the conditions of Renewable Operating Permit (ROP) number MI-ROP-B7220-2017a.

During the inspection, staff observed the following:

Process Description	Rule/Permit Condition Violated	Comments
FG-RICE-818-WLENGINES	ROP No. MI-ROP-B7220-2017a, Special Condition (SC) VI.6.a Rule 818(4)(ii)(A)	Failure to conduct 2019 NOx performance testing for Engine 1.

The January 14, 2020 inspection confirmed that the 2019 NOx performance test for Engine 1 had not been conducted. ROP No. MI-ROP-B7220-2017a, SC VI.6.a and Rule 818(4)(ii)(A) require annual NOx performance testing during each Ozone Control Period (May 1 – September 30).

Please initiate actions necessary to correct the cited violation and submit a written response to this Violation Notice by February 24, 2020 (which coincides with 21 calendar days from the date of this letter). The written response should include: the dates the violation occurred; an explanation of the causes and duration of the violation; whether the violation is ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violation and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.


Mr. Richard Connor
Trans Canada ANR Pipeline
Page 2
February 3, 2020

Please submit the written response to EGLE, AQD, Grand Rapids District, at 350 Ottawa Avenue, NW, Unit 10, Grand Rapids, Michigan 49503 and submit a copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor at EGLE, AQD, P.O. Box 30260, Lansing, Michigan 48909-7760.

If Woolfolk believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violation cited above and for the cooperation that was extended to me during my inspection of Woolfolk. If you have any questions regarding the violation or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Chris Robinson
Environmental Quality Analyst
Air Quality Division
616-356-0259

cc: Ms. Mary Ann Dolehanty, EGLE
Dr. Eduardo Olaguer, EGLE
Ms. Jenine Camilleri, EGLE
Mr. Christopher Ethridge, EGLE
Ms. Heidi Hollenbach, EGLE