

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION


FCE Summary Report

Facility : Sturgis Municipal Power Plant		SRN :	B7287
Location : 505 West Chicago Rd.		District :	Kalamazoo
		County :	SAINT JOSEPH
City : STURGIS	State: MI	Zip Code : 49091	Compliance Status : Compliance
Source Class : MAJOR		Staff :	Chance Collins
FCE Begin Date : 3/23/2021		FCE Completion Date :	3/24/2022
Comments : Full compliance evaluation. Facility appears to be in compliance.			

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
03/24/2022	ROP Annual Cert	Compliance	ROP Annual compliance certification. No deviations reported.
03/24/2022	ROP SEMI 2 CERT	Compliance	ROP Semi 2 certification. No deviations reported.
03/23/2022	On-site Inspection	Compliance	Scheduled Inspection for FCE
02/17/2022	NESHAP (Part 61)	Compliance	40 CFR Part 63, Subpart ZZZZ: Semi-annual Compliance Report
12/02/2021	ROP R215 Notification	Compliance	New Responsible Official is Michael Hughes, City Manager
09/23/2021	NESHAP (Part 61)	Compliance	40 CFR Part 63, Subpart ZZZZ: Semi-annual Compliance Report
09/23/2021	ROP Semi 1 Cert	Compliance	Semi annual ROP Certification 1. One deviation reported as described on Annual ROP Certification. CMS time stamp error during duration. CMS replaced in January 2021. Corrective action adequate.
05/13/2021	ROP Annual Cert	Compliance	Annual Compliance Certification form. One deviation reported. CMS had incorrect time stamp during entire time period. Pressure test not performed through front panel. Corrective action adequate, new CMS installed January 2021.

Activity Date	Activity Type	Compliance Status	Comments
05/13/2021	ROP SEMI 2 CERT	Compliance	Semi annual ROP Certification 2. One deviation reported as described on Annual ROP Certification. CMS time stamp error during duration. CMS replaced in January 2021. Corrective action adequate.

Name: 

Date: 3/24/22

Supervisor: RIL 3/24/22