

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
ACTIVITY REPORT: Scheduled Inspection

B753645115

FACILITY: HILLSDALE CITY OF PUBLIC UTILITIES		SRN / ID: B7536
LOCATION: 201 WATERWORKS AVE, HILLSDALE		DISTRICT: Jackson
CITY: HILLSDALE		COUNTY: HILLSDALE
CONTACT: Chris McArthur , Director		ACTIVITY DATE: 07/11/2018
STAFF: Brian Carley	COMPLIANCE STATUS: Compliance	SOURCE CLASS: MAJOR
SUBJECT: Scheduled inspection		
RESOLVED COMPLAINTS:		

Contact: Chris McArthur, Director of Utilities
Email: cmcarthur@hillsdalebpu.com
Phone: 517-437-6418

I arrived at the facility for a scheduled inspection and met with Chris McArthur and Brian Bennett of HBPU and Matt Burk from the Michigan Public Power Agency. We first discussed their upcoming ROP renewal application. Units 2, 3, and 4 have not run in a very long time and probably never will again due to the engines being so old and spare parts are hard to come by. Since they will have to do potential to emit (PTE) calculations for their ROP renewal application, I told them to look at what the PTE would be with just Units 5 and 6 once they permanently disconnect Units 2, 3, and 4. If it was below significance, then we should talk about voiding the ROP and if they would need an PTI or not. If they do not permanently disconnect Units 2,3, and 4 before their ROP renewal application is due (January 28, 2019), they will need to submit the ROP renewal application. There is the possibility that they may in the future bring in a turbine for additional power available, but nothing is in the works at this time.

At the time of the inspection, none of the engines were operating. Brian showed me the fuel specifications for their latest fuel shipment, which stated that the sulfur content of the fuel was 15 ppm (0.0015%). This is well below their limit of 1.0% sulfur content.

Based on the information provided during the inspection and the required reports that have been submitted, I have determined that they are in compliance with their ROP. I thanked them for time and left.

NAME Brian Carley

DATE 7/12/18

SUPERVISOR [Signature]