

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION
ACTIVITY REPORT: Scheduled Inspection

B793334217

FACILITY: JOHNSON OIL CO OF GAYLORD		SRN / ID: B7933
LOCATION: 812 E PARK, LAKE CITY		DISTRICT: Cadillac
CITY: LAKE CITY		COUNTY: MISSAUKEE
CONTACT:		ACTIVITY DATE: 04/07/2016
STAFF: Kurt Childs	COMPLIANCE STATUS: Compliance	SOURCE CLASS: MINOR
SUBJECT: Compliance Inspection.		
RESOLVED COMPLAINTS:		

This was a minor source "other" scheduled inspection conducted for Fiscal Year 2016. This facility was last inspected on 9/11/2008. The source has SRN B7933 but there are no records of a permit to install in District office files or the Permit Cards database. The source address of record is 812 E. Park St. This appears to be the address of a strip mall in Lake City, perhaps a previous company office location. The actual source location is at 5507 W. Houghton Lake Rd and the current office location is 5122 W. Houghton Lake Rd.

The source is a fleet fueling center consisting of 6 fuel pumps, three small above ground tanks holding "Rec Gas" and "Off-Road Diesel". There also appeared to be 5 underground tanks and a loading rack. There does not appear to be any equipment or processes that require an air use permit under the Michigan Air Pollution Control Rules. This source is not subject to air emission reporting requirements. The source may be subject to 40 CFR 63, Subpart CCCCCC for gasoline dispensing facilities which is applicable to area sources. The MDEQ Air Quality Division does not have delegation for this regulation therefore additional review was not conducted.

This source does not appear to be subject to 40 CFR 63, Subpart R or BBBBBB (6B) for gasoline distribution since it does not meet the definition of a Bulk Loading facility. This Source does not appear to be subject to 40 CFR 60, Subpart K, Ka, or Kb for Petroleum Liquid Storage or 40 CFR 60, Subpart XX for Bulk Gasoline terminals since these regulations apply to tanks greater than 40,000 gallons and bulk loading facilities respectively.

NAME



DATE

4/14/2016

SUPERVISOR

