

DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : ZEELAND BOARD OF PUBLIC WORKS	SRN : B7977
Location : 347 E. Washington Ave.	District : Grand Rapids
	County : OTTAWA
City : ZEELAND State: MI Zip Code : 49464	Compliance Status : Compliance
Source Class : MAJOR	Staff : Laura Martin
FCE Begin Date : 10/15/2023	FCE Completion Date : 10/15/2024
Comments : FCE following inspection.	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
10/15/2024	On-site Inspection	Compliance	Scheduled, unannounced inspection 2024.
09/10/2024	ROP Semi 1 Cert	Compliance	The Semi-Annual Compliance report pursuant to MI-ROP-B7977-2022 was received on time and complete. No deviations were reported for the reporting period.
09/10/2024	MACT (Part 63)	Compliance	The Semiannual Compliance Report pursuant to NESHAP, 40 CFR 63 Subpart ZZZZ and MI-ROP-B7977-2022 was received on time and complete. No deviations were reported for the reporting period, and no periodic testing was conducted. Of the seven (7) engines, Engine 11 operated the most, operating a total of 34.8 hours.
04/05/2024	Annual Emissions Report (or MAERS)	Compliance	Report Certification verifying submittal of MAERS (MiEnviro SLEIS) Received on-time. Facility is using system provided EF so no supporting documentation is needed. Submission is acceptable.
02/07/2024	ROP Annual Cert	Compliance	The Annual Compliance report pursuant to MI-ROP-B7977-2022 was received on time and complete. No deviations were reported for the reporting period.

Activity Date	Activity Type	Compliance Status	Comments
02/07/2024	ROP SEMI 2 CERT	Compliance	The Semi-Annual Compliance report pursuant to MI-ROP-B7977-2022 was received on time and complete. No deviations were reported for the reporting period.
02/07/2024	MACT (Part 63)	Compliance	Annual Compliance Report pursuant to 40 CFR 63 Subpart ZZZZ. No deviations were reported for the reporting period. Stack testing was performed during the reporting period and all engines meet the 70% CO reduction requirement. Operating hours for the engines during the reporting period were all 34.3 hours or less.

Name:

R. Marti

Date:

10/30/24

Supervisor:

