


DEPARTMENT OF ENVIRONMENTAL QUALITY
AIR QUALITY DIVISION

FCE Summary Report

Facility : GRAND VALLEY STATE UNIVERSITY	SRN : G7126
Location : 123 Service Building 1 Campus Drive	District : Grand Rapids
	County : OTTAWA
City : ALLENDALE State: MI Zip Code : 49401	Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Steve Lachance
FCE Begin Date : 7/17/2013	FCE Completion Date : 7/17/2014
Comments : FCE for FY '014 (SLachance, 7/17/14)	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
07/16/2014	Scheduled Inspection	Compliance	Scheduled Inspection for FY '014; on-site activities 7/16/14
03/19/2014	MAERS	Compliance	No changes to database as submitted; see comments in electronic MAERS Audit Console. (SLachance, 3/19/14)
12/19/2013	Telephone Notes	Compliance	GVSU will be test burning fuel oil; SL reminded Mr. Pahl that total hours of fuel usage should be < 48 hours per year, otherwise the boiler would be classified as "Liquid Use" for Area Source Boiler MACT; and so subject to further regulation. (SLachance, 12/19/13)

Name:  Date: 7/17/14 Supervisor: 