

DEPARTMENT OF ENVIRONMENTAL QUALITY

AIR QUALITY DIVISION

FCE Summary Report

Facility : Beaumont Hospital Farmington Hills	SRN : K2729
Location : 28050 GRAND RIVER AVENUE	District : Warren
	County : OAKLAND
City : FARMINGTN HLS	State: MI Zip Code : 48336 Compliance Status : Compliance
Source Class : SM OPT OUT	Staff : Iranna Konanahalli
FCE Begin Date : 6/14/2020	FCE Completion Date : 6/15/2022
Comments : This is a NSPS Dc Cat D fee (Diesel backup boilers) subject source. Natural gas usage records for each boilers are kept upon installation of meters, instrumentation and controls (Siemens). The hospital has no source of odor because it has now shut down	

List of Partial Compliance Evaluations :

Activity Date	Activity Type	Compliance Status	Comments
02/10/2022	On-site Inspection	Compliance	FY 2022 SM CMS Scheduled Inspection of Beaumont Hospital (fka Botsford General Hospital), an osteopathic hospital, located at 28050 Grand River Avenue, Farmington Hills, Michigan 480336-5933.
04/15/2021	MAERS	Compliance	MAERS emission factors being used to calculate emissions for all equipment. Fuel throughput for generators decreased about 30% from RY 2019, boiler throughput decreased about 5%. Reported fuel throughputs are less than limit in PTI 17-18. Reported emissions: 4.2 tons CO, 6.8 tons NOx, rest of criteria pollutants less than 0.5 tons. MAERS report indicates EU-EGEAST was removed/dismantled 3/8/2021.

Name: Iranna Konanahalli Date: June 15, 2022

Supervisor: Joyce