## DEPARTMENT OF ENVIRONMENTAL QUALITY AIR QUALITY DIVISION

## **FCE Summary Report**

Facility: SRN: ASCENTION PROVIDENCE SOUTHFIELD M1967 **HOSPITAL** 16001 WEST NINE MILE RD Location : District: Warren County: **OAKLAND** SOUTHFIELD MI **Zip Code**: 48075 Compliance City: State: Compliance Status: Source Class: Staff: SM OPT OUT Iranna Konanahalli **FCE Completion** FCE Begin Date: 3/15/2021 5/31/2022 Date: Comments: Hospital EO sterilizers have been removed about September 2015. The boilers are incompliance with NSPS Dc and the permit. Em. Generators, which are used for testing purposes only and no emergency has occurred in over a decade, are not subject to CI RICE E

## **List of Partial Compliance Evaluations:**

Activity Date	Activity Type	Compliance Status	Comments
05/09/2022	MAERS	Compliance	MAERS Report Submission
			No full audit performed.
03/22/2022	On-site Inspection	Compliance	FY 2022 SM CMS scheduled inspection of Providence Hospital ("Providence")

Name: Illenauchalt. Date: May 31, 2022 Supervisor:

Page 1 of 1