



MK

M3431

ST. JOSEPH MERCY ANN ARBOR
5301 East Huron River Drive
P.O. Box 995
Ann Arbor, MI 48106-0995
Phone: 734-712-3456
sjmercyhealth.org

May 23, 2022

EGLE, AQD Jackson District
301 East Louis Glick Highway
Jackson MI 49201

RECEIVED
MDEQ - JACKSON
JUN 01 2022
AIR QUALITY DIVISION

RE: SRN M3431 Permit to Install 318-74C
AQD Inspection Conducted March 3, 2022
UPDATE

To whom it may concern:

This communication is a follow up to correspondence sent to EGLE dated March 28, 2022 regarding Violation Notice dated March 8, 2022.

The inspection was conducted by Mike Kovalchick on March 3, 2022. The Violation Notice made note of the four generator stacks had flipper type rain caps. The response was to contract for the installation of compliant No Loss Rain Stacks on all four exhaust pipes.

This communication confirms the no-loss rain stacks have been installed. Please see attached pictures.

Please do not hesitate to call or write with any additional questions.

Sincerely,

A handwritten signature in black ink, appearing to read "P. Gonyon".

Pierre Gonyon CHSP

System Envir. Safety and Health Leader
Engineering and Safety
St. Joseph Mercy - AA
5301 E Huron River Dr PO Box 995
Ann Arbor MI 48106
tel: 734-712-3315 fax: 734-712-5082
cell: 734-646-8723

Copy: Jenine Camillerii, Enforcement Unit Supervisor,
EGLE AQD, PO Box 30260
Lansing MI 48909-7760





GRETCHEN WHITMER
GOVERNOR

STATE OF MICHIGAN
DEPARTMENT OF
ENVIRONMENT, GREAT LAKES, AND ENERGY
JACKSON DISTRICT OFFICE



LIESL EICHLER CLARK
DIRECTOR

March 8, 2022

EMAIL and CERTIFIED MAIL

Pierre Gonyon
St. Joseph Mercy Hospital
5301 East Huron River Drive
PO Box 995
Ann Arbor, MI 48106-0995

SRN: M3431, Washtenaw County

Dear Pierre Gonyon:

VIOLATION NOTICE

On March 3, 2022, the Department of Environment, Great Lakes and Energy (EGLE), Air Quality Division (AQD), conducted an announced compliance inspection of St. Joseph Mercy Hospital (Hospital) located at 5301 East Huron River Drive, Ann Arbor Michigan. The purpose of this inspection was to determine the Hospital's compliance with the requirements of the federal Clean Air Act; Part 55, Air Pollution Control, of the Natural Resources and Environmental Protection Act, 1994 PA 451, as amended (Act 451) and the associated Air Pollution Control Rules, and conditions of Permit to Install (PTI) 318-74C.

During the inspection and subsequent records review, AQD staff determined the following:

Process Description	Rule/Permit Condition Violated	Comments
FGENGINES- Four diesel fuel-fired reciprocating engines driving electric generators.	PTI 318-74C Special Condition VIII. STACK/VENT RESTRICTION(S)- 1. SVENGINE1, 2. SVENGINE2, 3. SVENGINE3, 4. SVENGINE4.	4 stacks do not vent unobstructed vertically upward; have flipper style caps on top of exhaust stacks.

Please initiate actions necessary to correct the cited violations and submit a written response to this Violation Notice by March 30, 2022. The written response should include: the dates the violations occurred; an explanation of the causes and duration of the violations; whether the violations are ongoing; a summary of the actions that have been taken and are proposed to be taken to correct the violations and the dates by which these actions will take place; and what steps are being taken to prevent a reoccurrence.


Please submit written response to the EGLE, AQD Jackson District, at 301 East Louis B Glick Highway, Jackson, Michigan 49201, and submit copy to Ms. Jenine Camilleri, Enforcement Unit Supervisor at the DEQ, AQD P.O. Box 30260, Lansing, Michigan 48909-7760.

Pierre Gonyon
St. Joseph Mercy Hospital
March 8, 2022
Page 2

If the Hospital believes the above observations or statements are inaccurate or do not constitute violations of the applicable legal requirements cited, please provide appropriate factual information to explain your position.

Thank you for your attention to resolving the violations cited above and for the cooperation that was extended to me during my recent inspection. If you have any questions regarding the violations or the actions necessary to bring this facility into compliance, please contact me at the number listed below.

Sincerely,



Mike Kovalchick
Senior Environmental Engineer
Air Quality Division
517-416-5025

cc: Chris Ethridge, EGLE
Jenine Camillari, EGLE
Jeff Rathbun, EGLE
Scott Miller, EGLE