Interpoll Laboratories, Inc. 4500 Ball Road N.E. Circle Pines, Minnesota 55014-1819

> TEL: (763) 786-6020 FAX: (763) 786-7854

RECEIVED

AUG 1 8 2017

AIR QUALITY DIV.

RESULTS OF THE JUNE 28, 2017 AIR EMISSION COMPLIANCE TESTING AT THE LOUISIANA PACIFIC SIDING PLANT IN NEWBERRY, MICHIGAN

Submitted to:

LOUISIANA-PACIFIC CORPORATION 7299 North C.R. 403 Newberry, Michigan 49868

Attention:

Matt Hieshetter

Reviewed by:

Eakstadt

Kathleen Eickstadt Coordinator Source Testing

Report Number 17-36094 (RTO) August 2, 2017 SF/sef

1 INTRODUCTION

On June 28, 2017 Interpoll Laboratories personnel conducted Air Emission compliance testing at the Louisiana Pacific Corporation (LP) OSB Plant located in Newberry, Michigan on the following source:

Source	Condition(s)	Parameters
Dryer RTO Outlet	Flue Gas Recirculation Off	PM/PM10, NO _x , CO, VOC's, Opacity

On-site testing was performed by Trent Johnson, Kevin Chesler and Joey Saba. Coordination between testing activities and plant operation was provided by Matt Hieshetter of Louisiana Pacific Corp. The tests were witnessed by David Patterson and Joseph Scanlon of the Michigan Department of Environmental Quality.

Particulate evaluations were performed in accordance with EPA Methods 1-5, CFR Title 40, Part 60, and Appendix A (revised July 1, 2016). A preliminary determination of the gas linear velocity profile was made at each test location before the first particulate determination to allow selection of the appropriate nozzle diameter for isokinetic sample withdrawal. An Interpoll Labs sampling train, which meets or exceeds specifications in the above-cited reference was used to isokinetically extract particulate samples by means of a heated glass-lined probe. Wet catch samples were collected in the back half of the Method 5 sampling train and analyzed in accordance with EPA Method 202.

Oxygen, carbon dioxide, oxides of nitrogen, carbon monoxide and total hydrocarbon concentrations were determined in accordance with Methods 3A, 7E, 10 and 25A (Ibid). A slipstream of sample gas was withdrawn from the exhaust gas stream using a heated stainless steel probe equipped with a filter to remove interfering particulate material. The particulate-free gas was transported to the analyzers by means of a heat-traced probe and filter assembly. After passing through the filter, the gas passed through a chilled condenser-type moisture removal system. The particulate-free dry gas was then transported to the analyzers with the excess exhausted to the atmosphere through a calibrated orifice, which was used to ensure that the flow from the stack exceeds the requirements of the analyzers.

1

Total gaseous hydrocarbon concentrations were determined instrumentally using a VIG Model 20/2 heated flame ionization detector (HFID) calibrated against propane in air standards. The THC concentration was continuously monitored by extracting a slipstream of exhaust gas by means of a heated probe and filter holder. A heat-traced Teflon line was used to transport the sample gas from the filter holder outlet to the analyzer inlet.

The analog response of each analyzer was recorded with a computer datalogger. The O₂, CO₂, NOx, CO and VOC analyzers were calibrated with EPA Protocol 1 standard gases. The instrument was calibrated before and after each run.

Testing on the Dryer RTO Outlet was conducted from two test ports oriented at 90 degrees. These test ports are located approximately 5.7 diameters downstream and 6.6 diameters upstream of the nearest flow disturbances. A 20-point traverse was used to collect representative particulate samples. Each traverse point was sampled for 3 minutes to give a total sampling time of 60 minutes per run.

The results of the test are summarized in Section 2. Detailed results are presented in Section 3. Field data and all other supporting information are presented in the appendices.

2 SUMMARY AND DISCUSSION

The results of the compliance tests are summarized in the following tables. The particulate results have been calculated using the dry plus method 202 condensible wet catch. An overview of all results is presented in the table below:

PARAMETER	LIMIT	MEASURED
PM/PM-10 (Measured using EPA Methods 5/202)		
DRY + WET CATCH(GR/DSCF)	0.02	0.0015
(LB/HR)	7.9	0.558
Oxides of Nitrogen		
(ppm, d)	N/A	12.57
(LB/HR)	14.8	3.82
Carbon Monoxide		
	N/A	49.98
(LB/HR)	23.98	9.07
VOC's		
(ppm C, w)	N/A	18.87
·(LBC/HR)	5.12	1.93
Visible Emissions		
	N/A	0.0

DRYER RTO OUTLET (Without Flue Gas Re-Circulation)

No difficulties were encountered in the field by Interpoll Labs or in the laboratory evaluation of the samples, which were conducted by Interpoll Labs. On the basis of these facts and a complete review of the data and results, it is our opinion that the results reported herein are accurate and closely reflect the actual values, which existed at the time the test was performed.

Item		Run 1	Run 2	Run 3	Average	
Date of test		06-28-17	06-28-17	06-28-17		
Time (Start/Finish)	(Hrs)	0807 / 0909	0945 / 1047	1125 / 1227		
Volumetric Flow						
Actual	(ACFM)	75,308	77,453	76,199	76,320	
Standard	(SCFM)	54,228	54,972	54,689	54,630	
Dry Standard	(DSCFM)	42,119	42,654	42,640	42,471	
Gas Temperature	(°F)	250	260	252	254	
Moisture Content	(%v/v)	22.33	22.41	22.03	22.26	
Gas Composition	(%v/v, dry)					
Carbon Dioxide		3.49	3.59	3.60	3.56	
Oxygen		17.46	17.33	17.26	17.35	
Nitrogen		79,04	79.08	79.14	79.09	
Sample Volume	(dscf)	38.39	38.78	38.59	38.59	
sokinetic Variation	(%)	100.3	100.1	99.6	100.0	
Particulate Results-EPA Methods 5 & 202 (Dry	Impinger Techni	que)				
Dry Catch Only						
Sample Mass (Nozzle, PW, Filter)	(g)	0.0012	0.0011	0.0024		
Concentration - Actual	(GR/ACF)	0.00027	0.00024	0.00054	0.00035	
Concentration - Actual	(MG/ACM)	0.618	0.551	1.229	0.79940	
Concentration - Standard	(GR/D\$CF)	0.00048	0.00044	0.00096	0.00063	
Emission Rate	(LB/HR)	0.174	0.160	0.351	0.228	
Organic CPM					χ.	
Sample Mass	(g)	0.0011	0.0009	0.0011		
Concentration - Actual	(GR/ACF)	0.00025	0.00020	0.00025	0.000230	
Concentration - Standard	(GR/DSCF)	0.00044	0.00036	0.00044	0.000413	
Emission Rate	(LB/HR)	0.160	0.131	0.161	0.151	
norganic CPM						
Sample Mass	(g)	0.0013	0.0011	0.0013		2
Concentration - Actual	(GR/ACF)	0.00029	0.00024	0.00029	0.000275	è
Concentration - Standard	(GR/DSCF)	0.00052	0.00044	0.00052	0.000493	
Emission Rate	(LB/HR)	0.188	0.160	0.190	0.179	
Total Particulate (Dry + Organic + Inorganic)						
Sample Mass	(g)	0.0036	0.0031	0.0048		
Concentration - Actual	(GR/ACF)	0.00081	0.00068	0.00107	0.000854	
Concentration - Standard	(GR/DSCF)	0.00145	0.00123	0.00192	0.001533	
Emission Rate	(LB/HR)	0.522	0.451	0.701	0.558	

Test 1 Summary of the June 28, 2017 Particulate Emission Compliance Test on the RTO Stack (P002) at the LP facility in Newberry, Michigan.

4

RECEIVED

AUG 1 8 ZOIZ

Test 2	Summary of the Results of the June 28, 2017, Oxides of Nitrogen, Carbon Monoxide and VOC Emission Compliance Test on the	Dryer
	System (P002) RTO at the Louisiana Pacific Facility Located in Newberry, Michigan.	

Item		Run 1	Run 2	Run 3	Average
Date of test		06-28-17	06-28-17	06-28-17	
Time runs were done	(Hrs)	0807 / 0907	0945 / 1045	1125 / 1225	
Volumetric Flow					
Actual	(ACFM)	75,308	77,453	76,199	76,320
Standard	(DSCFM)	42,119	42,654	42,640	, 42,471
Gas Temperature	(°F)	250	260	252	254
Moisture Content	(%v/v)	22.33	22.41	22.03	22.26
Gas Composition	(%v/v, dry)				
Carbon Dioxide		3.49	3.59	3.60	3.56
Oxygen		17.46	17.33	17.26	17.35
Nitrogen		79.04	79.08	79.14	79.09
Analytical Results					
Nox (EPA Method 7E)					
Concentration - ppm, dry	(ppm, d)	11.851	13.398	12.462	12.57
Emission Rate	(LB/HR)	3.575	4.093	3.806	3.82
CO (EPA Method 10)					
Concentration - ppm, dry	(ppm, d)	46.703	45.505	54.718	48.98
Emission Rate	(LB/HR)	8.579	8.466	10.176	9.07
VOC Outlet (EPA Method 25a)					
Concentration - ppm, wet	(TGNM ppm, w as C)	17.22	17.99	21.41	18.87
Concentration - ppm, dry	(TGNM ppm, d as C)	22.17	23.18	27.47	24.27
Emission Rate	(TGNM LB/HR)	1.74	1.85	2.19	1.93

.

3 RESULTS

The results of all field and laboratory evaluations are presented in this section. Gas composition and moisture is presented first followed by the computer printout of the particulate, oxides of nitrogen, opacity, carbon monoxide, and total hydrocarbons results. Preliminary measurements including test port locations are given in the appendices.

The results have been calculated on a personal computer using programs written in using Microsoft Excel spreadsheets specifically for source testing calculations. EPA-published equations have been used as the basis of the calculation techniques in these programs. The emission rates have been calculated using the product of the concentration times flow method.

AUG 1 8 2017

Interpoll Laboratories Report Number 17-36094 Louisiana Pacific 36094

Test Number 1 RTO

Results of Gas Composition and Moisture Analyses --- Methods 3A and 4 (% v/v)

Date of Run		Run 1 06-28-17	Run 2 06-28-17	Run 3 06-28-17
Dry basis				
Carbon Dioxide Oxygen Nitrogen	(%) (%) (%)	3.49 17.46 79.04	3.59 17.33 79.08	3.60 17.26 79.14
Wet basis				
Carbon Dioxide Oxygen Nitrogen Water Vapor	(%) (%) (%)	2.71 13.56 61.39 22,33	2.79 13.45 61.36 22.41	2.80 13.46 61.71 22.03
Dry Molecular Weight Wet Molecular Weight Specific Gravity Water Mass Flow	(g/gmole) (g/gmole) (lb/hr)	29.26 26.74 0.924 33977	29.27 26.74 0.924 34547	29.27 26.78 0.925 33793
Fo		0.984	0.994	1.012

Test Number 1 RTO

Results of EPA Method 5/202 Sampling Data

		Run 1	Run 2	Run 3
Date of Test		06-28-17	06-28-17	06-28-17
		00 20 11	00 10 17	00 20 11
Time of Runs	(Hrs)	0807 / 0909	0945 / 1047	1125 / 1227
Static Pressure	(In. of WC)	-0.47	-0.47	-0.47
Cross Sectional Area	(III. 01 110) (Sq. ft)	22.17	22.17	22.17
Pitot Tube Coefficient	(09.17)	0.84	0.84	0.84
Materia Comula Ora				
Water in Sample Gas Impingers	(g)	222.5	226,4	224,8
Desiccant	(g)	11.6	11.1	6.5
Total	(g)	234.1	237.5	231.3
	(9)	201.1	201.0	201.0
Gas Meter Coefficient		1.0027	1.0027	1.0027
Barometric Pressure	(In. of Hg)	29.00	29.00	29.00
Avg. Orifice Pressure Drop	(In. of WC)	1.42	1.46	1.44
Avg. Gas Meter Temperature	(°F)	79.8	83.2	83.9
Volume Through Gas Meter				
Meter Conditions	(CF)	40.26	40.91	40.77
Standard Conditions	(DSCF)	38.39	38.78	38.59
Total Sampling Time	(Min.)	60.00	60.00	60.00
Nozzle Diameter	、(ln.)	0.248	0.248	0.248
Avg. Stack Gas Temperature		250	260	252
Volumetric Flow Rate				
Actual	(ACFM)	75,308	77,453	76,199
Dry Standard	(DSCFM)	42,119	42,654	42,640
•				
		,	··· , ···	

ER

VISIBLE EMISSIONS EVALUATOR

Kevin Chesler

This is to certify that the above named observer has met the specifications of Federal Reference Method 9 and is qualified as a visible emissions evaluator. Maximum deviation on white and black smoke did not exceed 7.5% opacity and no single error exceeding 15% opacity was incurred during the certification test conducted by Eastern Technical Associates, Inc. of Raleigh, N.C. This certificate is valid for six months

from date of issue.

4467<u>18</u> Certificate #

4/5/2017

10/5/2017

Date of Certification

Certification Expiration Date



Student ID Number

Minneapolis, MN

NonETA

Location

Marty Hughes