

Interpoll Laboratories, Inc.
4500 Ball Road N.E.
Circle Pines, Minnesota 55014-1819

TEL: (763) 786-6020
FAX: (763) 786-7854

RECEIVED

OCT 08 2020

AIR QUALITY DIVISION

***RESULTS OF THE AUGUST 4-6, 2020
AIR EMISSION COMPLIANCE TESTING
AT THE LOUISIANA PACIFIC SIDING
PLANT IN NEWBERRY, MICHIGAN***

Submitted to:

LOUISIANA-PACIFIC CORPORATION
7299 North C.R. 403
Newberry, Michigan 49868

Attention:

Nick Waddell

Reviewed by:



Kathleen Eickstadt
Coordinator
Source Testing

Report Number 20-38627
September 9, 2020
SF/sef

TABLE OF CONTENTS

ABBREVIATIONS iii

1 INTRODUCTION 1

2 SUMMARY AND DISCUSSION 3

3 RESULTS 22

 3.1 Results of Gas Composition & Moisture Determinations..... 23

 3.2 Particulate/PM-10 Sampling Data..... 28

 3.3 MDI Sampling Data..... 31

 3.4 Visual Emissions (EPA Method 9) 34

APPENDICES:

- A - Test Protocol
- B - Field Data Sheets
- C - Interpoll Laboratories Analytical Results
- D - Computer Datalogger Printouts
- E - Measurement Systems Performance Specifications
- F - Calibration Gas Certification Sheets
- G - Process Rate Information
- H - Procedures
- I - Calculation Equations
- J - Sampling Train Calibration Data
- K - EPA Method 320 Data
- L - EPA Method 320 QA/QC Data

RECEIVED

OCT 08 2020

AIR QUALITY DIVISION

ABBREVIATIONS

ACFM	actual cubic feet per minute
cc (ml)	cubic centimeter (milliliter)
DSCFM	dry standard cubic foot of dry gas per minute
DSML	dry standard milliliter
DEG-F (°F)	degrees Fahrenheit
DIA.	Diameter
FT/SEC	feet per second
g	gram
GPM	gallons per minute
GR/ACF	grains per actual cubic foot
GR/DSCF	grains per dry standard cubic foot
g/dscm	grams per dry standard meter
HP	horsepower
HRS	hours
IN.	inches
IN.HG.	inches of mercury
IN.WC.	inches of water
LB	pound
LB/DSCF	pounds per dry standard cubic foot
LB/HR	pounds per hour
LB/106BTU	pounds per million British Thermal Units heat input
LB/MMBTU	pounds per million British Thermal Units heat input
MW	megawatt
mg/dscm	milligrams per dry standard cubic meter
ug/dscm	micrograms per dry standard cubic meter
microns (um)	micrometer
MIN.	minutes
ng	nanograms
PM	particulate matter
PPH	pounds per hour
PPM	parts per million
ppmC	parts per million carbon
ppm,d	parts per million, dry
ppm,w	parts per million, wet
ppt	parts per trillion
PSI	pounds per square inch
SQ.FT.	square feet
TPD	tons per day
ug	micrograms
v/v	percent by volume
w/w	percent by weight

Standard conditions are defined as 68 °F (20 °C) and 29.92 IN. of mercury pressure

1 INTRODUCTION

On August 4-6, 2020 Interpoll Laboratories personnel conducted Air Emission compliance testing on the Dryer RTO and the East/West Press Vents at the Louisiana Pacific Corporation (LP) OSB Plant located in Newberry, Michigan. On-site testing was performed by Trent Johnson, Jim Thoma, Chris Warneke, Josh Kircher and Ed Juers. Coordination between testing activities and plant operation was provided by Nick Waddell of Louisiana Pacific Corp. The tests were witnessed by members of the State of Michigan Department of Environment, Great Lakes, and Energy.

Particulate evaluations were performed in accordance with EPA Methods 1-5, CFR Title 40, Part 60, and Appendix A (revised July 1, 2020). A preliminary determination of the gas linear velocity profile was made at each test location before the first particulate determination to allow selection of the appropriate nozzle diameter for isokinetic sample withdrawal. An Interpoll Labs sampling train, which meets or exceeds specifications in the above-cited reference was used to isokinetically extract particulate samples by means of a heated glass-lined probe. Wet catch samples were collected in the back half of the Method 5 sampling train and analyzed in accordance with EPA Method 202.

Oxygen, carbon dioxide, oxides of nitrogen, carbon monoxide and total hydrocarbon concentrations were determined in accordance with Methods 3A, 7E, 10 and 25A (Ibid). A slipstream of sample gas was withdrawn from the exhaust gas stream using a heated stainless steel probe equipped with a filter to remove interfering particulate material. The particulate-free gas was transported to the analyzers by means of a heat-traced probe and filter assembly. After passing through the filter, the gas passed through a chilled condenser-type moisture removal system. The particulate-free dry gas was then transported to the analyzers with the excess exhausted to the atmosphere through a calibrated orifice, which was used to ensure that the flow from the stack exceeds the requirements of the analyzers. For the sampling on the press vents, a 24 point traverse was used.

Total gaseous hydrocarbon concentrations were determined instrumentally using a VIG Model 20/2 heated flame ionization detector (HFID) calibrated against propane in air standards. The THC concentration was continuously monitored by extracting a slipstream of exhaust gas by means of a heated probe and filter holder. A heat-traced Teflon line was used to transport the sample gas from the filter holder outlet to the analyzer inlet.

The analog response of each analyzer was recorded with a computer datalogger. The O₂, CO₂, NO_x, CO and VOC analyzers were calibrated with EPA Protocol 1 standard gases. The instrument was calibrated before and after each run.

MDI concentrations were determined in accordance with EPA Method 207. This method employs collection of MDI with 1,2-PP in toluene reagent, with analysis by HPLC.

Both Formaldehyde and Acetaldehyde were sampled using EPA Method 320 (FTIR). The on-line gas analysis was performed using a MKS MultiGas 2030 FTIR based analyzer. The MKS MultiGas 2030 FTIR has a fixed gas cell path length of 5.11 Meters and the detector was cooled by the use of liquid nitrogen. The gas was transported to the FTIR analyzer through a heat traced Teflon line originating from the manifold system described above. Three one-hour runs were conducted for each test condition. A leak-check was performed prior to and following the test on the sampling the system and was found to be acceptable. The Method 320 Data is contained in Appendix K. A dynamic spike (pre-test/post-test) was performed according to the guidelines spelled out in EPA Method 320. This was done using a compressed gas cylinder with certified quantities of acetaldehyde and sulfur hexafluoride. This data can be found in Appendix L.

NCASI 98.01 was used to measure both Phenol (Press Vents) and Acrolein (RTO) concentrations. The stack gas sample was extracted using a heated glass probe and Teflon filter holder loaded with a glass fiber filter to remove any particulate material present. The sample collection system is composed of three midjet impingers in series. Each of the three impingers is loaded with approximately 10ml of high purity water. The sampling rate was set at approximately 400 cc per minute. The volume sampled was recorded using a calibrated dry gas meter (DGM). One spike and one duplicate run were performed. During the spike test, one of the two systems was spiked with representative targeted analytes to determine compound capture efficiencies. Following the conclusion of sampling (typically 60 minutes), the impinger contents were recovered and labeled. All spike recoveries fell within the method requirements of 70-130%. All duplicate test runs also met the method criteria.

The results of the test are summarized in Section 2. Detailed results are presented in Section 3. Field data and all other supporting information are presented in the appendices.

2 **SUMMARY AND DISCUSSION**

The results of the compliance tests are summarized in the following tables. An overview of all results is presented in the table below:

Table 1: DRYER RTO OUTLET (Without Flue Gas Re-Circulation)

<u>PARAMETER</u>	<u>LIMIT</u>	<u>MEASURED</u>
<i>CO (EPA Method 10)</i> <i>Lbs/Hr.</i>	23.98	8.26
<i>NOx (EPA Method 7E)</i> <i>Lbs/Hr.</i>	14.8	3.14
<i>VOC (EPA Method 25a)</i> <i>TGNM.Lbs.C./Hr.</i>	5.12	3.33
<i>Acetaldehyde (EPA Method 320)</i> <i>Lbs/Hr.</i>	1.17	≤ 0.23
<i>Formaldehyde (EPA Method 320)</i> <i>Lbs/Hr.</i>	1.11	0.880
<i>Acrolein (NCASI 98.01)</i> <i>Lbs/Hr.</i>	0.195	< 0.067
<i>Visible Emissions (EPA Method 9)</i> <i>%</i>	NA	0.00

Test 9 Summary of the Results of the August 6, 2020, Method 320 (VOC/HAP's) Emission Test on the Dryer RTO Outlet (Without flue gas re-circ) at the Louisiana Pacific facility located in Newberry, Michigan

Item			Run 1	Run 2	Run 3	Average
Date of test			08-06-20	08-06-20	08-06-20	
Time runs were done (ET) (Hrs)			1300 / 1400	1440 / 1540	1610 / 1710	
Volumetric Flow						
	Actual	(ACFM)	78,437	80,258	80,710	79,802
	Standard	(SCFM)	57,842	59,440	59,774	59,019
	Standard	(DSCFM)	46,753	48,161	47,950	47,621
Gas Temperature (°F)			239	236	236	237
Moisture Content (%v/v)			19.17	18.98	19.78	19.31
Gas Composition (%v/v, dry)						
	Carbon Dioxide		3.34	3.52	3.19	3.35
	Oxygen		17.58	17.90	17.64	17.71
	Nitrogen		79.08	78.58	79.17	78.94
Acetaldehyde						
	Concentration	(ppm, d)	≤ 0.65	≤ 0.72	≤ 0.78	≤ 0.72
	Concentration	(ppm, w)	≤ 0.53	≤ 0.58	≤ 0.63	≤ 0.58
	Emission Rate	(LB /HR)	≤ 0.21	≤ 0.24	≤ 0.26	≤ 0.23
Formaldehyde						
	Concentration	(ppm, d)	3.77	3.79	4.30	3.95
	Emission Rate	(LB /HR)	0.824	0.852	0.964	0.880

Results of NCASI 98.01 Determinations

Interpoll Laboratories Report Number 20-38627
 Louisiana Pacific
 Newberry, MI

Test Number 9
 RTO Outlet (Without flue gas re-circ)

		Run 1		Run 2		Run 3		Average	
Date of Test		08-06-20		08-06-20		08-06-20			
Time of Runs									
	Start (Hrs)	1300		1440		1610			
	End (Hrs)	1400		1540		1712			
	Total (Min)	60		60		60			
Moisture Content	(%v/v)	19.2		19.0		19.8			
Volumetric Flow Rate	(DSCFM)	46,753		48,161		47,950			
		Spike/Duplicate		Spike/Duplicate		Spike/Duplicate			
Sample Volume	(DSL)	28.57	26.26	27.99	26.29	26.44	24.49		
Acrolein	(ppm,d)	< 0.16	0.30	< 0.15	0.30	< 0.17	0.44	< 0.16	
	(ppm,d of duplicate)		< 0.17		0.17		0.19		
	(LB/HR)	< 0.065		< 0.064		< 0.072		< 0.067	
	(Spike %)		77.77		76.67		105.46		
	(Duplicate %)		3.39%		4.92%		3.91%		

5

Test 10 Summary of the August 6, 2020, Oxides of Nitrogen, Carbon Monoxide and VOC's Test on the RTO Outlet Stack (Without flue gas re-circ) at the LP facility located in Newberry, Michigan.

Item		Run 1	Run 2	Run 3	Average
Date of test		08-06-20	08-06-20	08-06-20	
Time runs were done	(Hrs)	1300 / 1400	1440 / 1540	1610 / 1712	
Volumetric Flow					
Actual	(ACFM)	78,437	80,258	80,710	79,802
Standard	(SCFM)	57,842	59,440	59,774	59,019
Standard	(DSCFM)	46,753	48,161	47,950	47,621
Gas Temperature	(°F)	239	236	236	237
Moisture Content	(%v/v)	19.17	18.98	19.78	19.31
Gas Composition (%v/v, dry)					
Carbon Dioxide		3.34	3.52	3.19	3.35
Oxygen		17.58	17.90	17.64	17.70
Nitrogen		79.08	78.58	79.17	78.94
Results:					
Oxides of Nitrogen (EPA Method 7E)					
Concentration	(ppm, d)	9.40	9.20	9.05	9.22
Emission Rate	(LB /HR)	3.15	3.17	3.11	3.14
9 Carbon Monoxide (EPA Method 10)					
Concentration	(ppm, d)	38.70	36.00	44.67	39.79
Emission Rate	(LB /HR)	7.89	7.56	9.34	8.26
VOC (EPA Method 25a)					
Concentration	(TGNM ppm Propane, d)	14.03	13.31	10.09	12.48
Concentration	(TGNM ppm Carbon, d)	42.10	39.94	30.26	37.44
Emission Rate (Lb x/Hr)	(TGNM LB Carbon/HR)	3.68	3.60	2.72	3.33
TGNM = Total Gaseous Non-methane					

Table 2: PRESS VENTS (EAST AND WEST)

PARAMETER	LIMIT		MEASURED	
		East	West	Total
PM/PM-10 (Measured using EPA Methods 5/202) <i>Lbs/Hr</i>	24.0	1.176	0.913	2.089
CO (EPA Method 10) <i>Lbs/Hr</i>	4.64	<0.23	0.61	≤0.84
NOx (EPA Method 7E) <i>Lbs/Hr</i>	1.36	<0.37	≤0.44	≤0.81
VOC (EPA Method 25a) <i>Lbs.C/Hr</i>	73.6	3.02	2.14	5.16
Formaldehyde (EPA Method 320) <i>Lbs/Hr</i>	4.1	≤0.704	≤0.877	≤1.58
Phenol (NCASI 98.01) <i>Lbs/Hr</i>	2.0	<0.31	<0.35	<0.66
MDI (OTM-14) <i>Lbs/Hr</i>	0.53	≤0.030	≤0.025	≤0.055

No difficulties were encountered in the field by Interpoll Labs or in the laboratory evaluation of the samples, which were conducted by Interpoll Labs. It should be noted that some results are presented with either a “<” sign or a “≤” sign. Those results showing the “<” indicate that all analytical fractions, or instrumental readings, were Below the Detection Level (BDL). If a “≤” sign is shown, it indicates that at least one analytical fraction or instrumental reading used to calculate final results, was below the detection level, however, there are also analytical fractions or instrumental readings which do include detectable hits, or Detection Level Limited (DLL). On the basis of these facts and a complete review of the data and results, it is our opinion that the results reported herein are accurate and closely reflect the actual values, which existed at the time the test was performed.

Test 1 Summary of the Results of the August 4, 2020, Particulate Emission Compliance Test on the East Press Vent at the Louisiana Pacific Facility located in Newberry, MI.

Item		Run 1	Run 2	Run 3	Average
Date of test		08-04-20	08-04-20	08-04-20	
Time (Start/Finish)	(Hrs)	0940 / 1144	1240 / 1443	1548 / 1803	
Volumetric Flow					
Actual	(ACFM)	112,536	113,973	110,973	112,494
Standard	(SCFM)	104,138	105,357	102,101	103,865
Dry Standard	(DSCFM)	102,491	103,778	101,031	102,433
Gas Temperature	(°F)	96	96	99	97
Moisture Content	(%v/v)	1.58	1.50	1.05	1.38
Gas Composition (%v/v, dry)					
∞	Carbon Dioxide	< 0.03	< 0.03	0.08	0.05
	Oxygen	20.63	20.43	20.38	20.48
	Nitrogen	79.34	79.54	79.54	79.48
Sample Volume	(dscf)	81.59	82.46	80.10	81.39
Isokinetic Variation	(%)	100.0	99.8	99.6	99.8
Particulate Results-EPA Methods 5 & 202 (Dry Impinger Technique)					
<i>Front Half Dry Catch Only (Filterable only)</i>					
Sample Mass (Nozzle, PW, Filter)	(g)	0.0037	0.0034	0.0037	
Concentration - Actual	(GR/ACF)	0.00064	0.00058	0.00065	0.00062
Concentration - Actual	(MG/ACM)	1.458	1.325	1.485	1.42259
Concentration - Standard	(GR/DSCF)	0.00070	0.00064	0.00071	0.00068
Emission Rate	(LB/HR)	0.615	0.566	0.617	0.599
<i>Total Particulate (Dry + Organic + Inorganic)</i>					
Sample Mass	(g)	0.007	0.0067	0.0075	
Concentration - Actual	(GR/ACF)	0.00121	0.00114	0.00132	0.001221
Concentration - Standard	(GR/DSCF)	0.00132	0.00125	0.00145	0.001341
Emission Rate	(LB/HR)	1.163	1.115	1.251	1.176

Test 2 Summary of the August 4, 2020, Oxides of Nitrogen, Carbon Monoxide and VOC Emission Test on the Press Vent Stack (East) at the Louisiana Pacific Facility located in Newberry, MI.

Item		Run 1	Run 2	Run 3	Average				
Date of test		08-04-20	08-04-20	08-04-20					
Time runs were done (Hrs)		0940 / 1043	1240 / 1343	1548 / 1651					
Volumetric Flow									
Actual	(ACFM)	112,536	113,973	110,973	112,494				
Standard	(SCFM)	104,138	105,357	102,101	103,865				
Standard	(DSCFM)	102,491	103,778	101,031	102,433				
Gas Temperature (°F)		96	96	99	97				
Moisture Content (%v/v)		1.58	1.50	1.05	1.38				
Gas Composition (%v/v, dry)									
Carbon Dioxide	<	0.03	<	0.03	0.08				
Oxygen		20.63	20.43	20.38	20.48				
Nitrogen		79.34	79.54	79.54	79.48				
Results									
Nox									
NO	Concentration - ppm, dry	(ppm, d) <	0.502	<	0.502	<	0.502	<	0.502
	Emission Rate	(LB/HR) <	0.369	<	0.373	<	0.363	<	0.368
CO									
CO	Concentration - ppm, dry	(ppm, d) <	0.536	<	0.504	<	0.540	<	0.526
	Emission Rate	(LB/HR) <	0.24	<	0.21	<	0.24	<	0.228
VOC									
VOC	Concentration - ppm, dry	(ppm C, d)	21.44	14.37	11.44	15.750			
	Emission Rate	(LB C/HR)	4.11	2.79	2.16	3.017			

(<) a minimum detection limit of 2.0% of span gas was used to calculate results for NOx and CO.

Results of NCASI 98.01 Determinations

Interpoll Laboratories Report Number 20-38627
 Louisiana Pacific
 Newberry, MI

Test Number 3
 East Press Stack

	Run 1	Run 2	Run 3	Average
Date of Test	08-04-20	08-04-20	08-04-20	
Time of Runs				
Start (Hrs)	0940	1240	1548	
End (Hrs)	1043	1343	1651	
Total (Min)	60	60	60	
Moisture Content (%v/v)	1.6	1.5	1.0	
Volumetric Flow Rate (DSCFM)	102,491	103,778	101,030	
	Spike/Duplicate		Spike/Duplicate	
Sample Volume (DSL)	29.87	23.07	29.83	28.66
			30.22	28.47
Phenol (ppm,d)	< 0.20	1.44	< 0.21	1.12
(ppm,d of duplicate)	<	0.31	<	0.22
(LB/HR)	< 0.30		< 0.31	
(Spike %)		105.65		102.32
(Duplicate %)		23.15%		3.03%
				104.72
				0.05%
				8.74%

Test 3 Summary of the Results of the August 4, 2020, Method 320 (Formaldehyde) Emission Test on the East Press Stack at the Louisiana Pacific facility located in Newberry, Michigan.

Item		Run 1	Run 2	Run 3	Average
Date of test		08-04-20	08-04-20	08-04-20	
Time runs were done (ET) (Hrs)		0940 / 1043	1240 / 1343	1548 / 1651	
Volumetric Flow					
Actual	(ACFM)	112,536	113,973	110,973	112,494
Standard	(SCFM)	104,138	105,357	102,101	103,865
Standard	(DSCFM)	102,491	103,778	101,031	102,433
Gas Temperature (°F)		96	96	99	97
Moisture Content (%v/v)		2.03	1.66	1.05	1.58
Gas Composition (%v/v, dry)					
Carbon Dioxide	<	0.03	<	0.08	0.05
Oxygen		20.63	20.43	20.38	20.48
Nitrogen		79.34	79.54	79.54	79.47
Formaldehyde (Detection Limit ppm)		0.13	0.13	0.13	
Concentration	(ppm, d) ≤	1.17	2.02	1.21	1.47
Emission Rate	(LB /HR) ≤	0.562	0.980	0.570	0.704

11

Test 4 Summary of the August 5, 2020 MDI Emission Compliance Test on the Press Vent Stack (East) at the Louisiana Pacific facility in Newberry, MI.

Item		Run 1	Run 2	Run 3	Average
Date of test		08-05-20	08-05-20	08-05-20	
Time runs were done	(Hrs)	0850 / 1008	1110 / 1213	1305 / 1408	
Volumetric Flow					
Actual	(ACFM)	109,667	109,452	114,246	111,122
Standard	(DSCFM)	100,729	99,064	103,510	101,101
Gas Temperature	(°F)	81	80	81	81
Moisture Content	(%v/v)	1.23	1.24	0.84	1.11
Gas Composition	(%v/v, dry)				
Carbon Dioxide		0.03	0.03	0.03	0.03
Oxygen		20.90	20.90	20.90	20.90
Nitrogen		79.07	79.07	79.07	79.07
Isokinetic Variation	(%)	99.9	99.7	99.5	99.7
MDI Results					
Sample Volume	(DSCF)	40.06	39.31	40.99	40.12
Total Micrograms in Sample	(ug)	70.36	79.36	120.36	90.03
Concentration	(gr/dscf)	0.0000271	0.0000311	0.0000453	0.0000345
Concentration	(ppm,d)	0.00596	0.00685	0.00996	0.00759
Emission Rate	(LB/HR)	0.0234	0.0264	0.04019	0.0300
Emission Rate	(g/sec)	0.002948	0.003332	0.005064	0.003781

Test 5 Summary of the Results of the August 4, 2020, Particulate Emission Compliance Test on the West Press Stack at the LP Corporation Facility Located in Newberry, Michigan.

Item	Run 1	Run 2	Run 3	Average
Date of test	08-04-20	08-04-20	08-04-20	
Time (Start/Finish) (Hrs)	0940 / 1145	1240 / 1243	1548 / 1800	
Volumetric Flow				
Actual (ACFM)	102,987	102,949	105,391	103,776
Standard (SCFM)	95,246	95,404	99,054	96,568
Dry Standard (DSCFM)	93,844	94,032	97,568	95,148
Gas Temperature (°F)	97	96	88	94
Moisture Content (%v/v)	1.47	1.44	1.50	1.47
Gas Composition (%v/v, dry)				
Carbon Dioxide	0.05	0.03	0.06	0.05
Oxygen	20.85	20.89	20.90	20.88
Nitrogen	79.10	79.08	79.04	79.07
Sample Volume (dscf)	79.86	80.46	83.58	81.30
Isokinetic Variation (%)	99.4	99.9	100.0	99.8
Particulate Results-EPA Methods 5 & 202 (Dry Impinger Technique)				
<i>Front Half Dry Catch Only (Filterable only)</i>				
Sample Mass (Nozzle, PW, Filter) (g)	0.0033	0.0025	0.0031	
Concentration - Actual (GR/ACF)	0.00058	0.00044	0.00053	0.00052
Concentration - Actual (MG/ACM)	1.330	1.002	1.213	1.18155
Concentration - Standard (GR/DSCF)	0.00064	0.00048	0.00057	0.00056
Emission Rate (LB/HR)	0.513	0.386	0.478	0.459
<i>Total Particulate (Dry + Organic + Inorganic)</i>				
Sample Mass (g)	0.0056	0.0054	0.0067	
Concentration - Actual (GR/ACF)	0.00099	0.00095	0.00115	0.001026
Concentration - Standard (GR/DSCF)	0.00108	0.00104	0.00124	0.001118
Emission Rate (LB/HR)	0.870	0.835	1.034	0.913

13

RECEIVED
 OCT 08 2021
 AIR QUALITY DIVISION

Test 6 Summary of the Results of the August 4, 2020, Oxides of Nitrogen, Carbon Monoxide and VOC's Test on the West Press Stack at the Louisiana Pacific facility located in Newberry, MI.

Item		Run 1	Run 2	Run 3	Average
Date of test		08-04-20	08-04-20	08-04-20	
Time runs were done	(Hrs)	0940 / 0944	1240 / 1343	1548 / 1651	
Volumetric Flow					
Actual	(ACFM)	102,987	102,949	105,391	103,776
Standard	(SCFM)	95,246	95,404	99,054	96,568
Standard	(DSCFM)	93,844	94,032	97,568	95,148
Gas Temperature	(°F)	97	96	88	94
Moisture Content	(%v/v)	1.47	1.44	1.50	1.47
Gas Composition	(%v/v, dry)				
Carbon Dioxide		0.05	0.03	0.06	0.05
Oxygen		20.85	20.89	20.90	20.88
Nitrogen		79.10	79.08	79.04	79.07

Results:

Oxides of Nitrogen (EPA Method 7E)							
Concentration	(ppm, d) <	0.50	<	0.50	0.92	>	0.64
Emission Rate	(LB /HR) <	0.33	<	0.33	0.65	>	0.44
Carbon Monoxide (EPA Method 10)							
Concentration	(ppm, d)	1.35	1.12	1.90	1.46		
Emission Rate	(LB /HR)	0.55	0.46	0.81	0.61		
VOC (EPA Method 25a)							
Concentration	(ppm Propane, d)	4.53	3.37	4.10	4.00		
Concentration	(ppm Carbon, d)	13.59	10.10	12.31	12.00		
Emission Rate (Lb x/Hr)	(LB Carbon/HR)	2.39	1.78	2.24	2.14		
Emission Rate (Lb x/Hr)	(LB Propane/HR)	2.92	2.18	2.75	2.62		

(<) a minimum detection limit of 2.0% of span gas was used to calculate results for NOx.

Test 7 Summary of the Results of the August 4, 2020, Method 320 (HAP's) Emission Test on the West Press Stack at the Louisiana Pacific facility located in Newberry, MI.

15

Item			Run 1	Run 2	Run 3	Average
Date of test			08-04-20	08-04-20	08-04-20	
Time runs were done (ET) (Hrs)			0940 / 1044	1240 / 1343	1548 / 1651	
Volumetric Flow						
	Actual (ACFM)		102,987	102,949	105,391	103,776
	Standard (DSCFM)		93,844	94,034	97,568	95,149
Gas Temperature (°F)			97	96	88	94
Moisture Content (%v/v)			1.74	1.43	1.49	1.55
Gas Composition (%v/v, dry)						
	Carbon Dioxide		0.05	0.03	0.06	0.05
	Oxygen		20.85	20.89	20.90	20.88
	Nitrogen		79.10	79.08	79.04	79.07
Formaldehyde						
	Concentration (ppm, d)		2.62	1.56	1.75	1.98
	Emission Rate (LB /HR)		1.148	0.684	0.799	0.877

Results of NCASI 98.01 Determinations

Interpoll Laboratories Report Number 20-38627
 LP / Newberry
 Newberry, MI

Test Number 7
 West Press Stack

		Run 1		Run 2		Run 3		Average				
Date of Test		08-04-20		08-04-20		08-04-20						
Time of Runs												
Start	(Hrs)	0940		1240		1548						
End	(Hrs)	1044		1343		1648						
Total	(Min)	60		60		60						
Moisture Content	(%v/v)	1.5		1.4		1.5						
Volumetric Flow Rate	(DSCFM)	93,844		94,032		97,568						
Sample Volume	(DSL)											
		Spike/Duplicate		Spike/Duplicate		Spike/Duplicate						
		25.39	24.41	25.39	24.41	25.75	24.79					
Phenol	(ppm,d)	<	0.27	1.35	<	0.25	1.31	<	0.24	1.40	<	0.25
	(ppm,d of duplicate)		<	0.25		<	0.25		<	0.25		<
	(LB/HR)	<	0.37		<	0.35		<	0.34		<	0.35
	(Spike %)			98.80			96.09			104.24		97.44
	(Duplicate %)			2.48%			0.32%			2.10%		1.40%

Test 8 Summary of the August 5, 2020 MDI Emission Compliance Test on the West Press Stack at the Louisiana Pacific facility located in Newberry, MI.

Item		Run 1	Run 2	Run 3	Average
Date of test		08-05-20	08-05-20	08-05-20	
Time runs were done	(Hrs)	0850 / 1009	1110 / 1213	1305 / 1409	
Volumetric Flow					
Actual	(ACFM)	110,516	111,467	111,610	111,198
Standard	(SCFM)	101,482	100,173	100,808	100,821
Standard	(DSCFM)	100,831	98,422	99,614	99,623
Gas Temperature	(°F)	75	80	79	78
Moisture Content	(%v/v)	0.64	1.75	1.18	1.19
Gas Composition (%v/v, dry)					
Carbon Dioxide		0.03	0.03	0.03	0.03
Oxygen		20.90	20.90	20.90	20.90
Nitrogen		79.07	79.07	79.07	79.07
Isokinetic Variation	(%)	98.9	101.1	99.8	99.9
MDI Results					
Sample Volume	(DSCF)	29.23	29.15	29.13	29.17
Total Micrograms in Sample	(ug)	≤ 55.4	≤ 52.4	≤ 60.4	≤ 56.0
Concentration	(gr/dscf)	≤ 0.0000292	≤ 0.0000277	≤ 0.0000320	≤ 0.0000296
Concentration	(ppm,d)	≤ 0.00643	≤ 0.00610	≤ 0.00703	≤ 0.00652
Emission Rate	(LB/HR)	≤ 0.02525	≤ 0.0234	≤ 0.02730	≤ 0.0253
Emission Rate	(g/sec)	≤ 0.003181	≤ 0.002946	≤ 0.003440	≤ 0.003189

RESULTS

The results of all field and laboratory evaluations are presented in this section. Gas composition and moisture is presented first followed by the computer printout of the particulate, and trace metals sampling data. Preliminary measurements including test port locations are given in the appendices.

The results have been calculated on a personal computer using programs written in using Microsoft Excel spreadsheets specifically for source testing calculations. EPA-published equations have been used as the basis of the calculation techniques in these programs. The emission rates have been calculated using the product of the concentration times flow method.

3.1 Results of Gas Composition and Moisture Determinations

Test Number 1
East Press Stack

Results of Gas Composition and Moisture Analyses --- Methods 3A and 4 (% v/v)

Date of Run		Run 1 08-04-20	Run 2 08-04-20	Run 3 08-04-20
Dry basis				
Carbon Dioxide.....	(%)	0.03	0.03	0.08
Oxygen.....	(%)	20.63	20.43	20.38
Nitrogen.....	(%)	79.34	79.54	79.54
Wet basis				
Carbon Dioxide.....	(%)	0.03	0.03	0.08
Oxygen.....	(%)	20.30	20.12	20.16
Nitrogen.....	(%)	78.09	78.35	78.71
Water Vapor.....		1.58	1.50	1.05
Dry Molecular Weight.....	(g/gmole)	28.83	28.82	28.83
Wet Molecular Weight.....	(g/gmole)	28.66	28.66	28.71
Specific Gravity.....		0.990	0.990	0.992
Water Mass Flow.....	(lb/hr)	4620	4427	3002

Test Number 4
Press Vent Stack (East)

Results of Gas Composition and Moisture Analyses --- Methods 3A and 4 (% v/v)

Date of Run		Run 1 08-05-20	Run 2 08-05-20	Run 3 08-05-20
Dry basis				
Carbon Dioxide.....	(%)	0.03	0.03	0.03
Oxygen.....	(%)	20.90	20.90	20.90
Nitrogen.....	(%)	79.07	79.07	79.07
Wet basis (Orsat)				
Carbon Dioxide.....	(%)	0.03	0.03	0.03
Oxygen.....	(%)	20.64	20.64	20.72
Nitrogen.....	(%)	78.10	78.09	78.40
Water Vapor.....		1.23	1.24	0.84
Dry Molecular Weight.....	(g/gmole)	28.84	28.84	28.84
Wet Molecular Weight.....	(g/gmole)	28.71	28.71	28.75
Specific Gravity.....		0.992	0.992	0.993
Water Mass Flow.....	(lb/hr)	3527	3499	2437

Test Number 5
 West Press Stack

Results of Gas Composition and Moisture Analyses --- Methods 3A and 4 (% v/v)

		Run 1	Run 2	Run 3
Date of Run		08-04-20	08-04-20	08-04-20
Dry basis				
Carbon Dioxide.....	(%)	0.05	0.03	0.06
Oxygen.....	(%)	20.85	20.89	20.90
Nitrogen.....	(%)	79.10	79.08	79.04
Wet basis				
Carbon Dioxide.....	(%)	0.05	0.03	0.06
Oxygen.....	(%)	20.54	20.59	20.59
Nitrogen.....	(%)	77.94	77.94	77.85
Water Vapor.....		1.47	1.44	1.50
Dry Molecular Weight.....	(g/gmole)	28.84	28.84	28.85
Wet Molecular Weight.....	(g/gmole)	28.68	28.68	28.68
Specific Gravity.....		0.991	0.991	0.991
Water Mass Flow.....	(lb/hr)	3933	3848	4168

Test Number 8
 West Press Stack

Results of Gas Composition and Moisture Analyses --- Methods 3A and 4 (% v/v)

		Run 1	Run 2	Run 3
Date of Run		08-05-20	08-05-20	08-05-20
Dry basis				
Carbon Dioxide.....	(%)	0.03	0.03	0.03
Oxygen.....	(%)	20.90	20.90	20.90
Nitrogen.....	(%)	79.07	79.07	79.07
Wet basis (Orsat)				
Carbon Dioxide.....	(%)	0.03	0.03	0.03
Oxygen.....	(%)	20.77	20.53	20.65
Nitrogen.....	(%)	78.56	77.69	78.13
Water Vapor.....		0.64	1.75	1.18
Dry Molecular Weight.....	(g/gmole)	28.84	28.84	28.84
Wet Molecular Weight.....	(g/gmole)	28.77	28.65	28.71
Specific Gravity.....		0.994	0.990	0.992
Water Mass Flow.....	(lb/hr)	1825	4911	3347

3.2 Particulate Sampling Data

Test Number 1
East Press Stack

Results of EPA Method 5/202 Sampling Data

		Run 1	Run 2	Run 3
Date of Test		08-04-20	08-04-20	08-04-20
Time of Runs	(Hrs)	0940 / 1144	1240 / 1443	1548 / 1803
Static Pressure	(In. of WC)	-2.10	-2.10	-2.10
Cross Sectional Area	(Sq. ft)	26.27	26.27	26.27
Pitot Tube Coefficient		0.84	0.84	0.84
Avg. Sq. root of Delta p		1.219	1.234	1.200
Water in Sample Gas				
Impingers	(g)	1.5	2.1	-0.7
Desiccant	(g)	26.3	24.5	18.7
Total	(g)	27.8	26.6	18.0
Gas Meter Coefficient		0.9927	0.9927	0.9927
Barometric Pressure	(In. of Hg)	29.29	29.29	29.29
Avg. Orifice Pressure Drop	(In. of WC)	1.66	1.70	1.64
Avg. Gas Meter Temperature	(°F)	84.4	82.3	81.9
Volume Through Gas Meter				
Meter Conditions	(CF)	86.24	86.82	84.29
Standard Conditions	(DSCF)	81.59	82.46	80.10
Total Sampling Time	(Min.)	120.00	120.00	120.00
Nozzle Diameter	(In.)	0.179	0.179	0.179
Avg. Stack Gas Temperature	(°F)	96	96	99
Volumetric Flow Rate				
Actual	(ACFM)	112,536	113,973	110,973
Dry Standard	(DSCFM)	102,491	103,778	101,031
Isokinetic Variation	(%)	100.0	99.8	99.6

Test Number 5
West Press Stack

Results of EPA Method 5/202 Sampling Data

		Run 1	Run 2	Run 3
Date of Test		08-04-20	08-04-20	08-04-20
Time of Runs	(Hrs)	0940 / 1145	1240 / 1243	1548 / 1800
Static Pressure	(In. of WC)	-1.20	-1.20	-1.20
Cross Sectional Area	(Sq. ft)	26.27	26.27	26.27
Pitot Tube Coefficient		0.84	0.84	0.84
Avg. Sq. root of Delta p		1.115706741	1.116474664	1.151009052
Water in Sample Gas				
Impingers	(g)	9.3	0.9	3.0
Desiccant	(g)	16.0	24.0	24.0
Total	(g)	25.3	24.9	27.0
Gas Meter Coefficient		0.9959	0.9959	0.9959
Barometric Pressure	(In. of Hg)	29.29	29.29	29.29
Avg. Orifice Pressure Drop	In. of WC)	1.81	1.86	1.93
Avg. Gas Meter Temperature	(°F)	78.0	79.2	78.7
Volume Through Gas Meter				
Meter Conditions	(CF)	83.12	83.93	87.08
Standard Conditions	(DSCF)	79.86	80.46	83.58
Total Sampling Time	(Min.)	120.00	120.00	120.00
Nozzle Diameter	(In.)	0.185	0.185	0.185
Avg. Stack Gas Temperature	(°F)	97	96	88
Volumetric Flow Rate				
Actual	(ACFM)	102,987	102,949	105,391
Dry Standard	(DSCFM)	93,844	94,032	97,568
Isokinetic Variation	(%)	99.4	99.9	100.0

3.3 MDI Sampling Data

Test Number 4
Press Vent Stack (East)

Results of EPA OTM-14 (MDI) Sampling Data

		Run 1	Run 2	Run 3
Date of Test		08-05-20	08-05-20	08-05-20
Time of Runs	(Hrs)	0850 / 1008	1110 / 1213	1305 / 1408
Static Pressure	(In. of WC)	-2.10	-2.10	-2.10
Cross Sectional Area	(Sq. ft)	26.27	26.27	26.27
Pitot Tube Coefficient		0.84	0.84	0.84
Water in Sample Gas				
Impingers	(g)	-1.4	3.1	-3.3
Desiccant	(g)	12.0	7.4	10.6
Total	(g)	10.6	10.5	7.3
Gas Meter Coefficient		0.9927	0.9927	0.9927
Barometric Pressure	(In. of Hg)	29.27	29.27	29.27
Avg. Orifice Pressure Drop	(In. of WC)	1.64	1.57	1.67
Avg. Gas Meter Temperature	(°F)	80.8	80.2	80.5
Volume Through Gas Meter				
Meter Conditions	(CF)	42.09	41.27	43.05
Standard Conditions	(DSCF)	40.06	39.31	40.99
Total Sampling Time	(Min.)	60.00	60.00	60.00
Nozzle Diameter	(In.)	0.179	0.179	0.179
Avg. Stack Gas Temperature	(°F)	93	101	102
Volumetric Flow Rate				
Actual	(ACFM)	109,667	109,452	114,246
Dry Standard	(DSCFM)	100,729	99,064	103,510
Isokinetic Variation	(%)	99.9	99.7	99.5

Test Number 8
West Press Stack

Results of EPA OTM-14 (MDI) Sampling Data

		Run 1	Run 2	Run 3
Date of Test		08-05-20	08-05-20	08-05-20
Time of Runs	(Hrs)	0850 / 1009	1110 / 1213	1305 / 1409
Static Pressure	(In. of WC)	-1.20	-1.20	-1.20
Cross Sectional Area	(Sq. ft)	26.27	26.27	26.27
Pitot Tube Coefficient		0.84	0.84	0.84
Water in Sample Gas				
Impingers	(g)	-1.0	6.0	3.4
Desiccant	(g)	5.0	5.0	4.0
Total	(g)	4.0	11.0	7.4
Gas Meter Coefficient		0.9959	0.9959	0.9959
Barometric Pressure	(In. of Hg)	29.26	29.26	29.26
Avg. Orifice Pressure Drop	(In. of WC)	0.92	0.92	0.91
Avg. Gas Meter Temperature	(°F)	74.5	79.6	78.8
Volume Through Gas Meter				
Meter Conditions	(CF)	30.33	30.53	30.46
Standard Conditions	(DSCF)	29.23	29.15	29.13
Total Sampling Time	(Min.)	60.00	60.00	60.00
Nozzle Diameter	(In.)	0.153	0.153	0.153
Avg. Stack Gas Temperature	(°F)	101	113	110
Volumetric Flow Rate				
Actual	(ACFM)	110,516	111,467	111,610
Dry Standard	(DSCFM)	100,831	98,422	99,614
Isokinetic Variation	(%)	98.9	101.1	99.8

3.4 Visual Emission (EPA Method 9)



Certification of Visible Opacity Reading

Edward Juers III

qualified to conduct EPA Method 9 Tests for visible opacity in accordance with the methods established for such qualification in 40 CFR Part 60 Appendix A.

Certification Date: June 04, 2020

Expiration Date: December 04, 2020

AeroMet Instructor: Jim Breese

AEROMET ENGINEERING INC. CERTIFIES THAT

Edward Juers III

**has qualified as a CERTIFIED VISIBLE
EMISSIONS READER**

per Title 40 Part 60 Appendix A USEPA Method 9

Issued: 06/04/2020

Expires: 12/04/2020

EPA

Visible Emission Observation Form 1

Method Used (circle one) Multiple 203A 203B Other

Company Name LP Corp.

Facility Name Newberry

Street Address 7299 LP Mill Road

City Newberry State MT Zip 49868

Process Dryer RTD Unit # E00dryer Operating Mode >90%

Control Equipment RTU Operating Mode No Recirc

Describe Emission Point Tail Silver Stack

Height of Emission Point
Start 100' End same Height of Emission Point Relative to Observer
Start 335 End same

Distance to Emission Point
Start 350 End same Direction to Emission Point (Degrees)
Start 0° End same

Vertical angle to Observation Point
Start 15 End same Direction to Observation Point (Degrees)
Start 0° End same

Distance and Direction to Observation point from Emission Point
Start 700 same End same

Describe Emissions
Start None End same


Emission Color
Start NA End Water Droplet Plume
Attached Detached None

Describe Plume Background
Start sky/clouds End same

Background Color
Start gray/blue End Sky cloudy End same

Wind Speed
Start 5 mph End same Wind Direction
Start WSW End same

Ambient Temp. 75F End Wet Bulb Temp. 58° RH Percent 54%



Longitude 46.3343417 Latitude -89.4476022 Declination

Additional Information

Observer's Name (Print) Ed Swins

Observer's Signature [Signature] Date 8/6/20

Organization Interpoll Labs

Certified By Acromet Date 6/4/20

Form Number		Page 1 of 1		
Continued on Form Number				
Observation Date	Time Zone	Start Time	End Time	
8/6/20	Eastern	1440	1540	
Mn/Gier	0	15	15	Comments
1	0	0	0	
2	0	0	0	
3	0	0	0	
4	0	0	0	
5	0	0	0	
6	0	0	0	
7	0	0	0	
8	0	0	0	
9	0	0	0	
10	0	0	0	
11	0	0	0	
12	0	0	0	
13	0	0	0	
14	0	0	0	
15	0	0	0	
16	0	0	0	
17	0	0	0	
18	0	0	0	
19	0	0	0	
20	0	0	0	
21	0	0	0	
22	0	0	0	
23	0	0	0	
24	0	0	0	
25	0	0	0	
26	0	0	0	
27	0	0	0	
28	0	0	0	
29	0	0	0	
30	0	0	0	
31	0	0	0	
32	0	0	0	
33	0	0	0	
34	0	0	0	
35	0	0	0	
36	0	0	0	
37	0	0	0	
38	0	0	0	
39	0	0	0	
40	0	0	0	
41	0	0	0	
42	0	0	0	
43	0	0	0	
44	0	0	0	
45	0	0	0	
46	0	0	0	
47	0	0	0	
48	0	0	0	
49	0	0	0	
50	0	0	0	
51	0	0	0	
52	0	0	0	
53	0	0	0	
54	0	0	0	
55	0	0	0	
56	0	0	0	
57	0	0	0	
58	0	0	0	
59	0	0	0	
60	0	0	0	