

RECEIVED

NOV 27 2017

AIR QUALITY DIVISION

EMISSIONS COMPLIANCE STUDY

Performed At
Bluewater Booster Station
EU-COMP
Ray Township, Michigan

Test Date
October 4, 2017

Report No.

TRC Environmental Corporation Report 284125C

Report Submittal Date
November 1, 2017



EMISSIONS COMPLIANCE STUDY

1.0 INTRODUCTION

TRC Environmental Corporation (TRC) performed an emissions compliance test program on the EU-COMP at the Bluewater Booster Station in Ray Township, Michigan on October 4, 2017. The tests were authorized by and performed for Bluewater Booster Station.

The purpose of this test program was to determine compliance with United States Environmental Protection Agency (USEPA), Title 40 Code of Federal Regulations Part 63 (40CFR63), Subpart ZZZZ - National Emissions Standards for Hazardous Air Pollutants for Stationary Reciprocating Internal Combustion Engines.

1.1 Project Contact Information

Participants				
Test Facility	Bluewater Booster Station 324551 29 Mile Road Ray Township, Michigan 48096	Mr. Jeffrey Westrick Station Manager Bluewater Facilities (810) 367-3404 (phone) JJWestrick@integrysgroup.com		
Air Emissions Testing Body (AETB)	TRC Environmental Corporation 7521 Brush Hill Road Burr Ridge, Illinois 60527	Mr. Ben Cacao Field Team Leader 312-533-2042 (phone) 312-533-2070 (fax) bcacao@trcsolutions.com		

The tests were conducted by Billy Manny and Ben Cacao of TRC. Documentation of the on-site ASTM D7036-04 Qualified Individual(s) (QI) can be located in the appendix to this report.



2.0 SUMMARY OF RESULTS

The results of this test program are summarized in the table below. Detailed individual run results are presented in Section 6.0.

Unit ID	Pollutant Tested		Measured Emissions	Emission Limit
EU-COMP	со	ppmvd @ 15% O₂	1.2	47

The table below summarizes the test methods used, as well as the number and duration of each at each test location:

Source	Parameter Measured	Test Method	No. of Runs	Run Duration
	со	USEPA 10	3	15 min
EU-COMP	O ₂	USEPA 3A	3	15 min

3.0 DISCUSSION OF RESULTS

No problems were encountered with the testing equipment during the test program. Source operation appeared normal during the entire test program.

Unit operating data was recorded by plant personnel. Heat content of the natural gas was determined to support the performance tests. The fuel analysis reports are appended.

4.0 SAMPLING AND ANALYSIS PROCEDURES

All testing, sampling, analytical, and calibration procedures used for this test program were performed in accordance with the methods presented in the following sections. Where applicable, the *Quality Assurance Handbook for Air Pollution Measurement Systems*, Volume III, Stationary Source Specific Methods, USEPA 600/R-94/038c, September 1994 was used to supplement procedures.



4.1 Determination of the Concentration of Gaseous Pollutants Using a Multi-Pollutant Sampling System

Concentrations of the pollutants in the following sub-sections were determined using one sampling system.

A straight-extractive sampling system was used. A data logger continuously recorded pollutant concentrations and generated one-minute averages of those concentrations. All calibrations and system checks were conducted using USEPA Protocol 1 gases. Three-point linearity checks were performed prior to sampling, and in the event of a failing system bias or drift test (and subsequent corrective action). System bias and drift checks were performed using the low-level gas and either the mid- or high-level gas prior to and following each test run.

The Low Concentration Analyzers (those that routinely operate with a calibration span of less than 20 ppm) used by TRC are ambient-level analyzers. Per Section 3.12 of Method 7E, a Manufacturer's Stability Test is not required for ambient-level analyzers. Analyzer interference tests were conducted in accordance with the regulations in effect at the time that TRC placed an analyzer model in service.

4.1.1 O2 Determination by USEPA Method 3A

This method is applicable for the determination of O_2 concentrations in controlled and uncontrolled emissions from stationary sources only when specified within the regulations. The O_2 analyzer was equipped with a paramagnetic-based detector.

4.1.2 CO Determination by USEPA Method 10

This method is applicable for the determination of CO concentrations in controlled and uncontrolled emissions from stationary sources only when specified within the regulations. The non-dispersive infrared analyzer (NDIR) CO analyzer was equipped with an internal gas correlation filter wheel, which eliminates potential detector interference. As such, use of an interference removal trap was not required.

4.2 Determination of F-Factors by USEPA Method 19

This method is applicable for the determination of the pollutant emission rate using oxygen (O_2) or carbon dioxide (CO_2) concentrations and the appropriate F factor (the ratio of combustion gas volumes to heat inputs) and the pollutant concentration. The appropriate F-Factor was calculated from fuel analyses using the equations in Section 12.3.2.1 of Method 19.

RECEIVED

NOV 27 2017

AIR QUALITY DIVISION



5.0 QUALITY ASSURANCE PROCEDURES

TRC integrates our Quality Management System (QMS) into every aspect of our testing service. We follow the procedures specified in current published versions of the test Method(s) referenced in this report. Any modifications or deviations are specifically identified in the body of the report. We routinely participate in independent, third party audits of our activities, and maintain:

- Louisiana Environmental Lab Accreditation Program (LELAP) accreditation;
- Accreditation from the Stack Testing Accreditation Council (STAC) and the American Association for Laboratory Accreditation (A2LA) that our operations conform with the requirements of ASTM D 7036 as an Air Emission Testing Body (AETB).

These accreditations demonstrate that our systems for training, equipment maintenance and calibration, document control and project management will fully ensure that project objectives are achieved in a timely and efficient manner with a strict commitment to quality.

All calibrations are performed in accordance with the test Method(s) identified in this report. If a Method allows for more than one calibration approach, or if approved alternatives are available, the calibration documentation in the appendices specifies which approach was used. All measurement devices are calibrated or verified at set intervals against standards traceable to the National Institute of Standards and Technology (NIST). NIST traceability information is available upon request.

ASTM D7036-04 specifies that: "AETBs shall have and shall apply procedures for estimating the uncertainty of measurement. Conformance with this section may be demonstrated by the use of approved test protocols for all tests. When such protocols are used, reference shall be made to published literature, when available, where estimates of uncertainty for test methods may be found." TRC conforms with this section by using approved test protocols for all tests.



GASEOUS TEST RESULTS SUMMARY

Project Number:

284125

Start Date:

10/4/17

Customer:

Bluewater Booster Station

End Date:

10/4/17

Unit Identification:

EU-COMP

Facility:

Bluewater Booster Station

Sample Location:

Stack

Recorded by: Fc Factor:

Ben Cacao

RM Probe Type: Load Level/Condition: Extractive (Dry) 40 Percent

Fd Factor:

Run		Start	End	co	O2
#	Date	Time	Time	ppmvd	% v/v dry
1	10/4/17	8:00	8:14	2.8	7.7
2	10/4/17	8:33	8:47	2.7	8.0
3	10/4/17	9:05	9:19	2.7	7.9
Average			2.8	7.9	

Run	CO	CO	Heat Input	
#	lb/MMBtu	lb/hr	MMBtu/hr	Fd Factor
1	0.00285	0.0164	5.76	8,663
2	0.00272	0.0158	5.79	8,662
3	0.00277	0.0156	5.62	8,663
Average	0.00278	0.0159	5.72	8,663

Results Corrected to a		
Reference O ₂		
Concentration		
co		
ppmvd		
Run	corrected to	
#	15% Oxygen	
1	1.3	
2	1.2	
3	1.2	
Average	1,2	